




SECTION : M-M
SCALE 1:40




RC. DET. OF FDN. FOR PUMP MKD.
3650-PMP-007 & 008
(TOP VIEW OF SECOND STAGE CONCRETE)




SECTION : N-N
SCALE 1:40




RC. DET. OF FDN. FOR PUMP MKD.
3650-PMP-011 & 012
(TOP VIEW OF SECOND STAGE CONCRETE)




SECTION : N'-N'
SCALE 1:40




RC. DET. OF FDN. FOR PUMP MKD.
3650-PMP-001 & 002
(TOP VIEW OF SECOND STAGE CONCRETE)




RC. DET. OF FDN. FOR PUMP MKD.
3650-PMP-007 & 008
(TOP VIEW OF FIRST STAGE CONCRETE)
SCALE 1:40




RC. DET. OF FDN. FOR PUMP MKD.
3650-PMP-007 & 008
(BOTTOM VIEW)
SCALE 1:40




RC. DET. OF FDN. FOR PUMP MKD.
3650-PMP-011 & 012
(TOP VIEW OF FIRST STAGE CONCRETE)
SCALE 1:40




RC. DET. OF FDN. FOR PUMP MKD.
3650-PMP-011 & 012
(BOTTOM VIEW)
SCALE 1:40




RC. DET. OF FDN. FOR PUMP MKD.
3650-PMP-001 & 002
(TOP VIEW OF FIRST STAGE CONCRETE)
SCALE 1:40




RC. DET. OF FDN. FOR PUMP MKD.
3650-PMP-001 & 002
(BOTTOM VIEW)
SCALE 1:40




RCC. DET. OF C1 & C2
SCALE 1:20




RCC. DET. OF C3
SCALE 1:20




SECTION : P-P
SCALE 1:40




RC. DET. OF FDN. FOR PUMP MKD.
3650-PMP-005 & 006
(TOP VIEW OF SECOND STAGE CONCRETE)




SECTION : Q-Q
SCALE 1:40




RC. DET. OF FDN. FOR PUMP MKD.
3650-PMP-009 & 010
(TOP VIEW OF SECOND STAGE CONCRETE)




SECTION : D-D
SCALE 1:40




SECTION : D-D
SCALE 1:40




SECTION : F-F
SCALE 1:40




RCC. DETAIL OF
FOUNDATION MKD. F1
SCALE 1:40




RCC. DETAIL OF
FOUNDATION MKD. F2
SCALE 1:40




RCC. DETAIL OF
FOUNDATION MKD. F3
SCALE 1:40




RC. DET. OF FDN. FOR PUMP MKD.
3650-PMP-005 & 006
(TOP VIEW OF FIRST STAGE CONCRETE)
SCALE 1:40




RC. DET. OF FDN. FOR PUMP MKD.
3820-PMP-003
(TOP VIEW)




RC. DET. OF FDN. FOR PUMP MKD.
3610-PMP-012 & 013
(TOP VIEW)




RC. DET. OF FDN. FOR PUMP MKD.
3650-PMP-005 & 006
(BOTTOM VIEW)
SCALE 1:40




RC. DET. OF FDN. FOR PUMP MKD.
3820-PMP-003
(BOTTOM VIEW)
SCALE 1:40




RC. DET. OF FDN. FOR PUMP MKD.
3610-PMP-012 & 013
(BOTTOM VIEW)
SCALE 1:40




RC. DET. OF FDN. FOR PUMP MKD.
3650-PMP-009 & 010
(TOP VIEW OF FIRST STAGE CONCRETE)
SCALE 1:40



SECTION : T-T
SCALE 1:40



RC. DET. OF FDN. FOR PUMP MKD.
3650-PMP-009 & 010
(BOTTOM VIEW)
SCALE 1:40



SECTION : S-S
SCALE 1:40

LEGEND :-

R.L. - REDUCED LEVEL
℄ - CENTRE LINE
T.O.C. - TOP OF CONCRETE
F.G.L. - FINISHED GROUND LEVEL
F.F.L. - FINISHED FLOOR LEVEL
B.O.F. - BOTTOM OF FOUNDATION
TYP. - TYPICAL
T.O.G. - TOP OF GROUT
R.C - REINFORCED CONCRETE
MKD. - MARKED
P.C.C - PLAIN CEMENT CONCRETE
THK. - THICK
R.C.C - REINFORCED CEMENT CONCRETE
DET. - DETAIL
DIA. - DIAMETER
DRG. - DRAWING
FDN. - FOUNDATION
BOTTOM REINFORCEMENT (B) - - - - - - -
TOP REINFORCEMENT (T) - ———

NOTES:-

1. ALL DIMENSIONS ARE IN MILLIMETRES AND LEVELS AND CO-ORDINATES ARE IN METRES UNLESS OTHERWISE STATED.
2. GRADE OF CONCRETE SHALL BE C35 (35MPa) FOR FOUNDATION, C30 (30MPa) FOR GRADE SLAB & C15 (15MPa) FOR BLINDING CONCRETE.
3. GRADE OF REINFORCEMENT SHALL BE DEFORMED BAR 420 MPa (GRADE 60) - ASTM A615/A615M.
4. NET SAFE BEARING CAPACITY OF SOIL AT BOTTOM OF FOUNDATION IS CONSIDERED AS 350KN/ SQ. M.
5. CLEAR COVER TO REINFORCEMENT SHALL BE AS FOLLOWS
   a) FOUNDATION = 50 mm
   b) COLUMN = 50mm
6. FOR STANDARD REINFORCEMENT DETAIL & GENERAL NOTES FOR CIVIL WORKS REFER DRAWING NO. MD-216-1000-EG-CV-DED-1005 & 1001.

DOCUMENT NUMBER	REFERENCE DOCUMENTS	REV	DATE	REVISION DESCRIPTION	DRN	CHK	ENG	APP	EMP
MD-216-1000-EG-ST-CRT-1001	CIVIL, STRUCTURAL & ARCHITECTURAL - DESIGN CRITERIA	D01	22/02/2023	AS-BUILT	SYA	SJM	SOR	AG	
MD-216-3650-EG-ME-GAD-1015	POX ACID WASH/ELUTION/CARBON REGENERATION, PLAN AT EL. +912.700	C01	24/11/2020	ISSUED FOR CONSTRUCTION & REVISED AS MARKED C01	SYA	SJM	SOR	AG	
MD-216-3650-EG-CV-GAD-1001	POX ACID WASH-ELUTION AND CARBON REGENERATION, PLAN AT EL. +912.700	A01	19/10/2020	ISSUED FOR REFERENCE	SYA	SJM	SOR	AG	

RESERVED FOR VENDOR LOGO AND DRAWING NUMBER

LARSEN & TOUBRO

This drawing is the property of LARSEN & TOUBRO and must not be passed on to any person or body not authorized by us to receive it nor be copied or otherwise made use either in full or in part by such person or body without our prior permission in writing.

Outotec

The content of these documents are the sole property of Outotec Oyj. Any rights not expressly granted herein are reserved. Reproduction, transfer or distribution of part or all of the contents in any form without prior written permission of Outotec is prohibited.

MA'ADEN معادن
Saudi Arabian Mining Company شركة التعدين العربية السعودية

This document and the information contained herein is Ma'aden proprietary know-how. This document or any part thereof should not be reproduced, stored in a retrieval system or transmitted by any means, electronic or otherwise, or divulged without prior written permission of Ma'aden.

LARSEN & TOUBRO DRAWING NUMBER	019045_450_C_D_24560_001	REVISION 2
OUTOTEC DRAWING NUMBER	900707 _GAU01 _EE12 _CTB17 _36504	DOCUMENT ID OU100704156 / REVISION 2

DRAWN	SYA	15/10/2020
CHECKED	SJM	17/10/2020
ENGINEER	SOR	15/10/2020
APPROVED	AG	19/10/2020
EMPLOYER		
SCALE	1:50, 1:25, 1:20	A1

MANSOURAH - MASSARAH GOLD PROJECT
DETAIL DRAWING
POX ACID WASH, ELUTION & CARBON REGENERATION
RCC DETAILS OF FOUNDATION

DRAWING NUMBER MD-216-3650-EG-CV-DED-1341 REV D01