


DRAWING NUMBER MD-216-3120-EG-CV-GAD-1007 REV D01




SECTION 4-4
(SCALE-1:20)




SECTION 5-5
(SCALE-1:20)




SECTION 6-6
(SCALE-1:20)




DETAIL OF COLUMN BASE
FOR PEDESTAL MKD. P1
(SCALE-1:25)




DETAIL OF COLUMN BASE
FOR PEDESTAL MKD. P2
(SCALE-1:25)




DETAIL OF COLUMN BASE
FOR PEDESTAL MKD. P3
(SCALE-1:25)




DETAIL OF INSERT PLATE - IP1
(SCALE 1:10)




SECTION 7-7
(SCALE 1:10)



DETAIL OF INSERT PLATE - IP7 & IP11
(SCALE 1:10)




DETAIL OF INSERT PLATE - IP9, IP9A & IP10
(SCALE 1:10)




TYP. DET.OF KERB ANGLE
(FOR CUTOUT LOCATION)
(SCALE 1:10)


SCHEDULE OF INSERT PLATE		
INSERT PLATE MKD.	SIZE	PURPOSE
IP1	100x100x10 THK.	FOR EQUIPMENT
IP2	200x200x10 THK.	
IP11	300x200x10 THK.	
IP3	200x200x10 THK.	FOR CABLE SUPPORT
IP4	200x200x10 THK.	
IP5	200x200x10 THK.	
IP6	320x320x10 THK.	FOR CRUSHER SUPPORT
IP8	410x410x10 THK.	
IP7	300x200x10 THK.	FOR DUCT SUPPORT
IP10	300x250x10 THK.	
IP9	300x250x10 THK.	FOR MONORAIL SUPPORT
IP9A	300x250x10 THK.	
IP12	100x2735x10 THK.	FOR EQUIPMENT
IP13	100x2890x10 THK.	FOR DUCT SUPPORT
IP14	100x300x10 THK.	
IP15	100x200x10 THK.	




DETAIL OF INSERT PLATE - IP2,IP4 & IP5
(SCALE 1:10)



SECTION 8-8
(SCALE 1:10)




SECTION 11-11
(SCALE 1:10)




TYP. DETAIL OF 150 THK. GRADE SLAB
SCALE 1:10


DETAIL OF INSERT PLATE - IP3
(SCALE 1:10)




SECTION 9-9
(SCALE 1:10)




DETAIL OF INSERT PLATE - IP8
(SCALE 1:10)




SECTION 12-12
(SCALE 1:10)




DETAIL OF INSERT PLATE - IP6
(SCALE 1:10)




SECTION 10-10
(SCALE 1:10)




DETAIL OF INSERT PLATE - IP12
(SCALE 1:10)




SECTION 13-13
(SCALE 1:10)




DETAIL OF INSERT PLATE - IP13
(SCALE 1:10)



DETAIL OF INSERT PLATE - IP14
(SCALE 1:10)



DETAIL OF INSERT PLATE - IP15
(SCALE 1:10)



SECTION 14-14
(SCALE 1:10)

LEGENDS :-

R.L. - REDUCED LEVEL
℄ - CENTRE LINE
CJ - CONSTRUCTION JOINT
FDN. - FOUNDATION.
T.O.C. - TOP OF CONCRETE.
F.G.L. - FINISHED GROUND LEVEL.
F.F.L. - FINISHED FLOOR LEVEL.
B.O.F. - BOTTOM OF FOUNDATION
TYP. - TYPICAL.
B.O.B. - BOTTOM OF BEAM.
B.O.M. - BOTTOM OF MONORAIL.
R.C.C - REINFORCED CEMENT CONCRETE
P.C.C - PLAIN CEMENT CONCRETE
IP. - INSERT PLATE
MKD. - MARKED.
THK. - THICK

NOTES :-

1. ALL DIMENSIONS ARE IN MILLIMETRES AND LEVELS AND CO-ORDINATES ARE IN METRES. UNLESS OTHERWISE STATED.
2. GRADE OF CONCRETE SHALL BE C35 FOR FOUNDATION.
3. GRADE OF REINFORCEMENT SHALL BE DEFORMED BAR ASTM A615 - GRADE 60 (fy = 420 MPa).
4. NET SAFE BEARING CAPACITY OF SOIL AT BOTTOM OF FOUNDATION CONSIDERED 500KN/SQ. M.
5. CLEAR COVER TO MAIN REINFORCEMENT SHALL BE AS
   a) FOUNDATION = 75 mm (BOTTOM & SIDE) 50 mm. (TOP)
   b) COLUMN & PEDESTAL = 50mm
   c) BEAM = 50mm
   d) SLAB = 40mm
6. FOR MINIMUM LAP LENGTH OF REINFORCEMENT REFER STANDARD DRAWING NO. MD-216-1000-EG-CV-DED-1001
7. THIS DRG. SHALL BE READ IN CONJUNCTION WITH DRG. NO. MD-216-3120-EG-CV-GAD-1004 & MD-216-3120-EG-CV-DED-1004
8. FOR DETAIL OF HANDRAIL FIXING REFER STANDARD DRAWING.

DOCUMENT NUMBER	REFERENCE DOCUMENTS	REV	DATE	REVISION DESCRIPTION	DRN	CHK	ENG	APP	EMP
MD-216-3120-EG-ME-ELV-1012	SECONDARY CRUSHER HOUSE-ELEVATION								
MD-216-3120-EG-ME-ELV-1013	SECONDARY CRUSHER HOUSE-ELEVATION								
MD-216-3120-EG-ME-LPX-1014	SECONDARY CRUSHER HOUSE-PLAN VIEW	D01	24/7/2023	AS BUILT	MGH	SBY	APR	AG	
MD-216-3120-EG-ME-LPX-1015	SECONDARY CRUSHER HOUSE-PLAN VIEW	C02	26/06/2020	ISSUED FOR CONSTRUCTION & REVISED AS MKD. C02	MGH	SBY	APR	AG	
MD-216-3120-EG-ME-LPX-1016	SECONDARY CRUSHER HOUSE-PLAN VIEW	C01	09/04/2020	ISSUED FOR CONSTRUCTION, REVISED AS PER EMPLOYER					
MD-216-3120-EG-ME-LPX-1017	SECONDARY CRUSHER HOUSE-PLAN VIEW			COMMENTS DATED 04/04/2020 & REVISED AS MKD. C01	JKM	SBY	RPK	AG	
MD-216-3120-EG-ME-LPX-1018	SECONDARY CRUSHER HOUSE-PLAN VIEW	A01	11/03/2020	ISSUED FOR REFERENCE	JKM	SBY	APR	AG	

RESERVED FOR VENDOR LOGO AND DRAWING NUMBER

LARSEN & TOUBRO

This drawing is the property of LARSEN & TOUBRO and must not be passed on to any person or body not authorized by us to receive it nor be copied or otherwise made use either in full or in part by such person or body without our prior permission in writing.

Outotec

The content of these documents are the sole property of Outotec Oyj. Any rights not expressly granted herein are reserved. Reproduction, transfer or distribution of part or all of the contents in any form without prior written permission of Outotec is prohibited.

MA'ADEN معادن
Saudi Arabian Mining Company شركة التعدين العربية السعودية

This document and the information contained herein is Ma'aden proprietary know-how. This document or any part thereof should not be reproduced, stored in a retrieval system or transmitted by any means, electronic or otherwise, or divulged without prior written permission of Ma'aden.

LARSEN & TOUBRO DRAWING NUMBER: O19045_100_C_G_24062_002 — REVISION: 3
OUTOTEC DRAWING NUMBER: 900707__GAU01__ZC01__MTL01__31274 — DOCUMENT ID: OU100675148 — REVISION: 3

DRAWN	JKM	10/01/2020
CHECKED	SBY	21/01/2020
ENGINEER	APR	20/01/2020
APPROVED	AG	11/03/2020
EMPLOYER		
SCALE	1:25,1:20,1:10	A1

MANSOURAH - MASSARAH GOLD PROJECT
GENERAL ARRANGEMENT DRAWING
SECONDARY CRUSHING
DETAILS & SECTIONS

DRAWING NUMBER: MD-216-3120-EG-CV-GAD-1007 — REV: D01