





ANCHOR BOLT TYPE 'A'




ANCHOR BOLT TYPE 'B'




ANCHOR BOLT TYPE 'C'




ANCHOR BOLT TYPE 'D'



TYPICAL ANCHOR BOLT CAGE DETAIL




PLAN



ELEVATION

TYPICAL ANCHOR BOLT SLEEVE DETAIL



TYPICAL ANCHOR BOLT PROJECTION DETAIL

NOTE:

PROJECTION-'P' AND GROUT THICKNESS AS SPECIFIED ON THE DESIGN DRAWINGS FOR DIMENSIONS, SEE ANCHOR BOLT DATA TABLES ON DESIGN DRAWINGS

DIAMETER D	TYPE 'A'	TYPE 'B'	TYPE 'C'
	T	H	S MINIMUM
16	12	160	95
20	16	200	120
24	16	250	145
30	20	300	180
36	25	375	216
42	32	450	252
48	40	550	288

LEGEND

2x2 OR 4AB-A-D24-600-90(SR)

- DENOTES ADDITIONAL REQUIREMENTS EXAMPLE SR = SLEEVE REQUIRED, 2 = TWO NUTS REQUIRED, NC = NO CAGE REQUIRED
- DENOTES PROJECTION/THREAD LENGTH P
- DENOTES LENGTH L
- DENOTES ANCHOR BOLT DIAMETER D
- DENOTES ANCHOR BOLT TYPE
- DENOTES NUMBER OF ANCHOR BOLTS

NOTES:

1. FOR CONCRETE GENERAL NOTES REFER DRG MD-101-SMEM-EG-ST-DST-0001.
2. REFER ANCHOR BOLT SPECIFICATION MD-101-SMEM-EG-CV-SPC-0002.
3. UNLESS NOTED OTHERWISE ON DESIGN DRAWINGS, ANCHOR BOLT SLEEVES FOR STATIONARY EQUIPMENT AND STRUCTURAL BASE PLATES SHALL BE FILLED WITH GROUT AFTER THE COLUMN OR EQUIPMENT IS IN PLACE AND THE ANCHOR BOLTS ARE ALIGNED. WATER OR OTHER LOOSE PARTICLES SHALL NOT BE ALLOWED TO COLLECT IN THE SLEEVE BEFORE THE SLEEVE IS GROUTED.
4. ANCHOR BOLTS SHALL BE TIGHTENED TO A SNUG CONDITION UNLESS NOTED OTHERWISE ON THE DESIGN DRAWINGS. AT SLIDE PLATE LOCATIONS, NUTS SHALL BE BACKED OFF HALF A TURN AND A SECOND NUT SHALL BE ADDED.

DOCUMENT NUMBER	REFERENCE DOCUMENTS	REV	DATE	REVISION DESCRIPTION	DRN	CHK	ENG	APP	MD

This drawing and all the information contained herein it is the proprietary property of Ma'aden and is subject to confidentiality restrictions between Ma'aden and the recipient. The information contained herein is provided for a limited purpose and must be returned on request. Ma'aden makes no respresentations or warranties that this information is complete or fit for any particular purpose. Neither this drawing nor any information concerning it may be copied, exhibited or furnished to others. Nor may photographs be taken of any article fabricated or assembled from this drawing, without Ma'aden prior written consent.

REV C01 PREPARED FOR MA'ADEN BY HATCH ASSOCIATES H332701-0000-35-041-0005_C

MA'ADEN معادن Saudi Arabian Mining Company

DRAWN	J BADAL	01.02.11
CHECKED	J EDWARDS	31.03.11
ENGINEER	D KIRKWOOD	31.03.11
APPROVED	R COVELLA	11.05.11
MA'ADEN		
SCALE NTS		A1

MA'ADEN ENGINEERING MANUAL
ALL AREAS
STRUCTURAL STANDARDS
ANCHOR BOLT DETAILS

DRAWING NUMBER MD-101-SMEM-EG-ST-DST-0005 REV C01

$FILE$ $TIME$ $DATE$