


DRAWING NUMBER: MD-216-3120-EG-CV-GAD-2022 | REV: D01




SECTION 1-1
(SCALE-1:50)




SECTION 2-2
(SCALE-1:50)




SECTION 3-3
(SCALE-1:50)




SECTION 4-4
(SCALE-1:50)




SECTION 5-5
(SCALE-1:50)




SECTION 6-6
(SCALE-1:50)




SECTION 7-7
(SCALE-1:50)




SECTION 8-8
(SCALE-1:50)




SECTION 9-9
(SCALE-1:50)




SECTION 10-10
(SCALE-1:50)




SECTION 11-11
(SCALE-1:50)




SECTION 12-12
(SCALE-1:50)




SECTION 13-13
(SCALE-1:50)




SECTION 14-14
(SCALE-1:50)




SECTION 15-15
(SCALE-1:50)




SECTION 16-16
(SCALE-1:50)




SECTION 17-17
(SCALE-1:50)




DETAIL OF PEDESTAL MKD. PD1
(SCALE-1:25)




DETAIL OF PEDESTAL MKD. PD2
(SCALE-1:25)



DETAIL OF PEDESTAL MKD. PD3
(SCALE-1:25)




DETAIL OF PEDESTAL MKD. PC1
(SCALE-1:25)




TYP. DETAIL OF BOLT

SCHEDULE OF BOLTS


D BOLT DIA. MM	BxB BOTTOM PLATE (SQUARE) SQ MM	DIMENSIONS (MM)				
		L	A	C	T	H
16	50x50	350	150	100	10	30
20 DIA TYPE-1	60x60	450	350	110	10	30
20 DIA TYPE-2	60x60	450	160	110	10	30
20 DIA TYPE-3	60x60	450	140	110	10	30
24	75x75	600	175	125	12	30
30	100x100	800	200	150	16	45
36	110x110	1000	225	175	20	45
40	120x120	1000	225	175	20	50
50	150x150	1250	275	200	25	60




DETAIL OF PEDESTAL MKD. PF1
(SCALE-1:25)




DETAIL OF PEDESTAL MKD. PD4
(SCALE-1:25)




DETAIL OF PEDESTAL MKD. PD5
(SCALE-1:25)




DETAIL OF PEDESTAL MKD. PC2
(SCALE-1:25)




DETAIL OF PEDESTAL MKD. PT1
(SCALE-1:25)




DETAIL OF PEDESTAL MKD. PT2
(SCALE-1:25)




DETAIL OF PEDESTAL MKD. PS1
(SCALE-1:25)




DETAIL OF PEDESTAL MKD. PB1
(SCALE-1:25)




SECTION 20-20
(SCALE-1:20)




DETAIL OF PEDESTAL MKD. PP1
(SCALE-1:25)




SECTION 18-18
(SCALE-1:20)



DETAIL OF INSERT PLATE - IP1
(SCALE-1:20)




SECTION 21-21
(SCALE 1:10)



DETAIL OF PEDESTAL MKD. PP2
(SCALE-1:25)

TYP. DETAIL OF 150 THK. GRADE SLAB
SCALE 1:20



SECTION 19-19
(SCALE-1:20)

LEGENDS :-

R.L. - REDUCED LEVEL
℄ - CENTRE LINE
CJ - CONSTRUCTION JOINT
FDN. - FOUNDATION.
T.O.C. - TOP OF CONCRETE.
F.G.L. - FINISHED GROUND LEVEL.
F.F.L. - FINISHED FLOOR LEVEL.
B.O.F. - BOTTOM OF FOUNDATION
TYP. - TYPICAL.
R.C.C. - REINFORCED CEMENT CONCRETE
P.C.C. - PLAIN CEMENT CONCRETE
MKD. - MARKED.
THK. - THICK
PC - PEDESTAL FOR CONVEYOR
PD - PEDESTAL FOR DUCT SUPPORT
PB - PEDESTAL FOR BAG FILTER
PS - PEDESTAL FOR STAIR
PT - PEDESTAL FOR TRANSFER POINT
PF - PEDESTAL FOR FAN
PP - PEDESTAL FOR PLATFORM

NOTES :-

1. ALL DIMENSIONS ARE IN MILLIMETRES AND LEVELS AND CO-ORDINATES ARE IN METRES. UNLESS OTHERWISE STATED.
2. GRADE OF CONCRETE SHALL BE C35 FOR FOUNDATION.
3. GRADE OF REINFORCEMENT SHALL BE DEFORMED BAR ASTM A615 - GRADE 60 (fy = 420 MPa).
4. NET SAFE BEARING CAPACITY OF SOIL AT BOTTOM OF FOUNDATION CONSIDERED 500KN/ SQ. M.
5. CLEAR COVER TO MAIN REINFORCEMENT SHALL BE AS
   a) FOUNDATION = 75 mm (BOTTOM & SIDE) 50 mm. (TOP)
   b) COLUMN & PEDESTAL = 50mm
   c) BEAM = 50mm
   d) SLAB = 40mm.
6. FOR MINIMUM LAP LENGTH OF REINFORCEMENT AND OTHER GENERAL NOTES FOR CIVIL WORKS REFER STANDARD DRG : MD-216-1000-EG-CV-DED-1001
7. THIS DRG. SHALL BE READ IN CONJUNCTION WITH DRG. NO. MD-216-3120-EG-CV-GAD-2021
8. ALL STRUCTURAL WORK SHALL CONFORM TO CIVIL STRUCTURAL DESIGN CRITERIA NO. MD - 216 - 1000 -EG -ST - CRT - 1001
9. FOR OTHER STANDARD REINFORCEMENT DETAILS REFER DRG : MD-216-1000-EG-CV-DED-1005

DOCUMENT NUMBER	REFERENCE DOCUMENTS	REV	DATE	REVISION DESCRIPTION	DRN	CHK	ENG	APP	EMP
MD-216-3100-EG-ST-GAD-2024	SCREEN BUILDING BAG FILTER								
	PLAN, ELEVATION AND DETAIL OF STAIR								
MD-216-3130-EG-CV-GAD-1003	GA OF CONVEYORS 3130-CNV-003								
	LAYOUT & DETAIL								
MD-216-3120-EG-ST-GAD-1020	STRUCTURAL GA OF TP-2(3120 CNV-0011-1	D01	10/03/2023	AS-BUILT	JKM	SBY	APL	PRI	
	PLAN, ELEVATIONS & DETAILS	C04	02/07/2021	ISSUED FOR CONSTRUCTION & REVISED AS MKD. C03	JKM	SBY	APL	PRI	
MD-216-3120-EG-ST-GAD-2022	SCREEN BUILDING-PLAN, ELEVATION AND	C03	06/01/2021	ISSUED FOR CONSTRUCTION & REVISED AS MKD. C02	JKM	SBY	APL	PRI	
	DETAIL OF DEDUSTING DUCT SUPPORT	C02	10/12/2020	ISSUED FOR CONSTRUCTION & REVISED AS MKD. C01	JKM	SBY	APL	PRI	
MD-216-3120-EG-ST-GAD-2026	SCREEN BUILDING- DETAIL OF DEDUSTING DUCT SUPPORT	C01	14/10/2020	ISSUED FOR CONSTRUCTION & REVISED AS MKD. C00	JKM	SBY	APL	PRI	
MD-216-3100-EG-ME-LAD-V509-2001	FDN LOAD DATA FOR SEC. & TER. CRUSHER HOUSE BAG FILTER	A01	02/09/2020	ISSUED FOR REFERENCE	JKM	SBY	APL	PRI	

DOCUMENT NUMBER	REFERENCE DOCUMENTS	REV	DATE	REVISION DESCRIPTION	DRN	CHK	ENG	APP	EMP

RESERVED FOR VENDOR LOGO AND DRAWING NUMBER

LARSEN & TOUBRO DRAWING NUMBER: 019045_080_C_G_24368_003 | REVISION: 5
OUTOTEC DRAWING NUMBER: 900707__GAU01__ZC01__MTL01__31285 | DOCUMENT ID: OU100692112 | REVISION: 5

DRAWN	JKM	31/08/2020	MANSOURAH - MASSARAH GOLD PROJECT
CHECKED	SBY	01/09/2020	GENERAL ARRANGEMENT DRAWING
ENGINEER	APL	29/08/2020	SCREEN BUILDING
APPROVED	PRI	02/09/2020	LAYOUT OF BAG FILTER & DUCT SUPPORT FOUNDATION SHT 2
EMPLOYER			
SCALE 1:50		A0	DRAWING NUMBER: MD - 216 - 3120 - EG - CV - GAD - 2022 | REV: D01

This drawing is the property of LARSEN & TOUBRO and must not be passed on to any person or body not authorized by us to receive it nor be copied or otherwise made use either in full or in part by such person or body without our prior permission in writing.

The content of these documents are the sole property of Outotec Oyj. Any rights not expressly granted herein are reserved. Reproduction, transfer or distribution of part or all of the contents in any form without prior written permission of Outotec is prohibited.

This document and the information contained herein is Ma'aden proprietary know-how. This document or any part thereof should not be reproduced, stored in a retrieval system or transmitted by any means, electronic or otherwise, or divulged without prior written permission of Ma'aden.