




SECTION : D-D
SCALE 1:40




RC. DET. OF FDN. FOR PUMP MKD.
3660-PMP-011, 012 & 017
(TOP VIEW OF SECOND STAGE CONCRETE)




SECTION : E-E
SCALE 1:40




RC. DET. OF FDN. FOR PUMP MKD.
3660-PMP-018, 019 & 020
(TOP VIEW OF SECOND STAGE CONCRETE)




RC. DET. OF FDN. FOR PUMP MKD.
3660-PMP-011, 012 & 017
(TOP VIEW OF FIRST STAGE CONCRETE)
SCALE 1:40




RC. DET. OF FDN. FOR PUMP MKD.
3660-PMP-011, 012 & 017
(BOTTOM VIEW)
SCALE 1:40




RC. DET. OF FDN. FOR PUMP MKD.
3660-PMP-018, 019 & 020
(TOP VIEW OF FIRST STAGE CONCRETE)
SCALE 1:40




RC. DET. OF FDN. FOR PUMP MKD.
3660-PMP-018, 019 & 020
(BOTTOM VIEW)
SCALE 1:40




SECTION : A-A
SCALE 1:40



SECTION : B-B
SCALE 1:40



FDN. FOR PUMP MKD.
3660-PMP-011, 012 & 017
SCALE 1:40



FDN. FOR PUMP MKD.
3660-PMP-018, 019 & 020
SCALE 1:40

LEGEND :-
R.L. - REDUCED LEVEL
T.O.C. - TOP OF CONCRETE.
F.G.L. - FINISHED GROUND LEVEL.
F.F.L. - FINISHED FLOOR LEVEL.
B.O.F. - BOTTOM OF FOUNDATION
TYP. - TYPICAL.
P.C.D. - PITCH CIRCLE DIAMETER.
P.C.C - PLAIN CEMENT CONCRETE
MKD. - MARKED.
THK. - THICK
EQV. - EQUIVALENT
Ø - DIAMETER
CJ - CONSTRUCTION JOINT
SQ - SQUARE
RCC. - REINFORCED CEMENT CONCRETE
DIA - DIAMETER
DRG. - DRAWING
℄ - CENTRE LINE
FDN. - FOUNDATION
REGEN. - REGENERATION
R.C. - REINFORCED CONCRETE
DET. - DETAIL
(T) - TOP
(B) - BOTTOM
G.A. - GENERAL ARRANGEMENT

NOTES :-
1. ALL DIMENSIONS ARE IN MILLIMETRES AND LEVELS AND CO-ORDINATES ARE IN METRES. UNLESS OTHERWISE STATED.
2. GRADE OF CONCRETE SHALL BE C35 FOR FOUNDATION.
3. GRADE OF REINFORCEMENT SHALL BE DEFORMED BAR ASTM A615 - GRADE 60 (fy = 420 MPa).
4. NET SAFE BEARING CAPACITY OF SOIL AT BOTTOM OF FOUNDATION IS CONSIDERED 450KN/ SQ. M.
5. IF ANY PART OF FOUNDATION COMES ON BACKFILL ZONE OF ADJACENT FOUNDATION OR ANY LOOSE SOIL ARE ENCOUNTERED BELOW FOUNDATION LEVEL THE SAME SHALL BE REMOVED AND FILLED WITH PCC.
6. SAND SHALL BE COMPACTED TO A MAXIMUM DEPTH OF 300MM AND SHALL BE COMPACTED TO 80% RELATIVE DENSITY AS DETERMINED BY ASTM D4253 AND ASTM D4254.
7. CHEMICAL RESISTANT COATING SHALL BE APPLIED FOR PROTECTING CONCRETE AGAINST ACID & ALKALI .

DOCUMENT NUMBER	REFERENCE DOCUMENTS			REVISION DESCRIPTION	DRN	CHK	ENG	APP	EMP
MD-216-3660-EG-ME-GAD-V043-1009	GENERAL ARRANGEMENT DRAWING FOR PUMP 3660-PMP-018, 019 & 020								
MD-216-3660-EG-ME-GAD-V043-1005	GENERAL ARRANGEMENT DRAWING FOR PUMP 3660-PMP-011, 012 & 017	D01	05/05/2025	AS - BUILT	TEC	BJB	TEC	SJM	
		C01	10/02/2021	ISSUED FOR CONSTRUCTION & REVISED AS MARKED C01	TEC	BJB	TEC	SJM	
MD-216-3660-EG-ME-GAD-2011	G.A. & DETAILS OF FOUNDATION-1	A01	08/01/2021	ISSUED FOR REVIEW	TEC	BJB	TEC	SJM	

LARSEN & TOUBRO
This drawing is the property of LARSEN & TOUBRO and must not be passed on to any person or body not authorized by us to receive it nor be copied or otherwise made use either in full or in part by such person or body without our prior permission in writing.

Outotec
The content of these documents are the sole property of Outotec Oyj. Any rights not expressly granted herein are reserved. Reproduction, transfer or distribution of part or all of the contents in any form without prior written permission of Outotec is prohibited.

MA'ADEN معادن
Saudi Arabian Mining Company شركة التعدين العربية السعودية
This document and the information contained herein is Ma'aden proprietary know-how. This document or any part thereof should not be reproduced, stored in a retrieval system or transmitted by any means, electronic or otherwise, or divulged without prior written permission of Ma'aden.

LARSEN & TOUBRO DRAWING NUMBER	019045_450_C_G_24420_002		REVISION 2
OUTOTEC DRAWING NUMBER	900707 _GAU01 _EE13 _MTL01 _36673	DOCUMENT ID OU100711549	REVISION 2
DRAWN	TEC	02/01/2021	
CHECKED	BJB	04/01/2021	
ENGINEER	TEC	02/01/2021	
APPROVED	SJM	08/01/2021	
EMPLOYER			
SCALE 1:100, 1:40	A1		

MANSOURAH - MASSARAH GOLD PROJECT
GENERAL ARRANGEMENT DRAWING
LOW GRADE ACID WASH/ELUTION/CARBON REGEN
G.A & DETAILS OF FOUNDATION-2

DRAWING NUMBER: MD - 216 - 3660 - EG - CV - GAD - 2012
REV: D01