



Landlord Gas Safety Record

Cert. No. 606

Safety Inspection and reporting carried out in accordance with the Gas Safety (Installation and Use) Regulations 1998 section 26(9) and the Gas Industry Unsafe Situations Procedure.

Plumbing & Heating Svcs Ltd

Company / Installer		Job Address		Customer / Landlord	
Engineer	Chris Hargrave	Name		Name	Aksana
Company	Plumbing & Heating Svcs Ltd	Address	39	Company	Black & White Estate Agents
Address	20-30a Abington Street		Upton Grove	Address	31
	Abington Street		Milton Keynes		Caldecote Street
	Northampton		Shenley Lodge		Newport Pagnel
		Post Code	MK5 7GR		
Post Code	NN1 2AJ	Tel. No		Post Code	Mk16 0bu
Tel No.	07848010996			Tel. No	01908 550660
Gas Safe Reg	924472				
ID Card No.	924472				

Appliance Details						Inspection Details															
	Location	Appliance Type	Make	Model	Flue Type	Landlord's Appliance	Appliance Inspected	Operating Pressure (mbar)	Heat Input (kW/h)	High Combustion Reading			Low Combustion Reading			Safety device(s) correct operation	Ventilation Provision satisfactory	Visual condition of flue and termination satisfactory	Flue Performance test	Appliance Serviced	Appliance safe to use
										Ratio	CO ppm	CO2 %	Ratio	CO ppm	CO2 %						
1	Airing Cupboard	Boiler	Worcester Bosch	Greenstar 34 Cdi Classic	RS	Yes	Yes	19.33	30.24	0.0006	84	8.9	NA	NA	NA	Yes	Yes	Yes	Pass	NA	Yes
2	Kitchen	Cooker	Beko	Kdvf100k	FL	Yes	Yes	19.31	9.31	NA	NA	NA	NA	NA	NA	Yes	Yes	NA	NA	NA	Yes
3																					
4																					
5																					
6																					

Defects / Identified										Labels and Warning Notice Issued						CO Alarm(s)			
1	System pressure is dropping everyday. Expansion vessel recharged . If issue still occurring investigation will be required into water leak.									NA						CO Alarm(s) fitted CO Alarm(s) tested and Satisfactory		Yes Pass	
2	Front right burner not working knob won't turn Back left burner not burning correctly Both require repair or replacement									NA									
3																			
4																			
5																			
6																			

Emergency Control Accessible ☒ Yes	Gas Tightness Satisfactory ☒ Yes	Comments
Gas Installation Pipework Visual Inspection Satisfactory ☒ Yes		
Equipotential Bonding ☒ Yes		
NEXT INSPECTION DUE BEFORE	17-Apr-2027	

Signatures					
Issued by:	Signed	Received	Signed	Date	17-Apr-2026
		by:			
Print Name	Chris Hargrave	Print Name	Aksana		