



Product Service

CERTIFICATE

No. B 111540 0003 Rev. 00

Holder of Certificate: Guangzhou Cable Works Co.,Ltd

51,Lanzhang Road,Lanhe, Nansha
511480 Guangzhou
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product:

Electric Cables

**Electric cables for photovoltaic systems
with a voltage rating of 1.5kV DC**

Model(s):

H1Z2Z2-K

1×1.5 mm², 1×2.5 mm², 1×4 mm², 1×6mm²
1×10 mm², 1×16mm², 1×25 mm², 1×35 mm²
2×1.5 mm², 2×2.5 mm², 2×4 mm², 2×6mm²
2×10 mm²

62930 IEC 131

1×1.5 mm², 1×2.5 mm², 1×4 mm², 1×6mm²
1×10 mm², 1×16mm², 1×25 mm², 1×35 mm²
2×1.5 mm², 2×2.5 mm², 2×4 mm², 2×6mm²
2×10 mm²

Parameters:

Rated Voltage: DC 1500V (between conductors and
between conductor and earth)

AC U₀/U: 1.0/1.0 kV

Class(IEC 61140): II

Ambient Temperature -40°C~+90°C

Max. Temperature

at conductor: 120°C

Tested according to:

IEC 62930(ed.1)

EN 50618:2014

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier.

All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.:

704072304201-00

Valid until:

2028-03-08

Date, 2023-03-09

(Yaqun Alex Liu)