



Product Service

CERTIFICATE

No. B 111540 0004 Rev. 00

Holder of Certificate: Guangzhou Cable Works Co.,Ltd

51,Lanzhang Road,Lanhe, Nansha
511480 Guangzhou
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product:

Electric Cables

Cables for use in photovoltaic systems

Model(s):

PV1-F

1×1.5mm², 1×2.5mm², 1×4mm², 1×6mm²
1×10mm², 1×16mm², 1×25mm², 1×35mm²
2×1.5 mm², 2×2.5 mm², 2×4 mm², 2×6mm²
2×10 mm²

Parameters:

Rated Voltage:

AC U₀/U: 0.6/1.0 kV

Maximum DC voltage 1,8 kV(Conductor-conductor, non earthed system, circuit not under load).

U₀ is the r. m. s. value between any insulated conductor and earth, i.e.

Metal covering of the cable or the surrounding medium,

U is the r. m. s. value between any two phase-conductors of a multicore cable or of a system of single-core cables.

Class(IEC 61140):

II

Ambient Temperature

-40°C ~+90°C

Max. Temperature

at conductor:

120°C

Tested according to:

PPP 59074A:2019

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier.

All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.:

704072304202-00

Valid until:

2028-03-08

Date,

2023-03-09

(Yaquin Alex Liu)