

FIELD SERVICE REPORT

GENERAL INFORMATION

Report No.	00290					
Service Type	☐ Breakdown	☒ Preventive Maintenance	☐ Ad-hoc	☐ Others		
Scope of Work	☐ Electrical	☐ HVAC	☐ EMS	☐ Fire System	☐ WDS System	
	☐ Door Access	☐ UPS System	☐ Split Unit	☐ Genset	☐ Others	
Project Name	PREVENTIVE MAINTENANCE PAC LEVEL 14 SERVER ROOM					
Client	JKR					
Client PIC	ZAM					
Client Contact	017 2912838					
Site Address	JALAN SULTAN SALAHUDDIN, KUALA LUMPUR					
Date of Service	18/8/26					
Time On Site	12:30					
Time Off Site	1:30					

EQUIPMENT DETAILS

Item #	Type/Brand/Model	Serial Number	Location	Status	Remarks
1 CEV 1	EMERSON	21F0105802133010003	Server Room	OK	INROW 1
2 CEV 2	EMERSON	21F01088502133010000	Server Room	OK	INROW 2
3 CEV 3	EMERSON	21F01058502133010001	Server Room	OK	INROW 3
4					
5					
6					
7					
8					
9					
10					

WORK SUMMARY

Activities Performed	* PM Month of August 26 * Checking and Routine Preventive Maintenance, To Check and Measure Voltage, amp, water supply, blower and electrical Part. * All unit good Condition, Unit Normal Operation.
Tools/Equipment Used	
Parts Replaced	

OBSERVATIONS & RECOMMENDATIONS

* The existing filter is over 3 years old. It is recommended to be replaced it with new one. Can check at the picture.

SIGN-OFF

Engineer Declaration: I hereby confirm the above work was performed and functioning in good conditions

Attended by (Engineer)

Name	Horiz	Signature/Stamp		Date	18/8/26
------	-------	-----------------	---	------	---------

Acknowledged by (Client)

Name	MO SULTAN	Signature/Stamp	MOHD SUKIZAM B. MOHAMED ALI MECHANICAL SUPERVISOR CAKRA MAKOTA SDN BHD	Date	18/8/26
------	-----------	-----------------	--	------	---------

Sheet No: 1 of 3

Date: 18/8/26

PRECISION AIRCOND SERVICE CHECKLIST

(CIVIL) LIEBERT

Customer / User: JKE
Address: LEVEL 19 (SERVER ROOM)
Contact: _____ Phone: _____

Product Model: CE040FC10351012H15036CAXXX

Serial No: 21F01058302133010003

Type of Service: Schedule Service ☒ Breakdown ☐
Repair ☐ T&C ☐ Others _____

TIME & DATE

Origin Call: _____
Departure: _____
Arrival: _____
Sys. Restored: _____
Departed Site: _____

Maintenance Check List (Please Mark OK (), Not OK (X), Not applicable (NA) in the box)

- | | |
|---|--|
| 1. Air Filter cleaned. ☒ | 6. Blower Bearing checked ☐ |
| 2. Pulley alignment checked. ☐ | 7. Vee Belt checked. ☐ |
| 3. Drain Pan cleaned. ☐ | 8. Drain Pipe flushed. ☐ |
| 4. Refrigeration System OK. ☐ | 9. Compressor Oil checked. ☐ |
| 5. Electrical System checked. ☒ | 10. General cleanliness, OK? ☒ |

Refrigeration Check List

- | | |
|--|---|
| 1. Evaporator Coil cleaned. ☐ | 3. Condenser Coil cleaned. ☐ |
| 2. Fans vibration checked. ☐ | 4. Sight Glass checked? ☐ |

Pump and Valves: (if applicable)

- | | |
|--|---|
| 1. Strainer cleaned. ☐ | 6. Pump Seal checked. ☐ |
| 2. Pump Bearing checked. ☐ | 7. Valves operation checked. ☐ |
| 3. Discharge Service Valves operation checked. ☐ | |
| 4. Suction Service Valves operation checked. ☐ | |
| 5. Check Sign of Refrigerant leakage at Refrigeration system. ☐ | |

PART USED

Qty	Description
2	445 X 800 X 95 (mm)
	AIR FILTER

Set Temp (°C) 25+/- Act Temp (°C) 23
Set Humidity (%) 49+/- Act Humidity (%) 59

Operation Measurement (full load current)

No	Description	No. 1	No. 2	No. 3
1.	Compressors (Amp)			
2.	Blower Fan Motor (Amp)	1.3	1.2	1.4
3.	Reheat (Amp)	8.6	8.4	8.6
4.	Humidifier (Amp)			
5.	Condenser Fan Motors (Amp)			

Discharge Pressure (Psi) _____
Suction Pressure (Psi) _____

Description	Supply	Return
6. Chilled Water Pressure		
7. Chilled Water Temperature		

Total Parts Used:	RM.
Labour:	RM.
Expenses:	RM.
TOTAL:	RM.
P.O. No:	
P.O. Date:	

Remark: Do pm services. Check electrical system and unit condition.
Found dirty air filter need to change. unit normal operation.

Engineer / Representative

Signature: _____
Name: HARIZ / JUDIN / AMIRUL
Date: 18/8/26

Customer Acknowledgement

Signature: MOHD SUKZAM B. MOHAMED ALI
Name: MECHANICAL SUPERVISOR
Date: CAKRA MAKOTA SDN BHD

18/8/26

Sheet No: 3 of 3

Date: 18/8/26

PRECISION AIRCOND SERVICE CHECKLIST

CEV 3 LIEBERT

Customer / User: JKE
Address: LEVEL 19 (SERVER ROOM)
Contact: _____ Phone: _____

Product Model: CR040EC103SD1241S030C Axxx
Serial No: 21F0105850213306001

Type of Service: Schedule Service ☒ Breakdown ☐
Repair ☐ T&C ☐ Others _____

TIME & DATE
Origin Call: _____
Departure: _____
Arrival: _____
Sys. Restored: _____
Departed Site: _____

Maintenance Check List [Please Mark OK (☑), Not OK (X), Not applicable (NA) in the box]

- | | |
|---|--|
| 1. Air Filter cleaned. ☒ | 6. Blower Bearing checked. ☐ |
| 2. Pulley alignment checked. ☐ | 7. Vee Belt checked. ☐ |
| 3. Drain Pan cleaned. ☐ | 8. Drain Pipe flushed. ☐ |
| 4. Refrigeration System OK. ☐ | 9. Compressor Oil checked. ☐ |
| 5. Electrical System checked. ☒ | 10. General cleanliness, OK? ☒ |

Refrigeration Check List

- | | |
|--|---|
| 1. Evaporator Coil cleaned. ☐ | 3. Condenser Coil cleaned. ☐ |
| 2. Fans vibration checked. ☐ | 4. Sight Glass checked? ☐ |

Pump and Valves: (if applicable)

- | | |
|--|---|
| 1. Strainer cleaned. ☐ | 6. Pump Seal checked. ☐ |
| 2. Pump Bearing checked. ☐ | 7. Valves operation checked. ☐ |
| 3. Discharge Service Valves operation checked. ☐ | |
| 4. Suction Service Valves operation checked. ☐ | |
| 5. Check Sign of Refrigerant leakage at Refrigeration system. ☐ | |

Operation Measurement (full load current)

No	Description	No. 1	No. 2	No. 3
1.	Compressors (Amp)			
2.	Blower Fan Motor (Amp)	1.3	1.2	1.4
3.	Reheat (Amp)	8.6	8.6	8.8
4.	Humidifier (Amp)			
5.	Condenser Fan Motors (Amp)			

Description	Supply	Return
6. Chilled Water Pressure		
7. Chilled Water Temperature		

PART USED

Qty	Description
2	445 x 800 x 95 (mm) Air Filter -

Set Temp (°C) <u>25 +/-</u>	Act Temp (°C) <u>23.6</u>
Set Humidity (%) <u>50 +/-</u>	Act Humidity (%) <u>59</u>
Discharge Pressure (Psi) _____	
Suction Pressure (Psi) _____	

Total Parts Used:	RM.
Labour:	RM.
Expenses:	RM.
TOTAL:	RM.
P.O. No:	
P.O. Date:	

Remark: Do PM services. Check electrical system and unit condition.

Found dirty air filter need to change. unit normal operation.

Engineer / Representative

Signature: _____
Name: HARIZ / JUDIN / AMIRUL
Date: 18/8/26

Customer Acknowledgement

Signature: _____
Name: MOHD SURIZAM B. MOHAMED ALI
Date: 18/8/26
MECHANICAL SUPERVISOR
CAKRA MAKOTA SDN BHD

Sheet No: 2 of 3

Date: 18/8/2016

PRECISION AIRCOND SERVICE CHECKLIST

CRU 2 LIEBERT

Customer / User: JKE
Address: LEVEL 19 (SERVER ROOM)
Contact: _____ Phone: _____

Product Model: CR040RC10351012 H1 5018 ACAXX
Serial No: 21F01088500133010 000

Type of Service: Schedule Service ☒ Breakdown ☐
Repair ☐ T&C ☐ Others _____

TIME & DATE
Origin Call: _____
Departure: _____
Arrival: _____
Sys. Restored: _____
Departed Site: _____

Maintenance Check List (Please Mark OK (☑), Not OK (X), Not applicable (NA) in the box)

- | | |
|---|--|
| 1. Air Filter cleaned. ☒ | 6. Blower Bearing checked ☐ |
| 2. Pulley alignment checked. ☐ | 7. Vee Belt checked. ☐ |
| 3. Drain Pan cleaned. ☐ | 8. Drain Pipe flushed. ☐ |
| 4. Refrigeration System OK. ☐ | 9. Compressor Oil checked. ☐ |
| 5. Electrical System checked. ☒ | 10. General cleanliness, OK? ☒ |

Refrigeration Check List

- | | |
|--|---|
| 1. Evaporator Coil cleaned. ☐ | 3. Condenser Coil cleaned. ☐ |
| 2. Fans vibration checked. ☐ | 4. Sight Glass checked? ☐ |

Pump and Valves: (if applicable)

- | | |
|--|---|
| 1. Strainer cleaned. ☐ | 6. Pump Seal checked. ☐ |
| 2. Pump Bearing checked. ☐ | 7. Valves operation checked. ☐ |
| 3. Discharge Service Valves operation checked. ☐ | |
| 4. Suction Service Valves operation checked. ☐ | |
| 5. Check Sign of Refrigerant leakage at Refrigeration system. ☐ | |

Operation Measurement (full load current)

No	Description	No. 1	No. 2	No. 3
1.	Compressors (Amp)			
2.	Blower Fan Motor (Amp)	1.4	1.3	1.5
3.	Reheat (Amp)	8.6	8.7	8.9
4.	Humidifier (Amp)			
5.	Condenser Fan Motors (Amp)			

Description	Supply	Return
6. Chilled Water Pressure		
7. Chilled Water Temperature		

PART USED	
Qty	Description
2	445 X 800 X 95 (014)
	Air Filter

Set Temp (°C)	Act Temp (°C)
<u>25 +/-</u>	<u>22</u>
Set Humidity (%)	Act Humidity (%)
<u>49 +/-</u>	<u>60</u>
Discharge Pressure (Psi)	_____
Suction Pressure (Psi)	_____

Total Parts Used:	RM.
Labour:	RM.
Expenses:	RM.
TOTAL:	RM.
P.O. No:	
P.O. Date:	

Remark: Do PM service. check electrical system and unit condition.
Found dirty air filter need to change. unit normal operation.

Engineer / Representative

Signature: _____
Name: HARIZ / JUDIN / AMIRUL
Date: 18/8/2016

Customer Acknowledgement

Signature: _____
Name: MOHD SUKIZAM B / MOHAMED AU
Date: 18/8/2016