What If ChatGPT Could Help Pay Our Heating Bills?

An AI Heat Dividend for Rochester

1. Introduction

With the development of AI technology, ChatGPT has gradually become a very useful auxiliary tool in each of our lives. But what if I say that ChatGPT can not only assist us in data search and organization, but also help us add impetus to the environmental protection system in reality? What if a community could enable the same electricity to both perform AI calculations and provide usable heat?

My idea is to establish an AI Heat Dividend, that is, the "**AI Heat Dividend**" program. The data center sells the recyclable heat generated by AI calculations to the local heating agency, and nearby residents share the profits through lower heating fees. In this project, I plan to use a hypothetical community in Rochester as a case study.

The most attractive aspect of this idea to me is to make AI companies the heating partners of the surrounding residents. What I hope residents will receive is the benefits they can truly see on their bills, rather than just another general commitment to sustainability.

2. The Problem: Buying Heat While Throwing It Away

The International Energy Agency estimates that global data centers will consume approximately 485 terawatt-hours of electricity in 2025. This figure encompasses all types of data centers, not just AI data centers. It gave me a relatively specific understanding of the scale of this issue (IEA, 2026a).

The International Energy Agency also points out that almost all the electricity consumed by data centers is eventually converted into heat. Under suitable conditions, approximately 70% to 80% of the heat can be recovered through heat pumps. But this is only the total recoverable heat. The actual heat that can be delivered to residents' homes still needs to be calculated separately. (IEA, 2025).

It is of course beneficial to handle calculation and heating separately. The two systems can operate independently without having to depend on each other. However, I think we also need to calculate: Can data centers and nearby buildings share some facilities instead of always regarding their energy demands as two completely unrelated matters?

3. My Crazy Idea: The AI Heat Dividend

Heat is collected from the cooling system of the AI data center, the temperature is raised by heat pumps, and then the hot water is delivered to nearby buildings through insulated pipes. This part adopts the basic waste heat utilization methods introduced by the International Energy Agency (IEA, 2025).

The bolder change I propose is that if newly-built urban AI data centers hope to receive support from the municipal government, they should assess the possibility of providing waste heat to the surrounding communities. If the project is indeed feasible, the government should also approve it after collecting the opinions of the residents.

The heating network can be operated by existing public utility companies or community-owned heating institutions. AI data centers generate income by selling heat, while residents receive lower heating prices.

In fact, there are indeed precedents that can support the feasibility of AI waste heat recovery and utilization. Sitra reported that a data center in Mäntsälä, Finland, supplied **20 GWh of recovered heat in 2018**, covering **54% of the local heating system's demand**. Based on this operation mode, what I hope to add is a set of local cooperation rules: Since the data center has received community support, it should bring measurable actual benefits to the community (Sitra, 2019).

4. Let's Do the Math

I would first test the idea with a simplified scenario. The data center would already be operating without this heating project, so I count only the additional effects of heat recovery.

Here are my assumptions:

Item	Assumption
Average data center electricity load, before the added heat pump	10 MW
Heating season	180 days, operating 24 hours per day
Share captured as source heat before the heat pump	75%
Heat-pump coefficient of performance, or COP	3
Heat lost through the distribution network	10%
Useful heat needed per household per heating season	15 MWh

These are modeling assumptions, not measurements from Rochester. The 75% assumption is informed by the IEA's recovery range, but it is not a guaranteed result for this site.

Step 1: Calculate the recoverable heat.

$10 \times 24 \times 180 \times 0.75 = 32{,}400$ MWh

This means the data center could provide about 32,400 MWh of recoverable heat during the heating season.

Step 2: Calculate the electricity needed for the heat pump.

COP describes heat output divided by the electricity used to run the heat pump. At my assumed COP of 3, each unit of electricity supports three units of heat output: two recovered from the source and one from electricity.

$32{,}400 \div (3 - 1) = 16{,}200$ MWh

So, the heat pump would need an additional 16,200 MWh of electricity.

Step 3: Calculate the useful heat delivered to households.

After adding the heat pump's electricity input and accounting for a 10% heat loss through the distribution network:

$(32{,}400 + 16{,}200) \times 0.90 = 43{,}740$ MWh

This means about 43,740 MWh of useful heat could reach nearby buildings during the heating season.

Step 4: Estimate how many households could be heated.

If I assume that each household needs 15 MWh of heat during one heating season:

$43{,}740 \div 15 = 2{,}916$ households

Based on these assumptions, the recovered heat could provide the equivalent of one heating season's demand for approximately **2,900 households**.

Of course, the specific situation still needs to be discussed specifically. This figure may also change on the coldest day of the year. At the same time, the premise of this figure is that I assume all the recovered heat can be effectively utilized.

However, despite this, I believe this rough calculation can at least demonstrate that the waste heat recovery of an AI data center can indeed make a considerable

contribution to the heating of nearby communities.

5. Environmental and Economic Benefits

I wanted to check the money rather than just describe the recovered heat as free energy. For this example, I assume that the heat recovery equipment, pipelines, and necessary building upgrades would cost about $20 million in total. I also assume that electricity costs $80 per MWh, while other annual operating costs would be around $800,000. These costs include maintenance, circulation pumping, heat purchases, and backup heating arrangements.

Of course, these are just assumptions for my calculation, not actual prices from a project in Rochester.

I also assume that households currently pay $80 per MWh of useful heat. Under my proposal, they would pay $72 per MWh, which means a 10% discount on their heating costs.

Step 1: Calculate the annual revenue from selling heat.

43,740 MWh × $72 = $3,149,280

This means the heating provider could earn about $3.15 million per year by selling recovered heat to nearby households.

Step 2: Calculate the annual operating costs.

Electricity cost:

16,200 MWh × $80 = $1,296,000

Other annual operating costs:

$800,000

Total annual operating costs:

$1,296,000 + $800,000 = $2,096,000

Step 3: Calculate the money remaining after operating costs.

$3,149,280 − $2,096,000 = $1,053,280

Based on my assumptions, the project could generate about $1.05 million per year after operating costs, but before financing costs and taxes.

Step 4: Estimate how long it would take to recover the initial investment.

$20,000,000 ÷ $1,053,280 ≈ 19 years

So, the simple payback period would be approximately 19 years.

Step 5: Calculate how much households could save.

The heating price would decrease from $80 to $72 per MWh, meaning households would save $8 per MWh.

43,740 MWh × $8 = $349,920

Together, households could save about $350,000 per year.

For one household using 15 MWh of heat during the heating season:

15 MWh × $8 = $120

This means each household could save around $120 per heating season.

I think this is a useful result, but it also shows that the project would not provide free heating. The remaining revenue would still need to cover the initial investment. If financing costs or future equipment replacements were included, the project might become less attractive.

Step 6: Estimate the potential environmental benefits.

For the environmental side, I assume the recovered heat would replace natural gas boilers operating at 90% efficiency.

43,740 MWh ÷ 0.90 = 48,600 MWh

This means the project could avoid approximately **48,600 MWh** of natural gas consumption during one heating season.

However, the electricity consumed by the heat pump itself cannot be ignored either. According to the previous calculation, the heat pump still requires an additional 16,200 MWh of electricity, and other equipment also needs some energy. Moreover, the original data center will continue to use electricity, and carbon emissions will still exist.

If I don't know where the newly added electricity comes from or which specific heating method it replaces, I won't be able to accurately calculate how much carbon emissions the entire project can reduce. The research by Laine et al. (2020) also indicates that merely focusing on how much local emissions have been reduced may

lead us to misjudge the true environmental impact of the entire project.

Overall, I do think this idea may indeed bring environmental and economic benefits, but these figures also remind me that recycling waste heat does not necessarily mean the project will be profitable, nor does it necessarily mean it will play a significant role in environmental protection. The final outcome largely depends on electricity prices, construction costs, and whether the recovered heat can be truly and effectively utilized.

6. Economic Incentives: Why Would Anyone Participate?

The success of this plan, of course, cannot solely depend on the generosity of enterprises. AI data centers must provide sufficient relevant proof to support heating, and the operation of the heat network also needs to be promoted to attract a sufficient number of users willing to pay. Ultimately, residents also need an attractive price that is worth changing the heating method.

Selling heat brings private benefits to AI data centers. If the project does indeed reduce pollution, cleaner air may also benefit those who are not connected to the pipeline network. This is what constitutes a positive externality. These two kinds of returns are different.

I also saw a bargaining issue. After a community has spent money laying pipes, it may not be easy to change suppliers. Therefore, before the start of construction, it is also indispensable for all parties to determine the long-term pricing rules and heating arrangements.

In addition, the original fuel supplier might oppose this plan due to the loss of customers. Building owners may also be reluctant to pay for renovation costs and so on and so forth.

Based on these issues, I will attempt to involve existing heating companies and focus the access support on buildings that can actually benefit residents. Otherwise, this plan might in the end only benefit the landlord without helping those who actually spend money to keep the indoor warmth.

7. Challenges and Unintended Consequences

What I'm most worried about is the cost issue. The International Energy Agency has listed the initial investment, whether the temperature is matched, and how far the heat source is from the user as important obstacles to the utilization of waste heat. Sometimes, the distance may not seem far on the map, but laying pipes requires a huge amount of effort. This is a significant cost that is often overlooked. (IEA, 2026b

The success of this model is also closely related to the fluctuations in electricity prices. If the electricity price rises from $80 per MWh to $120, with all other conditions remaining unchanged, the annual balance, after deducting operating expenses and without calculating financing costs, will drop to $405,280. The simple payback period will be extended to approximately 49 years.

At this point, I would seriously doubt: Is it more worthwhile to use the same amount of money to improve building insulation or install independent heat pumps?

My second concern is reliability. Once an AI data center experiences an unexpected shutdown or needs to urgently reduce its operating load, the heating of all communities on the entire heating network will be affected. This is a very risky situation in the cold winter. I will require the project to retain reliable backup heating equipment to deal with the occurrence of such critical situations. But this doesn't mean it's foolproof. Meanwhile, the long-term maintenance of backup heating equipment is also part of the cost.

Besides, I also don't accept the statement that "using more AI automatically makes one more environmentally friendly." My plan makes use of the heat generated by the computing activities that will already occur. If unnecessary computing facilities are added for heating purposes, that would be another project, and the additional costs and emissions would also have to be recalculated.

8. Conclusion: Start With a Neighborhood, Not the Whole City

I still like this idea, but the calculation results tell me that there is still much room for improvement in my plan.

I will support launching a small-scale voluntary pilot program first to connect an existing data center with approximately 20 nearby apartments. The waste heat recovery equipment needs to be configured according to the actual demands of these buildings. The cost of small-scale solutions also needs to be quoted separately.

I will spend two winters recording the actual heat sent out, the additional electricity consumed, the downtime, the costs, and the actual bill discounts that residents receive. Before expanding the project, I will also compare the results with other heating renovation methods.

For me, the real innovation needed in this project lies in getting the data center operator, heating provider, building owner and residents to reach an agreement on "who pays, who benefits".

References

International Energy Agency. (2022). *The future of heat pumps: How a heat pump works.* https://www.iea.org/reports/the-future-of-heat-pumps/how-a-heat-pump-works

International Energy Agency. (2025, December 8). *Opportunities for district heating in the changing energy landscape.* https://www.iea.org/commentaries/opportunities-for-district-heating-in-the-changing-energy-landscape

International Energy Agency. (2026a). *Key questions on energy and AI: Executive summary.* https://www.iea.org/reports/key-questions-on-energy-and-ai/executive-summary

International Energy Agency. (2026b). *Renewables in district energy: Executive summary.* https://www.iea.org/reports/renewables-in-district-energy/executive-summary

Laine, J., Kontu, K., Heinonen, J., & Junnila, S. (2020). Uncertain greenhouse gas implication in waste heat utilization—A case study with a data center. *Journal of Sustainable Development of Energy, Water and Environment Systems, 8*(2), 360–372. https://www.sdewes.org/jsdewes/pid7.0301

Sitra. (2019, October 18). *District heating from data centre waste heat, Mäntsälä.* https://arkisto.sitra.fi/en/cases/district-heating-from-data-centre-waste-heat-mantsala/