

MODULE: 1756-IB32 CHASSIS: C1 SLOT: 3 TYPE: DI TERMINAL STRIP: C1S03-X1 POINTS: 32																RATING: 24V DC SINK/SOURCE PANEL: CA1 / MOTOR CONTROL																																															
PT								PLC ADDR								TB PIN								INTERNAL / BARRIER								FIELD DEST								TAG NUMBER								SERVICE / INSTRUMENT DESCRIPTION															
01								C1S03,01								X1:02																FUSE 1492-JD3FB (1A)								CA1								SPARE								Spare I/O Channel							
02								C1S03,02								X1:03																FUSE 1492-JD3FB (1A)								CA1								SPARE								Spare I/O Channel							
03								C1S03,03								X1:04																FUSE 1492-JD3FB (1A)								CA1								SPARE								Spare I/O Channel							
04								C1S03,04								X1:05																FUSE 1492-JD3FB (1A)								CA1								SPARE								Spare I/O Channel							
05								C1S03,05								X1:06																FUSE 1492-JD3FB (1A)								CA1								SPARE								Spare I/O Channel							
06								C1S03,06								X1:07																FUSE 1492-JD3FB (1A)								CA1								SPARE								Spare I/O Channel							
07								C1S03,07								X1:08																FUSE 1492-JD3FB (1A)								CA1								SPARE								Spare I/O Channel							
08								C1S03,08								X1:09																FUSE 1492-JD3FB (1A)								CA1								SPARE								Spare I/O Channel							
09								C1S03,09								X1:10																FUSE 1492-JD3FB (1A)								CA1								SPARE								Spare I/O Channel							
10								C1S03,10								X1:11																FUSE 1492-JD3FB (1A)								CA1								SPARE								Spare I/O Channel							
11								C1S03,11								X1:12																FUSE 1492-JD3FB (1A)								CA1								SPARE								Spare I/O Channel							
12								C1S03,12								X1:13																FUSE 1492-JD3FB (1A)								CA1								SPARE								Spare I/O Channel							
13								C1S03,13								X1:14																FUSE 1492-JD3FB (1A)								CA1								SPARE								Spare I/O Channel							
14								C1S03,14								X1:15																FUSE 1492-JD3FB (1A)								CA1								SPARE								Spare I/O Channel							
15								C1S03,15								X1:16																FUSE 1492-JD3FB (1A)								CA1								SPARE								Spare I/O Channel							
16								C1S03,16								X1:17																FUSE 1492-JD3FB (1A)								JB-401								FSL-40201								Slurry low flow P&ID: 3-25-01-402-PD-01							
17								C1S03,17								X1:18																FUSE 1492-JD3FB (1A)								JB-401								FSL-40202								Slurry low flow P&ID: 3-25-01-402-PD-01							
18								C1S03,18								X1:19																FUSE 1492-JD3FB (1A)								JB-401								FT-40201								Slurry flowrate & density check transfer.. P&ID: 325-01-400-PD-02							
19								C1S03,19								X1:20																FUSE 1492-JD3FB (1A)								JB-401								FT-40202								Feed Slurry Flow Transmitter for Pipe (P.. P&ID: 325-01-400-PD-02							
20								C1S03,20								X1:21																FUSE 1492-JD3FB (1A)								JB-401								HV-40201								Slurry Drain line P&ID: 325-01-400-PD-01							
21								C1S03,21								X1:22																FUSE 1492-JD3FB (1A)								JB-401								HV-40202								Slurry Drain line P&ID: 325-01-400-PD-01							
22								C1S03,22								X1:23																FUSE 1492-JD3FB (1A)								JB-401								HV-40203								Slurry Drain tank TS-40201 P&ID: 325-01-400-PD-01							
23								C1S03,23								X1:24																FUSE 1492-JD3FB (1A)								JB-401								HV-40204								Slurry Drain tank TS-40202 P&ID: 325-01-400-PD-01							
24								C1S03,24								X1:25																FUSE 1492-JD3FB (1A)								JB-401								HV-40205								Slurry Drain line P&ID: 325-01-400-PD-01							
25								C1S03,25								X1:26																FUSE 1492-JD3FB (1A)								JB-401								HV-40206								Slurry Drain tank TS-40203 P&ID: 325-01-400-PD-01							
26								C1S03,26								X1:27																FUSE 1492-JD3FB (1A)								JB-401								XV-40201A								Slurry feed-in pH Adjustment tank 1 P&ID: 3-25-01-402-PD-01							
27								C1S03,27								X1:28																FUSE 1492-JD3FB (1A)								JB-401								XV-40201A								Slurry feed-in pH Adjustment tank 1 P&ID: 3-25-01-402-PD-01							
28								C1S03,28								X1:29																FUSE 1492-JD3FB (1A)								JB-401								XV-40201B								Slurry feed-out Spray dryer infeed tank P&ID: 325-01-400-PD-01							
29								C1S03,29								X1:30																FUSE 1492-JD3FB (1A)								JB-401								XV-40201B								Slurry feed-out Spray dryer infeed tank P&ID: 325-01-400-PD-01							
30								C1S03,30								X1:31																FUSE 1492-JD3FB (1A)								JB-401								XV-40201C								Water washing line outlet Spray dryer in.. P&ID: 325-01-400-PD-01							
31								C1S03,31								X1:32																FUSE 1492-JD3FB (1A)								JB-401								XV-40201C								Water washing line outlet Spray dryer in.. P&ID: 325-01-400-PD-01							
								C1S03,00								X1:--																FUSE 1492-JD3FB (1A)								CA1								SPARE								Spare I/O Channel							
INGREDION (THAILAND) CO., LTD. KALASIN STARCH PLANT - JET COOKER PROJECT																AEC INDUSTRIAL ENGINEERING SYSTEMS INTEGRATION & AUTOMATION																																															
CHASSIS C1 SLOT 3 - 1756-IB32 (DI) WIRING SCHEMATIC MAIN CONTROL CABINET CA1 / CONTROLLOGIX 1756																DWG NO: KAL-JC-WIR-20001 REV: 3.6 DATE: 2026-09-08																																															
DRAWN: AEC-ENG CHECKED: LEAD-PE								STATUS: APPROVED SCALE: N.T.S.								PROJECT NO: R5THS00138-JC				SHEET NO: 04 / 40																																											