MODULE: 1756-IB32 | CHASSIS: C1 | SLOT: 4 | TYPE: DI | TERMINAL STRIP: C1S04-X1 | POINTS: 32

RATING: 24V DC SINK/SOURCE | PANEL: CA1 / MOTOR CONTROL

PT	PLC ADDR	TB PIN	INTERNAL / BARRIER	FIELD DEST	TAG NUMBER	SERVICE / INSTRUMENT DESCRIPTION
01	C1S04,01	X1:02	FUSE 1492-JD3FB (1A)	JB-401	XV-40201D	CIP water washing Spray dryer infeed tank P&ID: 325-01-400-PD-01
02	C1S04,02	X1:03	FUSE 1492-JD3FB (1A)	JB-401	XV-40201E	CIP hight pressure water washing Spray d.. P&ID: 325-01-400-PD-01
03	C1S04,03	X1:04	FUSE 1492-JD3FB (1A)	JB-401	XV-40201E	CIP hight pressure water washing Spray d.. P&ID: 325-01-400-PD-01
04	C1S04,04	X1:05	FUSE 1492-JD3FB (1A)	JB-401	XV-40201F	Slurry feed-to spray dry tank P&ID: 325-01-400-PD-01
05	C1S04,05	X1:06	FUSE 1492-JD3FB (1A)	JB-401	XV-40201F	Slurry feed-to spray dry tank P&ID: 325-01-400-PD-01
06	C1S04,06	X1:07	FUSE 1492-JD3FB (1A)	JB-401	XV-40201G	CIP water washing pH Adjustment tank 1 P&ID: 325-01-400-PD-01
07	C1S04,07	X1:08	FUSE 1492-JD3FB (1A)	JB-401	XV-40201G	CIP water washing pH Adjustment tank 1 P&ID: 325-01-400-PD-01
08	C1S04,08	X1:09	FUSE 1492-JD3FB (1A)	JB-401	XV-40201H	CIP Hight pressure water washing pH Adju.. P&ID: 325-01-400-PD-01
09	C1S04,09	X1:10	FUSE 1492-JD3FB (1A)	JB-401	XV-40201H	CIP Hight pressure water washing pH Adju.. P&ID: 325-01-400-PD-01
11	C1S04,11	X1:12	FUSE 1492-JD3FB (1A)	JB-401	XV-40202A	Slurry feed-in pH Adjustment tank 2 P&ID: 325-01-400-PD-01
12	C1S04,12	X1:13	FUSE 1492-JD3FB (1A)	JB-401	XV-40202B	Slurry feed-out pH Adjustment tank 2 P&ID: 325-01-400-PD-01
13	C1S04,13	X1:14	FUSE 1492-JD3FB (1A)	JB-401	XV-40202B	Slurry feed-out pH Adjustment tank 2 P&ID: 325-01-400-PD-01
14	C1S04,14	X1:15	FUSE 1492-JD3FB (1A)	JB-401	XV-40202C	Water washing line outlet pH Adjustment .. P&ID: 325-01-400-PD-01
15	C1S04,15	X1:16	FUSE 1492-JD3FB (1A)	JB-401	XV-40202C	Water washing line outlet pH Adjustment .. P&ID: 325-01-400-PD-01
16	C1S04,16	X1:17	FUSE 1492-JD3FB (1A)	JB-401	XV-40202D	Slurry circulation pH Adjustment tank 2 P&ID: 325-01-400-PD-01
17	C1S04,17	X1:18	FUSE 1492-JD3FB (1A)	JB-401	XV-40202D	Slurry circulation pH Adjustment tank 2 P&ID: 325-01-400-PD-01

PT	PLC ADDR	TB PIN	INTERNAL / BARRIER	FIELD DEST	TAG NUMBER	SERVICE / INSTRUMENT DESCRIPTION
18	C1S04,18	X1:19	FUSE 1492-JD3FB (1A)	JB-401	XV-40202E	Slurry pH Adjustment tank 2 transfer to .. P&ID: 325-01-400-PD-01
19	C1S04,19	X1:20	FUSE 1492-JD3FB (1A)	JB-401	XV-40202A	Slurry feed-in pH Adjustment tank 2 P&ID: 325-01-400-PD-01
19	C1S04,19	X1:20	FUSE 1492-JD3FB (1A)	JB-401	XV-40202E	Slurry pH Adjustment tank 2 transfer to .. P&ID: 325-01-400-PD-01
20	C1S04,20	X1:21	FUSE 1492-JD3FB (1A)	JB-401	XV-40202F	Slurry feed-to spray dry tank P&ID: 325-01-400-PD-01
21	C1S04,21	X1:22	FUSE 1492-JD3FB (1A)	JB-401	XV-40202F	Slurry feed-to spray dry tank P&ID: 325-01-400-PD-01
22	C1S04,22	X1:23	FUSE 1492-JD3FB (1A)	JB-401	XV-40202G	CIP water washing pH Adjustment tank 2 P&ID: 325-01-400-PD-01
23	C1S04,23	X1:24	FUSE 1492-JD3FB (1A)	JB-401	XV-40202G	CIP water washing pH Adjustment tank 2 P&ID: 325-01-400-PD-01
24	C1S04,24	X1:25	FUSE 1492-JD3FB (1A)	JB-401	XV-40202H	CIP Hight pressure water washing pH Adju.. P&ID: 325-01-400-PD-01
25	C1S04,25	X1:26	FUSE 1492-JD3FB (1A)	JB-401	XV-40202H	CIP Hight pressure water washing pH Adju.. P&ID: 325-01-400-PD-01
26	C1S04,26	X1:27	FUSE 1492-JD3FB (1A)	JB-401	XV-40203B	Slurry feed-out Spray dryer infeed tank P&ID: 325-01-400-PD-02
27	C1S04,27	X1:28	FUSE 1492-JD3FB (1A)	JB-401	XV-40203B	Slurry feed-out Spray dryer infeed tank P&ID: 325-01-400-PD-02
28	C1S04,28	X1:29	FUSE 1492-JD3FB (1A)	JB-401	XV-40203C	Water washing line outlet Spray dryer in.. P&ID: 325-01-400-PD-02
29	C1S04,29	X1:30	FUSE 1492-JD3FB (1A)	JB-401	XV-40203C	Water washing line outlet Spray dryer in.. P&ID: 325-01-400-PD-02
30	C1S04,30	X1:31	FUSE 1492-JD3FB (1A)	JB-401	XV-40203D	CIP water washing Spray dryer infeed tank P&ID: 325-01-400-PD-02
31	C1S04,31	X1:32	FUSE 1492-JD3FB (1A)	JB-401	XV-40203D	CIP water washing Spray dryer infeed tank P&ID: 325-01-400-PD-02
	C1S04,00	X1:--	FUSE 1492-JD3FB (1A)	JB-401	XV-40201D	CIP water washing Spray dryer infeed tank P&ID: 325-01-400-PD-01

INGREDION (THAILAND) CO., LTD.
KALASIN STARCH PLANT - JET COOKER PROJECT

AEC INDUSTRIAL ENGINEERING
SYSTEMS INTEGRATION & AUTOMATION

CHASSIS C1 SLOT 4 - 1756-IB32 (DI) WIRING SCHEMATIC
MAIN CONTROL CABINET CA1 / CONTROLLOGIX 1756

DWG NO: KAL-JC-WIR-20002
REV: 3.6 DATE: 2026-09-08

DRAWN: AEC-ENG
CHECKED: LEAD-PE

STATUS: APPROVED
SCALE: N.T.S.

PROJECT NO: R5THS00138-JC

SHEET NO: 05 / 40