

MODULE: 1756-IB32 CHASSIS: C1 SLOT: 5 TYPE: DI TERMINAL STRIP: C1S05-X1 POINTS: 32								RATING: 24V DC SINK/SOURCE PANEL: CA1 / MOTOR CONTROL							
PT	PLC ADDR	TB PIN		INTERNAL / BARRIER	FIELD DEST	TAG NUMBER	SERVICE / INSTRUMENT DESCRIPTION	PT	PLC ADDR	TB PIN		INTERNAL / BARRIER	FIELD DEST	TAG NUMBER	SERVICE / INSTRUMENT DESCRIPTION
01	C1S05,01	X1:02		FUSE 1492-JD3FB (1A)	JB-401	XV-40203E	CIP hight pressure water washing Spray d.. P&ID: 325-01-400-PD-02	17	C1S05,17	X1:18		FUSE 1492-JD3FB (1A)	JB-601	FS-60205	Cooling Water Return Flow Switch for Pos.. P&ID: 325-01-600-PD-01
02	C1S05,02	X1:03		FUSE 1492-JD3FB (1A)	JB-401	SPARE	Spare I/O Channel	18	C1S05,18	X1:19		FUSE 1492-JD3FB (1A)	JB-601	LSL-60201	Level low switch P&ID: 325-01-600-PD-11
03	C1S05,03	X1:04		FUSE 1492-JD3FB (1A)	JB-401	SPARE	Spare I/O Channel	19	C1S05,19	X1:20		FUSE 1492-JD3FB (1A)	JB-601	SV-60201	PA On/Off Valve for Cyclone-21 Rotary Va.. P&ID: 325-01-600-PD-08
04	C1S05,04	X1:05		FUSE 1492-JD3FB (1A)	JB-401	SPARE	Spare I/O Channel	20	C1S05,20	X1:21		FUSE 1492-JD3FB (1A)	JB-601	SV-60201	PA On/Off Valve for Cyclone-21 Rotary Va.. P&ID: 325-01-600-PD-08
05	C1S05,05	X1:06		FUSE 1492-JD3FB (1A)	JB-401	SPARE	Spare I/O Channel	21	C1S05,21	X1:22		FUSE 1492-JD3FB (1A)	JB-601	SV-60202	PA On/Off Valve for Cyclone-22 Rotary Va.. P&ID: 325-01-600-PD-08
06	C1S05,06	X1:07		FUSE 1492-JD3FB (1A)	JB-401	SPARE	Spare I/O Channel	22	C1S05,22	X1:23		FUSE 1492-JD3FB (1A)	JB-601	SV-60202	PA On/Off Valve for Cyclone-22 Rotary Va.. P&ID: 325-01-600-PD-08
07	C1S05,07	X1:08		FUSE 1492-JD3FB (1A)	JB-401	SPARE	Spare I/O Channel	23	C1S05,23	X1:24		FUSE 1492-JD3FB (1A)	JB-601	SV-60203	PA On/Off Valve for Bag House Rotary Val.. P&ID: 325-01-600-PD-08
08	C1S05,08	X1:09		FUSE 1492-JD3FB (1A)	JB-401	SPARE	Spare I/O Channel	24	C1S05,24	X1:25		FUSE 1492-JD3FB (1A)	JB-601	SV-60203	PA On/Off Valve for Bag House Rotary Val.. P&ID: 325-01-600-PD-08
09	C1S05,09	X1:10		FUSE 1492-JD3FB (1A)	JB-401	SPARE	Spare I/O Channel	25	C1S05,25	X1:26		FUSE 1492-JD3FB (1A)	JB-601	VS-60205	Vibration Gear Box Vibration Switch for .. P&ID: 325-01-600-PD-01
10	C1S05,10	X1:11		FUSE 1492-JD3FB (1A)	JB-401	SPARE	Spare I/O Channel	26	C1S05,26	X1:27		FUSE 1492-JD3FB (1A)	JB-601	SPARE	Spare I/O Channel
11	C1S05,11	X1:12		FUSE 1492-JD3FB (1A)	JB-401	SPARE	Spare I/O Channel	27	C1S05,27	X1:28		FUSE 1492-JD3FB (1A)	JB-601	SPARE	Spare I/O Channel
12	C1S05,12	X1:13		FUSE 1492-JD3FB (1A)	JB-401	SPARE	Spare I/O Channel	28	C1S05,28	X1:29		FUSE 1492-JD3FB (1A)	JB-601	SPARE	Spare I/O Channel
13	C1S05,13	X1:14		FUSE 1492-JD3FB (1A)	JB-401	SPARE	Spare I/O Channel	29	C1S05,29	X1:30		FUSE 1492-JD3FB (1A)	JB-601	SPARE	Spare I/O Channel
14	C1S05,14	X1:15		FUSE 1492-JD3FB (1A)	JB-401	SPARE	Spare I/O Channel	30	C1S05,30	X1:31		FUSE 1492-JD3FB (1A)	JB-601	SPARE	Spare I/O Channel
15	C1S05,15	X1:16		FUSE 1492-JD3FB (1A)	JB-401	SPARE	Spare I/O Channel	31	C1S05,31	X1:32		FUSE 1492-JD3FB (1A)	JB-601	SPARE	Spare I/O Channel
16	C1S05,16	X1:17		FUSE 1492-JD3FB (1A)	JB-601	ES-60202	E-Stop for PUPD-11 (Positive Displaceme.. P&ID: 325-01-600-PD-01		C1S05,00	X1:--		FUSE 1492-JD3FB (1A)	JB-401	XV-40203E	CIP hight pressure water washing Spray d.. P&ID: 325-01-400-PD-02
INGREDION (THAILAND) CO., LTD. KALASIN STARCH PLANT - JET COOKER PROJECT												AEC INDUSTRIAL ENGINEERING SYSTEMS INTEGRATION & AUTOMATION			
CHASSIS C1 SLOT 5 - 1756-IB32 (DI) WIRING SCHEMATIC MAIN CONTROL CABINET CA1 / CONTROLLOGIX 1756												DWG NO: KAL-JC-WIR-20003 REV: 3.6 DATE: 2026-09-08			
DRAWN: AEC-ENG CHECKED: LEAD-PE						STATUS: APPROVED SCALE: N.T.S.						PROJECT NO: R5THS00138-JC		SHEET NO: 06 / 40	