

MODULE: 1756-OB32 CHASSIS: C1 SLOT: 8 TYPE: DO TERMINAL STRIP: C1S08-X1 POINTS: 32																RATING: 24V DC SINK/SOURCE PANEL: CA1 / MOTOR CONTROL																																															
PT								PLC ADDR								TB PIN								INTERNAL / BARRIER								FIELD DEST								TAG NUMBER								SERVICE / INSTRUMENT DESCRIPTION															
01								C1S08,01								X1:02								 RELAY 700-HL (24VDC)								JB-401								XV-40201F								Slurry feed-to spray dry tank P&ID: 325-01-400-PD-01															
02								C1S08,02								X1:03								 RELAY 700-HL (24VDC)								JB-401								XV-40201G								CIP water washing pH Adjustment tank 1 P&ID: 325-01-400-PD-01															
03								C1S08,03								X1:04								 RELAY 700-HL (24VDC)								JB-401								XV-40201H								CIP Hight pressure water washing pH Adju.. P&ID: 325-01-400-PD-01															
04								C1S08,04								X1:05								 RELAY 700-HL (24VDC)								JB-401								XV-40202A								Slurry feed-in pH Adjustment tank 2 P&ID: 325-01-400-PD-01															
05								C1S08,05								X1:06								 RELAY 700-HL (24VDC)								JB-401								XV-40202B								Slurry feed-out pH Adjustment tank 2 P&ID: 325-01-400-PD-01															
06								C1S08,06								X1:07								 RELAY 700-HL (24VDC)								JB-401								XV-40202C								Water washing line outlet pH Adjustment .. P&ID: 325-01-400-PD-01															
07								C1S08,07								X1:08								 RELAY 700-HL (24VDC)								JB-401								XV-40202D								Slurry circulation pH Adjustment tank 2 P&ID: 325-01-400-PD-01															
08								C1S08,08								X1:09								 RELAY 700-HL (24VDC)								JB-401								SPARE								Spare I/O Channel															
09								C1S08,09								X1:10								 RELAY 700-HL (24VDC)								JB-401								SPARE								Spare I/O Channel															
10								C1S08,10								X1:11								 RELAY 700-HL (24VDC)								JB-401								SPARE								Spare I/O Channel															
11								C1S08,11								X1:12								 RELAY 700-HL (24VDC)								JB-401								SPARE								Spare I/O Channel															
12								C1S08,12								X1:13								 RELAY 700-HL (24VDC)								JB-401								SPARE								Spare I/O Channel															
13								C1S08,13								X1:14								 RELAY 700-HL (24VDC)								JB-401								SPARE								Spare I/O Channel															
14								C1S08,14								X1:15								 RELAY 700-HL (24VDC)								JB-401								SPARE								Spare I/O Channel															
15								C1S08,15								X1:16								 RELAY 700-HL (24VDC)								JB-401								SPARE								Spare I/O Channel															
16								C1S08,16								X1:17								 RELAY 700-HL (24VDC)								JB-601								SV-60201								PA On/Off Valve for Cyclone-21 Rotary Va.. P&ID: 325-01-600-PD-08															