

MODULE: 1756-IF16 CHASSIS: C1 SLOT: 9 TYPE: AI TERMINAL STRIP: C1S09-X1 POINTS: 16							RATING: 4-20mA CURRENT LOOP (ISOLATED) PANEL: CA1 / MOTOR CONTROL	
PT	PLC ADDR	TB PIN	INTERNAL / BARRIER		FIELD DEST	TAG NUMBER	SERVICE / INSTRUMENT DESCRIPTION	
01	C1S09,01	X1:02		LOOP POWERED (2-W)	JB-401	FT-40201	Slurry flowrate & density check transfer.. P&ID: 325-01-400-PD-02	
02	C1S09,02	X1:03		LOOP POWERED (2-W)	JB-401	FT-40202	Feed Slurry Flow Transmitter for Pipe (P.. P&ID: 325-01-400-PD-02	
03	C1S09,03	X1:04		LOOP POWERED (2-W)	JB-401	LT-40203	Level transmitter in Spray dryer infeed .. P&ID: 325-01-400-PD-02	
04	C1S09,04	X1:05		LOOP POWERED (2-W)	JB-401	LT-40201	Level transmitter in Spray dryer infeed .. P&ID: 325-01-400-PD-01	
05	C1S09,05	X1:06		LOOP POWERED (2-W)	JB-401	LT-40202	Level transmitter in pH Adjustment tank 2 P&ID: 325-01-400-PD-01	
06	C1S09,06	X1:07		LOOP POWERED (2-W)	JB-401	pHT-40201	pH analyzer in pH Adjustment tank 1 P&ID: 325-01-400-PD-01	
07	C1S09,07	X1:08		LOOP POWERED (2-W)	JB-401	pHT-40202	pH analyzer in pH Adjustment tank 2 P&ID: 325-01-400-PD-01	
08	C1S09,08	X1:09		LOOP POWERED (2-W)	JB-401	PT-40201	Pressure Transmitter for Inlet Filter S.. P&ID: 325-01-400-PD-02	
09	C1S09,09	X1:10		LOOP POWERED (2-W)	JB-401	PT-40202	Feed Slurry Pressure Transmitter for Pip.. P&ID: 325-01-400-PD-02	
10	C1S09,10	X1:11		LOOP POWERED (2-W)	JB-401	PT-60202	Feed Slurry Pressure Transmitter for Hig.. P&ID: 325-01-600-PD-01	
11	C1S09,11	X1:12		LOOP POWERED (2-W)	JB-401	SPARE	Spare I/O Channel	
12	C1S09,12	X1:13		LOOP POWERED (2-W)	JB-401	SPARE	Spare I/O Channel	
13	C1S09,13	X1:14		LOOP POWERED (2-W)	JB-401	SPARE	Spare I/O Channel	
14	C1S09,14	X1:15		LOOP POWERED (2-W)	JB-401	SPARE	Spare I/O Channel	
15	C1S09,15	X1:16		LOOP POWERED (2-W)	JB-401	SPARE	Spare I/O Channel	
	C1S09,00	X1:--		LOOP POWERED (2-W)	JB-401	FT-40201	Slurry flowrate & density check transfer.. P&ID: 325-01-400-PD-02	

INGREDION (THAILAND) CO., LTD. KALASIN STARCH PLANT - JET COOKER PROJECT		AEC INDUSTRIAL ENGINEERING SYSTEMS INTEGRATION & AUTOMATION	
CHASSIS C1 SLOT 9 - 1756-IF16 (AI) WIRING SCHEMATIC MAIN CONTROL CABINET CA1 / CONTROLLOGIX 1756		DWG NO: KAL-JC-WIR-20007 REV: 3.6 DATE: 2026-09-08	
DRAWN: AEC-ENG CHECKED: LEAD-PE	STATUS: APPROVED SCALE: N.T.S.	PROJECT NO: R5THS00138-JC	SHEET NO: 10 / 40