

KALASIN ENGINEERING — C3 (I/O EXPANSION RACK 2 (CHASSIS 3))

SLOT-BY-SLOT I/O SOURCE AND DESTINATION WIRING SCHEDULE

Project Ref: x2608003

Rack Location: Control Cabinet CA1 (Bay 3)

Network: EN4TR DLR Ring Node 3 (192.168.1.12)

Revision: Rev 3.6 | Date: 28-Sep-2026

CHASSIS ID C3	ACTIVE SLOTS 6 Slots	TOTAL CAPACITY 136 Channels	ACTIVE POINTS 74 Points	SPARE POINTS 62 (45.6%)	PANEL LOCATION Control Cabinet CA
------------------	-------------------------	--------------------------------	----------------------------	----------------------------	--------------------------------------

C3 SLOT 01 — 1756-IB32 (DI)																
Rack: I/O Expansion Rack 2 (Chassis 3) Location: Control Cabinet CA1 (Bay 3) Protocol: EN4TR DLR Ring Node 3 (192.168.1.12)																
SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)							SIGNAL SPEC			DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C3-S01-P00	0	1	1756-IB32	AT-40201_DI_1	Pin 1	C3S1:1/C3S01-X1:1	DI	24VDC Dry Contact	ACTIVE	IS-JB-603	Spray Dryer 3rd Floor	C3S01-X1	-	AT-40201		-
C3-S01-P01	1	2	1756-IB32	AT-40202_DI_1	Pin 2	C3S1:2/C3S01-X1:2	DI	24VDC Dry Contact	ACTIVE	IS-JB-603	Spray Dryer 3rd Floor	C3S01-X1	-	AT-40202		-
C3-S01-P02	2	3	1756-IB32	AT-40203_DI_1	Pin 3	C3S1:3/C3S01-X1:3	DI	24VDC Dry Contact	ACTIVE	IS-JB-603	Spray Dryer 3rd Floor	C3S01-X1	-	AT-40203		-
C3-S01-P03	3	4	1756-IB32	LSH-60230_DI_1	Pin 4	C3S1:4/C3S01-X1:4	DI	24VDC Dry Contact	ACTIVE	IS-JB-603	Spray Dryer 3rd Floor	C3S01-X1	-	LSH-60230		3-25-01-602-PD-04
C3-S01-P04	4	5	1756-IB32	LSH-60231_DI_1	Pin 5	C3S1:5/C3S01-X1:5	DI	24VDC Dry Contact	ACTIVE	IS-JB-603	Spray Dryer 3rd Floor	C3S01-X1	-	LSH-60231		3-25-01-602-PD-04
C3-S01-P05	5	6	1756-IB32	LSH-60240_DI_1	Pin 6	C3S1:6/C3S01-X1:6	DI	24VDC Dry Contact	ACTIVE	IS-JB-603	Spray Dryer 3rd Floor	C3S01-X1	-	LSH-60240		3-25-01-602-PD-05
C3-S01-P06	6	7	1756-IB32	PD-60202_DI_1	Pin 7	C3S1:7/C3S01-X1:7	DI	24VDC Dry Contact	ACTIVE	IS-JB-603	Spray Dryer 3rd Floor	C3S01-X1	-	PD-60202		-
C3-S01-P07	7	8	1756-IB32	RV-60204_DI_1	Pin 8	C3S1:8/C3S01-X1:8	DI	24VDC Dry Contact	ACTIVE	IS-JB-603	Spray Dryer 3rd Floor	C3S01-X1	-	RV-60204		-
C3-S01-P08	8	9	1756-IB32	ZS-60201C_DI_1	Pin 9	C3S1:9/C3S01-X1:9	DI	24VDC Dry Contact	ACTIVE	IS-JB-603	Spray Dryer 3rd Floor	C3S01-X1	-	ZS-60201C		3-25-01-602-PD-04
C3-S01-P09	9	10	1756-IB32	ZS-60201D_DI_1	Pin 10	C3S1:10/C3S01-X1:10	DI	24VDC Dry Contact	ACTIVE	IS-JB-603	Spray Dryer 3rd Floor	C3S01-X1	-	ZS-60201D		3-25-01-602-PD-04
C3-S01-P10	10	11	1756-IB32	ZS-60201E_DI_1	Pin 11	C3S1:11/C3S01-X1:11	DI	24VDC Dry Contact	ACTIVE	IS-JB-603	Spray Dryer 3rd Floor	C3S01-X1	-	ZS-60201E		3-25-01-602-PD-04
C3-S01-P11	11	12	1756-IB32	ZS-60229_DI_1	Pin 12	C3S1:12/C3S01-X1:12	DI	24VDC Dry Contact	ACTIVE	IS-JB-603	Spray Dryer 3rd Floor	C3S01-X1	-	ZS-60229		3-25-01-602-PD-04
C3-S01-P12	12	13	1756-IB32	ZS-60230_DI_1	Pin 13	C3S1:13/C3S01-X1:13	DI	24VDC Dry Contact	ACTIVE	IS-JB-603	Spray Dryer 3rd Floor	C3S01-X1	-	ZS-60230		3-25-01-602-PD-04

SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)							SIGNAL SPEC			DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C3-S01-P13	13	14	1756-IB32	ZS-60231A_DI_1	Pin 14	C3S1:14/C3S01-X1:14	DI	24VDC Dry Contact	ACTIVE	IS-JB-603	Spray Dryer 3rd Floor	C3S01-X1	-	ZS-60231A		3-25-01-602-PD-05
C3-S01-P14	14	15	1756-IB32	ZS-60231B_DI_1	Pin 15	C3S1:15/C3S01-X1:15	DI	24VDC Dry Contact	ACTIVE	IS-JB-603	Spray Dryer 3rd Floor	C3S01-X1	-	ZS-60231B		3-25-01-602-PD-05
C3-S01-P15	15	16	1756-IB32	Spare_DI_0	Pin 16	C3S1:16/C3S01-X1:16	DI	24VDC Dry Contact	SPARE	IS-JB-603	Spray Dryer 3rd Floor	C3S01-X1	-	Spare	Spare Channel	-
C3-S01-P16	16	17	1756-IB32	DV-61301_DI_1	Pin 17	C3S1:17/C3S01-X2:17	DI	24VDC Dry Contact	ACTIVE	JB-618	Packing Tower 8th Floor	C3S01-X2	-	DV-61301		3-25-01-613-PD-01
C3-S01-P17	17	18	1756-IB32	DV-61301_DI_2	Pin 18	C3S1:18/C3S01-X2:18	DI	24VDC Dry Contact	ACTIVE	JB-618	Packing Tower 8th Floor	C3S01-X2	-	DV-61301		3-25-01-613-PD-01
C3-S01-P18	18	19	1756-IB32	DV-61302_DI_1	Pin 19	C3S1:19/C3S01-X2:19	DI	24VDC Dry Contact	ACTIVE	JB-618	Packing Tower 8th Floor	C3S01-X2	-	DV-61302		3-25-01-613-PD-01
C3-S01-P19	19	20	1756-IB32	DV-61302_DI_2	Pin 20	C3S1:20/C3S01-X2:20	DI	24VDC Dry Contact	ACTIVE	JB-618	Packing Tower 8th Floor	C3S01-X2	-	DV-61302		3-25-01-613-PD-01
C3-S01-P20	20	21	1756-IB32	LS-61303_DI_1	Pin 21	C3S1:21/C3S01-X2:21	DI	24VDC Dry Contact	ACTIVE	JB-618	Packing Tower 8th Floor	C3S01-X2	-	LS-61303		3-25-01-613-PD-01
C3-S01-P21	21	22	1756-IB32	PSL-61301_DI_1	Pin 22	C3S1:22/C3S01-X2:22	DI	24VDC Dry Contact	ACTIVE	JB-618	Packing Tower 8th Floor	C3S01-X2	-	PSL-61301		-
C3-S01-P22	22	23	1756-IB32	PSL-61302_DI_1	Pin 23	C3S1:23/C3S01-X2:23	DI	24VDC Dry Contact	ACTIVE	JB-618	Packing Tower 8th Floor	C3S01-X2	-	PSL-61302		3-25-01-613-PD-01
C3-S01-P28	28	29	1756-IB32	Spare_DI_0	Pin 29	C3S1:29/C3S01-X2:29	DI	24VDC Dry Contact	SPARE	JB-618	Packing Tower 8th Floor	C3S01-X2	-	Spare	Spare Channel	-
C3-S01-P29	29	30	1756-IB32	Spare_DI_0	Pin 30	C3S1:30/C3S01-X2:30	DI	24VDC Dry Contact	SPARE	JB-618	Packing Tower 8th Floor	C3S01-X2	-	Spare	Spare Channel	-
C3-S01-P30	30	31	1756-IB32	Spare_DI_0	Pin 31	C3S1:31/C3S01-X2:31	DI	24VDC Dry Contact	SPARE	JB-618	Packing Tower 8th Floor	C3S01-X2	-	Spare	Spare Channel	-
C3-S01-P31	31	32	1756-IB32	Spare_DI_0	Pin 32	C3S1:32/C3S01-X2:32	DI	24VDC Dry Contact	SPARE	JB-618	Packing Tower 8th Floor	C3S01-X2	-	Spare	Spare Channel	-

C3 SLOT 02 — 1756-IB32 (DI)																
Rack: I/O Expansion Rack 2 (Chassis 3) Location: Control Cabinet CA1 (Bay 3) Protocol: EN4TR DLR Ring Node 3 (192.168.1.12)										Capacity: 37 Pts Active: 18 Spare: 19 (51.4%)						
SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)							SIGNAL SPEC			DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C3-S02-P00	0	1	1756-IB32	ISV-61301_DI_1	Pin 1	C3S2:1/C3S02-X1:1	DI	24VDC Dry Contact	ACTIVE	IS-JB-618	Packing Tower 8th Floor	C3S02-X1	-	ISV-61301		3-25-01-613-PD-01
C3-S02-P01	1	2	1756-IB32	LSH-61301_DI_1	Pin 2	C3S2:2/C3S02-X1:2	DI	24VDC Dry Contact	ACTIVE	IS-JB-618	Packing Tower 8th Floor	C3S02-X1	-	LSH-61301		3-25-01-613-PD-01
C3-S02-P02	2	3	1756-IB32	LSH-61303_DI_1	Pin 3	C3S2:3/C3S02-X1:3	DI	24VDC Dry Contact	ACTIVE	IS-JB-618	Packing Tower 8th Floor	C3S02-X1	-	LSH-61303		-
C3-S02-P03	3	4	1756-IB32	LSH-61306_DI_1	Pin 4	C3S2:4/C3S02-X1:4	DI	24VDC Dry Contact	ACTIVE	IS-JB-618	Packing Tower 8th Floor	C3S02-X1	-	LSH-61306		3-25-01-613-PD-01
C3-S02-P04	4	5	1756-IB32	LSH-61308_DI_1	Pin 5	C3S2:5/C3S02-X1:5	DI	24VDC Dry Contact	ACTIVE	IS-JB-618	Packing Tower 8th Floor	C3S02-X1	-	LSH-61308		3-25-01-613-PD-01
C3-S02-P05	5	6	1756-IB32	LSL-61302_DI_1	Pin 6	C3S2:6/C3S02-X1:6	DI	24VDC Dry Contact	ACTIVE	IS-JB-618	Packing Tower 8th Floor	C3S02-X1	-	LSL-61302		3-25-01-613-PD-01
C3-S02-P06	6	7	1756-IB32	PSE-61300_DI_1	Pin 7	C3S2:7/C3S02-X1:7	DI	24VDC Dry Contact	ACTIVE	IS-JB-618	Packing Tower 8th Floor	C3S02-X1	-	PSE-61300		3-25-01-613-PD-01
C3-S02-P07	7	8	1756-IB32	PSE-61301_DI_1	Pin 8	C3S2:8/C3S02-X1:8	DI	24VDC Dry Contact	ACTIVE	IS-JB-618	Packing Tower 8th Floor	C3S02-X1	-	PSE-61301		3-25-01-613-PD-01
C3-S02-P08	8	9	1756-IB32	PSE-61304_DI_1	Pin 9	C3S2:9/C3S02-X1:9	DI	24VDC Dry Contact	ACTIVE	IS-JB-618	Packing Tower 8th Floor	C3S02-X1	-	PSE-61304		3-25-01-613-PD-01
C3-S02-P09	9	10	1756-IB32	PSV-61301A_DI_1	Pin 10	C3S2:10/C3S02-X1:10	DI	24VDC Dry Contact	ACTIVE	IS-JB-618	Packing Tower 8th Floor	C3S02-X1	-	PSV-61301A		325-01-613-PD-01
C3-S02-P10	10	11	1756-IB32	PSV-61301B_DI_1	Pin 11	C3S2:11/C3S02-X1:11	DI	24VDC Dry Contact	ACTIVE	IS-JB-618	Packing Tower 8th Floor	C3S02-X1	-	PSV-61301B		325-01-613-PD-01
C3-S02-P11	11	12	1756-IB32	ZS-61310_DI_1	Pin 12	C3S2:12/C3S02-X1:12	DI	24VDC Dry Contact	ACTIVE	IS-JB-618	Packing Tower 8th Floor	C3S02-X1	-	ZS-61310		3-25-01-613-PD-01
C3-S02-P12	12	13	1756-IB32	ZS-61311_DI_1	Pin 13	C3S2:13/C3S02-X1:13	DI	24VDC Dry Contact	ACTIVE	IS-JB-618	Packing Tower 8th	C3S02-X1	-	ZS-61311		3-25-01-613-PD-01

SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)							SIGNAL SPEC			DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
											Floor					
C3-S02-P13	13	14	1756-IB32	Spare_DI_0	Pin 14	C3S2:14/C3S02-X1:14	DI	24VDC Dry Contact	SPARE	IS-JB-618	Packing Tower 8th Floor	C3S02-X1	-	Spare	Spare Channel	3-25-01-613-PD-01
C3-S02-P14	14	15	1756-IB32	Spare_DI_0	Pin 15	C3S2:15/C3S02-X1:15	DI	24VDC Dry Contact	SPARE	IS-JB-618	Packing Tower 8th Floor	C3S02-X1	-	Spare	Spare Channel	3-25-01-613-PD-01
C3-S02-P15	15	16	1756-IB32	Spare_DI_0	Pin 16	C3S2:16/C3S02-X1:16	DI	24VDC Dry Contact	SPARE	IS-JB-618	Packing Tower 8th Floor	C3S02-X1	-	Spare	Spare Channel	3-25-01-613-PD-01
C3-S02-P16	16	17	1756-IB32	Spare_DI_0	Pin 17	C3S2:17/C3S02-X2:17	DI	24VDC Dry Contact	SPARE	IS-JB-618	Packing Tower 8th Floor	C3S02-X2	-	Spare	Spare Channel	3-25-01-613-PD-01
C3-S02-P17	17	18	1756-IB32	Spare_DI_0	Pin 18	C3S2:18/C3S02-X2:18	DI	24VDC Dry Contact	SPARE	IS-JB-618	Packing Tower 8th Floor	C3S02-X2	-	Spare	Spare Channel	3-25-01-613-PD-01
C3-S02-P18	18	19	1756-IB32	Spare_DI_0	Pin 19	C3S2:19/C3S02-X2:19	DI	24VDC Dry Contact	SPARE	IS-JB-618	Packing Tower 8th Floor	C3S02-X2	-	Spare	Spare Channel	3-25-01-613-PD-01
C3-S02-P19	19	20	1756-IB32	Spare_DI_0	Pin 20	C3S2:20/C3S02-X2:20	DI	24VDC Dry Contact	SPARE	IS-JB-618	Packing Tower 8th Floor	C3S02-X2	-	Spare	Spare Channel	3-25-01-613-PD-01
C3-S02-P20	20	21	1756-IB32	Spare_DI_0	Pin 21	C3S2:21/C3S02-X2:21	DI	24VDC Dry Contact	SPARE	IS-JB-618	Packing Tower 8th Floor	C3S02-X2	-	Spare	Spare Channel	3-25-01-613-PD-01
C3-S02-P21	21	22	1756-IB32	Spare_DI_0	Pin 22	C3S2:22/C3S02-X2:22	DI	24VDC Dry Contact	SPARE	IS-JB-618	Packing Tower 8th Floor	C3S02-X2	-	Spare	Spare Channel	3-25-01-613-PD-01
C3-S02-P22	22	23	1756-IB32	Spare_DI_0	Pin 23	C3S2:23/C3S02-X2:23	DI	24VDC Dry Contact	SPARE	IS-JB-618	Packing Tower 8th Floor	C3S02-X2	-	Spare	Spare Channel	3-25-01-613-PD-01
C3-S02-P23	23	24	1756-IB32	PSL-61311_DI_1	Pin 24	C3S2:24/C3S02-X2:24	DI	24VDC Dry Contact	ACTIVE	JB-618	Packing Tower 8th Floor	C3S02-X2	-	PSL-61311		3-25-01-613-PD-04
C3-S02-P23	23	24	1756-IB32	Spare_DI_0	Pin 24	C3S2:24/C3S02-X2:24	DI	24VDC Dry Contact	SPARE	IS-JB-618	Packing Tower 8th Floor	C3S02-X2	-	Spare	Spare Channel	3-25-01-613-PD-01
C3-S02-P24	24	25	1756-IB32	Spare_DI_0	Pin 25	C3S2:25/C3S02-X2:25	DI	24VDC Dry Contact	SPARE	IS-JB-618	Packing Tower 8th Floor	C3S02-X2	-	Spare	Spare Channel	3-25-01-613-PD-01

SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)							SIGNAL SPEC			DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C3-S02-P24	24	25	1756-IB32	SV-61304_DI_1	Pin 25	C3S2:25/C3S02-X2:25	DI	24VDC Dry Contact	ACTIVE	JB-618	Packing Tower 8th Floor	C3S02-X2	-	SV-61304		3-25-01-613-PD-01
C3-S02-P25	25	26	1756-IB32	Spare_DI_0	Pin 26	C3S2:26/C3S02-X2:26	DI	24VDC Dry Contact	SPARE	IS-JB-618	Packing Tower 8th Floor	C3S02-X2	-	Spare	Spare Channel	3-25-01-613-PD-01
C3-S02-P25	25	26	1756-IB32	SV-61304_DI_2	Pin 26	C3S2:26/C3S02-X2:26	DI	24VDC Dry Contact	ACTIVE	JB-618	Packing Tower 8th Floor	C3S02-X2	-	SV-61304		3-25-01-613-PD-01
C3-S02-P26	26	27	1756-IB32	Spare_DI_0	Pin 27	C3S2:27/C3S02-X2:27	DI	24VDC Dry Contact	SPARE	IS-JB-618	Packing Tower 8th Floor	C3S02-X2	-	Spare	Spare Channel	3-25-01-613-PD-01
C3-S02-P26	26	27	1756-IB32	XV-61301_DI_1	Pin 27	C3S2:27/C3S02-X2:27	DI	24VDC Dry Contact	ACTIVE	JB-618	Packing Tower 8th Floor	C3S02-X2	-	XV-61301		3-25-01-613-PD-01
C3-S02-P27	27	28	1756-IB32	Spare_DI_0	Pin 28	C3S2:28/C3S02-X2:28	DI	24VDC Dry Contact	SPARE	IS-JB-618	Packing Tower 8th Floor	C3S02-X2	-	Spare	Spare Channel	3-25-01-613-PD-01
C3-S02-P27	27	28	1756-IB32	XV-61301_DI_2	Pin 28	C3S2:28/C3S02-X2:28	DI	24VDC Dry Contact	ACTIVE	JB-618	Packing Tower 8th Floor	C3S02-X2	-	XV-61301		3-25-01-613-PD-01
C3-S02-P28	28	29	1756-IB32	Spare_DI_0	Pin 29	C3S2:29/C3S02-X2:29	DI	24VDC Dry Contact	SPARE	IS-JB-618	Packing Tower 8th Floor	C3S02-X2	-	Spare	Spare Channel	3-25-01-613-PD-01
C3-S02-P29	29	30	1756-IB32	Spare_DI_0	Pin 30	C3S2:30/C3S02-X2:30	DI	24VDC Dry Contact	SPARE	IS-JB-618	Packing Tower 8th Floor	C3S02-X2	-	Spare	Spare Channel	3-25-01-613-PD-01
C3-S02-P30	30	31	1756-IB32	Spare_DI_0	Pin 31	C3S2:31/C3S02-X2:31	DI	24VDC Dry Contact	SPARE	IS-JB-618	Packing Tower 8th Floor	C3S02-X2	-	Spare	Spare Channel	3-25-01-613-PD-01
C3-S02-P31	31	32	1756-IB32	Spare_DI_0	Pin 32	C3S2:32/C3S02-X2:32	DI	24VDC Dry Contact	SPARE	IS-JB-618	Packing Tower 8th Floor	C3S02-X2	-	Spare	Spare Channel	3-25-01-613-PD-01

C3 SLOT 03 — 1756-OB32 (DO)											Capacity: 32 Pts Active: 9 Spare: 23 (71.9%)						
Rack: I/O Expansion Rack 2 (Chassis 3) Location: Control Cabinet CA1 (Bay 3) Protocol: EN4TR DLR Ring Node 3 (192.168.1.12)																	
Source Specification (PLC Rack / Card Pin / Eplan Wire Tag)							Signal Spec			Destination Specification (Field JB / MCC / Terminal Pin / Instrument Tag)							
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing	
C3-S03-P00	0	1	1756-OB32	DV-61301_DO_1	Pin 1	C3S3:1/C3S03-X1:1	DO	24VDC Sourcing	ACTIVE	JB-618	Packing Tower 8th Floor	C3S03-X1	-	DV-61301		3-25-01-613-PD-01	
C3-S03-P01	1	2	1756-OB32	DV-61302_DO_1	Pin 2	C3S3:2/C3S03-X1:2	DO	24VDC Sourcing	ACTIVE	JB-618	Packing Tower 8th Floor	C3S03-X1	-	DV-61302		3-25-01-613-PD-01	
C3-S03-P02	2	3	1756-OB32	SV-61301_DO_1	Pin 3	C3S3:3/C3S03-X1:3	DO	24VDC Sourcing	ACTIVE	JB-618	Packing Tower 8th Floor	C3S03-X1	-	SV-61301		-	
C3-S03-P03	3	4	1756-OB32	SV-61302_DO_1	Pin 4	C3S3:4/C3S03-X1:4	DO	24VDC Sourcing	ACTIVE	JB-618	Packing Tower 8th Floor	C3S03-X1	-	SV-61302		3-25-01-613-PD-01	
C3-S03-P04	4	5	1756-OB32	SV-61303_DO_1	Pin 5	C3S3:5/C3S03-X1:5	DO	24VDC Sourcing	ACTIVE	JB-618	Packing Tower 8th Floor	C3S03-X1	-	SV-61303		3-25-01-613-PD-01	
C3-S03-P05	5	6	1756-OB32	SV-61304_DO_1	Pin 6	C3S3:6/C3S03-X1:6	DO	24VDC Sourcing	ACTIVE	JB-618	Packing Tower 8th Floor	C3S03-X1	-	SV-61304		3-25-01-613-PD-01	
C3-S03-P06	6	7	1756-OB32	SV-61305_DO_1	Pin 7	C3S3:7/C3S03-X1:7	DO	24VDC Sourcing	ACTIVE	JB-618	Packing Tower 8th Floor	C3S03-X1	-	SV-61305		3-25-01-613-PD-01	
C3-S03-P07	7	8	1756-OB32	SV-61306_DO_1	Pin 8	C3S3:8/C3S03-X1:8	DO	24VDC Sourcing	ACTIVE	JB-618	Packing Tower 8th Floor	C3S03-X1	-	SV-61306		3-25-01-613-PD-01	
C3-S03-P08	8	9	1756-OB32	XV-61301_DO_1	Pin 9	C3S3:9/C3S03-X1:9	DO	24VDC Sourcing	ACTIVE	JB-618	Packing Tower 8th Floor	C3S03-X1	-	XV-61301		3-25-01-613-PD-01	
C3-S03-P09	9	10	1756-OB32	Spare_DO_0	Pin 10	C3S3:10/C3S03-X1:10	DO	24VDC Sourcing	SPARE	JB-618	Packing Tower 8th Floor	C3S03-X1	-	Spare	Spare Channel	-	
C3-S03-P10	10	11	1756-OB32	Spare_DO_0	Pin 11	C3S3:11/C3S03-X1:11	DO	24VDC Sourcing	SPARE	JB-618	Packing Tower 8th Floor	C3S03-X1	-	Spare	Spare Channel	-	
C3-S03-P11	11	12	1756-OB32	Spare_DO_0	Pin 12	C3S3:12/C3S03-X1:12	DO	24VDC Sourcing	SPARE	JB-618	Packing Tower 8th Floor	C3S03-X1	-	Spare	Spare Channel	-	
C3-S03-P12	12	13	1756-OB32	Spare_DO_0	Pin 13	C3S3:13/C3S03-X1:13	DO	24VDC Sourcing	SPARE	JB-618	Packing Tower 8th	C3S03-X1	-	Spare	Spare Channel	-	

SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)							SIGNAL SPEC			DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
											Floor					
C3-S03-P13	13	14	1756-OB32	Spare_D0_0	Pin 14	C3S3:14/C3S03-X1:14	DO	24VDC Sourcing	SPARE	JB-618	Packing Tower 8th Floor	C3S03-X1	-	Spare	Spare Channel	-
C3-S03-P14	14	15	1756-OB32	Spare_D0_0	Pin 15	C3S3:15/C3S03-X1:15	DO	24VDC Sourcing	SPARE	JB-618	Packing Tower 8th Floor	C3S03-X1	-	Spare	Spare Channel	-
C3-S03-P15	15	16	1756-OB32	Spare_D0_0	Pin 16	C3S3:16/C3S03-X1:16	DO	24VDC Sourcing	SPARE	JB-618	Packing Tower 8th Floor	C3S03-X1	-	Spare	Spare Channel	-
C3-S03-P16	16	17	1756-OB32	Spare_D0_0	Pin 17	C3S3:17/C3S03-X2:17	DO	24VDC Sourcing	SPARE	JB-618	Packing Tower 8th Floor	C3S03-X2	-	Spare	Spare Channel	-
C3-S03-P17	17	18	1756-OB32	Spare_D0_0	Pin 18	C3S3:18/C3S03-X2:18	DO	24VDC Sourcing	SPARE	JB-618	Packing Tower 8th Floor	C3S03-X2	-	Spare	Spare Channel	-
C3-S03-P18	18	19	1756-OB32	Spare_D0_0	Pin 19	C3S3:19/C3S03-X2:19	DO	24VDC Sourcing	SPARE	JB-618	Packing Tower 8th Floor	C3S03-X2	-	Spare	Spare Channel	-
C3-S03-P19	19	20	1756-OB32	Spare_D0_0	Pin 20	C3S3:20/C3S03-X2:20	DO	24VDC Sourcing	SPARE	JB-618	Packing Tower 8th Floor	C3S03-X2	-	Spare	Spare Channel	-
C3-S03-P20	20	21	1756-OB32	Spare_D0_0	Pin 21	C3S3:21/C3S03-X2:21	DO	24VDC Sourcing	SPARE	JB-618	Packing Tower 8th Floor	C3S03-X2	-	Spare	Spare Channel	-
C3-S03-P21	21	22	1756-OB32	Spare_D0_0	Pin 22	C3S3:22/C3S03-X2:22	DO	24VDC Sourcing	SPARE	JB-618	Packing Tower 8th Floor	C3S03-X2	-	Spare	Spare Channel	-
C3-S03-P22	22	23	1756-OB32	Spare_D0_0	Pin 23	C3S3:23/C3S03-X2:23	DO	24VDC Sourcing	SPARE	JB-618	Packing Tower 8th Floor	C3S03-X2	-	Spare	Spare Channel	-
C3-S03-P23	23	24	1756-OB32	Spare_D0_0	Pin 24	C3S3:24/C3S03-X2:24	DO	24VDC Sourcing	SPARE	JB-618	Packing Tower 8th Floor	C3S03-X2	-	Spare	Spare Channel	-
C3-S03-P24	24	25	1756-OB32	Spare_D0_0	Pin 25	C3S3:25/C3S03-X2:25	DO	24VDC Sourcing	SPARE	JB-618	Packing Tower 8th Floor	C3S03-X2	-	Spare	Spare Channel	-
C3-S03-P25	25	26	1756-OB32	Spare_D0_0	Pin 26	C3S3:26/C3S03-X2:26	DO	24VDC Sourcing	SPARE	JB-618	Packing Tower 8th Floor	C3S03-X2	-	Spare	Spare Channel	-

SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)							SIGNAL SPEC			DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C3-S03-P26	26	27	1756-OB32	Spare_D0_0	Pin 27	C3S3:27/C3S03-X2:27	DO	24VDC Sourcing	SPARE	JB-618	Packing Tower 8th Floor	C3S03-X2	-	Spare	Spare Channel	-
C3-S03-P27	27	28	1756-OB32	Spare_D0_0	Pin 28	C3S3:28/C3S03-X2:28	DO	24VDC Sourcing	SPARE	JB-618	Packing Tower 8th Floor	C3S03-X2	-	Spare	Spare Channel	-
C3-S03-P28	28	29	1756-OB32	Spare_D0_0	Pin 29	C3S3:29/C3S03-X2:29	DO	24VDC Sourcing	SPARE	JB-618	Packing Tower 8th Floor	C3S03-X2	-	Spare	Spare Channel	-
C3-S03-P29	29	30	1756-OB32	Spare_D0_0	Pin 30	C3S3:30/C3S03-X2:30	DO	24VDC Sourcing	SPARE	JB-618	Packing Tower 8th Floor	C3S03-X2	-	Spare	Spare Channel	-
C3-S03-P30	30	31	1756-OB32	Spare_D0_0	Pin 31	C3S3:31/C3S03-X2:31	DO	24VDC Sourcing	SPARE	JB-618	Packing Tower 8th Floor	C3S03-X2	-	Spare	Spare Channel	-
C3-S03-P31	31	32	1756-OB32	Spare_D0_0	Pin 32	C3S3:32/C3S03-X2:32	DO	24VDC Sourcing	SPARE	JB-618	Packing Tower 8th Floor	C3S03-X2	-	Spare	Spare Channel	-

C3 SLOT 04 — 1756-IF16 (AI)																
Rack: I/O Expansion Rack 2 (Chassis 3) Location: Control Cabinet CA1 (Bay 3) Protocol: EN4TR DLR Ring Node 3 (192.168.1.12)										Capacity: 16 Pts Active: 7 Spare: 9 (56.2%)						
SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)							SIGNAL SPEC			DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C3-S04-P00	0	1	1756-IF16	PT-60230_AI_1	Pin 1	C3S4:1/C3S04-X1:1	AI	4-20mA HART	ACTIVE	IS-JB-603	Spray Dryer 3rd Floor	C3S04-X1	–	PT-60230	Pressure Transmitter	3-25-01-602-PD-04
C3-S04-P01	1	2	1756-IF16	PT-60231_AI_1	Pin 2	C3S4:2/C3S04-X1:2	AI	4-20mA HART	ACTIVE	IS-JB-603	Spray Dryer 3rd Floor	C3S04-X1	–	PT-60231	Pressure Transmitter	3-25-01-602-PD-04
C3-S04-P02	2	3	1756-IF16	TT-60224_AI_1	Pin 3	C3S4:3/C3S04-X1:3	AI	4-20mA HART	ACTIVE	IS-JB-603	Spray Dryer 3rd Floor	C3S04-X1	–	TT-60224		3-25-01-602-PD-04
C3-S04-P03	3	4	1756-IF16	TT-60225_AI_1	Pin 4	C3S4:4/C3S04-X1:4	AI	4-20mA HART	ACTIVE	IS-JB-603	Spray Dryer 3rd Floor	C3S04-X1	–	TT-60225		3-25-01-602-PD-04
C3-S04-P04	4	5	1756-IF16	TT-60226_AI_1	Pin 5	C3S4:5/C3S04-X1:5	AI	4-20mA HART	ACTIVE	IS-JB-603	Spray Dryer 3rd Floor	C3S04-X1	–	TT-60226		3-25-01-602-PD-04
C3-S04-P05	5	6	1756-IF16	TT-60227_AI_1	Pin 6	C3S4:6/C3S04-X1:6	AI	4-20mA HART	ACTIVE	IS-JB-603	Spray Dryer 3rd Floor	C3S04-X1	–	TT-60227		3-25-01-602-PD-04
C3-S04-P06	6	7	1756-IF16	TT-60230_AI_1	Pin 7	C3S4:7/C3S04-X1:7	AI	4-20mA HART	ACTIVE	IS-JB-603	Spray Dryer 3rd Floor	C3S04-X1	–	TT-60230		3-25-01-602-PD-04
C3-S04-P07	7	8	1756-IF16	Spare_AI_0	Pin 8	C3S4:8/C3S04-X1:8	AI	4-20mA HART	SPARE	IS-JB-603	Spray Dryer 3rd Floor	C3S04-X1	–	Spare	Spare Channel	–
C3-S04-P08	8	9	1756-IF16	Spare_AI_0	Pin 9	C3S4:9/C3S04-X1:9	AI	4-20mA HART	SPARE	IS-JB-603	Spray Dryer 3rd Floor	C3S04-X1	–	Spare	Spare Channel	–
C3-S04-P09	9	10	1756-IF16	Spare_AI_0	Pin 10	C3S4:10/C3S04-X1:10	AI	4-20mA HART	SPARE	IS-JB-603	Spray Dryer 3rd Floor	C3S04-X1	–	Spare	Spare Channel	–
C3-S04-P10	10	11	1756-IF16	Spare_AI_0	Pin 11	C3S4:11/C3S04-X1:11	AI	4-20mA HART	SPARE	IS-JB-603	Spray Dryer 3rd Floor	C3S04-X1	–	Spare	Spare Channel	–
C3-S04-P11	11	12	1756-IF16	Spare_AI_0	Pin 12	C3S4:12/C3S04-X1:12	AI	4-20mA HART	SPARE	IS-JB-603	Spray Dryer 3rd Floor	C3S04-X1	–	Spare	Spare Channel	–
C3-S04-P12	12	13	1756-IF16	Spare_AI_0	Pin 13	C3S4:13/C3S04-X1:13	AI	4-20mA HART	SPARE	IS-JB-603	Spray Dryer 3rd Floor	C3S04-X1	–	Spare	Spare Channel	–
C3-S04-P13	13	14	1756-IF16	Spare_AI_0	Pin 14	C3S4:14/C3S04-X1:14	AI	4-20mA HART	SPARE	IS-JB-603	Spray Dryer 3rd Floor	C3S04-X1	–	Spare	Spare Channel	–
C3-S04-P14	14	15	1756-IF16	Spare_AI_0	Pin 15	C3S4:15/C3S04-X1:15	AI	4-20mA HART	SPARE	IS-JB-603	Spray Dryer 3rd Floor	C3S04-X1	–	Spare	Spare Channel	–
C3-S04-P15	15	16	1756-IF16	Spare_AI_0	Pin 16	C3S4:16/C3S04-X1:16	AI	4-20mA HART	SPARE	IS-JB-603	Spray Dryer 3rd Floor	C3S04-X1	–	Spare	Spare Channel	–

C3 SLOT 05 — 1756-IF16 (AI)																
Rack: I/O Expansion Rack 2 (Chassis 3) Location: Control Cabinet CA1 (Bay 3) Protocol: EN4TR DLR Ring Node 3 (192.168.1.12)													Capacity: 16 Pts Active: 13 Spare: 3 (18.8%)			
Source Specification (PLC Rack / Card Pin / Eplan Wire Tag)							Signal Spec			Destination Specification (Field JB / MCC / Terminal Pin / Instrument Tag)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C3-S05-P00	0	1	1756-IF16	PT-61303_AI_1	Pin 1	C3S5:1/C3S05-X1:1	AI	4-20mA HART	ACTIVE	JB-618	Packing Tower 8th Floor	C3S05-X1	-	PT-61303	Pressure Transmitter	3-25-01-613-PD-01
C3-S05-P01	1	2	1756-IF16	PT-61306_AI_1	Pin 2	C3S5:2/C3S05-X1:2	AI	4-20mA HART	ACTIVE	JB-618	Packing Tower 8th Floor	C3S05-X1	-	PT-61306		3-25-01-613-PD-01
C3-S05-P02	2	3	1756-IF16	TT-61303_AI_1	Pin 3	C3S5:3/C3S05-X1:3	AI	4-20mA HART	ACTIVE	JB-618	Packing Tower 8th Floor	C3S05-X1	-	TT-61303		3-25-01-613-PD-01
C3-S05-P03	3	4	1756-IF16	TT-61304_AI_1	Pin 4	C3S5:4/C3S05-X1:4	AI	4-20mA HART	ACTIVE	JB-618	Packing Tower 8th Floor	C3S05-X1	-	TT-61304		3-25-01-613-PD-01
C3-S05-P04	4	5	1756-IF16	DPT-61301_AI_1	Pin 5	C3S5:5/C3S05-X1:5	AI	4-20mA HART	ACTIVE	IS-JB-618	Packing Tower 8th Floor	C3S05-X1	-	DPT-61301	Differential Pressure Transmitte	3-25-01-613-PD-01
C3-S05-P05	5	6	1756-IF16	DPT-61302_AI_1	Pin 6	C3S5:6/C3S05-X1:6	AI	4-20mA HART	ACTIVE	IS-JB-618	Packing Tower 8th Floor	C3S05-X1	-	DPT-61302	Differential Pressure Transmitte	3-25-01-613-PD-01
C3-S05-P06	6	7	1756-IF16	LT-61301_AI_1	Pin 7	C3S5:7/C3S05-X1:7	AI	4-20mA HART	ACTIVE	IS-JB-618	Packing Tower 8th Floor	C3S05-X1	-	LT-61301	Level Transmitter	3-25-01-613-PD-01
C3-S05-P07	7	8	1756-IF16	PT-61301_AI_1	Pin 8	C3S5:8/C3S05-X1:8	AI	4-20mA HART	ACTIVE	IS-JB-618	Packing Tower 8th Floor	C3S05-X1	-	PT-61301	Pressure Transmitter	3-25-01-613-PD-01
C3-S05-P08	8	9	1756-IF16	PT-61303_AI_1	Pin 9	C3S5:9/C3S05-X1:9	AI	4-20mA HART	ACTIVE	IS-JB-618	Packing Tower 8th Floor	C3S05-X1	-	PT-61303	Pressure Transmitter	3-25-01-613-PD-01
C3-S05-P09	9	10	1756-IF16	PT-61304_AI_1	Pin 10	C3S5:10/C3S05-X1:10	AI	4-20mA HART	ACTIVE	IS-JB-618	Packing Tower 8th Floor	C3S05-X1	-	PT-61304	Pressure Transmitter	3-25-01-613-PD-01
C3-S05-P10	10	11	1756-IF16	PT-61305_AI_1	Pin 11	C3S5:11/C3S05-X1:11	AI	4-20mA HART	ACTIVE	IS-JB-618	Packing Tower 8th Floor	C3S05-X1	-	PT-61305	Pressure Transmitter	3-25-01-613-PD-01
C3-S05-P11	11	12	1756-IF16	TT-61301_AI_1	Pin 12	C3S5:12/C3S05-X1:12	AI	4-20mA HART	ACTIVE	IS-JB-618	Packing Tower 8th Floor	C3S05-X1	-	TT-61301		3-25-01-613-PD-01
C3-S05-P12	12	13	1756-IF16	TT-61302_AI_1	Pin 13	C3S5:13/C3S05-X1:13	AI	4-20mA HART	ACTIVE	IS-JB-618	Packing Tower 8th	C3S05-X1	-	TT-61302		3-25-01-613-PD-01

SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)							SIGNAL SPEC			DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
											Floor					
C3-S05-P13	13	14	1756-IF16	Spare_AI_0	Pin 14	C3S5:14/C3S05-X1:14	AI	4-20mA HART	SPARE	IS-JB-618	Packing Tower 8th Floor	C3S05-X1	-	Spare	Spare Channel	-
C3-S05-P14	14	15	1756-IF16	Spare_AI_0	Pin 15	C3S5:15/C3S05-X1:15	AI	4-20mA HART	SPARE	IS-JB-618	Packing Tower 8th Floor	C3S05-X1	-	Spare	Spare Channel	-
C3-S05-P15	15	16	1756-IF16	Spare_AI_0	Pin 16	C3S5:16/C3S05-X1:16	AI	4-20mA HART	SPARE	IS-JB-618	Packing Tower 8th Floor	C3S05-X1	-	Spare	Spare Channel	-

SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)							SIGNAL SPEC			DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C3-S13-P00	0	1	1756-OF8	TCV-40222_A0_1	Pin 1	C3S13:1/C3S13-X1:1	AO	4-20mA HART	ACTIVE	JB-402	Jet Cooker 2nd Floor	C3S13-X1	–	TCV-40222		325-01-402-PD-02
C3-S13-P01	1	2	1756-OF8	TV-60202_A0_1	Pin 2	C3S13:2/C3S13-X1:2	AO	4-20mA HART	ACTIVE	JB-602	Spray Dryer 3rd Floor	C3S13-X1	–	TV-60202		3-25-01-602-PD-07
C3-S13-P02	2	3	1756-OF8	TV-60214_A0_1	Pin 3	C3S13:3/C3S13-X1:3	AO	4-20mA HART	ACTIVE	JB-602	Spray Dryer 3rd Floor	C3S13-X1	–	TV-60214		3-25-01-602-PD-03
C3-S13-P03	3	4	1756-OF8	PV-60201_A0_1	Pin 4	C3S13:4/C3S13-X1:4	AO	4-20mA HART	ACTIVE	JB-607	Spray Dryer 7th Floor	C3S13-X1	–	PV-60201		3-25-01-602-PD-02
C3-S13-P04	4	5	1756-OF8	UY-FH-60210B_A0_1	Pin 5	C3S13:5/C3S13-X1:5	AO	4-20mA HART	ACTIVE	JB-607	Spray Dryer 7th Floor	C3S13-X1	–	UY-FH-60210B		–
C3-S13-P05	5	6	1756-OF8	Spare_A0_0	Pin 6	C3S13:6/C3S13-X1:6	AO	4-20mA HART	SPARE	JB-607	Spray Dryer 7th Floor	C3S13-X1	–	Spare	Spare Channel	–
C3-S13-P06	6	7	1756-OF8	Spare_A0_0	Pin 7	C3S13:7/C3S13-X1:7	AO	4-20mA HART	SPARE	JB-607	Spray Dryer 7th Floor	C3S13-X1	–	Spare	Spare Channel	–
C3-S13-P07	7	8	1756-OF8	Spare_A0_0	Pin 8	C3S13:8/C3S13-X1:8	AO	4-20mA HART	SPARE	JB-607	Spray Dryer 7th Floor	C3S13-X1	–	Spare	Spare Channel	–