

# KALASIN ENGINEERING — C4 (I/O EXPANSION RACK 3 (CHASSIS 4))

## SLOT-BY-SLOT I/O SOURCE AND DESTINATION WIRING SCHEDULE

Project Ref: x2608003

Rack Location: Control Cabinet CA1 (Bay 4)

Network: EN4TR DLR Ring Node 4 (192.168.1.13)

Revision: Rev 3.6 | Date: 28-Sep-2026

|                  |                         |                                |                            |                            |                                      |
|------------------|-------------------------|--------------------------------|----------------------------|----------------------------|--------------------------------------|
| CHASSIS ID<br>C4 | ACTIVE SLOTS<br>6 Slots | TOTAL CAPACITY<br>161 Channels | ACTIVE POINTS<br>75 Points | SPARE POINTS<br>86 (53.4%) | PANEL LOCATION<br>Control Cabinet CA |
|------------------|-------------------------|--------------------------------|----------------------------|----------------------------|--------------------------------------|

| C4 SLOT 01 — 1756-IB32 (DI)                                                                                                     |    |    |           |                |          |                     |             |                   |        |                                                                            |                       |           |     |                |                        |                   |
|---------------------------------------------------------------------------------------------------------------------------------|----|----|-----------|----------------|----------|---------------------|-------------|-------------------|--------|----------------------------------------------------------------------------|-----------------------|-----------|-----|----------------|------------------------|-------------------|
| Rack: I/O Expansion Rack 3 (Chassis 4)   Location: Control Cabinet CA1 (Bay 4)   Protocol: EN4TR DLR Ring Node 4 (192.168.1.13) |    |    |           |                |          |                     |             |                   |        |                                                                            |                       |           |     |                |                        |                   |
| SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)                                                                     |    |    |           |                |          |                     | SIGNAL SPEC |                   |        | DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG) |                       |           |     |                |                        |                   |
| Point Ref ID                                                                                                                    | Pt | Ch | Module    | PLC Tag Name   | Card Pin | ePlan Wire Tag      | Type        | Signal Spec       | Status | Destination                                                                | Location / Floor      | TB / Fuse | Pin | Instrument Tag | Instrument Description | P&ID Drawing      |
| C4-S01-P00                                                                                                                      | 0  | 1  | 1756-IB32 | FT-60203_DI_1  | Pin 1    | C4S1:1/C4S01-X1:1   | DI          | 24VDC Dry Contact | ACTIVE | JB-606                                                                     | Spray Dryer 6th Floor | C4S01-X1  | -   | FT-60203       |                        | 3-25-01-602-PD-09 |
| C4-S01-P01                                                                                                                      | 1  | 2  | 1756-IB32 | LSH-60250_DI_1 | Pin 2    | C4S1:2/C4S01-X1:2   | DI          | 24VDC Dry Contact | ACTIVE | JB-606                                                                     | Spray Dryer 6th Floor | C4S01-X1  | -   | LSH-60250      |                        | 3-25-01-602-PD-05 |
| C4-S01-P02                                                                                                                      | 2  | 3  | 1756-IB32 | XA-60261_DI_1  | Pin 3    | C4S1:3/C4S01-X1:3   | DI          | 24VDC Dry Contact | ACTIVE | JB-606                                                                     | Spray Dryer 6th Floor | C4S01-X1  | -   | XA-60261       |                        | -                 |
| C4-S01-P03                                                                                                                      | 3  | 4  | 1756-IB32 | XA-60262_DI_1  | Pin 4    | C4S1:4/C4S01-X1:4   | DI          | 24VDC Dry Contact | ACTIVE | JB-606                                                                     | Spray Dryer 6th Floor | C4S01-X1  | -   | XA-60262       |                        | -                 |
| C4-S01-P04                                                                                                                      | 4  | 5  | 1756-IB32 | Spare_DI_0     | Pin 5    | C4S1:5/C4S01-X1:5   | DI          | 24VDC Dry Contact | SPARE  | JB-606                                                                     | Spray Dryer 6th Floor | C4S01-X1  | -   | Spare          | Spare Channel          | -                 |
| C4-S01-P05                                                                                                                      | 5  | 6  | 1756-IB32 | Spare_DI_0     | Pin 6    | C4S1:6/C4S01-X1:6   | DI          | 24VDC Dry Contact | SPARE  | JB-606                                                                     | Spray Dryer 6th Floor | C4S01-X1  | -   | Spare          | Spare Channel          | -                 |
| C4-S01-P06                                                                                                                      | 6  | 7  | 1756-IB32 | Spare_DI_0     | Pin 7    | C4S1:7/C4S01-X1:7   | DI          | 24VDC Dry Contact | SPARE  | JB-606                                                                     | Spray Dryer 6th Floor | C4S01-X1  | -   | Spare          | Spare Channel          | -                 |
| C4-S01-P07                                                                                                                      | 7  | 8  | 1756-IB32 | Spare_DI_0     | Pin 8    | C4S1:8/C4S01-X1:8   | DI          | 24VDC Dry Contact | SPARE  | JB-606                                                                     | Spray Dryer 6th Floor | C4S01-X1  | -   | Spare          | Spare Channel          | -                 |
| C4-S01-P08                                                                                                                      | 8  | 9  | 1756-IB32 | Spare_DI_0     | Pin 9    | C4S1:9/C4S01-X1:9   | DI          | 24VDC Dry Contact | SPARE  | JB-606                                                                     | Spray Dryer 6th Floor | C4S01-X1  | -   | Spare          | Spare Channel          | -                 |
| C4-S01-P09                                                                                                                      | 9  | 10 | 1756-IB32 | Spare_DI_0     | Pin 10   | C4S1:10/C4S01-X1:10 | DI          | 24VDC Dry Contact | SPARE  | JB-606                                                                     | Spray Dryer 6th Floor | C4S01-X1  | -   | Spare          | Spare Channel          | -                 |
| C4-S01-P10                                                                                                                      | 10 | 11 | 1756-IB32 | Spare_DI_0     | Pin 11   | C4S1:11/C4S01-X1:11 | DI          | 24VDC Dry Contact | SPARE  | JB-606                                                                     | Spray Dryer 6th Floor | C4S01-X1  | -   | Spare          | Spare Channel          | -                 |
| C4-S01-P11                                                                                                                      | 11 | 12 | 1756-IB32 | Spare_DI_0     | Pin 12   | C4S1:12/C4S01-X1:12 | DI          | 24VDC Dry Contact | SPARE  | JB-606                                                                     | Spray Dryer 6th Floor | C4S01-X1  | -   | Spare          | Spare Channel          | -                 |
| C4-S01-P12                                                                                                                      | 12 | 13 | 1756-IB32 | Spare_DI_0     | Pin 13   | C4S1:13/C4S01-X1:13 | DI          | 24VDC Dry Contact | SPARE  | JB-606                                                                     | Spray Dryer 6th Floor | C4S01-X1  | -   | Spare          | Spare Channel          | -                 |

| SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG) |    |    |           |                |          |                     | SIGNAL SPEC |                   |        | DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG) |                       |           |     |                |                        |                   |
|-------------------------------------------------------------|----|----|-----------|----------------|----------|---------------------|-------------|-------------------|--------|----------------------------------------------------------------------------|-----------------------|-----------|-----|----------------|------------------------|-------------------|
| Point Ref ID                                                | Pt | Ch | Module    | PLC Tag Name   | Card Pin | ePlan Wire Tag      | Type        | Signal Spec       | Status | Destination                                                                | Location / Floor      | TB / Fuse | Pin | Instrument Tag | Instrument Description | P&ID Drawing      |
| C4-S01-P13                                                  | 13 | 14 | 1756-IB32 | Spare_DI_0     | Pin 14   | C4S1:14/C4S01-X1:14 | DI          | 24VDC Dry Contact | SPARE  | JB-606                                                                     | Spray Dryer 6th Floor | C4S01-X1  | -   | Spare          | Spare Channel          | -                 |
| C4-S01-P14                                                  | 14 | 15 | 1756-IB32 | Spare_DI_0     | Pin 15   | C4S1:15/C4S01-X1:15 | DI          | 24VDC Dry Contact | SPARE  | JB-606                                                                     | Spray Dryer 6th Floor | C4S01-X1  | -   | Spare          | Spare Channel          | -                 |
| C4-S01-P15                                                  | 15 | 16 | 1756-IB32 | Spare_DI_0     | Pin 16   | C4S1:16/C4S01-X1:16 | DI          | 24VDC Dry Contact | SPARE  | JB-606                                                                     | Spray Dryer 6th Floor | C4S01-X1  | -   | Spare          | Spare Channel          | -                 |
| C4-S01-P16                                                  | 16 | 17 | 1756-IB32 | ZS-60201A_DI_1 | Pin 17   | C4S1:17/C4S01-X2:17 | DI          | 24VDC Dry Contact | ACTIVE | IS-JB-608                                                                  | Spray Dryer 8th Floor | C4S01-X2  | -   | ZS-60201A      |                        | 3-25-01-602-PD-04 |
| C4-S01-P17                                                  | 17 | 18 | 1756-IB32 | ZS-60201B_DI_1 | Pin 18   | C4S1:18/C4S01-X2:18 | DI          | 24VDC Dry Contact | ACTIVE | IS-JB-608                                                                  | Spray Dryer 8th Floor | C4S01-X2  | -   | ZS-60201B      |                        | 3-25-01-602-PD-04 |
| C4-S01-P18                                                  | 18 | 19 | 1756-IB32 | ZS-60231C_DI_1 | Pin 19   | C4S1:19/C4S01-X2:19 | DI          | 24VDC Dry Contact | ACTIVE | IS-JB-608                                                                  | Spray Dryer 8th Floor | C4S01-X2  | -   | ZS-60231C      |                        | 3-25-01-602-PD-04 |
| C4-S01-P19                                                  | 19 | 20 | 1756-IB32 | ZS-60231D_DI_1 | Pin 20   | C4S1:20/C4S01-X2:20 | DI          | 24VDC Dry Contact | ACTIVE | IS-JB-608                                                                  | Spray Dryer 8th Floor | C4S01-X2  | -   | ZS-60231D      |                        | 3-25-01-602-PD-04 |
| C4-S01-P20                                                  | 20 | 21 | 1756-IB32 | ZS-60231E_DI_1 | Pin 21   | C4S1:21/C4S01-X2:21 | DI          | 24VDC Dry Contact | ACTIVE | IS-JB-608                                                                  | Spray Dryer 8th Floor | C4S01-X2  | -   | ZS-60231E      |                        | 3-25-01-602-PD-05 |
| C4-S01-P21                                                  | 21 | 22 | 1756-IB32 | ZS-60231F_DI_1 | Pin 22   | C4S1:22/C4S01-X2:22 | DI          | 24VDC Dry Contact | ACTIVE | IS-JB-608                                                                  | Spray Dryer 8th Floor | C4S01-X2  | -   | ZS-60231F      |                        | 3-25-01-602-PD-05 |
| C4-S01-P22                                                  | 22 | 23 | 1756-IB32 | ZS-60240_DI_1  | Pin 23   | C4S1:23/C4S01-X2:23 | DI          | 24VDC Dry Contact | ACTIVE | IS-JB-608                                                                  | Spray Dryer 8th Floor | C4S01-X2  | -   | ZS-60240       |                        | 3-25-01-602-PD-05 |
| C4-S01-P23                                                  | 23 | 24 | 1756-IB32 | Spare_DI_0     | Pin 24   | C4S1:24/C4S01-X2:24 | DI          | 24VDC Dry Contact | SPARE  | IS-JB-608                                                                  | Spray Dryer 8th Floor | C4S01-X2  | -   | Spare          | Spare Channel          | -                 |
| C4-S01-P24                                                  | 24 | 25 | 1756-IB32 | Spare_DI_0     | Pin 25   | C4S1:25/C4S01-X2:25 | DI          | 24VDC Dry Contact | SPARE  | IS-JB-608                                                                  | Spray Dryer 8th Floor | C4S01-X2  | -   | Spare          | Spare Channel          | -                 |
| C4-S01-P25                                                  | 25 | 26 | 1756-IB32 | Spare_DI_0     | Pin 26   | C4S1:26/C4S01-X2:26 | DI          | 24VDC Dry Contact | SPARE  | IS-JB-608                                                                  | Spray Dryer 8th Floor | C4S01-X2  | -   | Spare          | Spare Channel          | -                 |
| C4-S01-P26                                                  | 26 | 27 | 1756-IB32 | Spare_DI_0     | Pin 27   | C4S1:27/C4S01-X2:27 | DI          | 24VDC Dry Contact | SPARE  | IS-JB-608                                                                  | Spray Dryer 8th Floor | C4S01-X2  | -   | Spare          | Spare Channel          | -                 |
| C4-S01-P27                                                  | 27 | 28 | 1756-IB32 | Spare_DI_0     | Pin 28   | C4S1:28/C4S01-X2:28 | DI          | 24VDC Dry Contact | SPARE  | IS-JB-608                                                                  | Spray Dryer 8th Floor | C4S01-X2  | -   | Spare          | Spare Channel          | -                 |
| C4-S01-P28                                                  | 28 | 29 | 1756-IB32 | Spare_DI_0     | Pin 29   | C4S1:29/C4S01-X2:29 | DI          | 24VDC Dry Contact | SPARE  | IS-JB-608                                                                  | Spray Dryer 8th Floor | C4S01-X2  | -   | Spare          | Spare Channel          | -                 |
| C4-S01-P29                                                  | 29 | 30 | 1756-IB32 | Spare_DI_0     | Pin 30   | C4S1:30/C4S01-X2:30 | DI          | 24VDC Dry Contact | SPARE  | IS-JB-608                                                                  | Spray Dryer 8th Floor | C4S01-X2  | -   | Spare          | Spare Channel          | -                 |
| C4-S01-P30                                                  | 30 | 31 | 1756-IB32 | Spare_DI_0     | Pin 31   | C4S1:31/C4S01-X2:31 | DI          | 24VDC Dry Contact | SPARE  | IS-JB-608                                                                  | Spray Dryer 8th Floor | C4S01-X2  | -   | Spare          | Spare Channel          | -                 |

| SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG) |    |    |           |              |          |                     | SIGNAL SPEC |                   |        | DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG) |                       |           |     |                |                        |              |
|-------------------------------------------------------------|----|----|-----------|--------------|----------|---------------------|-------------|-------------------|--------|----------------------------------------------------------------------------|-----------------------|-----------|-----|----------------|------------------------|--------------|
| Point Ref ID                                                | Pt | Ch | Module    | PLC Tag Name | Card Pin | ePlan Wire Tag      | Type        | Signal Spec       | Status | Destination                                                                | Location / Floor      | TB / Fuse | Pin | Instrument Tag | Instrument Description | P&ID Drawing |
| C4-S01-P31                                                  | 31 | 32 | 1756-IB32 | Spare_DI_0   | Pin 32   | C4S1:32/C4S01-X2:32 | DI          | 24VDC Dry Contact | SPARE  | IS-JB-608                                                                  | Spray Dryer 8th Floor | C4S01-X2  | -   | Spare          | Spare Channel          | -            |

| C4 SLOT 02 — 1756-IB32 (DI)                                                                                                     |    |    |           |                |          |                     |             |                   |        |                                                                            |                         |           |     |                |                        |                   |
|---------------------------------------------------------------------------------------------------------------------------------|----|----|-----------|----------------|----------|---------------------|-------------|-------------------|--------|----------------------------------------------------------------------------|-------------------------|-----------|-----|----------------|------------------------|-------------------|
| Rack: I/O Expansion Rack 3 (Chassis 4)   Location: Control Cabinet CA1 (Bay 4)   Protocol: EN4TR DLR Ring Node 4 (192.168.1.13) |    |    |           |                |          |                     |             |                   |        | Capacity: 32 Pts   Active: 17   Spare: 15 (46.9%)                          |                         |           |     |                |                        |                   |
| SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)                                                                     |    |    |           |                |          |                     | SIGNAL SPEC |                   |        | DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG) |                         |           |     |                |                        |                   |
| Point Ref ID                                                                                                                    | Pt | Ch | Module    | PLC Tag Name   | Card Pin | ePlan Wire Tag      | Type        | Signal Spec       | Status | Destination                                                                | Location / Floor        | TB / Fuse | Pin | Instrument Tag | Instrument Description | P&ID Drawing      |
| C4-S02-P00                                                                                                                      | 0  | 1  | 1756-IB32 | PSL-61305_DI_1 | Pin 1    | C4S2:1/C4S02-X1:1   | DI          | 24VDC Dry Contact | ACTIVE | JB-612                                                                     | Packing Tower 2th Floor | C4S02-X1  | -   | PSL-61305      |                        | 3-25-01-613-PD-03 |
| C4-S02-P01                                                                                                                      | 1  | 2  | 1756-IB32 | PSL-61306_DI_1 | Pin 2    | C4S2:2/C4S02-X1:2   | DI          | 24VDC Dry Contact | ACTIVE | JB-612                                                                     | Packing Tower 2th Floor | C4S02-X1  | -   | PSL-61306      |                        | 3-25-01-613-PD-05 |
| C4-S02-P02                                                                                                                      | 2  | 3  | 1756-IB32 | PVM-61301_DI_1 | Pin 3    | C4S2:3/C4S02-X1:3   | DI          | 24VDC Dry Contact | ACTIVE | JB-612                                                                     | Packing Tower 2th Floor | C4S02-X1  | -   | PVM-61301      |                        | -                 |
| C4-S02-P03                                                                                                                      | 3  | 4  | 1756-IB32 | PVM-61301_DI_2 | Pin 4    | C4S2:4/C4S02-X1:4   | DI          | 24VDC Dry Contact | ACTIVE | JB-612                                                                     | Packing Tower 2th Floor | C4S02-X1  | -   | PVM-61301      |                        | -                 |
| C4-S02-P04                                                                                                                      | 4  | 5  | 1756-IB32 | XA-61301A_DI_1 | Pin 5    | C4S2:5/C4S02-X1:5   | DI          | 24VDC Dry Contact | ACTIVE | JB-612                                                                     | Packing Tower 2th Floor | C4S02-X1  | -   | XA-61301A      |                        | -                 |
| C4-S02-P05                                                                                                                      | 5  | 6  | 1756-IB32 | XA-61301B_DI_1 | Pin 6    | C4S2:6/C4S02-X1:6   | DI          | 24VDC Dry Contact | ACTIVE | JB-612                                                                     | Packing Tower 2th Floor | C4S02-X1  | -   | XA-61301B      |                        | -                 |
| C4-S02-P06                                                                                                                      | 6  | 7  | 1756-IB32 | XA-61301C_DI_1 | Pin 7    | C4S2:7/C4S02-X1:7   | DI          | 24VDC Dry Contact | ACTIVE | JB-612                                                                     | Packing Tower 2th Floor | C4S02-X1  | -   | XA-61301C      |                        | -                 |
| C4-S02-P07                                                                                                                      | 7  | 8  | 1756-IB32 | XA-61301D_DI_1 | Pin 8    | C4S2:8/C4S02-X1:8   | DI          | 24VDC Dry Contact | ACTIVE | JB-612                                                                     | Packing Tower 2th Floor | C4S02-X1  | -   | XA-61301D      |                        | -                 |
| C4-S02-P08                                                                                                                      | 8  | 9  | 1756-IB32 | XA-61301E_DI_1 | Pin 9    | C4S2:9/C4S02-X1:9   | DI          | 24VDC Dry Contact | ACTIVE | JB-612                                                                     | Packing Tower 2th Floor | C4S02-X1  | -   | XA-61301E      |                        | -                 |
| C4-S02-P09                                                                                                                      | 9  | 10 | 1756-IB32 | XA-61301F_DI_1 | Pin 10   | C4S2:10/C4S02-X1:10 | DI          | 24VDC Dry Contact | ACTIVE | JB-612                                                                     | Packing Tower 2th Floor | C4S02-X1  | -   | XA-61301F      |                        | -                 |
| C4-S02-P10                                                                                                                      | 10 | 11 | 1756-IB32 | XA-61301G_DI_1 | Pin 11   | C4S2:11/C4S02-X1:11 | DI          | 24VDC Dry Contact | ACTIVE | JB-612                                                                     | Packing Tower 2th Floor | C4S02-X1  | -   | XA-61301G      |                        | -                 |
| C4-S02-P11                                                                                                                      | 11 | 12 | 1756-IB32 | XA-61301H_DI_1 | Pin 12   | C4S2:12/C4S02-X1:12 | DI          | 24VDC Dry Contact | ACTIVE | JB-612                                                                     | Packing Tower 2th Floor | C4S02-X1  | -   | XA-61301H      |                        | -                 |
| C4-S02-P12                                                                                                                      | 12 | 13 | 1756-IB32 | XA-61301J_DI_1 | Pin 13   | C4S2:13/C4S02-X1:13 | DI          | 24VDC Dry Contact | ACTIVE | JB-612                                                                     | Packing Tower 2th       | C4S02-X1  | -   | XA-61301J      |                        | -                 |

| SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG) |    |    |           |               |          |                     | SIGNAL SPEC |                   |        | DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG) |                         |           |     |                |                        |                   |
|-------------------------------------------------------------|----|----|-----------|---------------|----------|---------------------|-------------|-------------------|--------|----------------------------------------------------------------------------|-------------------------|-----------|-----|----------------|------------------------|-------------------|
| Point Ref ID                                                | Pt | Ch | Module    | PLC Tag Name  | Card Pin | ePlan Wire Tag      | Type        | Signal Spec       | Status | Destination                                                                | Location / Floor        | TB / Fuse | Pin | Instrument Tag | Instrument Description | P&ID Drawing      |
|                                                             |    |    |           |               |          |                     |             |                   |        |                                                                            | Floor                   |           |     |                |                        |                   |
| C4-S02-P13                                                  | 13 | 14 | 1756-IB32 | XV-61302_DI_1 | Pin 14   | C4S2:14/C4S02-X1:14 | DI          | 24VDC Dry Contact | ACTIVE | JB-612                                                                     | Packing Tower 2th Floor | C4S02-X1  | -   | XV-61302       |                        | 3-25-01-613-PD-02 |
| C4-S02-P14                                                  | 14 | 15 | 1756-IB32 | XV-61302_DI_2 | Pin 15   | C4S2:15/C4S02-X1:15 | DI          | 24VDC Dry Contact | ACTIVE | JB-612                                                                     | Packing Tower 2th Floor | C4S02-X1  | -   | XV-61302       |                        | 3-25-01-613-PD-02 |
| C4-S02-P15                                                  | 15 | 16 | 1756-IB32 | XV-61303_DI_1 | Pin 16   | C4S2:16/C4S02-X1:16 | DI          | 24VDC Dry Contact | ACTIVE | JB-612                                                                     | Packing Tower 2th Floor | C4S02-X1  | -   | XV-61303       |                        | 3-25-01-613-PD-02 |
| C4-S02-P16                                                  | 16 | 17 | 1756-IB32 | XV-61303_DI_2 | Pin 17   | C4S2:17/C4S02-X2:17 | DI          | 24VDC Dry Contact | ACTIVE | JB-612                                                                     | Packing Tower 2th Floor | C4S02-X2  | -   | XV-61303       |                        | 3-25-01-613-PD-02 |
| C4-S02-P17                                                  | 17 | 18 | 1756-IB32 | Spare_DI_0    | Pin 18   | C4S2:18/C4S02-X2:18 | DI          | 24VDC Dry Contact | SPARE  | JB-612                                                                     | Packing Tower 2th Floor | C4S02-X2  | -   | Spare          | Spare Channel          | -                 |
| C4-S02-P18                                                  | 18 | 19 | 1756-IB32 | Spare_DI_0    | Pin 19   | C4S2:19/C4S02-X2:19 | DI          | 24VDC Dry Contact | SPARE  | JB-612                                                                     | Packing Tower 2th Floor | C4S02-X2  | -   | Spare          | Spare Channel          | -                 |
| C4-S02-P19                                                  | 19 | 20 | 1756-IB32 | Spare_DI_0    | Pin 20   | C4S2:20/C4S02-X2:20 | DI          | 24VDC Dry Contact | SPARE  | JB-612                                                                     | Packing Tower 2th Floor | C4S02-X2  | -   | Spare          | Spare Channel          | -                 |
| C4-S02-P20                                                  | 20 | 21 | 1756-IB32 | Spare_DI_0    | Pin 21   | C4S2:21/C4S02-X2:21 | DI          | 24VDC Dry Contact | SPARE  | JB-612                                                                     | Packing Tower 2th Floor | C4S02-X2  | -   | Spare          | Spare Channel          | -                 |
| C4-S02-P21                                                  | 21 | 22 | 1756-IB32 | Spare_DI_0    | Pin 22   | C4S2:22/C4S02-X2:22 | DI          | 24VDC Dry Contact | SPARE  | JB-612                                                                     | Packing Tower 2th Floor | C4S02-X2  | -   | Spare          | Spare Channel          | -                 |
| C4-S02-P22                                                  | 22 | 23 | 1756-IB32 | Spare_DI_0    | Pin 23   | C4S2:23/C4S02-X2:23 | DI          | 24VDC Dry Contact | SPARE  | JB-612                                                                     | Packing Tower 2th Floor | C4S02-X2  | -   | Spare          | Spare Channel          | -                 |
| C4-S02-P23                                                  | 23 | 24 | 1756-IB32 | Spare_DI_0    | Pin 24   | C4S2:24/C4S02-X2:24 | DI          | 24VDC Dry Contact | SPARE  | JB-612                                                                     | Packing Tower 2th Floor | C4S02-X2  | -   | Spare          | Spare Channel          | -                 |
| C4-S02-P24                                                  | 24 | 25 | 1756-IB32 | Spare_DI_0    | Pin 25   | C4S2:25/C4S02-X2:25 | DI          | 24VDC Dry Contact | SPARE  | JB-612                                                                     | Packing Tower 2th Floor | C4S02-X2  | -   | Spare          | Spare Channel          | -                 |
| C4-S02-P25                                                  | 25 | 26 | 1756-IB32 | Spare_DI_0    | Pin 26   | C4S2:26/C4S02-X2:26 | DI          | 24VDC Dry Contact | SPARE  | JB-612                                                                     | Packing Tower 2th Floor | C4S02-X2  | -   | Spare          | Spare Channel          | -                 |

| SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG) |    |    |           |              |          |                     | SIGNAL SPEC |                   |        | DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG) |                         |           |     |                |                        |              |
|-------------------------------------------------------------|----|----|-----------|--------------|----------|---------------------|-------------|-------------------|--------|----------------------------------------------------------------------------|-------------------------|-----------|-----|----------------|------------------------|--------------|
| Point Ref ID                                                | Pt | Ch | Module    | PLC Tag Name | Card Pin | ePlan Wire Tag      | Type        | Signal Spec       | Status | Destination                                                                | Location / Floor        | TB / Fuse | Pin | Instrument Tag | Instrument Description | P&ID Drawing |
| C4-S02-P26                                                  | 26 | 27 | 1756-IB32 | Spare_DI_0   | Pin 27   | C4S2:27/C4S02-X2:27 | DI          | 24VDC Dry Contact | SPARE  | JB-612                                                                     | Packing Tower 2th Floor | C4S02-X2  | -   | Spare          | Spare Channel          | -            |
| C4-S02-P27                                                  | 27 | 28 | 1756-IB32 | Spare_DI_0   | Pin 28   | C4S2:28/C4S02-X2:28 | DI          | 24VDC Dry Contact | SPARE  | JB-612                                                                     | Packing Tower 2th Floor | C4S02-X2  | -   | Spare          | Spare Channel          | -            |
| C4-S02-P28                                                  | 28 | 29 | 1756-IB32 | Spare_DI_0   | Pin 29   | C4S2:29/C4S02-X2:29 | DI          | 24VDC Dry Contact | SPARE  | JB-612                                                                     | Packing Tower 2th Floor | C4S02-X2  | -   | Spare          | Spare Channel          | -            |
| C4-S02-P29                                                  | 29 | 30 | 1756-IB32 | Spare_DI_0   | Pin 30   | C4S2:30/C4S02-X2:30 | DI          | 24VDC Dry Contact | SPARE  | JB-612                                                                     | Packing Tower 2th Floor | C4S02-X2  | -   | Spare          | Spare Channel          | -            |
| C4-S02-P30                                                  | 30 | 31 | 1756-IB32 | Spare_DI_0   | Pin 31   | C4S2:31/C4S02-X2:31 | DI          | 24VDC Dry Contact | SPARE  | JB-612                                                                     | Packing Tower 2th Floor | C4S02-X2  | -   | Spare          | Spare Channel          | -            |
| C4-S02-P31                                                  | 31 | 32 | 1756-IB32 | Spare_DI_0   | Pin 32   | C4S2:32/C4S02-X2:32 | DI          | 24VDC Dry Contact | SPARE  | JB-612                                                                     | Packing Tower 2th Floor | C4S02-X2  | -   | Spare          | Spare Channel          | -            |

| C4 SLOT 03 — 1756-IB32 (DI)                                                                                                     |    |    |           |                |          |                     |             |                   |        |                                                                            |                                                   |           |     |                |                        |                   |
|---------------------------------------------------------------------------------------------------------------------------------|----|----|-----------|----------------|----------|---------------------|-------------|-------------------|--------|----------------------------------------------------------------------------|---------------------------------------------------|-----------|-----|----------------|------------------------|-------------------|
| Rack: I/O Expansion Rack 3 (Chassis 4)   Location: Control Cabinet CA1 (Bay 4)   Protocol: EN4TR DLR Ring Node 4 (192.168.1.13) |    |    |           |                |          |                     |             |                   |        |                                                                            | Capacity: 31 Pts   Active: 15   Spare: 16 (51.6%) |           |     |                |                        |                   |
| Source Specification (PLC Rack / Card Pin / Eplan Wire Tag)                                                                     |    |    |           |                |          |                     | Signal Spec |                   |        | Destination Specification (Field JB / MCC / Terminal Pin / Instrument Tag) |                                                   |           |     |                |                        |                   |
| Point Ref ID                                                                                                                    | Pt | Ch | Module    | PLC Tag Name   | Card Pin | ePlan Wire Tag      | Type        | Signal Spec       | Status | Destination                                                                | Location / Floor                                  | TB / Fuse | Pin | Instrument Tag | Instrument Description | P&ID Drawing      |
| C4-S03-P00                                                                                                                      | 0  | 1  | 1756-IB32 | ISV-61303_DI_1 | Pin 1    | C4S3:1/C4S03-X1:1   | DI          | 24VDC Dry Contact | ACTIVE | IS-JB-612                                                                  | Packing Tower 2th Floor                           | C4S03-X1  | -   | ISV-61303      |                        | 3-25-01-613-PD-03 |
| C4-S03-P01                                                                                                                      | 1  | 2  | 1756-IB32 | ISV-61304_DI_1 | Pin 2    | C4S3:2/C4S03-X1:2   | DI          | 24VDC Dry Contact | ACTIVE | IS-JB-612                                                                  | Packing Tower 2th Floor                           | C4S03-X1  | -   | ISV-61304      |                        | 3-25-01-613-PD-05 |
| C4-S03-P02                                                                                                                      | 2  | 3  | 1756-IB32 | LSH-61304_DI_1 | Pin 3    | C4S3:3/C4S03-X1:3   | DI          | 24VDC Dry Contact | ACTIVE | IS-JB-612                                                                  | Packing Tower 2th Floor                           | C4S03-X1  | -   | LSH-61304      |                        | 3-25-01-613-PD-03 |
| C4-S03-P03                                                                                                                      | 3  | 4  | 1756-IB32 | LSH-61305_DI_1 | Pin 4    | C4S3:4/C4S03-X1:4   | DI          | 24VDC Dry Contact | ACTIVE | IS-JB-612                                                                  | Packing Tower 2th Floor                           | C4S03-X1  | -   | LSH-61305      |                        | 3-25-01-613-PD-05 |
| C4-S03-P04                                                                                                                      | 4  | 5  | 1756-IB32 | LSH-61307_DI_1 | Pin 5    | C4S3:5/C4S03-X1:5   | DI          | 24VDC Dry Contact | ACTIVE | IS-JB-612                                                                  | Packing Tower 2th Floor                           | C4S03-X1  | -   | LSH-61307      |                        | 3-25-01-613-PD-01 |
| C4-S03-P05                                                                                                                      | 5  | 6  | 1756-IB32 | LSH-61312_DI_1 | Pin 6    | C4S3:6/C4S03-X1:6   | DI          | 24VDC Dry Contact | ACTIVE | IS-JB-612                                                                  | Packing Tower 2th Floor                           | C4S03-X1  | -   | LSH-61312      |                        | 3-25-01-613-PD-05 |
| C4-S03-P06                                                                                                                      | 6  | 7  | 1756-IB32 | PSE-61302_DI_1 | Pin 7    | C4S3:7/C4S03-X1:7   | DI          | 24VDC Dry Contact | ACTIVE | IS-JB-612                                                                  | Packing Tower 2th Floor                           | C4S03-X1  | -   | PSE-61302      |                        | 3-25-01-613-PD-03 |
| C4-S03-P07                                                                                                                      | 7  | 8  | 1756-IB32 | PSE-61303_DI_1 | Pin 8    | C4S3:8/C4S03-X1:8   | DI          | 24VDC Dry Contact | ACTIVE | IS-JB-612                                                                  | Packing Tower 2th Floor                           | C4S03-X1  | -   | PSE-61303      |                        | 3-25-01-613-PD-05 |
| C4-S03-P09                                                                                                                      | 9  | 10 | 1756-IB32 | RV-61301_DI_1  | Pin 10   | C4S3:10/C4S03-X1:10 | DI          | 24VDC Dry Contact | ACTIVE | IS-JB-612                                                                  | Packing Tower 2th Floor                           | C4S03-X1  | -   | RV-61301       |                        | -                 |
| C4-S03-P10                                                                                                                      | 10 | 11 | 1756-IB32 | RV-61304_DI_1  | Pin 11   | C4S3:11/C4S03-X1:11 | DI          | 24VDC Dry Contact | ACTIVE | IS-JB-612                                                                  | Packing Tower 2th Floor                           | C4S03-X1  | -   | RV-61304       |                        | -                 |
| C4-S03-P11                                                                                                                      | 11 | 12 | 1756-IB32 | RV-61305_DI_1  | Pin 12   | C4S3:12/C4S03-X1:12 | DI          | 24VDC Dry Contact | ACTIVE | IS-JB-612                                                                  | Packing Tower 2th Floor                           | C4S03-X1  | -   | RV-61305       |                        | -                 |
| C4-S03-P12                                                                                                                      | 12 | 13 | 1756-IB32 | SC-61301_DI_1  | Pin 13   | C4S3:13/C4S03-X1:13 | DI          | 24VDC Dry Contact | ACTIVE | IS-JB-612                                                                  | Packing Tower 2th Floor                           | C4S03-X1  | -   | SC-61301       |                        | -                 |
| C4-S03-P13                                                                                                                      | 13 | 14 | 1756-IB32 | SC-61302_DI_1  | Pin 14   | C4S3:14/C4S03-X1:14 | DI          | 24VDC Dry Contact | ACTIVE | IS-JB-612                                                                  | Packing Tower 2th                                 | C4S03-X1  | -   | SC-61302       |                        | -                 |

| SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG) |    |    |           |               |          |                     | SIGNAL SPEC |                   |        | DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG) |                         |           |     |                |                        |                   |
|-------------------------------------------------------------|----|----|-----------|---------------|----------|---------------------|-------------|-------------------|--------|----------------------------------------------------------------------------|-------------------------|-----------|-----|----------------|------------------------|-------------------|
| Point Ref ID                                                | Pt | Ch | Module    | PLC Tag Name  | Card Pin | ePlan Wire Tag      | Type        | Signal Spec       | Status | Destination                                                                | Location / Floor        | TB / Fuse | Pin | Instrument Tag | Instrument Description | P&ID Drawing      |
|                                                             |    |    |           |               |          |                     |             |                   |        |                                                                            | Floor                   |           |     |                |                        |                   |
| C4-S03-P14                                                  | 14 | 15 | 1756-IB32 | ZS-61312_DI_1 | Pin 15   | C4S3:15/C4S03-X1:15 | DI          | 24VDC Dry Contact | ACTIVE | IS-JB-612                                                                  | Packing Tower 2th Floor | C4S03-X1  | -   | ZS-61312       |                        | 3-25-01-613-PD-01 |
| C4-S03-P15                                                  | 15 | 16 | 1756-IB32 | ZS-61313_DI_1 | Pin 16   | C4S3:16/C4S03-X1:16 | DI          | 24VDC Dry Contact | ACTIVE | IS-JB-612                                                                  | Packing Tower 2th Floor | C4S03-X1  | -   | ZS-61313       |                        | 3-25-01-613-PD-01 |
| C4-S03-P16                                                  | 16 | 17 | 1756-IB32 | Spare_DI_0    | Pin 17   | C4S3:17/C4S03-X2:17 | DI          | 24VDC Dry Contact | SPARE  | IS-JB-612                                                                  | Packing Tower 2th Floor | C4S03-X2  | -   | Spare          | Spare Channel          | -                 |
| C4-S03-P17                                                  | 17 | 18 | 1756-IB32 | Spare_DI_0    | Pin 18   | C4S3:18/C4S03-X2:18 | DI          | 24VDC Dry Contact | SPARE  | IS-JB-612                                                                  | Packing Tower 2th Floor | C4S03-X2  | -   | Spare          | Spare Channel          | -                 |
| C4-S03-P18                                                  | 18 | 19 | 1756-IB32 | Spare_DI_0    | Pin 19   | C4S3:19/C4S03-X2:19 | DI          | 24VDC Dry Contact | SPARE  | IS-JB-612                                                                  | Packing Tower 2th Floor | C4S03-X2  | -   | Spare          | Spare Channel          | -                 |
| C4-S03-P19                                                  | 19 | 20 | 1756-IB32 | Spare_DI_0    | Pin 20   | C4S3:20/C4S03-X2:20 | DI          | 24VDC Dry Contact | SPARE  | IS-JB-612                                                                  | Packing Tower 2th Floor | C4S03-X2  | -   | Spare          | Spare Channel          | -                 |
| C4-S03-P20                                                  | 20 | 21 | 1756-IB32 | Spare_DI_0    | Pin 21   | C4S3:21/C4S03-X2:21 | DI          | 24VDC Dry Contact | SPARE  | IS-JB-612                                                                  | Packing Tower 2th Floor | C4S03-X2  | -   | Spare          | Spare Channel          | -                 |
| C4-S03-P21                                                  | 21 | 22 | 1756-IB32 | Spare_DI_0    | Pin 22   | C4S3:22/C4S03-X2:22 | DI          | 24VDC Dry Contact | SPARE  | IS-JB-612                                                                  | Packing Tower 2th Floor | C4S03-X2  | -   | Spare          | Spare Channel          | -                 |
| C4-S03-P22                                                  | 22 | 23 | 1756-IB32 | Spare_DI_0    | Pin 23   | C4S3:23/C4S03-X2:23 | DI          | 24VDC Dry Contact | SPARE  | IS-JB-612                                                                  | Packing Tower 2th Floor | C4S03-X2  | -   | Spare          | Spare Channel          | -                 |
| C4-S03-P23                                                  | 23 | 24 | 1756-IB32 | Spare_DI_0    | Pin 24   | C4S3:24/C4S03-X2:24 | DI          | 24VDC Dry Contact | SPARE  | IS-JB-612                                                                  | Packing Tower 2th Floor | C4S03-X2  | -   | Spare          | Spare Channel          | -                 |
| C4-S03-P24                                                  | 24 | 25 | 1756-IB32 | Spare_DI_0    | Pin 25   | C4S3:25/C4S03-X2:25 | DI          | 24VDC Dry Contact | SPARE  | IS-JB-612                                                                  | Packing Tower 2th Floor | C4S03-X2  | -   | Spare          | Spare Channel          | -                 |
| C4-S03-P25                                                  | 25 | 26 | 1756-IB32 | Spare_DI_0    | Pin 26   | C4S3:26/C4S03-X2:26 | DI          | 24VDC Dry Contact | SPARE  | IS-JB-612                                                                  | Packing Tower 2th Floor | C4S03-X2  | -   | Spare          | Spare Channel          | -                 |
| C4-S03-P26                                                  | 26 | 27 | 1756-IB32 | Spare_DI_0    | Pin 27   | C4S3:27/C4S03-X2:27 | DI          | 24VDC Dry Contact | SPARE  | IS-JB-612                                                                  | Packing Tower 2th Floor | C4S03-X2  | -   | Spare          | Spare Channel          | -                 |

| SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG) |    |    |           |              |          |                     | SIGNAL SPEC |                   |        | DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG) |                         |           |     |                |                        |              |
|-------------------------------------------------------------|----|----|-----------|--------------|----------|---------------------|-------------|-------------------|--------|----------------------------------------------------------------------------|-------------------------|-----------|-----|----------------|------------------------|--------------|
| Point Ref ID                                                | Pt | Ch | Module    | PLC Tag Name | Card Pin | ePlan Wire Tag      | Type        | Signal Spec       | Status | Destination                                                                | Location / Floor        | TB / Fuse | Pin | Instrument Tag | Instrument Description | P&ID Drawing |
| C4-S03-P27                                                  | 27 | 28 | 1756-IB32 | Spare_DI_0   | Pin 28   | C4S3:28/C4S03-X2:28 | DI          | 24VDC Dry Contact | SPARE  | IS-JB-612                                                                  | Packing Tower 2th Floor | C4S03-X2  | -   | Spare          | Spare Channel          | -            |
| C4-S03-P28                                                  | 28 | 29 | 1756-IB32 | Spare_DI_0   | Pin 29   | C4S3:29/C4S03-X2:29 | DI          | 24VDC Dry Contact | SPARE  | IS-JB-612                                                                  | Packing Tower 2th Floor | C4S03-X2  | -   | Spare          | Spare Channel          | -            |
| C4-S03-P29                                                  | 29 | 30 | 1756-IB32 | Spare_DI_0   | Pin 30   | C4S3:30/C4S03-X2:30 | DI          | 24VDC Dry Contact | SPARE  | IS-JB-612                                                                  | Packing Tower 2th Floor | C4S03-X2  | -   | Spare          | Spare Channel          | -            |
| C4-S03-P30                                                  | 30 | 31 | 1756-IB32 | Spare_DI_0   | Pin 31   | C4S3:31/C4S03-X2:31 | DI          | 24VDC Dry Contact | SPARE  | IS-JB-612                                                                  | Packing Tower 2th Floor | C4S03-X2  | -   | Spare          | Spare Channel          | -            |
| C4-S03-P31                                                  | 31 | 32 | 1756-IB32 | Spare_DI_0   | Pin 32   | C4S3:32/C4S03-X2:32 | DI          | 24VDC Dry Contact | SPARE  | IS-JB-612                                                                  | Packing Tower 2th Floor | C4S03-X2  | -   | Spare          | Spare Channel          | -            |

| C4 SLOT 04 — 1756-OB32 (DO)                                                                                                     |    |    |           |                |          |                     |             |                |        |                                                                            |                         |           |     |                |                        |                   |
|---------------------------------------------------------------------------------------------------------------------------------|----|----|-----------|----------------|----------|---------------------|-------------|----------------|--------|----------------------------------------------------------------------------|-------------------------|-----------|-----|----------------|------------------------|-------------------|
| Rack: I/O Expansion Rack 3 (Chassis 4)   Location: Control Cabinet CA1 (Bay 4)   Protocol: EN4TR DLR Ring Node 4 (192.168.1.13) |    |    |           |                |          |                     |             |                |        |                                                                            |                         |           |     |                |                        |                   |
| SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)                                                                     |    |    |           |                |          |                     | SIGNAL SPEC |                |        | DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG) |                         |           |     |                |                        |                   |
| Point Ref ID                                                                                                                    | Pt | Ch | Module    | PLC Tag Name   | Card Pin | ePlan Wire Tag      | Type        | Signal Spec    | Status | Destination                                                                | Location / Floor        | TB / Fuse | Pin | Instrument Tag | Instrument Description | P&ID Drawing      |
| C4-S04-P00                                                                                                                      | 0  | 1  | 1756-OB32 | SV-60220_DO_1  | Pin 1    | C4S4:1/C4S04-X1:1   | DO          | 24VDC Sourcing | ACTIVE | JB-606                                                                     | Spray Dryer 6th Floor   | C4S04-X1  | -   | SV-60220       |                        | 3-25-01-602-PD-04 |
| C4-S04-P01                                                                                                                      | 1  | 2  | 1756-OB32 | Spare_DO_0     | Pin 2    | C4S4:2/C4S04-X1:2   | DO          | 24VDC Sourcing | SPARE  | JB-606                                                                     | Spray Dryer 6th Floor   | C4S04-X1  | -   | Spare          | Spare Channel          | -                 |
| C4-S04-P02                                                                                                                      | 2  | 3  | 1756-OB32 | Spare_DO_0     | Pin 3    | C4S4:3/C4S04-X1:3   | DO          | 24VDC Sourcing | SPARE  | JB-606                                                                     | Spray Dryer 6th Floor   | C4S04-X1  | -   | Spare          | Spare Channel          | -                 |
| C4-S04-P03                                                                                                                      | 3  | 4  | 1756-OB32 | Spare_DO_0     | Pin 4    | C4S4:4/C4S04-X1:4   | DO          | 24VDC Sourcing | SPARE  | JB-606                                                                     | Spray Dryer 6th Floor   | C4S04-X1  | -   | Spare          | Spare Channel          | -                 |
| C4-S04-P04                                                                                                                      | 4  | 5  | 1756-OB32 | Spare_DO_0     | Pin 5    | C4S4:5/C4S04-X1:5   | DO          | 24VDC Sourcing | SPARE  | JB-606                                                                     | Spray Dryer 6th Floor   | C4S04-X1  | -   | Spare          | Spare Channel          | -                 |
| C4-S04-P05                                                                                                                      | 5  | 6  | 1756-OB32 | Spare_DO_0     | Pin 6    | C4S4:6/C4S04-X1:6   | DO          | 24VDC Sourcing | SPARE  | JB-606                                                                     | Spray Dryer 6th Floor   | C4S04-X1  | -   | Spare          | Spare Channel          | -                 |
| C4-S04-P06                                                                                                                      | 6  | 7  | 1756-OB32 | Spare_DO_0     | Pin 7    | C4S4:7/C4S04-X1:7   | DO          | 24VDC Sourcing | SPARE  | JB-606                                                                     | Spray Dryer 6th Floor   | C4S04-X1  | -   | Spare          | Spare Channel          | -                 |
| C4-S04-P07                                                                                                                      | 7  | 8  | 1756-OB32 | Spare_DO_0     | Pin 8    | C4S4:8/C4S04-X1:8   | DO          | 24VDC Sourcing | SPARE  | JB-606                                                                     | Spray Dryer 6th Floor   | C4S04-X1  | -   | Spare          | Spare Channel          | -                 |
| C4-S04-P08                                                                                                                      | 8  | 9  | 1756-OB32 | XA-60201_DO_1  | Pin 9    | C4S4:9/C4S04-X1:9   | DO          | 24VDC Sourcing | ACTIVE | IS-JB-608                                                                  | Spray Dryer 8th Floor   | C4S04-X1  | -   | XA-60201       |                        | 3-25-01-602-PD-03 |
| C4-S04-P09                                                                                                                      | 9  | 10 | 1756-OB32 | Spare_DO_0     | Pin 10   | C4S4:10/C4S04-X1:10 | DO          | 24VDC Sourcing | SPARE  | IS-JB-608                                                                  | Spray Dryer 8th Floor   | C4S04-X1  | -   | Spare          | Spare Channel          | -                 |
| C4-S04-P10                                                                                                                      | 10 | 11 | 1756-OB32 | Spare_DO_0     | Pin 11   | C4S4:11/C4S04-X1:11 | DO          | 24VDC Sourcing | SPARE  | IS-JB-608                                                                  | Spray Dryer 8th Floor   | C4S04-X1  | -   | Spare          | Spare Channel          | -                 |
| C4-S04-P11                                                                                                                      | 11 | 12 | 1756-OB32 | Spare_DO_0     | Pin 12   | C4S4:12/C4S04-X1:12 | DO          | 24VDC Sourcing | SPARE  | IS-JB-608                                                                  | Spray Dryer 8th Floor   | C4S04-X1  | -   | Spare          | Spare Channel          | -                 |
| C4-S04-P12                                                                                                                      | 12 | 13 | 1756-OB32 | Spare_DO_0     | Pin 13   | C4S4:13/C4S04-X1:13 | DO          | 24VDC Sourcing | SPARE  | IS-JB-608                                                                  | Spray Dryer 8th Floor   | C4S04-X1  | -   | Spare          | Spare Channel          | -                 |
| C4-S04-P13                                                                                                                      | 13 | 14 | 1756-OB32 | Spare_DO_0     | Pin 14   | C4S4:14/C4S04-X1:14 | DO          | 24VDC Sourcing | SPARE  | IS-JB-608                                                                  | Spray Dryer 8th Floor   | C4S04-X1  | -   | Spare          | Spare Channel          | -                 |
| C4-S04-P14                                                                                                                      | 14 | 15 | 1756-OB32 | Spare_DO_0     | Pin 15   | C4S4:15/C4S04-X1:15 | DO          | 24VDC Sourcing | SPARE  | IS-JB-608                                                                  | Spray Dryer 8th Floor   | C4S04-X1  | -   | Spare          | Spare Channel          | -                 |
| C4-S04-P15                                                                                                                      | 15 | 16 | 1756-OB32 | Spare_DO_0     | Pin 16   | C4S4:16/C4S04-X1:16 | DO          | 24VDC Sourcing | SPARE  | IS-JB-608                                                                  | Spray Dryer 8th Floor   | C4S04-X1  | -   | Spare          | Spare Channel          | -                 |
| C4-S04-P16                                                                                                                      | 16 | 17 | 1756-OB32 | PVM-61301_DO_1 | Pin 17   | C4S4:17/C4S04-X2:17 | DO          | 24VDC Sourcing | ACTIVE | JB-612                                                                     | Packing Tower 2th Floor | C4S04-X2  | -   | PVM-61301      |                        | -                 |

| SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG) |    |    |           |                |          |                     | SIGNAL SPEC |                |        | DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG) |                         |           |     |                |                        |                   |
|-------------------------------------------------------------|----|----|-----------|----------------|----------|---------------------|-------------|----------------|--------|----------------------------------------------------------------------------|-------------------------|-----------|-----|----------------|------------------------|-------------------|
| Point Ref ID                                                | Pt | Ch | Module    | PLC Tag Name   | Card Pin | ePlan Wire Tag      | Type        | Signal Spec    | Status | Destination                                                                | Location / Floor        | TB / Fuse | Pin | Instrument Tag | Instrument Description | P&ID Drawing      |
| C4-S04-P17                                                  | 17 | 18 | 1756-OB32 | PVM-61301_DO_2 | Pin 18   | C4S4:18/C4S04-X2:18 | DO          | 24VDC Sourcing | ACTIVE | JB-612                                                                     | Packing Tower 2th Floor | C4S04-X2  | -   | PVM-61301      |                        | -                 |
| C4-S04-P18                                                  | 18 | 19 | 1756-OB32 | SV-61307_DO_1  | Pin 19   | C4S4:19/C4S04-X2:19 | DO          | 24VDC Sourcing | ACTIVE | JB-612                                                                     | Packing Tower 2th Floor | C4S04-X2  | -   | SV-61307       |                        | 3-25-01-613-PD-01 |
| C4-S04-P19                                                  | 19 | 20 | 1756-OB32 | SV-61308_DO_1  | Pin 20   | C4S4:20/C4S04-X2:20 | DO          | 24VDC Sourcing | ACTIVE | JB-612                                                                     | Packing Tower 2th Floor | C4S04-X2  | -   | SV-61308       |                        | -                 |
| C4-S04-P20                                                  | 20 | 21 | 1756-OB32 | SV-61309_DO_1  | Pin 21   | C4S4:21/C4S04-X2:21 | DO          | 24VDC Sourcing | ACTIVE | JB-612                                                                     | Packing Tower 2th Floor | C4S04-X2  | -   | SV-61309       |                        | 3-25-01-613-PD-03 |
| C4-S04-P21                                                  | 21 | 22 | 1756-OB32 | SV-61310_DO_1  | Pin 22   | C4S4:22/C4S04-X2:22 | DO          | 24VDC Sourcing | ACTIVE | JB-612                                                                     | Packing Tower 2th Floor | C4S04-X2  | -   | SV-61310       |                        | -                 |
| C4-S04-P22                                                  | 22 | 23 | 1756-OB32 | SV-61311_DO_1  | Pin 23   | C4S4:23/C4S04-X2:23 | DO          | 24VDC Sourcing | ACTIVE | JB-612                                                                     | Packing Tower 2th Floor | C4S04-X2  | -   | SV-61311       |                        | 3-25-01-613-PD-05 |
| C4-S04-P23                                                  | 23 | 24 | 1756-OB32 | XS-61301A_DO_1 | Pin 24   | C4S4:24/C4S04-X2:24 | DO          | 24VDC Sourcing | ACTIVE | JB-612                                                                     | Packing Tower 2th Floor | C4S04-X2  | -   | XS-61301A      |                        | -                 |
| C4-S04-P24                                                  | 24 | 25 | 1756-OB32 | XS-61301B_DO_1 | Pin 25   | C4S4:25/C4S04-X2:25 | DO          | 24VDC Sourcing | ACTIVE | JB-612                                                                     | Packing Tower 2th Floor | C4S04-X2  | -   | XS-61301B      |                        | -                 |
| C4-S04-P25                                                  | 25 | 26 | 1756-OB32 | XS-61301C_DO_1 | Pin 26   | C4S4:26/C4S04-X2:26 | DO          | 24VDC Sourcing | ACTIVE | JB-612                                                                     | Packing Tower 2th Floor | C4S04-X2  | -   | XS-61301C      |                        | -                 |
| C4-S04-P26                                                  | 26 | 27 | 1756-OB32 | XS-61301D_DO_1 | Pin 27   | C4S4:27/C4S04-X2:27 | DO          | 24VDC Sourcing | ACTIVE | JB-612                                                                     | Packing Tower 2th Floor | C4S04-X2  | -   | XS-61301D      |                        | -                 |
| C4-S04-P27                                                  | 27 | 28 | 1756-OB32 | XS-61301E_DO_1 | Pin 28   | C4S4:28/C4S04-X2:28 | DO          | 24VDC Sourcing | ACTIVE | JB-612                                                                     | Packing Tower 2th Floor | C4S04-X2  | -   | XS-61301E      |                        | -                 |
| C4-S04-P28                                                  | 28 | 29 | 1756-OB32 | XS-61301F_DO_1 | Pin 29   | C4S4:29/C4S04-X2:29 | DO          | 24VDC Sourcing | ACTIVE | JB-612                                                                     | Packing Tower 2th Floor | C4S04-X2  | -   | XS-61301F      |                        | -                 |
| C4-S04-P29                                                  | 29 | 30 | 1756-OB32 | XV-61302_DO_1  | Pin 30   | C4S4:30/C4S04-X2:30 | DO          | 24VDC Sourcing | ACTIVE | JB-612                                                                     | Packing Tower 2th Floor | C4S04-X2  | -   | XV-61302       |                        | 3-25-01-613-PD-02 |

| Source Specification (PLC Rack / Card Pin / ePlan Wire Tag) |    |    |           |               |          |                     | Signal Spec |                |        | Destination Specification (Field JB / MCC / Terminal Pin / Instrument Tag) |                         |           |     |                |                        |                   |
|-------------------------------------------------------------|----|----|-----------|---------------|----------|---------------------|-------------|----------------|--------|----------------------------------------------------------------------------|-------------------------|-----------|-----|----------------|------------------------|-------------------|
| Point Ref ID                                                | Pt | Ch | Module    | PLC Tag Name  | Card Pin | ePlan Wire Tag      | Type        | Signal Spec    | Status | Destination                                                                | Location / Floor        | TB / Fuse | Pin | Instrument Tag | Instrument Description | P&ID Drawing      |
| C4-S04-P30                                                  | 30 | 31 | 1756-OB32 | XV-61303_D0_1 | Pin 31   | C4S4:31/C4S04-X2:31 | DO          | 24VDC Sourcing | ACTIVE | JB-612                                                                     | Packing Tower 2th Floor | C4S04-X2  | -   | XV-61303       |                        | 3-25-01-613-PD-02 |
| C4-S04-P31                                                  | 31 | 32 | 1756-OB32 | Spare_D0_0    | Pin 32   | C4S4:32/C4S04-X2:32 | DO          | 24VDC Sourcing | SPARE  | JB-612                                                                     | Packing Tower 2th Floor | C4S04-X2  | -   | Spare          | Spare Channel          | -                 |

| C4 SLOT 05 — 1756-IF16 (AI)                                                                                                     |    |    |           |                |          |                     |             |             |        |                                                                            | Capacity: 26 Pts   Active: 7   Spare: 19 (73.1%) |           |     |                |                                  |                   |  |
|---------------------------------------------------------------------------------------------------------------------------------|----|----|-----------|----------------|----------|---------------------|-------------|-------------|--------|----------------------------------------------------------------------------|--------------------------------------------------|-----------|-----|----------------|----------------------------------|-------------------|--|
| Rack: I/O Expansion Rack 3 (Chassis 4)   Location: Control Cabinet CA1 (Bay 4)   Protocol: EN4TR DLR Ring Node 4 (192.168.1.13) |    |    |           |                |          |                     |             |             |        |                                                                            |                                                  |           |     |                |                                  |                   |  |
| Source Specification (PLC Rack / Card Pin / Eplan Wire Tag)                                                                     |    |    |           |                |          |                     | Signal Spec |             |        | Destination Specification (Field JB / MCC / Terminal Pin / Instrument Tag) |                                                  |           |     |                |                                  |                   |  |
| Point Ref ID                                                                                                                    | Pt | Ch | Module    | PLC Tag Name   | Card Pin | ePlan Wire Tag      | Type        | Signal Spec | Status | Destination                                                                | Location / Floor                                 | TB / Fuse | Pin | Instrument Tag | Instrument Description           | P&ID Drawing      |  |
| C4-S05-P00                                                                                                                      | 0  | 1  | 1756-IF16 | DPT-60201_AI_1 | Pin 1    | C4S5:1/C4S05-X1:1   | AI          | 4-20mA HART | ACTIVE | JB-606                                                                     | Spray Dryer 6th Floor                            | C4S05-X1  | -   | DPT-60201      | Differential Pressure Transmitte | 3-25-01-602-PD-09 |  |
| C4-S05-P01                                                                                                                      | 1  | 2  | 1756-IF16 | FT-60203_AI_1  | Pin 2    | C4S5:2/C4S05-X1:2   | AI          | 4-20mA HART | ACTIVE | JB-606                                                                     | Spray Dryer 6th Floor                            | C4S05-X1  | -   | FT-60203       |                                  | 3-25-01-602-PD-09 |  |
| C4-S05-P02                                                                                                                      | 2  | 3  | 1756-IF16 | TT-60245_AI_1  | Pin 3    | C4S5:3/C4S05-X1:3   | AI          | 4-20mA HART | ACTIVE | JB-608                                                                     | Spray Dryer 8th Floor                            | C4S05-X1  | -   | TT-60245       |                                  | 3-25-01-602-PD-05 |  |
| C4-S05-P03                                                                                                                      | 3  | 4  | 1756-IF16 | Spare_AI_0     | Pin 4    | C4S5:4/C4S05-X1:4   | AI          | 4-20mA HART | SPARE  | JB-608                                                                     | Spray Dryer 8th Floor                            | C4S05-X1  | -   | Spare          | Spare Channel                    | -                 |  |
| C4-S05-P04                                                                                                                      | 4  | 5  | 1756-IF16 | Spare_AI_0     | Pin 5    | C4S5:5/C4S05-X1:5   | AI          | 4-20mA HART | SPARE  | JB-608                                                                     | Spray Dryer 8th Floor                            | C4S05-X1  | -   | Spare          | Spare Channel                    | -                 |  |
| C4-S05-P05                                                                                                                      | 5  | 6  | 1756-IF16 | Spare_AI_0     | Pin 6    | C4S5:6/C4S05-X1:6   | AI          | 4-20mA HART | SPARE  | JB-608                                                                     | Spray Dryer 8th Floor                            | C4S05-X1  | -   | Spare          | Spare Channel                    | -                 |  |
| C4-S05-P06                                                                                                                      | 6  | 7  | 1756-IF16 | Spare_AI_0     | Pin 7    | C4S5:7/C4S05-X1:7   | AI          | 4-20mA HART | SPARE  | JB-608                                                                     | Spray Dryer 8th Floor                            | C4S05-X1  | -   | Spare          | Spare Channel                    | -                 |  |
| C4-S05-P06                                                                                                                      | 6  | 7  | 1756-IF16 | Spare_AI_0     | Pin 7    | C4S5:7/C4S05-X1:7   | AI          | 4-20mA HART | SPARE  | IS-JB-608                                                                  | Spray Dryer 8th Floor                            | C4S05-X1  | -   | Spare          | Spare Channel                    | -                 |  |
| C4-S05-P07                                                                                                                      | 7  | 8  | 1756-IF16 | Spare_AI_0     | Pin 8    | C4S5:8/C4S05-X1:8   | AI          | 4-20mA HART | SPARE  | JB-608                                                                     | Spray Dryer 8th Floor                            | C4S05-X1  | -   | Spare          | Spare Channel                    | -                 |  |
| C4-S05-P07                                                                                                                      | 7  | 8  | 1756-IF16 | Spare_AI_0     | Pin 8    | C4S5:8/C4S05-X1:8   | AI          | 4-20mA HART | SPARE  | IS-JB-608                                                                  | Spray Dryer 8th Floor                            | C4S05-X1  | -   | Spare          | Spare Channel                    | -                 |  |
| C4-S05-P08                                                                                                                      | 8  | 9  | 1756-IF16 | PT-61302_AI_1  | Pin 9    | C4S5:9/C4S05-X1:9   | AI          | 4-20mA HART | ACTIVE | JB-612                                                                     | Packing Tower 2th Floor                          | C4S05-X1  | -   | PT-61302       | Pressure Transmitter             | 3-25-01-613-PD-03 |  |
| C4-S05-P09                                                                                                                      | 9  | 10 | 1756-IF16 | PT-61309_AI_1  | Pin 10   | C4S5:10/C4S05-X1:10 | AI          | 4-20mA HART | ACTIVE | JB-612                                                                     | Packing Tower 2th Floor                          | C4S05-X1  | -   | PT-61309       | Pressure Transmitter             | 3-25-01-613-PD-04 |  |
| C4-S05-P10                                                                                                                      | 10 | 11 | 1756-IF16 | Spare_AI_0     | Pin 11   | C4S5:11/C4S05-X1:11 | AI          | 4-20mA HART | SPARE  | JB-612                                                                     | Packing Tower 2th Floor                          | C4S05-X1  | -   | Spare          | Spare Channel                    | -                 |  |
| C4-S05-P11                                                                                                                      | 11 | 12 | 1756-IF16 | Spare_AI_0     | Pin 12   | C4S5:12/C4S05-X1:12 | AI          | 4-20mA HART | SPARE  | JB-612                                                                     | Packing Tower 2th Floor                          | C4S05-X1  | -   | Spare          | Spare Channel                    | -                 |  |
| C4-S05-P12                                                                                                                      | 12 | 13 | 1756-IF16 | PT-61302_AI_1  | Pin 13   | C4S5:13/C4S05-X1:13 | AI          | 4-20mA HART | ACTIVE | JB-612                                                                     | Packing Tower 2th Floor                          | C4S05-X1  | -   | PT-61302       | Pressure Transmitter             | 3-25-01-613-PD-03 |  |

| SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG) |    |    |           |               |          |                     | SIGNAL SPEC |             |        | DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG) |                         |           |     |                |                        |                   |
|-------------------------------------------------------------|----|----|-----------|---------------|----------|---------------------|-------------|-------------|--------|----------------------------------------------------------------------------|-------------------------|-----------|-----|----------------|------------------------|-------------------|
| Point Ref ID                                                | Pt | Ch | Module    | PLC Tag Name  | Card Pin | ePlan Wire Tag      | Type        | Signal Spec | Status | Destination                                                                | Location / Floor        | TB / Fuse | Pin | Instrument Tag | Instrument Description | P&ID Drawing      |
| C4-S05-P13                                                  | 13 | 14 | 1756-IF16 | PT-61309_AI_1 | Pin 14   | C4S5:14/C4S05-X1:14 | AI          | 4-20mA HART | ACTIVE | JB-612                                                                     | Packing Tower 2th Floor | C4S05-X1  | -   | PT-61309       | Pressure Transmitter   | 3-25-01-613-PD-04 |
| C4-S05-P14                                                  | 14 | 15 | 1756-IF16 | Spare_AI_0    | Pin 15   | C4S5:15/C4S05-X1:15 | AI          | 4-20mA HART | SPARE  | JB-612                                                                     | Packing Tower 2th Floor | C4S05-X1  | -   | Spare          | Spare Channel          | -                 |
| C4-S05-P14                                                  | 14 | 15 | 1756-IF16 | Spare_AI_0    | Pin 15   | C4S5:15/C4S05-X1:15 | AI          | 4-20mA HART | SPARE  | IS-JB-612                                                                  | Packing Tower 2th Floor | C4S05-X1  | -   | Spare          | Spare Channel          | -                 |
| C4-S05-P14                                                  | 14 | 15 | 1756-IF16 | Spare_AI_0    | Pin 15   | C4S5:15/C4S05-X1:15 | AI          | 4-20mA HART | SPARE  | IS-JB-612                                                                  | Packing Tower 2th Floor | C4S05-X1  | -   | Spare          | Spare Channel          | -                 |
| C4-S05-P14                                                  | 14 | 15 | 1756-IF16 | Spare_AI_0    | Pin 15   | C4S5:15/C4S05-X1:15 | AI          | 4-20mA HART | SPARE  | IS-JB-612                                                                  | Packing Tower 2th Floor | C4S05-X1  | -   | Spare          | Spare Channel          | -                 |
| C4-S05-P14                                                  | 14 | 15 | 1756-IF16 | Spare_AI_0    | Pin 15   | C4S5:15/C4S05-X1:15 | AI          | 4-20mA HART | SPARE  | IS-JB-612                                                                  | Packing Tower 2th Floor | C4S05-X1  | -   | Spare          | Spare Channel          | -                 |
| C4-S05-P14                                                  | 14 | 15 | 1756-IF16 | Spare_AI_0    | Pin 15   | C4S5:15/C4S05-X1:15 | AI          | 4-20mA HART | SPARE  | IS-JB-612                                                                  | Packing Tower 2th Floor | C4S05-X1  | -   | Spare          | Spare Channel          | -                 |
| C4-S05-P14                                                  | 14 | 15 | 1756-IF16 | Spare_AI_0    | Pin 15   | C4S5:15/C4S05-X1:15 | AI          | 4-20mA HART | SPARE  | IS-JB-612                                                                  | Packing Tower 2th Floor | C4S05-X1  | -   | Spare          | Spare Channel          | -                 |
| C4-S05-P14                                                  | 14 | 15 | 1756-IF16 | Spare_AI_0    | Pin 15   | C4S5:15/C4S05-X1:15 | AI          | 4-20mA HART | SPARE  | IS-JB-612                                                                  | Packing Tower 2th Floor | C4S05-X1  | -   | Spare          | Spare Channel          | -                 |
| C4-S05-P15                                                  | 15 | 16 | 1756-IF16 | Spare_AI_0    | Pin 16   | C4S5:16/C4S05-X1:16 | AI          | 4-20mA HART | SPARE  | JB-612                                                                     | Packing Tower 2th Floor | C4S05-X1  | -   | Spare          | Spare Channel          | -                 |

| <div>C4 SLOT 06 — 1756-IF16 (AI)</div> <div>Rack: I/O Expansion Rack 3 (Chassis 4)   Location: Control Cabinet CA1 (Bay 4)   Protocol: EN4TR DLR Ring Node 4 (192.168.1.13)</div> <div>Capacity: 8 Pts   Active: 8   Spare: 0 (0.0%)</div> |    |    |           |                |          |                   |             |             |        |                                                                            |                         |           |     |                |                                   |                   |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----|----|-----------|----------------|----------|-------------------|-------------|-------------|--------|----------------------------------------------------------------------------|-------------------------|-----------|-----|----------------|-----------------------------------|-------------------|
| SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)                                                                                                                                                                                |    |    |           |                |          |                   | SIGNAL SPEC |             |        | DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG) |                         |           |     |                |                                   |                   |
| Point Ref ID                                                                                                                                                                                                                               | Pt | Ch | Module    | PLC Tag Name   | Card Pin | ePlan Wire Tag    | Type        | Signal Spec | Status | Destination                                                                | Location / Floor        | TB / Fuse | Pin | Instrument Tag | Instrument Description            | P&ID Drawing      |
| C4-S06-P00                                                                                                                                                                                                                                 | 0  | 1  | 1756-IF16 | PT-60220_AI_1  | Pin 1    | C4S6:1/C4S06-X1:1 | AI          | 4-20mA HART | ACTIVE | IS-JB-608                                                                  | Spray Dryer 8th Floor   | C4S06-X1  | –   | PT-60220       | Pressure Transmitter              | 3-25-01-602-PD-04 |
| C4-S06-P01                                                                                                                                                                                                                                 | 1  | 2  | 1756-IF16 | TT-60220_AI_1  | Pin 2    | C4S6:2/C4S06-X1:2 | AI          | 4-20mA HART | ACTIVE | IS-JB-608                                                                  | Spray Dryer 8th Floor   | C4S06-X1  | –   | TT-60220       |                                   | 3-25-01-602-PD-04 |
| C4-S06-P02                                                                                                                                                                                                                                 | 2  | 3  | 1756-IF16 | TT-60221_AI_1  | Pin 3    | C4S6:3/C4S06-X1:3 | AI          | 4-20mA HART | ACTIVE | IS-JB-608                                                                  | Spray Dryer 8th Floor   | C4S06-X1  | –   | TT-60221       |                                   | 3-25-01-602-PD-04 |
| C4-S06-P03                                                                                                                                                                                                                                 | 3  | 4  | 1756-IF16 | TT-60222_AI_1  | Pin 4    | C4S6:4/C4S06-X1:4 | AI          | 4-20mA HART | ACTIVE | IS-JB-608                                                                  | Spray Dryer 8th Floor   | C4S06-X1  | –   | TT-60222       |                                   | 3-25-01-602-PD-04 |
| C4-S06-P04                                                                                                                                                                                                                                 | 4  | 5  | 1756-IF16 | TT-60223_AI_1  | Pin 5    | C4S6:5/C4S06-X1:5 | AI          | 4-20mA HART | ACTIVE | IS-JB-608                                                                  | Spray Dryer 8th Floor   | C4S06-X1  | –   | TT-60223       |                                   | 3-25-01-602-PD-04 |
| C4-S06-P05                                                                                                                                                                                                                                 | 5  | 6  | 1756-IF16 | XT-60201_AI_1  | Pin 6    | C4S6:6/C4S06-X1:6 | AI          | 4-20mA HART | ACTIVE | IS-JB-608                                                                  | Spray Dryer 8th Floor   | C4S06-X1  | –   | XT-60201       |                                   | 3-25-01-602-PD-03 |
| C4-S06-P06                                                                                                                                                                                                                                 | 6  | 7  | 1756-IF16 | DPT-61310_AI_1 | Pin 7    | C4S6:7/C4S06-X1:7 | AI          | 4-20mA HART | ACTIVE | IS-JB-612                                                                  | Packing Tower 2th Floor | C4S06-X1  | –   | DPT-61310      | Differential Pressure Transmitter | 3-25-01-613-PD-03 |
| C4-S06-P07                                                                                                                                                                                                                                 | 7  | 8  | 1756-IF16 | DPT-61312_AI_1 | Pin 8    | C4S6:8/C4S06-X1:8 | AI          | 4-20mA HART | ACTIVE | IS-JB-612                                                                  | Packing Tower 2th Floor | C4S06-X1  | –   | DPT-61312      |                                   | 3-25-01-613-PD-05 |