

KALASIN ENGINEERING — C6 (MCC AUXILIARY I/O (CHASSIS 6))

SLOT-BY-SLOT I/O SOURCE AND DESTINATION WIRING SCHEDULE

Project Ref: x2608003

Rack Location: Motor Control Center Room (MCC Panel)

Network: MCC Hardwired Trunk Line

Revision: Rev 3.6 | Date: 28-Sep-2026

CHASSIS ID

C6

ACTIVE SLOTS

2 Slots

TOTAL CAPACITY

18 Channels

ACTIVE POINTS

18 Points

SPARE POINTS

0 (0.0%)

PANEL LOCATION

Motor Control Cent

C6 SLOT 05 — 1756 I/O (DO)																
Rack: MCC Auxiliary I/O (Chassis 6) Location: Motor Control Center Room (MCC Panel) Protocol: MCC Hardwired Trunk Line																
SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)							SIGNAL SPEC			DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C6-S05-P00	0	1		PCM-2030_DO_1	Pin 1	C6S5:1/C6S05-:1	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C6S05-	-	PCM-2030		3-25-01-202-PD-01
C6-S05-P01	1	2		PCM-2030_DO_2	Pin 2	C6S5:2/C6S05-:2	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C6S05-	-	PCM-2030		3-25-01-202-PD-01
C6-S05-P02	2	3		PCM-2031_DO_1	Pin 3	C6S5:3/C6S05-:3	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C6S05-	-	PCM-2031		3-25-01-202-PD-01
C6-S05-P03	3	4		PCM-2031_DO_2	Pin 4	C6S5:4/C6S05-:4	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C6S05-	-	PCM-2031		3-25-01-202-PD-01
C6-S05-P04	4	5		PCY-814201_DO_1	Pin 5	C6S5:5/C6S05-:5	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C6S05-	-	PCY-814201	PUMP	-
C6-S05-P05	5	6		PCY-814202_DO_1	Pin 6	C6S5:6/C6S05-:6	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C6S05-	-	PCY-814202	PUMP	-
C6-S05-P06	6	7		XS-80305_DO_1	Pin 7	C6S5:7/C6S05-:7	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C6S05-	-	XS-80305		-
C6-S05-P07	7	8		XS-80306_DO_1	Pin 8	C6S5:8/C6S05-:8	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C6S05-	-	XS-80306	Pressure Transmitter	-

C6 SLOT 06 — 1756 I/O (DI)																
Rack: MCC Auxiliary I/O (Chassis 6) Location: Motor Control Center Room (MCC Panel) Protocol: MCC Hardwired Trunk Line																
SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)										SIGNAL SPEC		DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG)				
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C6-S06-P00	0	1		PCM-2030_DI_1	Pin 1	C6S6:1/C6S06-:1	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C6S06-	-	PCM-2030		3-25-01-202-PD-01
C6-S06-P01	1	2		PCM-2030_DI_2	Pin 2	C6S6:2/C6S06-:2	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C6S06-	-	PCM-2030		3-25-01-202-PD-01
C6-S06-P02	2	3		PCM-2031_DI_1	Pin 3	C6S6:3/C6S06-:3	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C6S06-	-	PCM-2031		3-25-01-202-PD-01
C6-S06-P03	3	4		PCM-2031_DI_2	Pin 4	C6S6:4/C6S06-:4	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C6S06-	-	PCM-2031		3-25-01-202-PD-01
C6-S06-P04	4	5		PCY-814201_DI_1	Pin 5	C6S6:5/C6S06-:5	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C6S06-	-	PCY-814201	PUMP	-
C6-S06-P05	5	6		PCY-814201_DI_2	Pin 6	C6S6:6/C6S06-:6	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C6S06-	-	PCY-814201	PUMP	-
C6-S06-P06	6	7		PCY-814201_DI_3	Pin 7	C6S6:7/C6S06-:7	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C6S06-	-	PCY-814201	PUMP	-
C6-S06-P07	7	8		PCY-814202_DI_1	Pin 8	C6S6:8/C6S06-:8	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C6S06-	-	PCY-814202	PUMP	-
C6-S06-P08	8	9		PCY-814202_DI_2	Pin 9	C6S6:9/C6S06-:9	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C6S06-	-	PCY-814202	PUMP	-
C6-S06-P09	9	10		PCY-814202_DI_3	Pin 10	C6S6:10/C6S06-:10	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C6S06-	-	PCY-814202	PUMP	-