

KALASIN ENGINEERING — C7 (MCC FIELDBUS & NETWORK INTERFACE (CHASSIS 7))

SLOT-BY-SLOT I/O SOURCE AND DESTINATION WIRING SCHEDULE

Project Ref: x2608003
Rack Location: Motor Control Center Room (MCC Panel & Field Bus)
Network: Modbus TCP / EtherNet Trunk
Revision: Rev 3.6 | Date: 28-Sep-2026

CHASSIS ID
C7

ACTIVE SLOTS
8 Slots

TOTAL CAPACITY
226 Channels

ACTIVE POINTS
158 Points

SPARE POINTS
68 (30.1%)

PANEL LOCATION
Motor Control Cent

C7 SLOT 00 — 1756 I/O (BUS)																
Rack: MCC Fieldbus & Network Interface (Chassis 7) Location: Motor Control Center Room (MCC Panel & Field Bus) Protocol: Modbus TCP / EtherNet Trunk																
SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)							SIGNAL SPEC			DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C7-S00-P00	0	1		ATY-40201_BUS_1	Pin 1	C7S0:1/C7S00-:1	BUS	4-20mA HART	ACTIVE	MCC	MCC Room	C7S00-	-	ATY-40201	Tank Agitator	3-25-01-402-PD-01
C7-S00-P00	0	1		ATY-40202_BUS_1	Pin 1	C7S0:1/C7S00-:1	BUS	4-20mA HART	ACTIVE	MCC	MCC Room	C7S00-	-	ATY-40202	Tank Agitator	3-25-01-402-PD-01
C7-S00-P00	0	1		ATY-40203_BUS_1	Pin 1	C7S0:1/C7S00-:1	BUS	4-20mA HART	ACTIVE	MCC	MCC Room	C7S00-	-	ATY-40203	Tank Agitator	3-25-01-402-PD-02
C7-S00-P00	0	1		BFY-60206_BUS_1	Pin 1	C7S0:1/C7S00-:1	BUS	4-20mA HART	ACTIVE	MCC	MCC Room	C7S00-	-	BFY-60206		-
C7-S00-P00	0	1		BFY-60210_BUS_1	Pin 1	C7S0:1/C7S00-:1	BUS	4-20mA HART	ACTIVE	MCC	MCC Room	C7S00-	-	BFY-60210		-
C7-S00-P00	0	1		BFY-60211_BUS_1	Pin 1	C7S0:1/C7S00-:1	BUS	4-20mA HART	ACTIVE	MCC	MCC Room	C7S00-	-	BFY-60211		-
C7-S00-P00	0	1		BFY-60220_BUS_1	Pin 1	C7S0:1/C7S00-:1	BUS	4-20mA HART	ACTIVE	MCC	MCC Room	C7S00-	-	BFY-60220		-
C7-S00-P00	0	1		BFY-60240_BUS_1	Pin 1	C7S0:1/C7S00-:1	BUS	4-20mA HART	ACTIVE	MCC	MCC Room	C7S00-	-	BFY-60240		-
C7-S00-P00	0	1		BFY-61301_BUS_1	Pin 1	C7S0:1/C7S00-:1	BUS	4-20mA HART	ACTIVE	MCC	MCC Room	C7S00-	-	BFY-61301		-
C7-S00-P00	0	1		BFY-61302_BUS_1	Pin 1	C7S0:1/C7S00-:1	BUS	4-20mA HART	ACTIVE	MCC	MCC Room	C7S00-	-	BFY-61302		-
C7-S00-P00	0	1		BFY-61303_BUS_1	Pin 1	C7S0:1/C7S00-:1	BUS	4-20mA HART	ACTIVE	MCC	MCC Room	C7S00-	-	BFY-61303		-
C7-S00-P00	0	1		COM-FH-60210B_BUS_1	Pin 1	C7S0:1/C7S00-:1	BUS	4-20mA HART	ACTIVE	JB-607	Spray Dryer 7th Floor	C7S00-	-	COM-FH-60210B		-
C7-S00-P00	0	1		Communication Signal_BUS_1	Pin 1	C7S0:1/C7S00-:1	BUS	4-20mA HART	ACTIVE	JB-612	Packing Tower 2th Floor	C7S00-	-	Communication Signal		-

SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)							SIGNAL SPEC			DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C7-S00-P00	0	1		PCY-40201_BUS_1	Pin 1	C7S0:1/C7S00-:1	BUS	4-20mA HART	ACTIVE	MCC	MCC Room	C7S00-	-	PCY-40201	PUMP	3-25-01-402-PD-01
C7-S00-P00	0	1		PCY-40202_BUS_1	Pin 1	C7S0:1/C7S00-:1	BUS	4-20mA HART	ACTIVE	MCC	MCC Room	C7S00-	-	PCY-40202	PUMP	3-25-01-402-PD-01
C7-S00-P00	0	1		PCY-40203_BUS_1	Pin 1	C7S0:1/C7S00-:1	BUS	4-20mA HART	ACTIVE	MCC	MCC Room	C7S00-	-	PCY-40203	PUMP	3-25-01-402-PD-02
C7-S00-P00	0	1		PCY-60205_BUS_1	Pin 1	C7S0:1/C7S00-:1	BUS	4-20mA HART	ACTIVE	JB-601	Spray Dryer 1st Floor	C7S00-	-	PCY-60205		-
C7-S00-P00	0	1		PCY-60215_BUS_1	Pin 1	C7S0:1/C7S00-:1	BUS	4-20mA HART	ACTIVE	MCC	MCC Room	C7S00-	-	PCY-60215	PUMP	-
C7-S00-P00	0	1		PCY-814201_BUS_1	Pin 1	C7S0:1/C7S00-:1	BUS	4-20mA HART	ACTIVE	MCC	MCC Room	C7S00-	-	PCY-814201	PUMP	-
C7-S00-P00	0	1		PCY-814202_BUS_1	Pin 1	C7S0:1/C7S00-:1	BUS	4-20mA HART	ACTIVE	MCC	MCC Room	C7S00-	-	PCY-814202	PUMP	-

C7 SLOT 01 — 1756 I/O (DI)												Capacity: 32 Pts Active: 24 Spare: 8 (25.0%)				
Rack: MCC Fieldbus & Network Interface (Chassis 7) Location: Motor Control Center Room (MCC Panel & Field Bus) Protocol: Modbus TCP / EtherNet Trunk																
SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)							SIGNAL SPEC			DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C7-S01-P00	0	1		Spare_DI_0	Pin 1	C7S1:1/C7S01-:1	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S01-	-	Spare	Spare Channel	3-25-01-402-PD-01
C7-S01-P01	1	2		Spare_DI_0	Pin 2	C7S1:2/C7S01-:2	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S01-	-	Spare	Spare Channel	3-25-01-402-PD-01
C7-S01-P02	2	3		Spare_DI_0	Pin 3	C7S1:3/C7S01-:3	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S01-	-	Spare	Spare Channel	3-25-01-402-PD-01
C7-S01-P03	3	4		Spare_DI_0	Pin 4	C7S1:4/C7S01-:4	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S01-	-	Spare	Spare Channel	3-25-01-402-PD-01
C7-S01-P04	4	5		Spare_DI_0	Pin 5	C7S1:5/C7S01-:5	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S01-	-	Spare	Spare Channel	3-25-01-402-PD-01
C7-S01-P05	5	6		Spare_DI_0	Pin 6	C7S1:6/C7S01-:6	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S01-	-	Spare	Spare Channel	3-25-01-402-PD-01
C7-S01-P06	6	7		Spare_DI_0	Pin 7	C7S1:7/C7S01-:7	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S01-	-	Spare	Spare Channel	3-25-01-402-PD-01
C7-S01-P07	7	8		Spare_DI_0	Pin 8	C7S1:8/C7S01-:8	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S01-	-	Spare	Spare Channel	3-25-01-402-PD-01
C7-S01-P08	8	9		ATY-40201_DI_1	Pin 9	C7S1:9/C7S01-:9	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S01-	-	ATY-40201	Tank Agitator	3-25-01-402-PD-01
C7-S01-P09	9	10		ATY-40201_DI_2	Pin 10	C7S1:10/C7S01-:10	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S01-	-	ATY-40201	Tank Agitator	3-25-01-402-PD-01
C7-S01-P10	10	11		ATY-40201_DI_3	Pin 11	C7S1:11/C7S01-:11	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S01-	-	ATY-40201	Tank Agitator	3-25-01-402-PD-01
C7-S01-P11	11	12		ATY-40202_DI_1	Pin 12	C7S1:12/C7S01-:12	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S01-	-	ATY-40202	Tank Agitator	3-25-01-402-PD-01
C7-S01-P12	12	13		ATY-40202_DI_2	Pin 13	C7S1:13/C7S01-:13	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S01-	-	ATY-40202	Tank Agitator	3-25-01-402-PD-01
C7-S01-P13	13	14		ATY-40202_DI_3	Pin 14	C7S1:14/C7S01-:14	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S01-	-	ATY-40202	Tank Agitator	3-25-01-402-PD-01
C7-S01-P14	14	15		ATY-40203_DI_1	Pin 15	C7S1:15/C7S01-:15	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S01-	-	ATY-40203	Tank Agitator	3-25-01-402-PD-02
C7-S01-P15	15	16		ATY-40203_DI_2	Pin 16	C7S1:16/C7S01-:16	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S01-	-	ATY-40203	Tank Agitator	3-25-01-402-PD-02
C7-S01-P16	16	17		ATY-40203_DI_3	Pin 17	C7S1:17/C7S01-:17	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S01-	-	ATY-40203	Tank Agitator	3-25-01-402-PD-02

SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)							SIGNAL SPEC			DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C7-S01-P17	17	18		PCY-40201_DI_1	Pin 18	C7S1:18/C7S01-:18	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S01-	-	PCY-40201	PUMP	3-25-01-402-PD-01
C7-S01-P18	18	19		PCY-40201_DI_2	Pin 19	C7S1:19/C7S01-:19	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S01-	-	PCY-40201	PUMP	3-25-01-402-PD-01
C7-S01-P19	19	20		PCY-40201_DI_3	Pin 20	C7S1:20/C7S01-:20	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S01-	-	PCY-40201	PUMP	3-25-01-402-PD-01
C7-S01-P20	20	21		PCY-40202_DI_1	Pin 21	C7S1:21/C7S01-:21	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S01-	-	PCY-40202	PUMP	3-25-01-402-PD-01
C7-S01-P21	21	22		PCY-40202_DI_2	Pin 22	C7S1:22/C7S01-:22	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S01-	-	PCY-40202	PUMP	3-25-01-402-PD-01
C7-S01-P22	22	23		PCY-40202_DI_3	Pin 23	C7S1:23/C7S01-:23	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S01-	-	PCY-40202	PUMP	3-25-01-402-PD-01
C7-S01-P23	23	24		PCY-40203_DI_1	Pin 24	C7S1:24/C7S01-:24	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S01-	-	PCY-40203	PUMP	3-25-01-402-PD-02
C7-S01-P24	24	25		PCY-40203_DI_2	Pin 25	C7S1:25/C7S01-:25	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S01-	-	PCY-40203	PUMP	3-25-01-402-PD-02
C7-S01-P25	25	26		PCY-40203_DI_3	Pin 26	C7S1:26/C7S01-:26	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S01-	-	PCY-40203	PUMP	3-25-01-402-PD-02
C7-S01-P26	26	27		BFY-60206_DI_1	Pin 27	C7S1:27/C7S01-:27	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S01-	-	BFY-60206		-
C7-S01-P27	27	28		PCM-60205-2_DI_1	Pin 28	C7S1:28/C7S01-:28	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S01-	-	PCM-60205-2		-
C7-S01-P28	28	29		PCM-60205-2_DI_2	Pin 29	C7S1:29/C7S01-:29	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S01-	-	PCM-60205-2		-
C7-S01-P29	29	30		PCM-60205-3_DI_1	Pin 30	C7S1:30/C7S01-:30	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S01-	-	PCM-60205-3		-
C7-S01-P30	30	31		PCM-60205-3_DI_2	Pin 31	C7S1:31/C7S01-:31	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S01-	-	PCM-60205-3		-
C7-S01-P31	31	32		PCM-60205-4_DI_1	Pin 32	C7S1:32/C7S01-:32	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S01-	-	PCM-60205-4		-

C7 SLOT 02 — 1756 I/O (DI)													Capacity: 32 Pts Active: 32 Spare: 0 (0.0%)				
Rack: MCC Fieldbus & Network Interface (Chassis 7) Location: Motor Control Center Room (MCC Panel & Field Bus) Protocol: Modbus TCP / EtherNet Trunk																	
Source Specification (PLC Rack / Card Pin / Eplan Wire Tag)							Signal Spec			Destination Specification (Field JB / MCC / Terminal Pin / Instrument Tag)							
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing	
C7-S02-P00	0	1		PCM-60205-4_DI_2	Pin 1	C7S2:1/C7S02-:1	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S02-	-	PCM-60205-4		-	
C7-S02-P01	1	2		PCM-60205-5_DI_1	Pin 2	C7S2:2/C7S02-:2	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S02-	-	PCM-60205-5		-	
C7-S02-P02	2	3		PCM-60205-5_DI_2	Pin 3	C7S2:3/C7S02-:3	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S02-	-	PCM-60205-5		-	
C7-S02-P03	3	4		PCY-60205_DI_1	Pin 4	C7S2:4/C7S02-:4	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C7S02-	-	PCY-60205		-	
C7-S02-P04	4	5		PCY-60205_DI_2	Pin 5	C7S2:5/C7S02-:5	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C7S02-	-	PCY-60205		-	
C7-S02-P05	5	6		RVM-60201_DI_1	Pin 6	C7S2:6/C7S02-:6	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S02-	-	RVM-60201		-	
C7-S02-P06	6	7		RVM-60201_DI_2	Pin 7	C7S2:7/C7S02-:7	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S02-	-	RVM-60201		-	
C7-S02-P07	7	8		RVM-60202_DI_1	Pin 8	C7S2:8/C7S02-:8	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S02-	-	RVM-60202		-	
C7-S02-P08	8	9		RVM-60202_DI_2	Pin 9	C7S2:9/C7S02-:9	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S02-	-	RVM-60202		-	
C7-S02-P09	9	10		RVM-60203_DI_1	Pin 10	C7S2:10/C7S02-:10	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S02-	-	RVM-60203		-	
C7-S02-P10	10	11		RVM-60203_DI_2	Pin 11	C7S2:11/C7S02-:11	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S02-	-	RVM-60203		-	
C7-S02-P11	11	12		BFY-60210_DI_1	Pin 12	C7S2:12/C7S02-:12	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S02-	-	BFY-60210		-	
C7-S02-P12	12	13		BFY-60211_DI_1	Pin 13	C7S2:13/C7S02-:13	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S02-	-	BFY-60211		-	
C7-S02-P13	13	14		BFY-60240_DI_1	Pin 14	C7S2:14/C7S02-:14	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S02-	-	BFY-60240		-	
C7-S02-P14	14	15		PCY-60215_DI_1	Pin 15	C7S2:15/C7S02-:15	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S02-	-	PCY-60215	PUMP	-	
C7-S02-P15	15	16		PCY-60215_DI_2	Pin 16	C7S2:16/C7S02-:16	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S02-	-	PCY-60215	PUMP	-	
C7-S02-P16	16	17		PCY-60215_DI_3	Pin 17	C7S2:17/C7S02-:17	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S02-	-	PCY-60215	PUMP	-	

SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)							SIGNAL SPEC			DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C7-S02-P17	17	18		BFY-60220_DI_1	Pin 18	C7S2:18/C7S02-:18	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S02-	-	BFY-60220		-
C7-S02-P18	18	19		BFY-61302_DI_1	Pin 19	C7S2:19/C7S02-:19	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S02-	-	BFY-61302		-
C7-S02-P19	19	20		HS-61307F_DI_1	Pin 20	C7S2:20/C7S02-:20	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S02-	-	HS-61307F		3-25-01-613-PD-03
C7-S02-P20	20	21		HS-61307G_DI_1	Pin 21	C7S2:21/C7S02-:21	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S02-	-	HS-61307G		3-25-01-613-PD-03
C7-S02-P21	21	22		HS-61307H_DI_1	Pin 22	C7S2:22/C7S02-:22	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S02-	-	HS-61307H		3-25-01-613-PD-03
C7-S02-P22	22	23		HS-61307I_DI_1	Pin 23	C7S2:23/C7S02-:23	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S02-	-	HS-61307I		3-25-01-613-PD-03
C7-S02-P23	23	24		HS-61307J_DI_1	Pin 24	C7S2:24/C7S02-:24	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S02-	-	HS-61307J		3-25-01-613-PD-03
C7-S02-P24	24	25		HS-61307K_DI_1	Pin 25	C7S2:25/C7S02-:25	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S02-	-	HS-61307K		3-25-01-613-PD-03
C7-S02-P25	25	26		HS-61307L_DI_1	Pin 26	C7S2:26/C7S02-:26	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S02-	-	HS-61307L		3-25-01-613-PD-03
C7-S02-P26	26	27		HS-61307M_DI_1	Pin 27	C7S2:27/C7S02-:27	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S02-	-	HS-61307M		3-25-01-613-PD-03
C7-S02-P27	27	28		HS-61307N_DI_1	Pin 28	C7S2:28/C7S02-:28	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S02-	-	HS-61307N		3-25-01-613-PD-03
C7-S02-P28	28	29		HS-61307O_DI_1	Pin 29	C7S2:29/C7S02-:29	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S02-	-	HS-61307O		3-25-01-613-PD-03
C7-S02-P29	29	30		HS-61307P_DI_1	Pin 30	C7S2:30/C7S02-:30	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S02-	-	HS-61307P		3-25-01-613-PD-03
C7-S02-P30	30	31		HS-61307Q_DI_1	Pin 31	C7S2:31/C7S02-:31	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S02-	-	HS-61307Q		3-25-01-613-PD-03
C7-S02-P31	31	32		HS-61307R_DI_1	Pin 32	C7S2:32/C7S02-:32	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S02-	-	HS-61307R		3-25-01-613-PD-03

C7 SLOT 03 — 1756 I/O (DI)													Capacity: 26 Pts Active: 26 Spare: 0 (0.0%)			
Rack: MCC Fieldbus & Network Interface (Chassis 7) Location: Motor Control Center Room (MCC Panel & Field Bus) Protocol: Modbus TCP / EtherNet Trunk																
Source Specification (PLC Rack / Card Pin / Eplan Wire Tag)							Signal Spec			Destination Specification (Field JB / MCC / Terminal Pin / Instrument Tag)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C7-S03-P00	0	1		RVM-61302_DI_1	Pin 1	C7S3:1/C7S03-:1	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S03-	-	RVM-61302		-
C7-S03-P01	1	2		RVM-61302_DI_2	Pin 2	C7S3:2/C7S03-:2	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S03-	-	RVM-61302		-
C7-S03-P02	2	3		RVM-61303_DI_1	Pin 3	C7S3:3/C7S03-:3	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S03-	-	RVM-61303		-
C7-S03-P03	3	4		RVM-61303_DI_2	Pin 4	C7S3:4/C7S03-:4	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S03-	-	RVM-61303		-
C7-S03-P04	4	5		SCM-61301_DI_1	Pin 5	C7S3:5/C7S03-:5	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S03-	-	SCM-61301		-
C7-S03-P05	5	6		SCM-61301_DI_2	Pin 6	C7S3:6/C7S03-:6	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S03-	-	SCM-61301		-
C7-S03-P06	6	7		SCM-61302_DI_2	Pin 7	C7S3:7/C7S03-:7	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S03-	-	SCM-61302		-
C7-S03-P07	7	8		SCM-61302_DI_1	Pin 8	C7S3:8/C7S03-:8	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S03-	-	SCM-61302		-
C7-S03-P08	8	9		BFY-61301_DI_1	Pin 9	C7S3:9/C7S03-:9	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S03-	-	BFY-61301		-
C7-S03-P09	9	10		BFY-61303_DI_1	Pin 10	C7S3:10/C7S03-:10	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S03-	-	BFY-61303		-
C7-S03-P10	10	11		BLM-61302_DI_1	Pin 11	C7S3:11/C7S03-:11	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S03-	-	BLM-61302		-
C7-S03-P11	11	12		BLM-61302_DI_2	Pin 12	C7S3:12/C7S03-:12	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S03-	-	BLM-61302		-
C7-S03-P12	12	13		HS-61307A_DI_1	Pin 13	C7S3:13/C7S03-:13	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S03-	-	HS-61307A		3-25-01-613-PD-03
C7-S03-P13	13	14		HS-61307B_DI_1	Pin 14	C7S3:14/C7S03-:14	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S03-	-	HS-61307B		3-25-01-613-PD-03
C7-S03-P14	14	15		HS-61307C_DI_1	Pin 15	C7S3:15/C7S03-:15	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S03-	-	HS-61307C		3-25-01-613-PD-03
C7-S03-P15	15	16		HS-61307D_DI_1	Pin 16	C7S3:16/C7S03-:16	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S03-	-	HS-61307D		3-25-01-613-PD-03
C7-S03-P16	16	17		HS-61307E_DI_1	Pin 17	C7S3:17/C7S03-:17	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S03-	-	HS-61307E		3-25-01-613-PD-03

SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)							SIGNAL SPEC			DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C7-S03-P17	17	18		RVM-60204_DI_1	Pin 18	C7S3:18/C7S03-:18	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S03-	-	RVM-60204		-
C7-S03-P18	18	19		RVM-60204_DI_2	Pin 19	C7S3:19/C7S03-:19	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S03-	-	RVM-60204		-
C7-S03-P19	19	20		RVM-61301_DI_1	Pin 20	C7S3:20/C7S03-:20	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S03-	-	RVM-61301		-
C7-S03-P20	20	21		RVM-61301_DI_2	Pin 21	C7S3:21/C7S03-:21	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S03-	-	RVM-61301		-
C7-S03-P21	21	22		RVM-61304_DI_1	Pin 22	C7S3:22/C7S03-:22	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S03-	-	RVM-61304		-
C7-S03-P22	22	23		RVM-61304_DI_2	Pin 23	C7S3:23/C7S03-:23	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S03-	-	RVM-61304		-
C7-S03-P23	23	24		RVM-61305_DI_1	Pin 24	C7S3:24/C7S03-:24	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S03-	-	RVM-61305		-
C7-S03-P24	24	25		RVM-61305_DI_2	Pin 25	C7S3:25/C7S03-:25	DI	24VDC Dry Contact	ACTIVE	MCC	MCC Room	C7S03-	-	RVM-61305		-
C7-S03-P25	25	26		PCY-60205_DI_3	Pin 26	C7S3:26/C7S03-:26	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C7S03-	-	PCY-60205		-

C7 SLOT 04 — 1756 I/O (DI) Rack: MCC Fieldbus & Network Interface (Chassis 7) Location: Motor Control Center Room (MCC Panel & Field Bus) Protocol: Modbus TCP / EtherNet Trunk Capacity: 28 Pts Active: 0 Spare: 28 (100.0%)																
SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)							SIGNAL SPEC			DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C7-S04-P04	4	5		Spare_DI_0	Pin 5	C7S4:5/C7S04-:5	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S04-	-	Spare	Spare Channel	-
C7-S04-P05	5	6		Spare_DI_0	Pin 6	C7S4:6/C7S04-:6	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S04-	-	Spare	Spare Channel	-
C7-S04-P06	6	7		Spare_DI_0	Pin 7	C7S4:7/C7S04-:7	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S04-	-	Spare	Spare Channel	-
C7-S04-P07	7	8		Spare_DI_0	Pin 8	C7S4:8/C7S04-:8	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S04-	-	Spare	Spare Channel	-
C7-S04-P08	8	9		Spare_DI_0	Pin 9	C7S4:9/C7S04-:9	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S04-	-	Spare	Spare Channel	-
C7-S04-P09	9	10		Spare_DI_0	Pin 10	C7S4:10/C7S04-:10	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S04-	-	Spare	Spare Channel	-
C7-S04-P10	10	11		Spare_DI_0	Pin 11	C7S4:11/C7S04-:11	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S04-	-	Spare	Spare Channel	-
C7-S04-P11	11	12		Spare_DI_0	Pin 12	C7S4:12/C7S04-:12	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S04-	-	Spare	Spare Channel	-
C7-S04-P12	12	13		Spare_DI_0	Pin 13	C7S4:13/C7S04-:13	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S04-	-	Spare	Spare Channel	-
C7-S04-P13	13	14		Spare_DI_0	Pin 14	C7S4:14/C7S04-:14	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S04-	-	Spare	Spare Channel	-
C7-S04-P14	14	15		Spare_DI_0	Pin 15	C7S4:15/C7S04-:15	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S04-	-	Spare	Spare Channel	-
C7-S04-P15	15	16		Spare_DI_0	Pin 16	C7S4:16/C7S04-:16	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S04-	-	Spare	Spare Channel	-
C7-S04-P16	16	17		Spare_DI_0	Pin 17	C7S4:17/C7S04-:17	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S04-	-	Spare	Spare Channel	-
C7-S04-P17	17	18		Spare_DI_0	Pin 18	C7S4:18/C7S04-:18	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S04-	-	Spare	Spare Channel	-
C7-S04-P18	18	19		Spare_DI_0	Pin 19	C7S4:19/C7S04-:19	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S04-	-	Spare	Spare Channel	-
C7-S04-P19	19	20		Spare_DI_0	Pin 20	C7S4:20/C7S04-:20	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S04-	-	Spare	Spare Channel	-

SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)							SIGNAL SPEC			DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C7-S04-P20	20	21		Spare_DI_0	Pin 21	C7S4:21/C7S04-:21	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S04-	-	Spare	Spare Channel	-
C7-S04-P21	21	22		Spare_DI_0	Pin 22	C7S4:22/C7S04-:22	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S04-	-	Spare	Spare Channel	-
C7-S04-P22	22	23		Spare_DI_0	Pin 23	C7S4:23/C7S04-:23	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S04-	-	Spare	Spare Channel	-
C7-S04-P23	23	24		Spare_DI_0	Pin 24	C7S4:24/C7S04-:24	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S04-	-	Spare	Spare Channel	-
C7-S04-P24	24	25		Spare_DI_0	Pin 25	C7S4:25/C7S04-:25	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S04-	-	Spare	Spare Channel	-
C7-S04-P25	25	26		Spare_DI_0	Pin 26	C7S4:26/C7S04-:26	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S04-	-	Spare	Spare Channel	-
C7-S04-P26	26	27		Spare_DI_0	Pin 27	C7S4:27/C7S04-:27	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S04-	-	Spare	Spare Channel	-
C7-S04-P27	27	28		Spare_DI_0	Pin 28	C7S4:28/C7S04-:28	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S04-	-	Spare	Spare Channel	-
C7-S04-P28	28	29		Spare_DI_0	Pin 29	C7S4:29/C7S04-:29	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S04-	-	Spare	Spare Channel	-
C7-S04-P29	29	30		Spare_DI_0	Pin 30	C7S4:30/C7S04-:30	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S04-	-	Spare	Spare Channel	-
C7-S04-P30	30	31		Spare_DI_0	Pin 31	C7S4:31/C7S04-:31	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S04-	-	Spare	Spare Channel	-
C7-S04-P31	31	32		Spare_DI_0	Pin 32	C7S4:32/C7S04-:32	DI	24VDC Dry Contact	SPARE	MCC	MCC Room	C7S04-	-	Spare	Spare Channel	-

C7 SLOT 05 — 1756 I/O (DO)												Capacity: 32 Pts Active: 24 Spare: 8 (25.0%)				
Rack: MCC Fieldbus & Network Interface (Chassis 7) Location: Motor Control Center Room (MCC Panel & Field Bus) Protocol: Modbus TCP / EtherNet Trunk																
Source Specification (PLC Rack / Card Pin / Eplan Wire Tag)							Signal Spec			Destination Specification (Field JB / MCC / Terminal Pin / Instrument Tag)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C7-S05-P00	0	1		Spare_D0_0	Pin 1	C7S5:1/C7S05-:1	DO	24VDC Sourcing	SPARE	MCC	MCC Room	C7S05-	-	Spare	Spare Channel	3-25-01-402-PD-01
C7-S05-P01	1	2		Spare_D0_0	Pin 2	C7S5:2/C7S05-:2	DO	24VDC Sourcing	SPARE	MCC	MCC Room	C7S05-	-	Spare	Spare Channel	3-25-01-402-PD-01
C7-S05-P02	2	3		Spare_D0_0	Pin 3	C7S5:3/C7S05-:3	DO	24VDC Sourcing	SPARE	MCC	MCC Room	C7S05-	-	Spare	Spare Channel	3-25-01-402-PD-01
C7-S05-P03	3	4		Spare_D0_0	Pin 4	C7S5:4/C7S05-:4	DO	24VDC Sourcing	SPARE	MCC	MCC Room	C7S05-	-	Spare	Spare Channel	3-25-01-402-PD-01
C7-S05-P04	4	5		Spare_D0_0	Pin 5	C7S5:5/C7S05-:5	DO	24VDC Sourcing	SPARE	MCC	MCC Room	C7S05-	-	Spare	Spare Channel	3-25-01-402-PD-01
C7-S05-P05	5	6		Spare_D0_0	Pin 6	C7S5:6/C7S05-:6	DO	24VDC Sourcing	SPARE	MCC	MCC Room	C7S05-	-	Spare	Spare Channel	3-25-01-402-PD-01
C7-S05-P06	6	7		Spare_D0_0	Pin 7	C7S5:7/C7S05-:7	DO	24VDC Sourcing	SPARE	MCC	MCC Room	C7S05-	-	Spare	Spare Channel	3-25-01-402-PD-01
C7-S05-P07	7	8		Spare_D0_0	Pin 8	C7S5:8/C7S05-:8	DO	24VDC Sourcing	SPARE	MCC	MCC Room	C7S05-	-	Spare	Spare Channel	3-25-01-402-PD-01
C7-S05-P08	8	9		ATY-40201_D0_1	Pin 9	C7S5:9/C7S05-:9	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S05-	-	ATY-40201	Tank Agitator	3-25-01-402-PD-01
C7-S05-P09	9	10		ATY-40202_D0_1	Pin 10	C7S5:10/C7S05-:10	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S05-	-	ATY-40202	Tank Agitator	3-25-01-402-PD-01
C7-S05-P10	10	11		ATY-40203_D0_1	Pin 11	C7S5:11/C7S05-:11	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S05-	-	ATY-40203	Tank Agitator	3-25-01-402-PD-02
C7-S05-P11	11	12		PCY-40201_D0_1	Pin 12	C7S5:12/C7S05-:12	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S05-	-	PCY-40201	PUMP	3-25-01-402-PD-01
C7-S05-P12	12	13		PCY-40202_D0_1	Pin 13	C7S5:13/C7S05-:13	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S05-	-	PCY-40202	PUMP	3-25-01-402-PD-01
C7-S05-P13	13	14		PCY-40203_D0_1	Pin 14	C7S5:14/C7S05-:14	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S05-	-	PCY-40203	PUMP	3-25-01-402-PD-02
C7-S05-P14	14	15		BFY-60206_D0_1	Pin 15	C7S5:15/C7S05-:15	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S05-	-	BFY-60206		-
C7-S05-P15	15	16		PCM-60205-2_D0_1	Pin 16	C7S5:16/C7S05-:16	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S05-	-	PCM-60205-2		-
C7-S05-P16	16	17		PCM-60205-2_D0_2	Pin 17	C7S5:17/C7S05-:17	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S05-	-	PCM-60205-2		-

SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)							SIGNAL SPEC			DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C7-S05-P17	17	18		PCM-60205-3_DO_1	Pin 18	C7S5:18/C7S05--:18	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S05-	-	PCM-60205-3		-
C7-S05-P18	18	19		PCM-60205-3_DO_2	Pin 19	C7S5:19/C7S05--:19	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S05-	-	PCM-60205-3		-
C7-S05-P19	19	20		PCM-60205-4_DO_1	Pin 20	C7S5:20/C7S05--:20	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S05-	-	PCM-60205-4		-
C7-S05-P20	20	21		PCM-60205-4_DO_2	Pin 21	C7S5:21/C7S05--:21	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S05-	-	PCM-60205-4		-
C7-S05-P21	21	22		PCM-60205-5_DO_1	Pin 22	C7S5:22/C7S05--:22	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S05-	-	PCM-60205-5		-
C7-S05-P22	22	23		PCM-60205-5_DO_2	Pin 23	C7S5:23/C7S05--:23	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S05-	-	PCM-60205-5		-
C7-S05-P23	23	24		RVM-60201_DO_1	Pin 24	C7S5:24/C7S05--:24	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S05-	-	RVM-60201		-
C7-S05-P24	24	25		RVM-60201_DO_2	Pin 25	C7S5:25/C7S05--:25	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S05-	-	RVM-60201		-
C7-S05-P25	25	26		RVM-60202_DO_1	Pin 26	C7S5:26/C7S05--:26	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S05-	-	RVM-60202		-
C7-S05-P26	26	27		RVM-60202_DO_2	Pin 27	C7S5:27/C7S05--:27	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S05-	-	RVM-60202		-
C7-S05-P27	27	28		RVM-60203_DO_1	Pin 28	C7S5:28/C7S05--:28	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S05-	-	RVM-60203		-
C7-S05-P28	28	29		RVM-60203_DO_2	Pin 29	C7S5:29/C7S05--:29	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S05-	-	RVM-60203		-
C7-S05-P29	29	30		XS-60205_DO_1	Pin 30	C7S5:30/C7S05--:30	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S05-	-	XS-60205		-
C7-S05-P30	30	31		BFY-60210_DO_1	Pin 31	C7S5:31/C7S05--:31	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S05-	-	BFY-60210		-
C7-S05-P31	31	32		BFY-60211_DO_1	Pin 32	C7S5:32/C7S05--:32	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S05-	-	BFY-60211		-

C7 SLOT 06 — 1756 I/O (DO)													Capacity: 32 Pts Active: 32 Spare: 0 (0.0%)				
Rack: MCC Fieldbus & Network Interface (Chassis 7) Location: Motor Control Center Room (MCC Panel & Field Bus) Protocol: Modbus TCP / EtherNet Trunk																	
Source Specification (PLC Rack / Card Pin / Eplan Wire Tag)							Signal Spec			Destination Specification (Field JB / MCC / Terminal Pin / Instrument Tag)							
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing	
C7-S06-P00	0	1		BFY-60240_DO_1	Pin 1	C7S6:1/C7S06-:1	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S06-	-	BFY-60240		-	
C7-S06-P01	1	2		PCY-60215_DO_1	Pin 2	C7S6:2/C7S06-:2	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S06-	-	PCY-60215	PUMP	-	
C7-S06-P02	2	3		XS-60240A_DO_1	Pin 3	C7S6:3/C7S06-:3	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S06-	-	XS-60240A		-	
C7-S06-P03	3	4		XS-60241A_DO_1	Pin 4	C7S6:4/C7S06-:4	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S06-	-	XS-60241A		-	
C7-S06-P04	4	5		XS-60242A_DO_1	Pin 5	C7S6:5/C7S06-:5	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S06-	-	XS-60242A		-	
C7-S06-P04	4	5		XS-60243A_DO_1	Pin 5	C7S6:5/C7S06-:5	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S06-	-	XS-60243A		-	
C7-S06-P06	6	7		XS-60260_DO_1	Pin 7	C7S6:7/C7S06-:7	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S06-	-	XS-60260		-	
C7-S06-P07	7	8		BFY-60220_DO_1	Pin 8	C7S6:8/C7S06-:8	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S06-	-	BFY-60220		-	
C7-S06-P08	8	9		XS-FH-60210A_DO_1	Pin 9	C7S6:9/C7S06-:9	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S06-	-	XS-FH-60210A		-	
C7-S06-P09	9	10		XS-FH-60210B_DO_1	Pin 10	C7S6:10/C7S06-:10	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S06-	-	XS-FH-60210B		-	
C7-S06-P10	10	11		BFY-61302_DO_1	Pin 11	C7S6:11/C7S06-:11	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S06-	-	BFY-61302		-	
C7-S06-P11	11	12		RVM-61302_DO_1	Pin 12	C7S6:12/C7S06-:12	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S06-	-	RVM-61302		-	
C7-S06-P12	12	13		RVM-61302_DO_2	Pin 13	C7S6:13/C7S06-:13	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S06-	-	RVM-61302		-	
C7-S06-P13	13	14		RVM-61303_DO_1	Pin 14	C7S6:14/C7S06-:14	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S06-	-	RVM-61303		-	
C7-S06-P14	14	15		RVM-61303_DO_2	Pin 15	C7S6:15/C7S06-:15	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S06-	-	RVM-61303		-	
C7-S06-P15	15	16		SCM-61301_DO_1	Pin 16	C7S6:16/C7S06-:16	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S06-	-	SCM-61301		-	
C7-S06-P16	16	17		SCM-61301_DO_2	Pin 17	C7S6:17/C7S06-:17	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S06-	-	SCM-61301		-	

SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)							SIGNAL SPEC			DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C7-S06-P17	17	18		SCM-61302_D0_1	Pin 18	C7S6:18/C7S06--:18	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S06-	-	SCM-61302		-
C7-S06-P18	18	19		SCM-61302_D0_2	Pin 19	C7S6:19/C7S06--:19	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S06-	-	SCM-61302		-
C7-S06-P19	19	20		BFY-61301_D0_1	Pin 20	C7S6:20/C7S06--:20	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S06-	-	BFY-61301		-
C7-S06-P20	20	21		BFY-61303_D0_1	Pin 21	C7S6:21/C7S06--:21	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S06-	-	BFY-61303		-
C7-S06-P21	21	22		BLM-61302_D0_1	Pin 22	C7S6:22/C7S06--:22	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S06-	-	BLM-61302		-
C7-S06-P22	22	23		BLM-61302_D0_2	Pin 23	C7S6:23/C7S06--:23	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S06-	-	BLM-61302		-
C7-S06-P23	23	24		RVM-60204_D0_1	Pin 24	C7S6:24/C7S06--:24	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S06-	-	RVM-60204		-
C7-S06-P24	24	25		RVM-60204_D0_2	Pin 25	C7S6:25/C7S06--:25	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S06-	-	RVM-60204		-
C7-S06-P25	25	26		RVM-61301_D0_1	Pin 26	C7S6:26/C7S06--:26	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S06-	-	RVM-61301		-
C7-S06-P26	26	27		RVM-61301_D0_2	Pin 27	C7S6:27/C7S06--:27	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S06-	-	RVM-61301		-
C7-S06-P27	27	28		RVM-61304_D0_1	Pin 28	C7S6:28/C7S06--:28	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S06-	-	RVM-61304		-
C7-S06-P28	28	29		RVM-61304_D0_2	Pin 29	C7S6:29/C7S06--:29	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S06-	-	RVM-61304		-
C7-S06-P29	29	30		RVM-61305_D0_1	Pin 30	C7S6:30/C7S06--:30	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S06-	-	RVM-61305		-
C7-S06-P30	30	31		RVM-61305_D0_2	Pin 31	C7S6:31/C7S06--:31	DO	24VDC Sourcing	ACTIVE	MCC	MCC Room	C7S06-	-	RVM-61305		-
C7-S06-P31	31	32		PCY-60205_D0_1	Pin 32	C7S6:32/C7S06--:32	DO	24VDC Sourcing	ACTIVE	JB-601	Spray Dryer 1st Floor	C7S06-	-	PCY-60205		-

C7 SLOT 07 — 1756 I/O (DO) Rack: MCC Fieldbus & Network Interface (Chassis 7) Location: Motor Control Center Room (MCC Panel & Field Bus) Protocol: Modbus TCP / EtherNet Trunk Capacity: 24 Pts Active: 0 Spare: 24 (100.0%)																
SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)							SIGNAL SPEC			DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C7-S07-P08	8	9		Spare_DO_0	Pin 9	C7S7:9/C7S07-:9	DO	24VDC Sourcing	SPARE	MCC	MCC Room	C7S07-	-	Spare	Spare Channel	-
C7-S07-P09	9	10		Spare_DO_0	Pin 10	C7S7:10/C7S07-:10	DO	24VDC Sourcing	SPARE	MCC	MCC Room	C7S07-	-	Spare	Spare Channel	-
C7-S07-P10	10	11		Spare_DO_0	Pin 11	C7S7:11/C7S07-:11	DO	24VDC Sourcing	SPARE	MCC	MCC Room	C7S07-	-	Spare	Spare Channel	-
C7-S07-P11	11	12		Spare_DO_0	Pin 12	C7S7:12/C7S07-:12	DO	24VDC Sourcing	SPARE	MCC	MCC Room	C7S07-	-	Spare	Spare Channel	-
C7-S07-P12	12	13		Spare_DO_0	Pin 13	C7S7:13/C7S07-:13	DO	24VDC Sourcing	SPARE	MCC	MCC Room	C7S07-	-	Spare	Spare Channel	-
C7-S07-P13	13	14		Spare_DO_0	Pin 14	C7S7:14/C7S07-:14	DO	24VDC Sourcing	SPARE	MCC	MCC Room	C7S07-	-	Spare	Spare Channel	-
C7-S07-P14	14	15		Spare_DO_0	Pin 15	C7S7:15/C7S07-:15	DO	24VDC Sourcing	SPARE	MCC	MCC Room	C7S07-	-	Spare	Spare Channel	-
C7-S07-P15	15	16		Spare_DO_0	Pin 16	C7S7:16/C7S07-:16	DO	24VDC Sourcing	SPARE	MCC	MCC Room	C7S07-	-	Spare	Spare Channel	-
C7-S07-P16	16	17		Spare_DO_0	Pin 17	C7S7:17/C7S07-:17	DO	24VDC Sourcing	SPARE	MCC	MCC Room	C7S07-	-	Spare	Spare Channel	-
C7-S07-P17	17	18		Spare_DO_0	Pin 18	C7S7:18/C7S07-:18	DO	24VDC Sourcing	SPARE	MCC	MCC Room	C7S07-	-	Spare	Spare Channel	-
C7-S07-P18	18	19		Spare_DO_0	Pin 19	C7S7:19/C7S07-:19	DO	24VDC Sourcing	SPARE	MCC	MCC Room	C7S07-	-	Spare	Spare Channel	-
C7-S07-P19	19	20		Spare_DO_0	Pin 20	C7S7:20/C7S07-:20	DO	24VDC Sourcing	SPARE	MCC	MCC Room	C7S07-	-	Spare	Spare Channel	-
C7-S07-P20	20	21		Spare_DO_0	Pin 21	C7S7:21/C7S07-:21	DO	24VDC Sourcing	SPARE	MCC	MCC Room	C7S07-	-	Spare	Spare Channel	-
C7-S07-P21	21	22		Spare_DO_0	Pin 22	C7S7:22/C7S07-:22	DO	24VDC Sourcing	SPARE	MCC	MCC Room	C7S07-	-	Spare	Spare Channel	-
C7-S07-P22	22	23		Spare_DO_0	Pin 23	C7S7:23/C7S07-:23	DO	24VDC Sourcing	SPARE	MCC	MCC Room	C7S07-	-	Spare	Spare Channel	-
C7-S07-P23	23	24		Spare_DO_0	Pin 24	C7S7:24/C7S07-:24	DO	24VDC Sourcing	SPARE	MCC	MCC Room	C7S07-	-	Spare	Spare Channel	-

SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)							SIGNAL SPEC			DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C7-S07-P24	24	25		Spare_D0_0	Pin 25	C7S7:25/C7S07-:25	DO	24VDC Sourcing	SPARE	MCC	MCC Room	C7S07-	-	Spare	Spare Channel	-
C7-S07-P25	25	26		Spare_D0_0	Pin 26	C7S7:26/C7S07-:26	DO	24VDC Sourcing	SPARE	MCC	MCC Room	C7S07-	-	Spare	Spare Channel	-
C7-S07-P26	26	27		Spare_D0_0	Pin 27	C7S7:27/C7S07-:27	DO	24VDC Sourcing	SPARE	MCC	MCC Room	C7S07-	-	Spare	Spare Channel	-
C7-S07-P27	27	28		Spare_D0_0	Pin 28	C7S7:28/C7S07-:28	DO	24VDC Sourcing	SPARE	MCC	MCC Room	C7S07-	-	Spare	Spare Channel	-
C7-S07-P28	28	29		Spare_D0_0	Pin 29	C7S7:29/C7S07-:29	DO	24VDC Sourcing	SPARE	MCC	MCC Room	C7S07-	-	Spare	Spare Channel	-
C7-S07-P29	29	30		Spare_D0_0	Pin 30	C7S7:30/C7S07-:30	DO	24VDC Sourcing	SPARE	MCC	MCC Room	C7S07-	-	Spare	Spare Channel	-
C7-S07-P30	30	31		Spare_D0_0	Pin 31	C7S7:31/C7S07-:31	DO	24VDC Sourcing	SPARE	MCC	MCC Room	C7S07-	-	Spare	Spare Channel	-
C7-S07-P31	31	32		Spare_D0_0	Pin 32	C7S7:32/C7S07-:32	DO	24VDC Sourcing	SPARE	MCC	MCC Room	C7S07-	-	Spare	Spare Channel	-