

PROJECT JET COOKER

INSTRUMENT I/O LIST - JUNCTION BOX MASTER REPORT

Document Number:	Instrument I/O List (Kalasin Rev. 3.6)
Engineering Contractor:	AEC Industrial Engineering Co., Ltd.
Total Enclosures Covered:	16 Enclosures (14 Field JBs, CA1 Cabinet, MCC)
Total Configured I/O Points:	1210 Points (763 Active, 447 Spares - 36.9%)
Report Issue Date:	2026-09-07

This document compiles the detailed signal wiring schedule and terminal assignments for all junction boxes.

JUNCTION BOX & ENCLOSURE EXECUTIVE SUMMARY SCHEDULE

No.	Enclosure Tag	Type / Classification	Location	Dimension (mm)	Total	Active	Spare	DI	DO	AI	AO	BUS
1	CA1	Main Control Cabinet (PLC CA1)	Main Control Cabinet	1600-2000-800	32	0	32	16	16	0	0	0
2	IS-JB-603	Intrinsically Safe Junction Box (Ex i / LS)	Spray Dryer 3rd Floor	300-200-150	32	22	10	16	0	16	0	0
3	IS-JB-608	Intrinsically Safe Junction Box (Ex i / LS)	Spray Dryer 8th Floor	300-200-150	32	14	18	16	8	8	0	0
4	IS-JB-612	Intrinsically Safe Junction Box (Ex i / LS)	Packing Tower 2th Floor	300-200-150	41	17	24	31	0	10	0	0
5	IS-JB-618	Intrinsically Safe Junction Box (Ex i / LS)	Packing Tower 8th Floor	450-300-150	44	22	22	32	0	12	0	0
6	JB-401	Field Junction Box (Standard)	Infeed 2nd Floor	800-600-250	112	85	27	64	32	16	0	0
7	JB-402	Field Junction Box (Standard)	Jet Cooker 2nd Floor	450-300-150	65	41	24	32	16	16	1	0
8	JB-601	Field Junction Box (Standard)	Spray Dryer 1st Floor	500-400-200	85	58	27	51	17	16	0	1
9	JB-602	Field Junction Box (Standard)	Spray Dryer 3rd Floor	800-600-250	82	57	25	32	16	32	2	0
10	JB-606	Field Junction Box (Standard)	Spray Dryer 6th Floor	300-200-150	26	7	19	16	8	2	0	0
11	JB-607	Field Junction Box (Standard)	Spray Dryer 7th Floor	800-600-250	195	151	44	93	64	32	5	1
12	JB-608	Field Junction Box (Standard)	Spray Dryer 8th Floor	300-200-150	6	1	5	0	0	6	0	0
13	JB-612	Field Junction Box (Standard)	Packing Tower 2th Floor	450-300-150	57	37	20	32	16	8	0	1
14	JB-618	Field Junction Box (Standard)	Packing Tower 8th Floor	450-300-150	52	25	27	16	32	4	0	0
15	MCC	Motor Control Center Enclosure (MCC)	MCC Room	Draw-out Switchgear Pa	237	169	68	125	95	0	0	17
16	RIO-200	Remote I/O Enclosure (RIO Panel)	Slurry - Out Building 2nd Floor	800-1000-400	112	57	55	64	32	16	0	0
TOTAL (ALL ENCLOSURES)					1210	763	447	636	352	194	8	20

ENCLOSURE: CA1 | TYPE: Main Control Cabinet (PLC CA1) | LOCATION: Main Control Cabinet | SIZE: 1600-2000-800 mm

SUMMARY: Total Channels: 32 | Active: 0 | Spare: 32 (100.0%) | DI: 16 | DO: 16 | AI: 0 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
1	C1S03-X1	C1/S3	C1S03,00	1756-IB32-0	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Main Control Cab...
2	C1S03-X1	C1/S3	C1S03,01	1756-IB32-1	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Main Control Cab...
3	C1S03-X1	C1/S3	C1S03,02	1756-IB32-2	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Main Control Cab...
4	C1S03-X1	C1/S3	C1S03,03	1756-IB32-3	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Main Control Cab...
5	C1S03-X1	C1/S3	C1S03,04	1756-IB32-4	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Main Control Cab...
6	C1S03-X1	C1/S3	C1S03,05	1756-IB32-5	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Main Control Cab...
7	C1S03-X1	C1/S3	C1S03,06	1756-IB32-6	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Main Control Cab...
8	C1S03-X1	C1/S3	C1S03,07	1756-IB32-7	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Main Control Cab...
9	C1S03-X1	C1/S3	C1S03,08	1756-IB32-8	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Main Control Cab...
10	C1S03-X1	C1/S3	C1S03,09	1756-IB32-9	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Main Control Cab...
11	C1S03-X1	C1/S3	C1S03,10	1756-IB32-10	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Main Control Cab...
12	C1S03-X1	C1/S3	C1S03,11	1756-IB32-11	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Main Control Cab...
13	C1S03-X1	C1/S3	C1S03,12	1756-IB32-12	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Main Control Cab...
14	C1S03-X1	C1/S3	C1S03,13	1756-IB32-13	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Main Control Cab...
15	C1S03-X1	C1/S3	C1S03,14	1756-IB32-14	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Main Control Cab...
16	C1S03-X1	C1/S3	C1S03,15	1756-IB32-15	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Main Control Cab...
17	C1S07-X1	C1/S7	C1S07,00	1756-OB32-0	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
18	C1S07-X1	C1/S7	C1S07,01	1756-OB32-1	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
19	C1S07-X1	C1/S7	C1S07,02	1756-OB32-2	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
20	C1S07-X1	C1/S7	C1S07,03	1756-OB32-3	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
21	C1S07-X1	C1/S7	C1S07,04	1756-OB32-4	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
22	C1S07-X1	C1/S7	C1S07,05	1756-OB32-5	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
23	C1S07-X1	C1/S7	C1S07,06	1756-OB32-6	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
24	C1S07-X1	C1/S7	C1S07,07	1756-OB32-7	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
25	C1S07-X1	C1/S7	C1S07,08	1756-OB32-8	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
26	C1S07-X1	C1/S7	C1S07,09	1756-OB32-9	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
27	C1S07-X1	C1/S7	C1S07,10	1756-OB32-10	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
28	C1S07-X1	C1/S7	C1S07,11	1756-OB32-11	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
29	C1S07-X1	C1/S7	C1S07,12	1756-OB32-12	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
30	C1S07-X1	C1/S7	C1S07,13	1756-OB32-13	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
31	C1S07-X1	C1/S7	C1S07,14	1756-OB32-14	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-

ENCLOSURE: CA1 | TYPE: Main Control Cabinet (PLC CA1) | LOCATION: Main Control Cabinet | SIZE: 1600-2000-800 mm

SUMMARY: Total Channels: 32 | Active: 0 | Spare: 32 (100.0%) | DI: 16 | DO: 16 | AI: 0 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
32	C1S07-X1	C1/S7	C1S07,15	1756-OB32-15	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-

ENCLOSURE: IS-JB-603 | TYPE: Intrinsically Safe Junction Box (Ex i / LS) | LOCATION: Spray Dryer 3rd Floor | SIZE: 300-200-150 mm

SUMMARY: Total Channels: 32 | Active: 22 | Spare: 10 (31.2%) | DI: 16 | DO: 0 | AI: 16 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
1	C3S01-X1	C3/S1	C3S01,00	1756-IB32-0	DI	-	AT-40201	AT-40201_DI_1	-	-	Spray Dryer / 3rd
2	C3S01-X1	C3/S1	C3S01,01	1756-IB32-1	DI	-	AT-40202	AT-40202_DI_1	-	-	Spray Dryer / 3rd
3	C3S01-X1	C3/S1	C3S01,02	1756-IB32-2	DI	-	AT-40203	AT-40203_DI_1	-	-	Spray Dryer / 3rd
4	C3S01-X1	C3/S1	C3S01,03	1756-IB32-3	DI	Dry Contact	LSH-60230	LSH-60230_DI_1	3-25-01-602-PD-04	0	Spray Dryer / 1st
5	C3S01-X1	C3/S1	C3S01,04	1756-IB32-4	DI	Dry Contact	LSH-60231	LSH-60231_DI_1	3-25-01-602-PD-04	0	Spray Dryer / 1st
6	C3S01-X1	C3/S1	C3S01,05	1756-IB32-5	DI	Dry Contact	LSH-60240	LSH-60240_DI_1	3-25-01-602-PD-05	0	Spray Dryer / 1st
7	C3S01-X1	C3/S1	C3S01,06	1756-IB32-6	DI	-	PD-60202	PD-60202_DI_1	-	-	Spray Dryer / 3rd
8	C3S04-X1	C3/S4	C3S04,00	1756-IF16-0	AI	4 - 20 mA	PT-60230	PT-60230_AI_1	3-25-01-602-PD-04	Pressure Transmitter	Spray Dryer / 4th
9	C3S04-X1	C3/S4	C3S04,01	1756-IF16-1	AI	4 - 20 mA	PT-60231	PT-60231_AI_1	3-25-01-602-PD-04	Pressure Transmitter	Spray Dryer / 4th
10	C3S01-X1	C3/S1	C3S01,07	1756-IB32-7	DI	-	RV-60204	RV-60204_DI_1	-	-	Spray Dryer / 3rd
11	C3S01-X1	C3/S1	C3S01,15	1756-IB32-15	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
12	C3S04-X1	C3/S4	C3S04,07	1756-IF16-7	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
13	C3S04-X1	C3/S4	C3S04,08	1756-IF16-8	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
14	C3S04-X1	C3/S4	C3S04,09	1756-IF16-9	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
15	C3S04-X1	C3/S4	C3S04,10	1756-IF16-10	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
16	C3S04-X1	C3/S4	C3S04,11	1756-IF16-11	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
17	C3S04-X1	C3/S4	C3S04,12	1756-IF16-12	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
18	C3S04-X1	C3/S4	C3S04,13	1756-IF16-13	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
19	C3S04-X1	C3/S4	C3S04,14	1756-IF16-14	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
20	C3S04-X1	C3/S4	C3S04,15	1756-IF16-15	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
21	C3S04-X1	C3/S4	C3S04,02	1756-IF16-2	AI	4 - 20 mA	TT-60224	TT-60224_AI_1	3-25-01-602-PD-04	0	Spray Dryer / 4th
22	C3S04-X1	C3/S4	C3S04,03	1756-IF16-3	AI	4 - 20 mA	TT-60225	TT-60225_AI_1	3-25-01-602-PD-04	0	Spray Dryer / 3rd
23	C3S04-X1	C3/S4	C3S04,04	1756-IF16-4	AI	4 - 20 mA	TT-60226	TT-60226_AI_1	3-25-01-602-PD-04	0	Spray Dryer / 2nd
24	C3S04-X1	C3/S4	C3S04,05	1756-IF16-5	AI	4 - 20 mA	TT-60227	TT-60227_AI_1	3-25-01-602-PD-04	0	Spray Dryer / 1st
25	C3S04-X1	C3/S4	C3S04,06	1756-IF16-6	AI	4 - 20 mA	TT-60230	TT-60230_AI_1	3-25-01-602-PD-04	0	Spray Dryer / 3rd
26	C3S01-X1	C3/S1	C3S01,08	1756-IB32-8	DI	Dry Contact	ZS-60201C	ZS-60201C_DI_1	3-25-01-602-PD-04	0	Spray Dryer / 4th
27	C3S01-X1	C3/S1	C3S01,09	1756-IB32-9	DI	Dry Contact	ZS-60201D	ZS-60201D_DI_1	3-25-01-602-PD-04	0	Spray Dryer / 4th
28	C3S01-X1	C3/S1	C3S01,10	1756-IB32-10	DI	Dry Contact	ZS-60201E	ZS-60201E_DI_1	3-25-01-602-PD-04	0	Spray Dryer / 1st
29	C3S01-X1	C3/S1	C3S01,11	1756-IB32-11	DI	Dry Contact	ZS-60229	ZS-60229_DI_1	3-25-01-602-PD-04	0	Spray Dryer / 4th
30	C3S01-X1	C3/S1	C3S01,12	1756-IB32-12	DI	Dry Contact	ZS-60230	ZS-60230_DI_1	3-25-01-602-PD-04	0	Spray Dryer / 4th
31	C3S01-X1	C3/S1	C3S01,13	1756-IB32-13	DI	Dry Contact	ZS-60231A	ZS-60231A_DI_1	3-25-01-602-PD-05	0	Spray Dryer / 4th

ENCLOSURE: IS-JB-603 | TYPE: Intrinsically Safe Junction Box (Ex i / LS) | LOCATION: Spray Dryer 3rd Floor | SIZE: 300-200-150 mm

SUMMARY: Total Channels: 32 | Active: 22 | Spare: 10 (31.2%) | DI: 16 | DO: 0 | AI: 16 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
32	C3S01-X1	C3/S1	C3S01,14	1756-IB32-14	DI	Dry Contact	ZS-60231B	ZS-60231B_DI_1	3-25-01-602-PD-05	0	Spray Dryer / 4th

ENCLOSURE: IS-JB-608 | TYPE: Intrinsically Safe Junction Box (Ex i / LS) | LOCATION: Spray Dryer 8th Floor | SIZE: 300-200-150 mm

SUMMARY: Total Channels: 32 | Active: 14 | Spare: 18 (56.2%) | DI: 16 | DO: 8 | AI: 8 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
1	C4S06-X1	C4/S6	C4S06,00	1756-IF16-0	AI	4 - 20 mA	PT-60220	PT-60220_AI_1	3-25-01-602-PD-04	Pressure Transmitter	Spray Dryer / 6th
2	C4S01-X2	C4/S1	C4S01,23	1756-IB32-23	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
3	C4S01-X2	C4/S1	C4S01,24	1756-IB32-24	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
4	C4S01-X2	C4/S1	C4S01,25	1756-IB32-25	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
5	C4S01-X2	C4/S1	C4S01,26	1756-IB32-26	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
6	C4S01-X2	C4/S1	C4S01,27	1756-IB32-27	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
7	C4S01-X2	C4/S1	C4S01,28	1756-IB32-28	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
8	C4S01-X2	C4/S1	C4S01,29	1756-IB32-29	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
9	C4S01-X2	C4/S1	C4S01,30	1756-IB32-30	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
10	C4S01-X2	C4/S1	C4S01,31	1756-IB32-31	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
11	C4S04-X1	C4/S4	C4S04,09	1756-OB32-9	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
12	C4S04-X1	C4/S4	C4S04,10	1756-OB32-10	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
13	C4S04-X1	C4/S4	C4S04,11	1756-OB32-11	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
14	C4S04-X1	C4/S4	C4S04,12	1756-OB32-12	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
15	C4S04-X1	C4/S4	C4S04,13	1756-OB32-13	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
16	C4S04-X1	C4/S4	C4S04,14	1756-OB32-14	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
17	C4S04-X1	C4/S4	C4S04,15	1756-OB32-15	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
18	C4S05-X1	C4/S5	C4S05,06	1756-IF16-6	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
19	C4S05-X1	C4/S5	C4S05,07	1756-IF16-7	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
20	C4S06-X1	C4/S6	C4S06,01	1756-IF16-1	AI	4 - 20 mA	TT-60220	TT-60220_AI_1	3-25-01-602-PD-04	0	Spray Dryer / 6th
21	C4S06-X1	C4/S6	C4S06,02	1756-IF16-2	AI	4 - 20 mA	TT-60221	TT-60221_AI_1	3-25-01-602-PD-04	0	Spray Dryer / 6th
22	C4S06-X1	C4/S6	C4S06,03	1756-IF16-3	AI	4 - 20 mA	TT-60222	TT-60222_AI_1	3-25-01-602-PD-04	0	Spray Dryer / 5th
23	C4S06-X1	C4/S6	C4S06,04	1756-IF16-4	AI	4 - 20 mA	TT-60223	TT-60223_AI_1	3-25-01-602-PD-04	0	Spray Dryer / 5th
24	C4S04-X1	C4/S4	C4S04,08	1756-OB32-8	DO	4 - 20 mA	XA-60201	XA-60201_DO_1	3-25-01-602-PD-03	0	Spray Dryer / 5th
25	C4S06-X1	C4/S6	C4S06,05	1756-IF16-5	AI	4 - 20 mA	XT-60201	XT-60201_AI_1	3-25-01-602-PD-03	0	Spray Dryer / 5th
26	C4S01-X2	C4/S1	C4S01,16	1756-IB32-16	DI	Dry Contact	ZS-60201A	ZS-60201A_DI_1	3-25-01-602-PD-04	0	Spray Dryer / 6th
27	C4S01-X2	C4/S1	C4S01,17	1756-IB32-17	DI	Dry Contact	ZS-60201B	ZS-60201B_DI_1	3-25-01-602-PD-04	0	Spray Dryer / 6th
28	C4S01-X2	C4/S1	C4S01,18	1756-IB32-18	DI	Dry Contact	ZS-60231C	ZS-60231C_DI_1	3-25-01-602-PD-04	0	Spray Dryer / 5th
29	C4S01-X2	C4/S1	C4S01,19	1756-IB32-19	DI	Dry Contact	ZS-60231D	ZS-60231D_DI_1	3-25-01-602-PD-04	0	Spray Dryer / 5th
30	C4S01-X2	C4/S1	C4S01,20	1756-IB32-20	DI	Dry Contact	ZS-60231E	ZS-60231E_DI_1	3-25-01-602-PD-05	0	Spray Dryer / 5th
31	C4S01-X2	C4/S1	C4S01,21	1756-IB32-21	DI	Dry Contact	ZS-60231F	ZS-60231F_DI_1	3-25-01-602-PD-05	0	Spray Dryer / 5th

ENCLOSURE: IS-JB-608 | TYPE: Intrinsically Safe Junction Box (Ex i / LS) | LOCATION: Spray Dryer 8th Floor | SIZE: 300-200-150 mm

SUMMARY: Total Channels: 32 | Active: 14 | Spare: 18 (56.2%) | DI: 16 | DO: 8 | AI: 8 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
32	C4S01-X2	C4/S1	C4S01,22	1756-IB32-22	DI	Dry Contact	ZS-60240	ZS-60240_DI_1	3-25-01-602-PD-05	0	Spray Dryer / 6th

ENCLOSURE: IS-JB-612 | TYPE: Intrinsically Safe Junction Box (Ex i / LS) | LOCATION: Packing Tower 2th Floor | SIZE: 300-200-150 mm

SUMMARY: Total Channels: 41 | Active: 17 | Spare: 24 (58.5%) | DI: 31 | DO: 0 | AI: 10 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
1	C4S06-X1	C4/S6	C4S06,06	1756-IF16-6	AI	4 - 20 mA	DPT-61310	DPT-61310_AI_1	3-25-01-613-PD-03	Differential Pressure Transmitter	Packing Tower / ...
2	C4S06-X1	C4/S6	C4S06,07	1756-IF16-7	AI	-	DPT-61312	DPT-61312_AI_1	3-25-01-613-PD-05	-	Packing Tower / ...
3	C4S03-X1	C4/S3	C4S03,00	1756-IB32-0	DI	Dry Contact	ISV-61303	ISV-61303_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
4	C4S03-X1	C4/S3	C4S03,01	1756-IB32-1	DI	Dry Contact	ISV-61304	ISV-61304_DI_1	3-25-01-613-PD-05	0	Packing Tower / ...
5	C4S03-X1	C4/S3	C4S03,02	1756-IB32-2	DI	Dry Contact	LSH-61304	LSH-61304_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
6	C4S03-X1	C4/S3	C4S03,03	1756-IB32-3	DI	Dry Contact	LSH-61305	LSH-61305_DI_1	3-25-01-613-PD-05	0	Packing Tower / ...
7	C4S03-X1	C4/S3	C4S03,04	1756-IB32-4	DI	Dry Contact	LSH-61307	LSH-61307_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...
8	C4S03-X1	C4/S3	C4S03,05	1756-IB32-5	DI	Dry Contact	LSH-61312	LSH-61312_DI_1	3-25-01-613-PD-05	0	Packing Tower / ...
9	C4S03-X1	C4/S3	C4S03,06	1756-IB32-6	DI	Dry Contact	PSE-61302	PSE-61302_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
10	C4S03-X1	C4/S3	C4S03,07	1756-IB32-7	DI	Dry Contact	PSE-61303	PSE-61303_DI_1	3-25-01-613-PD-05	0	Packing Tower / ...
11	C4S03-X1	C4/S3	C4S03,09	1756-IB32-9	DI	-	RV-61301	RV-61301_DI_1	-	-	Packing Tower / ...
12	C4S03-X1	C4/S3	C4S03,10	1756-IB32-10	DI	-	RV-61304	RV-61304_DI_1	-	-	Packing Tower / ...
13	C4S03-X1	C4/S3	C4S03,11	1756-IB32-11	DI	-	RV-61305	RV-61305_DI_1	-	-	Packing Tower / ...
14	C4S03-X1	C4/S3	C4S03,12	1756-IB32-12	DI	-	SC-61301	SC-61301_DI_1	-	-	Packing Tower / ...
15	C4S03-X1	C4/S3	C4S03,13	1756-IB32-13	DI	-	SC-61302	SC-61302_DI_1	-	-	Packing Tower / ...
16	C4S03-X2	C4/S3	C4S03,16	1756-IB32-16	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
17	C4S03-X2	C4/S3	C4S03,17	1756-IB32-17	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
18	C4S03-X2	C4/S3	C4S03,18	1756-IB32-18	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
19	C4S03-X2	C4/S3	C4S03,19	1756-IB32-19	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
20	C4S03-X2	C4/S3	C4S03,20	1756-IB32-20	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
21	C4S03-X2	C4/S3	C4S03,21	1756-IB32-21	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
22	C4S03-X2	C4/S3	C4S03,22	1756-IB32-22	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
23	C4S03-X2	C4/S3	C4S03,23	1756-IB32-23	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
24	C4S03-X2	C4/S3	C4S03,24	1756-IB32-24	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
25	C4S03-X2	C4/S3	C4S03,25	1756-IB32-25	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
26	C4S03-X2	C4/S3	C4S03,26	1756-IB32-26	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
27	C4S03-X2	C4/S3	C4S03,27	1756-IB32-27	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
28	C4S03-X2	C4/S3	C4S03,28	1756-IB32-28	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
29	C4S03-X2	C4/S3	C4S03,29	1756-IB32-29	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
30	C4S03-X2	C4/S3	C4S03,30	1756-IB32-30	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
31	C4S03-X2	C4/S3	C4S03,31	1756-IB32-31	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-

ENCLOSURE: IS-JB-612 | TYPE: Intrinsically Safe Junction Box (Ex i / LS) | LOCATION: Packing Tower 2th Floor | SIZE: 300-200-150 mm

SUMMARY: Total Channels: 41 | Active: 17 | Spare: 24 (58.5%) | DI: 31 | DO: 0 | AI: 10 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
32	C4S05-X1	C4/S5	C4S05,14	1756-IF16-14	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
33	C4S05-X1	C4/S5	C4S05,14	1756-IF16-14	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
34	C4S05-X1	C4/S5	C4S05,14	1756-IF16-14	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
35	C4S05-X1	C4/S5	C4S05,14	1756-IF16-14	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
36	C4S05-X1	C4/S5	C4S05,14	1756-IF16-14	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
37	C4S05-X1	C4/S5	C4S05,14	1756-IF16-14	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
38	C4S05-X1	C4/S5	C4S05,14	1756-IF16-14	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
39	C4S05-X1	C4/S5	C4S05,14	1756-IF16-14	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
40	C4S03-X1	C4/S3	C4S03,14	1756-IB32-14	DI	Dry Contact	ZS-61312	ZS-61312_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...
41	C4S03-X1	C4/S3	C4S03,15	1756-IB32-15	DI	Dry Contact	ZS-61313	ZS-61313_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...

ENCLOSURE: IS-JB-618 | TYPE: Intrinsically Safe Junction Box (Ex i / LS) | LOCATION: Packing Tower 8th Floor | SIZE: 450-300-150 mm

SUMMARY: Total Channels: 44 | Active: 22 | Spare: 22 (50.0%) | DI: 32 | DO: 0 | AI: 12 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
1	C3S05-X1	C3/S5	C3S05,04	1756-IF16-4	AI	4 - 20 mA	DPT-61301	DPT-61301_AI_1	3-25-01-613-PD-01	Differential Pressure Transmitter	Packing Tower / ...
2	C3S05-X1	C3/S5	C3S05,05	1756-IF16-5	AI	4 - 20 mA	DPT-61302	DPT-61302_AI_1	3-25-01-613-PD-01	Differential Pressure Transmitter	Packing Tower / ...
3	C3S02-X1	C3/S2	C3S02,00	1756-IB32-0	DI	-	ISV-61301	ISV-61301_DI_1	3-25-01-613-PD-01	-	Packing Tower / ...
4	C3S02-X1	C3/S2	C3S02,01	1756-IB32-1	DI	Dry Contact	LSH-61301	LSH-61301_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...
5	C3S02-X1	C3/S2	C3S02,02	1756-IB32-2	DI	-	LSH-61303	LSH-61303_DI_1	325-01-613-PD-01	-	Packing Tower / ...
6	C3S02-X1	C3/S2	C3S02,03	1756-IB32-3	DI	Dry Contact	LSH-61306	LSH-61306_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...
7	C3S02-X1	C3/S2	C3S02,04	1756-IB32-4	DI	Dry Contact	LSH-61308	LSH-61308_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...
8	C3S02-X1	C3/S2	C3S02,05	1756-IB32-5	DI	Dry Contact	LSL-61302	LSL-61302_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...
9	C3S05-X1	C3/S5	C3S05,06	1756-IF16-6	AI	4 - 20 mA	LT-61301	LT-61301_AI_1	3-25-01-613-PD-01	Level Transmitter	Packing Tower / ...
10	C3S02-X1	C3/S2	C3S02,06	1756-IB32-6	DI	Dry Contact	PSE-61300	PSE-61300_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...
11	C3S02-X1	C3/S2	C3S02,07	1756-IB32-7	DI	Dry Contact	PSE-61301	PSE-61301_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...
12	C3S02-X1	C3/S2	C3S02,08	1756-IB32-8	DI	Dry Contact	PSE-61304	PSE-61304_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...
13	C3S02-X1	C3/S2	C3S02,09	1756-IB32-9	DI	-	PSV-61301A	PSV-61301A_DI_1	325-01-613-PD-01	-	Packing Tower / ...
14	C3S02-X1	C3/S2	C3S02,10	1756-IB32-10	DI	-	PSV-61301B	PSV-61301B_DI_1	325-01-613-PD-01	-	Packing Tower / ...
15	C3S05-X1	C3/S5	C3S05,07	1756-IF16-7	AI	4 - 20 mA	PT-61301	PT-61301_AI_1	3-25-01-613-PD-01	Pressure Transmitter	Packing Tower / ...
16	C3S05-X1	C3/S5	C3S05,08	1756-IF16-8	AI	4 - 20 mA	PT-61303	PT-61303_AI_1	3-25-01-613-PD-01	Pressure Transmitter	Packing Tower / ...
17	C3S05-X1	C3/S5	C3S05,09	1756-IF16-9	AI	4 - 20 mA	PT-61304	PT-61304_AI_1	3-25-01-613-PD-01	Pressure Transmitter	Packing Tower / ...
18	C3S05-X1	C3/S5	C3S05,10	1756-IF16-10	AI	4 - 20 mA	PT-61305	PT-61305_AI_1	3-25-01-613-PD-01	Pressure Transmitter	Packing Tower / ...
19	C3S02-X1	C3/S2	C3S02,13	1756-IB32-13	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
20	C3S02-X1	C3/S2	C3S02,14	1756-IB32-14	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
21	C3S02-X1	C3/S2	C3S02,15	1756-IB32-15	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
22	C3S02-X2	C3/S2	C3S02,16	1756-IB32-16	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
23	C3S02-X2	C3/S2	C3S02,17	1756-IB32-17	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
24	C3S02-X2	C3/S2	C3S02,18	1756-IB32-18	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
25	C3S02-X2	C3/S2	C3S02,19	1756-IB32-19	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
26	C3S02-X2	C3/S2	C3S02,20	1756-IB32-20	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
27	C3S02-X2	C3/S2	C3S02,21	1756-IB32-21	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
28	C3S02-X2	C3/S2	C3S02,22	1756-IB32-22	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
29	C3S02-X2	C3/S2	C3S02,23	1756-IB32-23	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
30	C3S02-X2	C3/S2	C3S02,24	1756-IB32-24	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
31	C3S02-X2	C3/S2	C3S02,25	1756-IB32-25	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...

ENCLOSURE: IS-JB-618 | TYPE: Intrinsically Safe Junction Box (Ex i / LS) | LOCATION: Packing Tower 8th Floor | SIZE: 450-300-150 mm

SUMMARY: Total Channels: 44 | Active: 22 | Spare: 22 (50.0%) | DI: 32 | DO: 0 | AI: 12 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
32	C3S02-X2	C3/S2	C3S02,26	1756-IB32-26	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
33	C3S02-X2	C3/S2	C3S02,27	1756-IB32-27	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
34	C3S02-X2	C3/S2	C3S02,28	1756-IB32-28	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
35	C3S02-X2	C3/S2	C3S02,29	1756-IB32-29	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
36	C3S02-X2	C3/S2	C3S02,30	1756-IB32-30	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
37	C3S02-X2	C3/S2	C3S02,31	1756-IB32-31	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
38	C3S05-X1	C3/S5	C3S05,13	1756-IF16-13	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
39	C3S05-X1	C3/S5	C3S05,14	1756-IF16-14	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
40	C3S05-X1	C3/S5	C3S05,15	1756-IF16-15	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
41	C3S05-X1	C3/S5	C3S05,11	1756-IF16-11	AI	4 - 20 mA	TT-61301	TT-61301_AI_1	3-25-01-613-PD-01	0	Packing Tower / ...
42	C3S05-X1	C3/S5	C3S05,12	1756-IF16-12	AI	4 - 20 mA	TT-61302	TT-61302_AI_1	3-25-01-613-PD-01	0	Packing Tower / ...
43	C3S02-X1	C3/S2	C3S02,11	1756-IB32-11	DI	Dry Contact	ZS-61310	ZS-61310_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...
44	C3S02-X1	C3/S2	C3S02,12	1756-IB32-12	DI	Dry Contact	ZS-61311	ZS-61311_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...

ENCLOSURE: JB-401 | TYPE: Field Junction Box (Standard) | LOCATION: Infeed 2nd Floor | SIZE: 800-600-250 mm

SUMMARY: Total Channels: 112 | Active: 85 | Spare: 27 (24.1%) | DI: 64 | DO: 32 | AI: 16 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
1	C1S03-X2	C1/S3	C1S03,16	1756-IB32-16	DI	Dry Contact	FSL-40201	FSL-40201_DI_1	3-25-01-402-PD-01	Flow Switch	PH Adjustment / ...
2	C1S03-X2	C1/S3	C1S03,17	1756-IB32-17	DI	Dry Contact	FSL-40202	FSL-40202_DI_1	3-25-01-402-PD-01	Flow Switch	PH Adjustment / ...
3	C1S09-X1	C1/S9	C1S09,00	1756-IF16-0	AI	4 - 20 mA,Pulse	FT-40201	FT-40201_AI_1	3-25-01-402-PD-02	Coriolis Flow Transmitter	Infeed Tank / 1st
4	C1S09-X1	C1/S9	C1S09,01	1756-IF16-1	AI	4 - 20 mA,Pulse	FT-40201	FT-40201_AI_2	3-25-01-402-PD-02	Coriolis Flow Transmitter	Infeed Tank / 1st
5	C1S03-X2	C1/S3	C1S03,18	1756-IB32-18	DI	4 - 20 mA,Pulse	FT-40201	FT-40201_DI_1	3-25-01-402-PD-02	Coriolis Flow Transmitter	Infeed Tank / 1st
6	C1S09-X1	C1/S9	C1S09,02	1756-IF16-2	AI	4 - 20 mA,Pulse	FT-40202	FT-40202_AI_1	3-25-01-402-PD-02	Magnetic Flow Transmitter	Infeed Tank / 1st
7	C1S03-X2	C1/S3	C1S03,19	1756-IB32-19	DI	4 - 20 mA,Pulse	FT-40202	FT-40202_DI_1	3-25-01-402-PD-02	Magnetic Flow Transmitter	Infeed Tank / 1st
8	C1S03-X2	C1/S3	C1S03,20	1756-IB32-20	DI	Dry Contact	HV-40201	HV-40201_DI_1	3-25-01-402-PD-01	Manual Valve With Position Switch	PH Adjustment / ...
9	C1S03-X2	C1/S3	C1S03,21	1756-IB32-21	DI	Dry Contact	HV-40202	HV-40202_DI_1	3-25-01-402-PD-01	Manual Valve With Position Switch	PH Adjustment / ...
10	C1S03-X2	C1/S3	C1S03,22	1756-IB32-22	DI	Dry Contact	HV-40203	HV-40203_DI_1	3-25-01-402-PD-01	Manual Valve With Position Switch	PH Adjustment / ...
11	C1S03-X2	C1/S3	C1S03,23	1756-IB32-23	DI	Dry Contact	HV-40204	HV-40204_DI_1	3-25-01-402-PD-01	Manual Valve With Position Switch	PH Adjustment / ...
12	C1S03-X2	C1/S3	C1S03,24	1756-IB32-24	DI	Dry Contact	HV-40205	HV-40205_DI_1	3-25-01-402-PD-02	Manual Valve With Position Switch	Infeed Tank / 1st
13	C1S03-X2	C1/S3	C1S03,25	1756-IB32-25	DI	Dry Contact	HV-40206	HV-40206_DI_1	3-25-01-402-PD-02	Manual Valve With Position Switch	Infeed Tank / 1st
14	C1S09-X1	C1/S9	C1S09,04	1756-IF16-4	AI	4 - 20 mA	LT-40201	LT-40201_AI_1	3-25-01-402-PD-01	Level Transmitter	PH Adjustment / ...
15	C1S09-X1	C1/S9	C1S09,05	1756-IF16-5	AI	4 - 20 mA	LT-40202	LT-40202_AI_1	3-25-01-402-PD-01	Level Transmitter	PH Adjustment / ...
16	C1S09-X1	C1/S9	C1S09,03	1756-IF16-3	AI	4 - 20 mA	LT-40203	LT-40203_AI_1	3-25-01-402-PD-02	Level Transmitter	Infeed Tank / 1st
17	C1S09-X1	C1/S9	C1S09,06	1756-IF16-6	AI	4 - 20 mA	pHT-40201	pHT-40201_AI_1	3-25-01-402-PD-01	PH Transmitter	PH Adjustment / ...
18	C1S09-X1	C1/S9	C1S09,07	1756-IF16-7	AI	4 - 20 mA	pHT-40202	pHT-40202_AI_1	3-25-01-402-PD-01	PH Transmitter	PH Adjustment / ...
19	C1S09-X1	C1/S9	C1S09,08	1756-IF16-8	AI	4 - 20 mA	PT-40201	PT-40201_AI_1	3-25-01-402-PD-02	Pressure Transmitter	Infeed Tank / 1st
20	C1S09-X1	C1/S9	C1S09,09	1756-IF16-9	AI	4 - 20 mA	PT-40202	PT-40202_AI_1	3-25-01-402-PD-02	Pressure Transmitter	Infeed Tank / 1st
21	C1S09-X1	C1/S9	C1S09,10	1756-IF16-10	AI	4 - 20 mA	PT-60202	PT-60202_AI_1	3-25-01-602-PD-01	Pressure Transmitter	Infeed Tank / 1st
22	C1S09-X1	C1/S9	C1S09,11	1756-IF16-11	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
23	C1S09-X1	C1/S9	C1S09,12	1756-IF16-12	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
24	C1S09-X1	C1/S9	C1S09,13	1756-IF16-13	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
25	C1S09-X1	C1/S9	C1S09,14	1756-IF16-14	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
26	C1S09-X1	C1/S9	C1S09,15	1756-IF16-15	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
27	C1S05-X1	C1/S5	C1S05,02	1756-IB32-2	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
28	C1S05-X1	C1/S5	C1S05,03	1756-IB32-3	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
29	C1S05-X1	C1/S5	C1S05,04	1756-IB32-4	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
30	C1S05-X1	C1/S5	C1S05,05	1756-IB32-5	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
31	C1S05-X1	C1/S5	C1S05,06	1756-IB32-6	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-

ENCLOSURE: JB-401 | TYPE: Field Junction Box (Standard) | LOCATION: Infeed 2nd Floor | SIZE: 800-600-250 mm

SUMMARY: Total Channels: 112 | Active: 85 | Spare: 27 (24.1%) | DI: 64 | DO: 32 | AI: 16 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
32	C1S05-X1	C1/S5	C1S05,07	1756-IB32-7	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
33	C1S05-X1	C1/S5	C1S05,08	1756-IB32-8	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
34	C1S05-X1	C1/S5	C1S05,09	1756-IB32-9	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
35	C1S05-X1	C1/S5	C1S05,10	1756-IB32-10	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
36	C1S05-X1	C1/S5	C1S05,11	1756-IB32-11	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
37	C1S05-X1	C1/S5	C1S05,12	1756-IB32-12	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
38	C1S05-X1	C1/S5	C1S05,13	1756-IB32-13	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
39	C1S05-X1	C1/S5	C1S05,14	1756-IB32-14	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
40	C1S05-X1	C1/S5	C1S05,15	1756-IB32-15	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
41	C1S08-X1	C1/S8	C1S08,08	1756-OB32-8	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
42	C1S08-X1	C1/S8	C1S08,09	1756-OB32-9	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
43	C1S08-X1	C1/S8	C1S08,10	1756-OB32-10	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
44	C1S08-X1	C1/S8	C1S08,11	1756-OB32-11	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
45	C1S08-X1	C1/S8	C1S08,12	1756-OB32-12	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
46	C1S08-X1	C1/S8	C1S08,13	1756-OB32-13	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
47	C1S08-X1	C1/S8	C1S08,14	1756-OB32-14	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
48	C1S08-X1	C1/S8	C1S08,15	1756-OB32-15	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
49	C1S07-X2	C1/S7	C1S07,24	1756-OB32-24	DO	24 VDC energized	SV-40201	SV-40201_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
50	C1S07-X2	C1/S7	C1S07,25	1756-OB32-25	DO	24 VDC energized	SV-40202	SV-40202_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
51	C1S07-X2	C1/S7	C1S07,26	1756-OB32-26	DO	24 VDC energized	SV-40203	SV-40203_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
52	C1S07-X2	C1/S7	C1S07,27	1756-OB32-27	DO	24 VDC energized	SV-40204	SV-40204_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
53	C1S03-X2	C1/S3	C1S03,26	1756-IB32-26	DI	24 VDC energized	XV-40201A	XV-40201A_DI_1	3-25-01-402-PD-01	0	PH Adjustment / ...
54	C1S03-X2	C1/S3	C1S03,27	1756-IB32-27	DI	24 VDC energized	XV-40201A	XV-40201A_DI_2	3-25-01-402-PD-01	0	PH Adjustment / ...
55	C1S07-X2	C1/S7	C1S07,28	1756-OB32-28	DO	24 VDC energized	XV-40201A	XV-40201A_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
56	C1S03-X2	C1/S3	C1S03,28	1756-IB32-28	DI	24 VDC energized	XV-40201B	XV-40201B_DI_1	3-25-01-402-PD-01	0	PH Adjustment / ...
57	C1S03-X2	C1/S3	C1S03,29	1756-IB32-29	DI	24 VDC energized	XV-40201B	XV-40201B_DI_2	3-25-01-402-PD-01	0	PH Adjustment / ...
58	C1S07-X2	C1/S7	C1S07,29	1756-OB32-29	DO	24 VDC energized	XV-40201B	XV-40201B_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
59	C1S03-X2	C1/S3	C1S03,30	1756-IB32-30	DI	24 VDC energized	XV-40201C	XV-40201C_DI_1	3-25-01-402-PD-01	0	PH Adjustment / ...
60	C1S03-X2	C1/S3	C1S03,31	1756-IB32-31	DI	24 VDC energized	XV-40201C	XV-40201C_DI_2	3-25-01-402-PD-01	0	PH Adjustment / ...
61	C1S07-X2	C1/S7	C1S07,30	1756-OB32-30	DO	24 VDC energized	XV-40201C	XV-40201C_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
62	C1S04-X1	C1/S4	C1S04,00	1756-IB32-0	DI	24 VDC energized	XV-40201D	XV-40201D_DI_1	3-25-01-402-PD-01	0	PH Adjustment / ...

ENCLOSURE: JB-401 | TYPE: Field Junction Box (Standard) | LOCATION: Infeed 2nd Floor | SIZE: 800-600-250 mm

SUMMARY: Total Channels: 112 | Active: 85 | Spare: 27 (24.1%) | DI: 64 | DO: 32 | AI: 16 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
63	C1S04-X1	C1/S4	C1S04,01	1756-IB32-1	DI	24 VDC energized	XV-40201D	XV-40201D_DI_2	3-25-01-402-PD-01	0	PH Adjustment / ...
64	C1S07-X2	C1/S7	C1S07,31	1756-OB32-31	DO	24 VDC energized	XV-40201D	XV-40201D_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
65	C1S04-X1	C1/S4	C1S04,02	1756-IB32-2	DI	24 VDC energized	XV-40201E	XV-40201E_DI_1	3-25-01-402-PD-01	0	PH Adjustment / ...
66	C1S04-X1	C1/S4	C1S04,03	1756-IB32-3	DI	24 VDC energized	XV-40201E	XV-40201E_DI_2	3-25-01-402-PD-01	0	PH Adjustment / ...
67	C1S08-X1	C1/S8	C1S08,00	1756-OB32-0	DO	24 VDC energized	XV-40201E	XV-40201E_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
68	C1S04-X1	C1/S4	C1S04,04	1756-IB32-4	DI	24 VDC energized	XV-40201F	XV-40201F_DI_1	3-25-01-402-PD-01	0	PH Adjustment / ...
69	C1S04-X1	C1/S4	C1S04,05	1756-IB32-5	DI	24 VDC energized	XV-40201F	XV-40201F_DI_2	3-25-01-402-PD-01	0	PH Adjustment / ...
70	C1S08-X1	C1/S8	C1S08,01	1756-OB32-1	DO	24 VDC energized	XV-40201F	XV-40201F_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
71	C1S04-X1	C1/S4	C1S04,06	1756-IB32-6	DI	24 VDC energized	XV-40201G	XV-40201G_DI_1	3-25-01-402-PD-01	0	PH Adjustment / ...
72	C1S04-X1	C1/S4	C1S04,07	1756-IB32-7	DI	24 VDC energized	XV-40201G	XV-40201G_DI_2	3-25-01-402-PD-01	0	PH Adjustment / ...
73	C1S08-X1	C1/S8	C1S08,02	1756-OB32-2	DO	24 VDC energized	XV-40201G	XV-40201G_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
74	C1S04-X1	C1/S4	C1S04,08	1756-IB32-8	DI	24 VDC energized	XV-40201H	XV-40201H_DI_1	3-25-01-402-PD-01	0	PH Adjustment / ...
75	C1S04-X1	C1/S4	C1S04,09	1756-IB32-9	DI	24 VDC energized	XV-40201H	XV-40201H_DI_2	3-25-01-402-PD-01	0	PH Adjustment / ...
76	C1S08-X1	C1/S8	C1S08,03	1756-OB32-3	DO	24 VDC energized	XV-40201H	XV-40201H_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
77	C1S04-X2	C1/S4	C1S04,19	1756-IB32-19	DI	24 VDC energized	XV-40202A	XV-40202A_DI_1	3-25-01-402-PD-01	0	PH Adjustment / ...
78	C1S04-X1	C1/S4	C1S04,11	1756-IB32-11	DI	24 VDC energized	XV-40202A	XV-40202A_DI_2	3-25-01-402-PD-01	0	PH Adjustment / ...
79	C1S08-X1	C1/S8	C1S08,04	1756-OB32-4	DO	24 VDC energized	XV-40202A	XV-40202A_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
80	C1S04-X1	C1/S4	C1S04,12	1756-IB32-12	DI	24 VDC energized	XV-40202B	XV-40202B_DI_1	3-25-01-402-PD-01	0	PH Adjustment / ...
81	C1S04-X1	C1/S4	C1S04,13	1756-IB32-13	DI	24 VDC energized	XV-40202B	XV-40202B_DI_2	3-25-01-402-PD-01	0	PH Adjustment / ...
82	C1S08-X1	C1/S8	C1S08,05	1756-OB32-5	DO	24 VDC energized	XV-40202B	XV-40202B_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
83	C1S04-X1	C1/S4	C1S04,14	1756-IB32-14	DI	24 VDC energized	XV-40202C	XV-40202C_DI_1	3-25-01-402-PD-01	0	PH Adjustment / ...
84	C1S04-X1	C1/S4	C1S04,15	1756-IB32-15	DI	24 VDC energized	XV-40202C	XV-40202C_DI_2	3-25-01-402-PD-01	0	PH Adjustment / ...
85	C1S08-X1	C1/S8	C1S08,06	1756-OB32-6	DO	24 VDC energized	XV-40202C	XV-40202C_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
86	C1S04-X2	C1/S4	C1S04,16	1756-IB32-16	DI	24 VDC energized	XV-40202D	XV-40202D_DI_1	3-25-01-402-PD-01	0	PH Adjustment / ...
87	C1S04-X2	C1/S4	C1S04,17	1756-IB32-17	DI	24 VDC energized	XV-40202D	XV-40202D_DI_2	3-25-01-402-PD-01	0	PH Adjustment / ...
88	C1S08-X1	C1/S8	C1S08,07	1756-OB32-7	DO	24 VDC energized	XV-40202D	XV-40202D_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
89	C1S04-X2	C1/S4	C1S04,18	1756-IB32-18	DI	24 VDC energized	XV-40202E	XV-40202E_DI_1	3-25-01-402-PD-01	0	PH Adjustment / ...
90	C1S04-X2	C1/S4	C1S04,19	1756-IB32-19	DI	24 VDC energized	XV-40202E	XV-40202E_DI_2	3-25-01-402-PD-01	0	PH Adjustment / ...
91	C1S07-X2	C1/S7	C1S07,16	1756-OB32-16	DO	24 VDC energized	XV-40202E	XV-40202E_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
92	C1S04-X2	C1/S4	C1S04,20	1756-IB32-20	DI	24 VDC energized	XV-40202F	XV-40202F_DI_1	3-25-01-402-PD-01	0	PH Adjustment / ...
93	C1S04-X2	C1/S4	C1S04,21	1756-IB32-21	DI	24 VDC energized	XV-40202F	XV-40202F_DI_2	3-25-01-402-PD-01	0	PH Adjustment / ...

ENCLOSURE: JB-401 | TYPE: Field Junction Box (Standard) | LOCATION: Infeed 2nd Floor | SIZE: 800-600-250 mm

SUMMARY: Total Channels: 112 | Active: 85 | Spare: 27 (24.1%) | DI: 64 | DO: 32 | AI: 16 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
94	C1S07-X2	C1/S7	C1S07,17	1756-OB32-17	DO	24 VDC energized	XV-40202F	XV-40202F_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
95	C1S04-X2	C1/S4	C1S04,22	1756-IB32-22	DI	24 VDC energized	XV-40202G	XV-40202G_DI_1	3-25-01-402-PD-01	0	PH Adjustment / ...
96	C1S04-X2	C1/S4	C1S04,23	1756-IB32-23	DI	24 VDC energized	XV-40202G	XV-40202G_DI_2	3-25-01-402-PD-01	0	PH Adjustment / ...
97	C1S07-X2	C1/S7	C1S07,18	1756-OB32-18	DO	24 VDC energized	XV-40202G	XV-40202G_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
98	C1S04-X2	C1/S4	C1S04,24	1756-IB32-24	DI	24 VDC energized	XV-40202H	XV-40202H_DI_1	3-25-01-402-PD-01	0	PH Adjustment / ...
99	C1S04-X2	C1/S4	C1S04,25	1756-IB32-25	DI	24 VDC energized	XV-40202H	XV-40202H_DI_2	3-25-01-402-PD-01	0	PH Adjustment / ...
100	C1S07-X2	C1/S7	C1S07,19	1756-OB32-19	DO	24 VDC energized	XV-40202H	XV-40202H_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
101	C1S04-X2	C1/S4	C1S04,26	1756-IB32-26	DI	24 VDC energized	XV-40203B	XV-40203B_DI_1	3-25-01-402-PD-02	0	Infeed Tank / 1st
102	C1S04-X2	C1/S4	C1S04,27	1756-IB32-27	DI	24 VDC energized	XV-40203B	XV-40203B_DI_2	3-25-01-402-PD-02	0	Infeed Tank / 1st
103	C1S07-X2	C1/S7	C1S07,20	1756-OB32-20	DO	24 VDC energized	XV-40203B	XV-40203B_DO_1	3-25-01-402-PD-02	0	Infeed Tank / 1st
104	C1S04-X2	C1/S4	C1S04,28	1756-IB32-28	DI	24 VDC energized	XV-40203C	XV-40203C_DI_1	3-25-01-402-PD-02	0	Infeed Tank / 1st
105	C1S04-X2	C1/S4	C1S04,29	1756-IB32-29	DI	24 VDC energized	XV-40203C	XV-40203C_DI_2	3-25-01-402-PD-02	0	Infeed Tank / 1st
106	C1S07-X2	C1/S7	C1S07,21	1756-OB32-21	DO	24 VDC energized	XV-40203C	XV-40203C_DO_1	3-25-01-402-PD-02	0	Infeed Tank / 1st
107	C1S04-X2	C1/S4	C1S04,30	1756-IB32-30	DI	24 VDC energized	XV-40203D	XV-40203D_DI_1	3-25-01-402-PD-02	0	Infeed Tank / 1st
108	C1S04-X2	C1/S4	C1S04,31	1756-IB32-31	DI	24 VDC energized	XV-40203D	XV-40203D_DI_2	3-25-01-402-PD-02	0	Infeed Tank / 1st
109	C1S07-X2	C1/S7	C1S07,22	1756-OB32-22	DO	24 VDC energized	XV-40203D	XV-40203D_DO_1	3-25-01-402-PD-02	0	Infeed Tank / 1st
110	C1S05-X1	C1/S5	C1S05,00	1756-IB32-0	DI	24 VDC energized	XV-40203E	XV-40203E_DI_1	3-25-01-402-PD-02	0	Infeed Tank / 1st
111	C1S05-X1	C1/S5	C1S05,01	1756-IB32-1	DI	24 VDC energized	XV-40203E	XV-40203E_DI_2	3-25-01-402-PD-02	0	Infeed Tank / 1st
112	C1S07-X2	C1/S7	C1S07,23	1756-OB32-23	DO	24 VDC energized	XV-40203E	XV-40203E_DO_1	3-25-01-402-PD-02	0	Infeed Tank / 1st

ENCLOSURE: JB-402 | TYPE: Field Junction Box (Standard) | LOCATION: Jet Cooker 2nd Floor | SIZE: 450-300-150 mm

SUMMARY: Total Channels: 65 | Active: 41 | Spare: 24 (36.9%) | DI: 32 | DO: 16 | AI: 16 | AO: 1 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
1	C2S01-X1	C2/S1	C2S01,00	1756-IB32-0	DI	Dry Contact	FS-40204	FS-40204_DI_1	325-01-402-PD-01	Flow Switch	Jet Cooker / 2nd
2	C2S01-X1	C2/S1	C2S01,01	1756-IB32-1	DI	Dry Contact	FS-40205	FS-40205_DI_1	325-01-402-PD-02	Flow Switch	Jet Cooker / 2nd
3	C2S01-X1	C2/S1	C2S01,02	1756-IB32-2	DI	4 - 20 mA,Pulse	FT-40221	FT-40221_DI_1	325-01-402-PD-02	Coriolis Flow Transmitter	Jet Cooker / 2nd
4	C2S09-X1	C2/S9	C2S09,00	1756-IF16-0	AI	4 - 20 mA,Pulse	FT-40221	FT-40221_AI_1	325-01-402-PD-02	Coriolis Flow Transmitter	Jet Cooker / 2nd
5	C2S09-X1	C2/S9	C2S09,01	1756-IF16-1	AI	4 - 20 mA,Pulse	FT-40221	FT-40221_AI_2	325-01-402-PD-02	Coriolis Flow Transmitter	Jet Cooker / 2nd
6	C2S01-X1	C2/S1	C2S01,03	1756-IB32-3	DI	4 - 20 mA,Pulse	FT-40222	FT-40222_DI_1	325-01-402-PD-02	Coriolis Flow Transmitter	Jet Cooker / 2nd
7	C2S09-X1	C2/S9	C2S09,02	1756-IF16-2	AI	4 - 20 mA,Pulse	FT-40222	FT-40222_AI_1	325-01-402-PD-02	Coriolis Flow Transmitter	Jet Cooker / 2nd
8	C2S09-X1	C2/S9	C2S09,03	1756-IF16-3	AI	4 - 20 mA,Pulse	FT-40222	FT-40222_AI_2	325-01-402-PD-02	Coriolis Flow Transmitter	Jet Cooker / 2nd
9	C2S01-X1	C2/S1	C2S01,04	1756-IB32-4	DI	Dry Contact	HV-40207	HV-40207_DI_1	325-01-402-PD-01	Manual Valve With Position Switch	Jet Cooker / 2nd
10	C2S01-X1	C2/S1	C2S01,05	1756-IB32-5	DI	Dry Contact	HV-40208	HV-40208_DI_1	325-01-402-PD-01	Manual Valve With Position Switch	Jet Cooker / 2nd
11	C2S09-X1	C2/S9	C2S09,04	1756-IF16-4	AI	4 - 20 mA	PT-40222	PT-40222_AI_1	325-01-402-PD-02	Pressure Transmitter	Jet Cooker / 2nd
12	C2S01-X2	C2/S1	C2S01,24	1756-IB32-24	DI	-	Spare	Spare_DI_2	-	Spare I/O Point	Jet Cooker / 2nd
13	C2S01-X2	C2/S1	C2S01,25	1756-IB32-25	DI	-	Spare	Spare_DI_2	-	Spare I/O Point	Jet Cooker / 2nd
14	C2S01-X2	C2/S1	C2S01,26	1756-IB32-26	DI	-	Spare	Spare_DI_2	-	Spare I/O Point	Jet Cooker / 2nd
15	C2S01-X2	C2/S1	C2S01,27	1756-IB32-27	DI	-	Spare	Spare_DI_2	-	Spare I/O Point	Jet Cooker / 2nd
16	C2S01-X2	C2/S1	C2S01,28	1756-IB32-28	DI	-	Spare	Spare_DI_2	-	Spare I/O Point	Jet Cooker / 2nd
17	C2S01-X2	C2/S1	C2S01,29	1756-IB32-29	DI	-	Spare	Spare_DI_2	-	Spare I/O Point	Jet Cooker / 2nd
18	C2S01-X2	C2/S1	C2S01,30	1756-IB32-30	DI	-	Spare	Spare_DI_2	-	Spare I/O Point	Jet Cooker / 2nd
19	C2S01-X2	C2/S1	C2S01,31	1756-IB32-31	DI	-	Spare	Spare_DI_2	-	Spare I/O Point	Jet Cooker / 2nd
20	C2S06-X1	C2/S6	C2S06,09	1756-OB32-9	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
21	C2S06-X1	C2/S6	C2S06,10	1756-OB32-10	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
22	C2S06-X1	C2/S6	C2S06,11	1756-OB32-11	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
23	C2S06-X1	C2/S6	C2S06,12	1756-OB32-12	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
24	C2S06-X1	C2/S6	C2S06,13	1756-OB32-13	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
25	C2S06-X1	C2/S6	C2S06,14	1756-OB32-14	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
26	C2S06-X1	C2/S6	C2S06,15	1756-OB32-15	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
27	C2S09-X1	C2/S9	C2S09,07	1756-IF16-7	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
28	C2S09-X1	C2/S9	C2S09,08	1756-IF16-8	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
29	C2S09-X1	C2/S9	C2S09,09	1756-IF16-9	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
30	C2S09-X1	C2/S9	C2S09,10	1756-IF16-10	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
31	C2S09-X1	C2/S9	C2S09,11	1756-IF16-11	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-

ENCLOSURE: JB-402 | TYPE: Field Junction Box (Standard) | LOCATION: Jet Cooker 2nd Floor | SIZE: 450-300-150 mm

SUMMARY: Total Channels: 65 | Active: 41 | Spare: 24 (36.9%) | DI: 32 | DO: 16 | AI: 16 | AO: 1 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
32	C2S09-X1	C2/S9	C2S09,12	1756-IF16-12	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
33	C2S09-X1	C2/S9	C2S09,13	1756-IF16-13	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
34	C2S09-X1	C2/S9	C2S09,14	1756-IF16-14	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
35	C2S09-X1	C2/S9	C2S09,15	1756-IF16-15	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
36	C3S13-X1	C3/S13	C3S13,00	1756-OF8-0	AO	4 - 20 mA	TCV-40222	TCV-40222_AO_1	325-01-402-PD-02	0	Jet Cooker / 2nd
37	C2S09-X1	C2/S9	C2S09,05	1756-IF16-5	AI	4 - 20 mA	TT-40221	TT-40221_AI_1	325-01-402-PD-02	0	Jet Cooker / 2nd
38	C2S09-X1	C2/S9	C2S09,06	1756-IF16-6	AI	4 - 20 mA	TT-40222	TT-40222_AI_1	325-01-402-PD-02	0	Jet Cooker / 2nd
39	C2S01-X1	C2/S1	C2S01,06	1756-IB32-6	DI	24 VDC energized	XV-40203F	XV-40203F_DI_1	325-01-402-PD-02	0	Jet Cooker / 2nd
40	C2S01-X1	C2/S1	C2S01,07	1756-IB32-7	DI	24 VDC energized	XV-40203F	XV-40203F_DI_2	325-01-402-PD-02	0	Jet Cooker / 2nd
41	C2S06-X1	C2/S6	C2S06,00	1756-OB32-0	DO	24 VDC energized	XV-40203F	XV-40203F_DO_1	325-01-402-PD-02	0	Jet Cooker / 2nd
42	C2S01-X1	C2/S1	C2S01,08	1756-IB32-8	DI	24 VDC energized	XV-40204B	XV-40204B_DI_1	325-01-402-PD-01	0	Jet Cooker / 2nd
43	C2S01-X1	C2/S1	C2S01,09	1756-IB32-9	DI	24 VDC energized	XV-40204B	XV-40204B_DI_2	325-01-402-PD-01	0	Jet Cooker / 2nd
44	C2S06-X1	C2/S6	C2S06,01	1756-OB32-1	DO	24 VDC energized	XV-40204B	XV-40204B_DO_1	325-01-402-PD-01	0	Jet Cooker / 2nd
45	C2S01-X1	C2/S1	C2S01,10	1756-IB32-10	DI	24 VDC energized	XV-40204C	XV-40204C_DI_1	325-01-402-PD-01	0	Jet Cooker / 2nd
46	C2S01-X1	C2/S1	C2S01,11	1756-IB32-11	DI	24 VDC energized	XV-40204C	XV-40204C_DI_2	325-01-402-PD-01	0	Jet Cooker / 2nd
47	C2S06-X1	C2/S6	C2S06,02	1756-OB32-2	DO	24 VDC energized	XV-40204C	XV-40204C_DO_1	325-01-402-PD-01	0	Jet Cooker / 2nd
48	C2S01-X1	C2/S1	C2S01,12	1756-IB32-12	DI	24 VDC energized	XV-40205A	XV-40205A_DI_1	325-01-402-PD-02	0	Jet Cooker / 2nd
49	C2S01-X1	C2/S1	C2S01,13	1756-IB32-13	DI	24 VDC energized	XV-40205A	XV-40205A_DI_2	325-01-402-PD-02	0	Jet Cooker / 2nd
50	C2S06-X1	C2/S6	C2S06,03	1756-OB32-3	DO	24 VDC energized	XV-40205A	XV-40205A_DO_1	325-01-402-PD-02	0	Jet Cooker / 2nd
51	C2S01-X1	C2/S1	C2S01,14	1756-IB32-14	DI	24 VDC energized	XV-40205B	XV-40205B_DI_1	325-01-402-PD-02	0	Jet Cooker / 2nd
52	C2S01-X1	C2/S1	C2S01,15	1756-IB32-15	DI	24 VDC energized	XV-40205B	XV-40205B_DI_2	325-01-402-PD-02	0	Jet Cooker / 2nd
53	C2S06-X1	C2/S6	C2S06,04	1756-OB32-4	DO	24 VDC energized	XV-40205B	XV-40205B_DO_1	325-01-402-PD-02	0	Jet Cooker / 2nd
54	C2S01-X2	C2/S1	C2S01,16	1756-IB32-16	DI	24 VDC energized	XV-40205C	XV-40205C_DI_1	325-01-402-PD-02	0	Jet Cooker / 2nd
55	C2S01-X2	C2/S1	C2S01,17	1756-IB32-17	DI	24 VDC energized	XV-40205C	XV-40205C_DI_2	325-01-402-PD-02	0	Jet Cooker / 2nd
56	C2S06-X1	C2/S6	C2S06,05	1756-OB32-5	DO	24 VDC energized	XV-40205C	XV-40205C_DO_1	325-01-402-PD-02	0	Jet Cooker / 2nd
57	C2S01-X2	C2/S1	C2S01,18	1756-IB32-18	DI	24 VDC energized	XV-40205D	XV-40205D_DI_1	325-01-402-PD-02	0	Jet Cooker / 2nd
58	C2S01-X2	C2/S1	C2S01,19	1756-IB32-19	DI	24 VDC energized	XV-40205D	XV-40205D_DI_2	325-01-402-PD-02	0	Jet Cooker / 2nd
59	C2S06-X1	C2/S6	C2S06,06	1756-OB32-6	DO	24 VDC energized	XV-40205D	XV-40205D_DO_1	325-01-402-PD-02	0	Jet Cooker / 2nd
60	C2S01-X2	C2/S1	C2S01,20	1756-IB32-20	DI	24 VDC energized	XV-40205F	XV-40205F_DI_1	325-01-402-PD-02	0	Jet Cooker / 2nd
61	C2S01-X2	C2/S1	C2S01,21	1756-IB32-21	DI	24 VDC energized	XV-40205F	XV-40205F_DI_2	325-01-402-PD-02	0	Jet Cooker / 2nd
62	C2S06-X1	C2/S6	C2S06,07	1756-OB32-7	DO	24 VDC energized	XV-40205F	XV-40205F_DO_1	325-01-402-PD-02	0	Jet Cooker / 2nd

ENCLOSURE: JB-402 | TYPE: Field Junction Box (Standard) | LOCATION: Jet Cooker 2nd Floor | SIZE: 450-300-150 mm

SUMMARY: Total Channels: 65 | Active: 41 | Spare: 24 (36.9%) | DI: 32 | DO: 16 | AI: 16 | AO: 1 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
63	C2S01-X2	C2/S1	C2S01,22	1756-IB32-22	DI	24 VDC energized	XV-40222	XV-40222_DI_1	325-01-402-PD-02	0	Jet Cooker / 2nd
64	C2S01-X2	C2/S1	C2S01,23	1756-IB32-23	DI	24 VDC energized	XV-40222	XV-40222_DI_2	-	0	Jet Cooker / 2nd
65	C2S06-X1	C2/S6	C2S06,08	1756-OB32-8	DO	24 VDC energized	XV-40222	XV-40222_DO_1	325-01-402-PD-02	0	Jet Cooker / 2nd

ENCLOSURE: JB-601 | TYPE: Field Junction Box (Standard) | LOCATION: Spray Dryer 1st Floor | SIZE: 500-400-200 mm

SUMMARY: Total Channels: 85 | Active: 58 | Spare: 27 (31.8%) | DI: 51 | DO: 17 | AI: 16 | AO: 0 | BUS: 1

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
1	C1S10-X1	C1/S10	C1S10,00	1756-IF16-0	AI	4 - 20 mA	DPI-60240	DPI-60240_AI_1	325-01-600-PD-05	0	Spray Dryer / 1st
2	C1S10-X1	C1/S10	C1S10,01	1756-IF16-1	AI	4 - 20 mA	DPT-60202	DPT-60202_AI_1	3-25-01-602-PD-08	Differential Pressure Transmitt	Spray Dryer / 1st
3	C1S05-X2	C1/S5	C1S05,16	1756-IB32-16	DI	0	ES-60202	ES-60202_DI_1	325-01-600-PD-01	0	Spray Dryer / 1st
4	C1S05-X2	C1/S5	C1S05,17	1756-IB32-17	DI	0	FS-60205	FS-60205_DI_1	3-25-01-602-PD-01	Flow Switch	Spray Dryer / 1st
5	C1S10-X1	C1/S10	C1S10,02	1756-IF16-2	AI	4 - 20 mA	FT-60201	FT-60201_AI_1	3-25-01-602-PD-08	0	Spray Dryer / 1st
6	C1S10-X1	C1/S10	C1S10,03	1756-IF16-3	AI	4 - 20 mA	FT-60204	FT-60204_AI_1	3-25-01-602-PD-10	0	Spray Dryer / 1st
7	C1S10-X1	C1/S10	C1S10,04	1756-IF16-4	AI	4 - 20 mA	FT-61307	FT-61307_AI_1	3-25-01-613-PD-04	0	Spray Dryer / 1st
8	C1S05-X2	C1/S5	C1S05,18	1756-IB32-18	DI	Dry Contact	LSL-60201	LSL-60201_DI_1	3-25-01-602-PD-11	0	Spray Dryer / 1st
9	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	PCY-60205	PCY-60205_BUS_1	325-01-600-PD-01	-	Spray Dryer / 1st
10	C7S02-	C7/S2	C7S02,03	-	DI	-	PCY-60205	PCY-60205_DI_1	325-01-600-PD-01	-	Spray Dryer / 1st
11	C7S02-	C7/S2	C7S02,04	-	DI	-	PCY-60205	PCY-60205_DI_2	325-01-600-PD-01	-	Spray Dryer / 1st
12	C7S03-	C7/S3	C7S03,25	-	DI	-	PCY-60205	PCY-60205_DI_3	325-01-600-PD-01	-	Spray Dryer / 1st
13	C7S06-	C7/S6	C7S06,31	-	DO	-	PCY-60205	PCY-60205_DO_1	325-01-600-PD-01	-	Spray Dryer / 1st
14	C1S10-X1	C1/S10	C1S10,05	1756-IF16-5	AI	4 - 20 mA	PT-60203	PT-60203_AI_1	3-25-01-602-PD-08	Pressure Transmitter	Spray Dryer / 1st
15	C1S10-X1	C1/S10	C1S10,06	1756-IF16-6	AI	4 - 20 mA	PT-60204	PT-60204_AI_1	3-25-01-602-PD-10	Pressure Transmitter	Spray Dryer / 1st
16	C1S10-X1	C1/S10	C1S10,07	1756-IF16-7	AI	4 - 20 mA	PT-60205	PT-60205_AI_1	3-25-01-602-PD-01	Pressure Transmitter	Spray Dryer / 1st
17	C1S05-X2	C1/S5	C1S05,26	1756-IB32-26	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
18	C1S05-X2	C1/S5	C1S05,27	1756-IB32-27	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
19	C1S05-X2	C1/S5	C1S05,28	1756-IB32-28	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
20	C1S05-X2	C1/S5	C1S05,29	1756-IB32-29	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
21	C1S05-X2	C1/S5	C1S05,30	1756-IB32-30	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
22	C1S05-X2	C1/S5	C1S05,31	1756-IB32-31	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
23	C1S06-X2	C1/S6	C1S06,23	1756-IB32-23	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer / 1st
24	C1S06-X2	C1/S6	C1S06,24	1756-IB32-24	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer / 1st
25	C1S06-X2	C1/S6	C1S06,25	1756-IB32-25	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer / 1st
26	C1S06-X2	C1/S6	C1S06,26	1756-IB32-26	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer / 1st
27	C1S06-X2	C1/S6	C1S06,27	1756-IB32-27	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer / 1st
28	C1S06-X2	C1/S6	C1S06,28	1756-IB32-28	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer / 1st
29	C1S06-X2	C1/S6	C1S06,29	1756-IB32-29	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer / 1st
30	C1S06-X2	C1/S6	C1S06,30	1756-IB32-30	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer / 1st
31	C1S06-X2	C1/S6	C1S06,31	1756-IB32-31	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer / 1st

ENCLOSURE: JB-601 | TYPE: Field Junction Box (Standard) | LOCATION: Spray Dryer 1st Floor | SIZE: 500-400-200 mm

SUMMARY: Total Channels: 85 | Active: 58 | Spare: 27 (31.8%) | DI: 51 | DO: 17 | AI: 16 | AO: 0 | BUS: 1

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
32	C1S08-X2	C1/S8	C1S08,28	1756-OB32-28	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
33	C1S08-X2	C1/S8	C1S08,29	1756-OB32-29	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
34	C1S08-X2	C1/S8	C1S08,30	1756-OB32-30	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
35	C1S08-X2	C1/S8	C1S08,31	1756-OB32-31	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
36	C1S10-X1	C1/S10	C1S10,08	1756-IF16-8	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
37	C1S10-X1	C1/S10	C1S10,09	1756-IF16-9	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
38	C1S10-X1	C1/S10	C1S10,10	1756-IF16-10	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
39	C1S10-X1	C1/S10	C1S10,11	1756-IF16-11	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
40	C1S10-X1	C1/S10	C1S10,12	1756-IF16-12	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
41	C1S10-X1	C1/S10	C1S10,13	1756-IF16-13	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
42	C1S10-X1	C1/S10	C1S10,14	1756-IF16-14	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
43	C1S10-X1	C1/S10	C1S10,15	1756-IF16-15	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
44	C1S05-X2	C1/S5	C1S05,19	1756-IB32-19	DI	24 VDC energized	SV-60201	SV-60201_DI_1	3-25-01-602-PD-08	0	Spray Dryer / 1st
45	C1S05-X2	C1/S5	C1S05,20	1756-IB32-20	DI	24 VDC energized	SV-60201	SV-60201_DI_2	3-25-01-602-PD-08	0	Spray Dryer / 1st
46	C1S08-X2	C1/S8	C1S08,16	1756-OB32-16	DO	24 VDC energized	SV-60201	SV-60201_DO_1	3-25-01-602-PD-08	0	Spray Dryer / 1st
47	C1S05-X2	C1/S5	C1S05,21	1756-IB32-21	DI	24 VDC energized	SV-60202	SV-60202_DI_1	3-25-01-602-PD-08	0	Spray Dryer / 1st
48	C1S05-X2	C1/S5	C1S05,22	1756-IB32-22	DI	24 VDC energized	SV-60202	SV-60202_DI_2	3-25-01-602-PD-08	0	Spray Dryer / 1st
49	C1S08-X2	C1/S8	C1S08,17	1756-OB32-17	DO	24 VDC energized	SV-60202	SV-60202_DO_1	3-25-01-602-PD-08	0	Spray Dryer / 1st
50	C1S05-X2	C1/S5	C1S05,23	1756-IB32-23	DI	24 VDC energized	SV-60203	SV-60203_DI_1	3-25-01-602-PD-08	0	Spray Dryer / 1st
51	C1S05-X2	C1/S5	C1S05,24	1756-IB32-24	DI	24 VDC energized	SV-60203	SV-60203_DI_2	3-25-01-602-PD-08	0	Spray Dryer / 1st
52	C1S08-X2	C1/S8	C1S08,19	1756-OB32-19	DO	24 VDC energized	SV-60203	SV-60203_DO_1	3-25-01-602-PD-08	0	Spray Dryer / 1st
53	C1S08-X2	C1/S8	C1S08,18	1756-OB32-18	DO	24 VDC energized	SV-60230	SV-60230_DO_1	3-25-01-602-PD-04	0	Spray Dryer / 1st
54	C1S08-X2	C1/S8	C1S08,21	1756-OB32-21	DO	24 VDC energized	SV-60231	SV-60231_DO_1	3-25-01-602-PD-04	0	Spray Dryer / 1st
55	C1S08-X2	C1/S8	C1S08,20	1756-OB32-20	DO	24 VDC energized	SV-60240A	SV-60240A_DO_1	3-25-01-602-PD-05	0	Spray Dryer / 1st
56	C1S08-X2	C1/S8	C1S08,22	1756-OB32-22	DO	24 VDC energized	SV-60240B	SV-60240B_DO_1	3-25-01-602-PD-05	0	Spray Dryer / 1st
57	C1S08-X2	C1/S8	C1S08,23	1756-OB32-23	DO	24 VDC energized	SV-60240C	SV-60240C_DO_1	3-25-01-602-PD-05	0	Spray Dryer / 1st
58	C1S05-X2	C1/S5	C1S05,25	1756-IB32-25	DI	Dry Contact	VS-60205	VS-60205_DI_1	3-25-01-602-PD-01	Vibration Switch	Spray Dryer / 1st
59	C1S06-X1	C1/S6	C1S06,00	1756-IB32-0	DI	Dry Contact	XA-60202A	XA-60202A_DI_1	325-01-600-PD-08	0	Spray Dryer / 1st
60	C1S06-X1	C1/S6	C1S06,01	1756-IB32-1	DI	Dry Contact	XA-60202B	XA-60202B_DI_1	325-01-600-PD-08	0	Spray Dryer / 1st
61	C1S06-X1	C1/S6	C1S06,02	1756-IB32-2	DI	Dry Contact	XA-60202C	XA-60202C_DI_1	325-01-600-PD-08	0	Spray Dryer / 1st
62	C1S06-X1	C1/S6	C1S06,03	1756-IB32-3	DI	Dry Contact	XA-60202D	XA-60202D_DI_1	325-01-600-PD-08	0	Spray Dryer / 1st

ENCLOSURE: JB-601 | TYPE: Field Junction Box (Standard) | LOCATION: Spray Dryer 1st Floor | SIZE: 500-400-200 mm

SUMMARY: Total Channels: 85 | Active: 58 | Spare: 27 (31.8%) | DI: 51 | DO: 17 | AI: 16 | AO: 0 | BUS: 1

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
63	C1S06-X1	C1/S6	C1S06,04	1756-IB32-4	DI	Dry Contact	XA-60202E	XA-60202E_DI_1	325-01-600-PD-08	0	Spray Dryer / 1st
64	C1S06-X1	C1/S6	C1S06,05	1756-IB32-5	DI	Dry Contact	XA-60202F	XA-60202F_DI_1	325-01-600-PD-08	0	Spray Dryer / 1st
65	C1S06-X1	C1/S6	C1S06,06	1756-IB32-6	DI	Dry Contact	XA-60202G	XA-60202G_DI_1	325-01-600-PD-08	0	Spray Dryer / 1st
66	C1S06-X1	C1/S6	C1S06,07	1756-IB32-7	DI	Dry Contact	XA-60202H	XA-60202H_DI_1	325-01-600-PD-08	0	Spray Dryer / 1st
67	C1S06-X1	C1/S6	C1S06,08	1756-IB32-8	DI	-	XA-60202I	XA-60202I_DI_1	325-01-600-PD-08	-	Spray Dryer / 1st
68	C1S06-X1	C1/S6	C1S06,09	1756-IB32-9	DI	Dry Contact	XA-60202J	XA-60202J_DI_1	325-01-600-PD-08	0	Spray Dryer / 1st
69	C1S06-X1	C1/S6	C1S06,10	1756-IB32-10	DI	Dry Contact	XA-60202K	XA-60202K_DI_1	325-01-600-PD-08	0	Spray Dryer / 1st
70	C1S06-X1	C1/S6	C1S06,11	1756-IB32-11	DI	Dry Contact	XA-60202L	XA-60202L_DI_1	325-01-600-PD-08	0	Spray Dryer / 1st
71	C1S06-X1	C1/S6	C1S06,12	1756-IB32-12	DI	Dry Contact	XA-60202M	XA-60202M_DI_1	325-01-600-PD-08	0	Spray Dryer / 1st
72	C1S06-X1	C1/S6	C1S06,13	1756-IB32-13	DI	24 VDC energized	XV-60202	XV-60202_DI_1	3-25-01-602-PD-11	0	Spray Dryer / 1st
73	C1S06-X1	C1/S6	C1S06,14	1756-IB32-14	DI	24 VDC energized	XV-60202	XV-60202_DI_2	3-25-01-602-PD-11	0	Spray Dryer / 1st
74	C1S08-X2	C1/S8	C1S08,26	1756-OB32-26	DO	24 VDC energized	XV-60202	XV-60202_DO_1	3-25-01-602-PD-11	0	Spray Dryer / 1st
75	C1S06-X1	C1/S6	C1S06,15	1756-IB32-15	DI	24 VDC energized,...	XV-60205A	XV-60205A_DI_1	3-25-01-602-PD-01	0	Spray Dryer / 1st
76	C1S06-X2	C1/S6	C1S06,16	1756-IB32-16	DI	24 VDC energized,...	XV-60205A	XV-60205A_DI_2	3-25-01-602-PD-01	0	Spray Dryer / 1st
77	C1S08-X2	C1/S8	C1S08,27	1756-OB32-27	DO	24 VDC energized,...	XV-60205A	XV-60205A_DO_1	3-25-01-602-PD-01	0	Spray Dryer / 1st
78	C1S06-X2	C1/S6	C1S06,17	1756-IB32-17	DI	-	XV-60240D	XV-60240D_DI_1	325-01-600-PD-05	-	Spray Dryer / 1st
79	C1S06-X2	C1/S6	C1S06,18	1756-IB32-18	DI	-	XV-60240D	XV-60240D_DI_2	3-25-01-602-PD-05	-	Spray Dryer / 1st
80	C1S06-X2	C1/S6	C1S06,19	1756-IB32-19	DI	-	XV-60240D	XV-60240D_DI_1	325-01-600-PD-05	-	Spray Dryer / 1st
81	C1S06-X2	C1/S6	C1S06,20	1756-IB32-20	DI	-	XV-60240D	XV-60240D_DI_2	3-25-01-602-PD-05	-	Spray Dryer / 1st
82	C1S08-X2	C1/S8	C1S08,24	1756-OB32-24	DO	-	XV-60240D	XV-60240D_DO_1	325-01-600-PD-05	-	Spray Dryer / 1st
83	C1S08-X2	C1/S8	C1S08,25	1756-OB32-25	DO	24 VDC energized	XV-60251	XV-60251_DO_1	3-25-01-602-PD-01	0	Infeed Tank / 1st
84	C1S06-X2	C1/S6	C1S06,21	1756-IB32-21	DI	0	YA-60205	YA-60205_DI_1	325-01-600-PD-01	0	Spray Dryer / 1st
85	C1S06-X2	C1/S6	C1S06,22	1756-IB32-22	DI	0	YI-60205	YI-60205_DI_1	325-01-600-PD-01	0	Spray Dryer / 1st

ENCLOSURE: JB-602 | TYPE: Field Junction Box (Standard) | LOCATION: Spray Dryer 3rd Floor | SIZE: 800-600-250 mm

SUMMARY: Total Channels: 82 | Active: 57 | Spare: 25 (30.5%) | DI: 32 | DO: 16 | AI: 32 | AO: 2 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
1	C2S10-X1	C2/S10	C2S10,00	1756-IF16-0	AI	4 - 20 mA	AT-60241	AT-60241_AI_1	3-25-01-602-PD-05	Dust Analyzer Transmitter	Spray Dryer / 5th
2	C2S10-X1	C2/S10	C2S10,01	1756-IF16-1	AI	4 - 20 mA	DPT-60203	DPT-60203_AI_1	3-25-01-602-PD-03	Differential Pressure Transmitter	Spray Dryer / 5th
3	C2S02-X1	C2/S2	C2S02,00	1756-IB32-0	DI	4 - 20 mA	FT-60202	FT-60202_DI_1	3-25-01-602-PD-09	0	Spray Dryer / 5th
4	C2S10-X1	C2/S10	C2S10,02	1756-IF16-2	AI	4 - 20 mA	FT-60202	FT-60202_AI_1	3-25-01-602-PD-09	0	Spray Dryer / 5th
5	C2S11-X1	C2/S11	C2S11,09	1756-IF16-9	AI	4 - 20 mA	FT-60210	FT-60210_AI_1	3-25-01-602-PD-03	0	Spray Dryer / 5th
6	C2S11-X1	C2/S11	C2S11,11	1756-IF16-11	AI	4 - 20 mA	FT-60210	FT-60210_AI_2	3-25-01-602-PD-03	0	Spray Dryer / 5th
7	C2S11-X1	C2/S11	C2S11,10	1756-IF16-10	AI	4 - 20 mA	FT-60211	FT-60211_AI_1	3-25-01-602-PD-03	0	Spray Dryer / 5th
8	C2S11-X1	C2/S11	C2S11,12	1756-IF16-12	AI	4 - 20 mA	FT-60211	FT-60211_AI_2	3-25-01-602-PD-03	0	Spray Dryer / 5th
9	C2S02-X1	C2/S2	C2S02,01	1756-IB32-1	DI	Dry Contact	LSH-60251	LSH-60251_DI_1	3-25-01-602-PD-04	0	Spray Dryer / 4th
10	C2S02-X1	C2/S2	C2S02,02	1756-IB32-2	DI	Dry Contact	PSL-60220	PSL-60220_DI_1	3-25-01-602-PD-04	0	Spray Dryer / 5th
11	C2S10-X1	C2/S10	C2S10,03	1756-IF16-3	AI	4 - 20 mA	PT-60210	PT-60210_AI_1	3-25-01-602-PD-03	Pressure Transmitter	Spray Dryer / 5th
12	C2S10-X1	C2/S10	C2S10,04	1756-IF16-4	AI	4 - 20 mA	PT-60215	PT-60215_AI_1	3-25-01-602-PD-03	Pressure Transmitter	Spray Dryer / 5th
13	C2S10-X1	C2/S10	C2S10,05	1756-IF16-5	AI	4 - 20 mA	PT-60216	PT-60216_AI_1	3-25-01-602-PD-03	Pressure Transmitter	Spray Dryer / 5th
14	C2S10-X1	C2/S10	C2S10,06	1756-IF16-6	AI	4 - 20 mA	PT-60240	PT-60240_AI_1	3-25-01-602-PD-05	Pressure Transmitter	Spray Dryer / 5th
15	C2S10-X1	C2/S10	C2S10,07	1756-IF16-7	AI	4 - 20 mA	PT-60241	PT-60241_AI_1	3-25-01-602-PD-05	Pressure Transmitter	Spray Dryer / 5th
16	C2S02-X2	C2/S2	C2S02,23	1756-IB32-23	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
17	C2S02-X2	C2/S2	C2S02,24	1756-IB32-24	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
18	C2S02-X2	C2/S2	C2S02,25	1756-IB32-25	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
19	C2S02-X2	C2/S2	C2S02,26	1756-IB32-26	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
20	C2S02-X2	C2/S2	C2S02,27	1756-IB32-27	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
21	C2S02-X2	C2/S2	C2S02,28	1756-IB32-28	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
22	C2S02-X2	C2/S2	C2S02,29	1756-IB32-29	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
23	C2S02-X2	C2/S2	C2S02,30	1756-IB32-30	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
24	C2S02-X2	C2/S2	C2S02,31	1756-IB32-31	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
25	C2S06-X2	C2/S6	C2S06,19	1756-OB32-19	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	Spray Dryer
26	C2S06-X2	C2/S6	C2S06,20	1756-OB32-20	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	Spray Dryer
27	C2S06-X2	C2/S6	C2S06,21	1756-OB32-21	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	Spray Dryer
28	C2S06-X2	C2/S6	C2S06,22	1756-OB32-22	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	Spray Dryer
29	C2S06-X2	C2/S6	C2S06,23	1756-OB32-23	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	Spray Dryer
30	C2S06-X2	C2/S6	C2S06,24	1756-OB32-24	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	Spray Dryer
31	C2S06-X2	C2/S6	C2S06,25	1756-OB32-25	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	Spray Dryer

ENCLOSURE: JB-602 | TYPE: Field Junction Box (Standard) | LOCATION: Spray Dryer 3rd Floor | SIZE: 800-600-250 mm

SUMMARY: Total Channels: 82 | Active: 57 | Spare: 25 (30.5%) | DI: 32 | DO: 16 | AI: 32 | AO: 2 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
32	C2S06-X2	C2/S6	C2S06,26	1756-OB32-26	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	Spray Dryer
33	C2S06-X2	C2/S6	C2S06,27	1756-OB32-27	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	Spray Dryer
34	C2S06-X2	C2/S6	C2S06,28	1756-OB32-28	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	Spray Dryer
35	C2S06-X2	C2/S6	C2S06,29	1756-OB32-29	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	Spray Dryer
36	C2S06-X2	C2/S6	C2S06,30	1756-OB32-30	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	Spray Dryer
37	C2S06-X2	C2/S6	C2S06,31	1756-OB32-31	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	Spray Dryer
38	C2S11-X1	C2/S11	C2S11,13	1756-IF16-13	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
39	C2S11-X1	C2/S11	C2S11,14	1756-IF16-14	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
40	C2S11-X1	C2/S11	C2S11,15	1756-IF16-15	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
41	C2S02-X1	C2/S2	C2S02,03	1756-IB32-3	DI	Dry Contact	TSH-60230	TSH-60230_DI_1	3-25-01-602-PD-04	0	Spray Dryer / 3rd
42	C2S02-X1	C2/S2	C2S02,04	1756-IB32-4	DI	Dry Contact	TSH-60240	TSH-60240_DI_1	3-25-01-602-PD-05	0	Spray Dryer / 5th
43	C2S02-X1	C2/S2	C2S02,05	1756-IB32-5	DI	Dry Contact	TSH-60241A	TSH-60241A_DI_1	3-25-01-602-PD-05	0	Spray Dryer / 4th
44	C2S02-X1	C2/S2	C2S02,06	1756-IB32-6	DI	Dry Contact	TSH-60242A	TSH-60242A_DI_1	3-25-01-602-PD-05	0	Spray Dryer / 3rd
45	C2S02-X1	C2/S2	C2S02,07	1756-IB32-7	DI	Dry Contact	TSH-60243A	TSH-60243A_DI_1	3-25-01-602-PD-05	0	Spray Dryer / 4th
46	C2S02-X1	C2/S2	C2S02,08	1756-IB32-8	DI	Dry Contact	TSL-60241B	TSL-60241B_DI_1	3-25-01-602-PD-05	0	Spray Dryer / 4th
47	C2S02-X1	C2/S2	C2S02,09	1756-IB32-9	DI	Dry Contact	TSL-60242B	TSL-60242B_DI_1	3-25-01-602-PD-05	0	Spray Dryer / 3rd
48	C2S02-X1	C2/S2	C2S02,10	1756-IB32-10	DI	Dry Contact	TSL-60243B	TSL-60243B_DI_1	3-25-01-602-PD-05	0	Spray Dryer / 4th
49	C2S10-X1	C2/S10	C2S10,08	1756-IF16-8	AI	4 - 20 mA	TT-60210	TT-60210_AI_1	3-25-01-602-PD-03	0	Spray Dryer / 5th
50	C2S10-X1	C2/S10	C2S10,09	1756-IF16-9	AI	-	TT-60210A	TT-60210A_AI_1	325-01-600-PD-03	-	Spray Dryer / 5th
51	C2S10-X1	C2/S10	C2S10,10	1756-IF16-10	AI	-	TT-60210B	TT-60210B_AI_1	325-01-600-PD-03	-	Spray Dryer / 5th
52	C2S10-X1	C2/S10	C2S10,11	1756-IF16-11	AI	4 - 20 mA	TT-60211	TT-60211_AI_1	3-25-01-602-PD-03	0	Spray Dryer / 5th
53	C2S10-X1	C2/S10	C2S10,12	1756-IF16-12	AI	4 - 20 mA	TT-60212A	TT-60212A_AI_1	3-25-01-602-PD-03	0	Spray Dryer / 5th
54	C2S10-X1	C2/S10	C2S10,13	1756-IF16-13	AI	4 - 20 mA	TT-60212B	TT-60212B_AI_1	3-25-01-602-PD-03	0	Spray Dryer / 5th
55	C2S10-X1	C2/S10	C2S10,14	1756-IF16-14	AI	4 - 20 mA	TT-60214	TT-60214_AI_1	3-25-01-602-PD-03	0	Spray Dryer / 5th
56	C2S10-X1	C2/S10	C2S10,15	1756-IF16-15	AI	4 - 20 mA	TT-60215A	TT-60215A_AI_1	3-25-01-602-PD-03	0	Spray Dryer / 5th
57	C2S11-X1	C2/S11	C2S11,00	1756-IF16-0	AI	4 - 20 mA	TT-60215B	TT-60215B_AI_1	3-25-01-602-PD-03	0	Spray Dryer / 5th
58	C2S11-X1	C2/S11	C2S11,01	1756-IF16-1	AI	4 - 20 mA	TT-60216	TT-60216_AI_1	3-25-01-602-PD-03	0	Spray Dryer / 5th
59	C2S11-X1	C2/S11	C2S11,02	1756-IF16-2	AI	4 - 20 mA	TT-60240	TT-60240_AI_1	3-25-01-602-PD-05	0	Spray Dryer / 5th
60	C2S11-X1	C2/S11	C2S11,03	1756-IF16-3	AI	4 - 20 mA	TT-60241A	TT-60241A_AI_1	3-25-01-602-PD-05	0	Spray Dryer / 5th
61	C2S11-X1	C2/S11	C2S11,04	1756-IF16-4	AI	4 - 20 mA	TT-60241B	TT-60241B_AI_1	3-25-01-602-PD-05	0	Spray Dryer / 5th
62	C3S13-X1	C3/S13	C3S13,01	1756-OF8-1	AO	-	TV-60202	TV-60202_AO_1	3-25-01-602-PD-07	-	Spray Dryer / 3rd

ENCLOSURE: JB-602 | TYPE: Field Junction Box (Standard) | LOCATION: Spray Dryer 3rd Floor | SIZE: 800-600-250 mm

SUMMARY: Total Channels: 82 | Active: 57 | Spare: 25 (30.5%) | DI: 32 | DO: 16 | AI: 32 | AO: 2 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
63	C3S13-X1	C3/S13	C3S13,02	1756-OF8-2	AO	-	TV-60214	TV-60214_AO_1	3-25-01-602-PD-03	-	Spray Dryer / 5th
64	C2S11-X1	C2/S11	C2S11,05	1756-IF16-5	AI	4 - 20 mA	VT-60210A	VT-60210A_AI_1	3-25-01-602-PD-03	0	Spray Dryer / 5th
65	C2S11-X1	C2/S11	C2S11,06	1756-IF16-6	AI	4 - 20 mA	VT-60210B	VT-60210B_AI_1	3-25-01-602-PD-03	0	Spray Dryer / 5th
66	C2S11-X1	C2/S11	C2S11,07	1756-IF16-7	AI	4 - 20 mA	VT-60241A	VT-60241A_AI_1	3-25-01-602-PD-05	0	Spray Dryer / 5th
67	C2S11-X1	C2/S11	C2S11,08	1756-IF16-8	AI	4 - 20 mA	VT-60241B	VT-60241B_AI_1	3-25-01-602-PD-05	0	Spray Dryer / 5th
68	C2S02-X1	C2/S2	C2S02,11	1756-IB32-11	DI	Dry Contact	XA-60240A	XA-60240A_DI_1	325-01-600-PD-05	0	Spray Dryer / 4th
69	C2S02-X1	C2/S2	C2S02,12	1756-IB32-12	DI	Dry Contact	XA-60240B	XA-60240B_DI_1	325-01-600-PD-05	0	Spray Dryer / 4th
70	C2S02-X1	C2/S2	C2S02,13	1756-IB32-13	DI	Dry Contact	XA-60241A	XA-60241A_DI_1	325-01-600-PD-05	0	Spray Dryer / 4th
71	C2S02-X1	C2/S2	C2S02,14	1756-IB32-14	DI	Dry Contact	XA-60241B	XA-60241B_DI_1	325-01-600-PD-05	0	Spray Dryer / 4th
72	C2S02-X1	C2/S2	C2S02,15	1756-IB32-15	DI	Dry Contact	XA-60242A	XA-60242A_DI_1	325-01-600-PD-05	0	Spray Dryer / 3rd
73	C2S02-X2	C2/S2	C2S02,16	1756-IB32-16	DI	Dry Contact	XA-60242B	XA-60242B_DI_1	325-01-600-PD-05	0	Spray Dryer / 3rd
74	C2S02-X2	C2/S2	C2S02,17	1756-IB32-17	DI	Dry Contact	XA-60243A	XA-60243A_DI_1	325-01-600-PD-05	0	Spray Dryer / 4th
75	C2S02-X2	C2/S2	C2S02,18	1756-IB32-18	DI	Dry Contact	XA-60243B	XA-60243B_DI_1	325-01-600-PD-05	0	Spray Dryer / 4th
76	C2S06-X2	C2/S6	C2S06,16	1756-OB32-16	DO	Dry Contact	XS-60240B	XS-60240B_DO_1	325-01-600-PD-05	0	Spray Dryer / 4th
77	C2S02-X2	C2/S2	C2S02,19	1756-IB32-19	DI	24 VDC energized	XV-60214	XV-60214_DI_1	3-25-01-602-PD-03	0	Spray Dryer / 5th
78	C2S02-X2	C2/S2	C2S02,20	1756-IB32-20	DI	24 VDC energized	XV-60214	XV-60214_DI_2	3-25-01-602-PD-03	0	Spray Dryer / 5th
79	C2S06-X2	C2/S6	C2S06,17	1756-OB32-17	DO	24 VDC energized	XV-60214	XV-60214_DO_1	3-25-01-602-PD-03	0	Spray Dryer / 5th
80	C2S02-X2	C2/S2	C2S02,21	1756-IB32-21	DI	24 VDC energized,...	XV-60241	XV-60241_DI_1	3-25-01-602-PD-05	0	Spray Dryer / 5th
81	C2S02-X2	C2/S2	C2S02,22	1756-IB32-22	DI	24 VDC energized,...	XV-60241	XV-60241_DI_2	3-25-01-602-PD-05	0	Spray Dryer / 5th
82	C2S06-X2	C2/S6	C2S06,18	1756-OB32-18	DO	24 VDC energized,...	XV-60241	XV-60241_DO_1	3-25-01-602-PD-05	0	Spray Dryer / 5th

ENCLOSURE: JB-606 | TYPE: Field Junction Box (Standard) | LOCATION: Spray Dryer 6th Floor | SIZE: 300-200-150 mm

SUMMARY: Total Channels: 26 | Active: 7 | Spare: 19 (73.1%) | DI: 16 | DO: 8 | AI: 2 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
1	C4S05-X1	C4/S5	C4S05,00	1756-IF16-0	AI	4 - 20 mA	DPT-60201	DPT-60201_AI_1	3-25-01-602-PD-09	Differential Pressure Transmitter	Spray Dryer / 6th
2	C4S01-X1	C4/S1	C4S01,00	1756-IB32-0	DI	4 - 20 mA	FT-60203	FT-60203_DI_1	3-25-01-602-PD-09	0	Spray Dryer / 6th
3	C4S05-X1	C4/S5	C4S05,01	1756-IF16-1	AI	4 - 20 mA	FT-60203	FT-60203_AI_1	3-25-01-602-PD-09	0	Spray Dryer / 6th
4	C4S01-X1	C4/S1	C4S01,01	1756-IB32-1	DI	Dry Contact	LSH-60250	LSH-60250_DI_1	3-25-01-602-PD-05	0	Spray Dryer / 6th
5	C4S01-X1	C4/S1	C4S01,04	1756-IB32-4	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
6	C4S01-X1	C4/S1	C4S01,05	1756-IB32-5	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
7	C4S01-X1	C4/S1	C4S01,06	1756-IB32-6	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
8	C4S01-X1	C4/S1	C4S01,07	1756-IB32-7	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
9	C4S01-X1	C4/S1	C4S01,08	1756-IB32-8	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
10	C4S01-X1	C4/S1	C4S01,09	1756-IB32-9	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
11	C4S01-X1	C4/S1	C4S01,10	1756-IB32-10	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
12	C4S01-X1	C4/S1	C4S01,11	1756-IB32-11	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
13	C4S01-X1	C4/S1	C4S01,12	1756-IB32-12	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
14	C4S01-X1	C4/S1	C4S01,13	1756-IB32-13	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
15	C4S01-X1	C4/S1	C4S01,14	1756-IB32-14	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
16	C4S01-X1	C4/S1	C4S01,15	1756-IB32-15	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
17	C4S04-X1	C4/S4	C4S04,01	1756-OB32-1	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	Spray Dryer
18	C4S04-X1	C4/S4	C4S04,02	1756-OB32-2	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	Spray Dryer
19	C4S04-X1	C4/S4	C4S04,03	1756-OB32-3	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	Spray Dryer
20	C4S04-X1	C4/S4	C4S04,04	1756-OB32-4	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	Spray Dryer
21	C4S04-X1	C4/S4	C4S04,05	1756-OB32-5	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	Spray Dryer
22	C4S04-X1	C4/S4	C4S04,06	1756-OB32-6	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	Spray Dryer
23	C4S04-X1	C4/S4	C4S04,07	1756-OB32-7	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	Spray Dryer
24	C4S04-X1	C4/S4	C4S04,00	1756-OB32-0	DO	24 VDC energized	SV-60220	SV-60220_DO_1	3-25-01-602-PD-04	0	Spray Dryer / 6th
25	C4S01-X1	C4/S1	C4S01,02	1756-IB32-2	DI	Dry Contact	XA-60261	XA-60261_DI_1	325-01-600-PD-05	0	Spray Dryer / 6th
26	C4S01-X1	C4/S1	C4S01,03	1756-IB32-3	DI	Dry Contact	XA-60262	XA-60262_DI_1	325-01-600-PD-05	0	Spray Dryer / 6th

ENCLOSURE: JB-607 | TYPE: Field Junction Box (Standard) | LOCATION: Spray Dryer 7th Floor | SIZE: 800-600-250 mm

SUMMARY: Total Channels: 195 | Active: 151 | Spare: 44 (22.6%) | DI: 93 | DO: 64 | AI: 32 | AO: 5 | BUS: 1

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
1	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	COM-FH-60210B	COM-FH-60210B_BUS...	325-01-600-PD-06	0	Spray Dryer / 7th
2	C2S12-X1	C2/S12	C2S12,00	1756-IF16-0	AI	4 - 20 mA	FT-60207	FT-60207_AI_1	3-25-01-602-PD-07	0	Spray Dryer / 7th
3	C2S12-X1	C2/S12	C2S12,01	1756-IF16-1	AI	4 - 20 mA	FT-60221	FT-60221_AI_1	3-25-01-602-PD-04	0	Spray Dryer / 7th
4	C2S12-X1	C2/S12	C2S12,02	1756-IF16-2	AI	4 - 20 mA	FT-60261FA	FT-60261FA_AI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
5	C2S12-X1	C2/S12	C2S12,03	1756-IF16-3	AI	4 - 20 mA	FT-60261FB	FT-60261FB_AI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
6	C2S12-X1	C2/S12	C2S12,04	1756-IF16-4	AI	4 - 20 mA	FT-60261FC	FT-60261FC_AI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
7	C2S12-X1	C2/S12	C2S12,05	1756-IF16-5	AI	4 - 20 mA	FT-60261FD	FT-60261FD_AI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
8	C2S12-X1	C2/S12	C2S12,06	1756-IF16-6	AI	4 - 20 mA	FT-60262FE	FT-60262FE_AI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
9	C2S12-X1	C2/S12	C2S12,07	1756-IF16-7	AI	4 - 20 mA	FT-60262FF	FT-60262FF_AI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
10	C2S12-X1	C2/S12	C2S12,08	1756-IF16-8	AI	4 - 20 mA	FT-60262FG	FT-60262FG_AI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
11	C2S12-X1	C2/S12	C2S12,09	1756-IF16-9	AI	4 - 20 mA	FT-60262FH	FT-60262FH_AI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
12	C2S12-X1	C2/S12	C2S12,10	1756-IF16-10	AI	4 - 20 mA	FT-60263FJ	FT-60263FJ_AI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
13	C2S12-X1	C2/S12	C2S12,11	1756-IF16-11	AI	4 - 20 mA	FT-60263FK	FT-60263FK_AI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
14	C2S12-X1	C2/S12	C2S12,12	1756-IF16-12	AI	4 - 20 mA	FT-60263FL	FT-60263FL_AI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
15	C2S12-X1	C2/S12	C2S12,13	1756-IF16-13	AI	4 - 20 mA	FT-60263FM	FT-60263FM_AI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
16	C2S12-X1	C2/S12	C2S12,14	1756-IF16-14	AI	4 - 20 mA	FT-60264FN	FT-60264FN_AI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
17	C2S12-X1	C2/S12	C2S12,15	1756-IF16-15	AI	4 - 20 mA	FT-60264FP	FT-60264FP_AI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
18	C2S13-X1	C2/S13	C2S13,00	1756-IF16-0	AI	4 - 20 mA	FT-60264FQ	FT-60264FQ_AI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
19	C2S13-X1	C2/S13	C2S13,01	1756-IF16-1	AI	4 - 20 mA	FT-60264FR	FT-60264FR_AI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
20	C2S13-X1	C2/S13	C2S13,02	1756-IF16-2	AI	4 - 20 mA	PT-60201	PT-60201_AI_1	3-25-01-602-PD-02	Pressure Transmitter	Spray Dryer / 7th
21	C2S13-X1	C2/S13	C2S13,03	1756-IF16-3	AI	4 - 20 mA	PT-60207	PT-60207_AI_1	3-25-01-602-PD-07	Pressure Transmitter	Spray Dryer / 7th
22	C2S13-X1	C2/S13	C2S13,04	1756-IF16-4	AI	4 - 20 mA	PT-60221	PT-60221_AI_1	3-25-01-602-PD-04	Pressure Transmitter	Spray Dryer / 7th
23	C2S13-X1	C2/S13	C2S13,05	1756-IF16-5	AI	4 - 20 mA	PT-60221	PT-60221_AI_1	3-25-01-602-PD-04	Pressure Transmitter	Spray Dryer / 7th
24	C3S13-X1	C3/S13	C3S13,03	1756-OF8-3	AO	-	PV-60201	PV-60201_AO_1	3-25-01-602-PD-02	-	Spray Dryer / 7th
25	C2S05-X2	C2/S5	C2S05,20	1756-IB32-20	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer
26	C2S05-X2	C2/S5	C2S05,21	1756-IB32-21	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer
27	C2S05-X2	C2/S5	C2S05,22	1756-IB32-22	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer
28	C2S05-X2	C2/S5	C2S05,23	1756-IB32-23	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer
29	C2S05-X2	C2/S5	C2S05,24	1756-IB32-24	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer
30	C2S05-X2	C2/S5	C2S05,25	1756-IB32-25	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer
31	C2S05-X2	C2/S5	C2S05,26	1756-IB32-26	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer

ENCLOSURE: JB-607 | TYPE: Field Junction Box (Standard) | LOCATION: Spray Dryer 7th Floor | SIZE: 800-600-250 mm

SUMMARY: Total Channels: 195 | Active: 151 | Spare: 44 (22.6%) | DI: 93 | DO: 64 | AI: 32 | AO: 5 | BUS: 1

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
32	C2S05-X2	C2/S5	C2S05,27	1756-IB32-27	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer
33	C2S05-X2	C2/S5	C2S05,28	1756-IB32-28	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer
34	C2S05-X2	C2/S5	C2S05,29	1756-IB32-29	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer
35	C2S05-X2	C2/S5	C2S05,30	1756-IB32-30	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer
36	C2S05-X2	C2/S5	C2S05,31	1756-IB32-31	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer
37	C2S07-X2	C2/S7	C2S07,31	1756-OB32-31	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
38	C2S08-X1	C2/S8	C2S08,09	1756-OB32-9	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
39	C2S08-X1	C2/S8	C2S08,10	1756-OB32-10	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
40	C2S08-X1	C2/S8	C2S08,11	1756-OB32-11	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
41	C2S08-X1	C2/S8	C2S08,12	1756-OB32-12	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
42	C2S08-X1	C2/S8	C2S08,13	1756-OB32-13	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
43	C2S08-X1	C2/S8	C2S08,14	1756-OB32-14	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
44	C2S08-X1	C2/S8	C2S08,15	1756-OB32-15	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
45	C2S08-X2	C2/S8	C2S08,16	1756-OB32-16	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
46	C2S08-X2	C2/S8	C2S08,17	1756-OB32-17	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
47	C2S08-X2	C2/S8	C2S08,18	1756-OB32-18	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
48	C2S08-X2	C2/S8	C2S08,19	1756-OB32-19	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
49	C2S08-X2	C2/S8	C2S08,20	1756-OB32-20	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
50	C2S08-X2	C2/S8	C2S08,21	1756-OB32-21	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
51	C2S08-X2	C2/S8	C2S08,22	1756-OB32-22	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
52	C2S08-X2	C2/S8	C2S08,23	1756-OB32-23	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
53	C2S08-X2	C2/S8	C2S08,24	1756-OB32-24	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
54	C2S08-X2	C2/S8	C2S08,25	1756-OB32-25	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
55	C2S08-X2	C2/S8	C2S08,26	1756-OB32-26	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
56	C2S08-X2	C2/S8	C2S08,27	1756-OB32-27	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
57	C2S08-X2	C2/S8	C2S08,28	1756-OB32-28	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
58	C2S08-X2	C2/S8	C2S08,29	1756-OB32-29	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
59	C2S08-X2	C2/S8	C2S08,30	1756-OB32-30	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
60	C2S08-X2	C2/S8	C2S08,31	1756-OB32-31	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
61	C2S13-X1	C2/S13	C2S13,11	1756-IF16-11	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
62	C2S13-X1	C2/S13	C2S13,12	1756-IF16-12	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-

ENCLOSURE: JB-607 | TYPE: Field Junction Box (Standard) | LOCATION: Spray Dryer 7th Floor | SIZE: 800-600-250 mm

SUMMARY: Total Channels: 195 | Active: 151 | Spare: 44 (22.6%) | DI: 93 | DO: 64 | AI: 32 | AO: 5 | BUS: 1

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
63	C2S13-X1	C2/S13	C2S13,13	1756-IF16-13	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
64	C2S13-X1	C2/S13	C2S13,14	1756-IF16-14	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
65	C2S13-X1	C2/S13	C2S13,15	1756-IF16-15	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
66	C3S13-X1	C3/S13	C3S13,05	1756-OF8-5	AO	-	Spare	Spare_AO_0	-	Spare I/O Point	-
67	C3S13-X1	C3/S13	C3S13,06	1756-OF8-6	AO	-	Spare	Spare_AO_0	-	Spare I/O Point	-
68	C3S13-X1	C3/S13	C3S13,07	1756-OF8-7	AO	-	Spare	Spare_AO_0	-	Spare I/O Point	-
69	C2S03-X1	C2/S3	C2S03,08	1756-IB32-8	DI	24 VDC energized	SV-60207	SV-60207_DI_1	3-25-01-602-PD-07	0	Spray Dryer / 7th
70	C2S03-X1	C2/S3	C2S03,09	1756-IB32-9	DI	24 VDC energized	SV-60207	SV-60207_DI_2	3-25-01-602-PD-07	0	Spray Dryer / 7th
71	C2S07-X1	C2/S7	C2S07,00	1756-OB32-0	DO	24 VDC energized	SV-60207	SV-60207_DO_1	3-25-01-602-PD-07	0	Spray Dryer / 7th
72	C2S13-X1	C2/S13	C2S13,06	1756-IF16-6	AI	4 - 20 mA	TI-FH-60210	TI-FH-60210_AI_1	325-01-600-PD-06	0	Spray Dryer / 7th
73	C2S13-X1	C2/S13	C2S13,07	1756-IF16-7	AI	4 - 20 mA	TT-60201	TT-60201_AI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
74	C2S13-X1	C2/S13	C2S13,08	1756-IF16-8	AI	4 - 20 mA	TT-60202	TT-60202_AI_1	3-25-01-602-PD-07	0	Spray Dryer / 7th
75	C2S13-X1	C2/S13	C2S13,09	1756-IF16-9	AI	4 - 20 mA	TT-60207	TT-60207_AI_1	3-25-01-602-PD-07	0	Spray Dryer / 7th
76	C2S13-X1	C2/S13	C2S13,10	1756-IF16-10	AI	4 - 20 mA	UY-FH-60210A	UY-FH-60210A_AI_1	325-01-600-PD-06	0	Spray Dryer / 7th
77	C3S13-X1	C3/S13	C3S13,04	1756-OF8-4	AO	4 - 20 mA	UY-FH-60210B	UY-FH-60210B_AO_1	325-01-600-PD-06	0	Spray Dryer / 7th
78	C2S03-X1	C2/S3	C2S03,00	1756-IB32-0	DI	Dry Contact	XA-FH-60210A	XA-FH-60210A_DI_1	325-01-600-PD-06	0	Spray Dryer / 7th
79	C2S03-X1	C2/S3	C2S03,01	1756-IB32-1	DI	Dry Contact	XA-FH-60210B	XA-FH-60210B_DI_1	325-01-600-PD-06	0	Spray Dryer / 7th
80	C2S03-X1	C2/S3	C2S03,02	1756-IB32-2	DI	Dry Contact	XA-FH-60210C	XA-FH-60210C_DI_1	325-01-600-PD-06	0	Spray Dryer / 7th
81	C2S03-X1	C2/S3	C2S03,03	1756-IB32-3	DI	Dry Contact	XA-FH-60210D	XA-FH-60210D_DI_1	325-01-600-PD-06	0	Spray Dryer / 7th
82	C2S03-X1	C2/S3	C2S03,04	1756-IB32-4	DI	Dry Contact	XA-FH-60210E	XA-FH-60210E_DI_1	325-01-600-PD-06	0	Spray Dryer / 7th
83	C2S07-X1	C2/S7	C2S07,01	1756-OB32-1	DO	Dry Contact	XS-FH-60210C	XS-FH-60210C_DO_1	325-01-600-PD-06	0	Spray Dryer / 7th
84	C2S07-X1	C2/S7	C2S07,02	1756-OB32-2	DO	Dry Contact	XS-FH-60210D	XS-FH-60210D_DO_1	325-01-600-PD-06	0	Spray Dryer / 7th
85	C2S03-X2	C2/S3	C2S03,16	1756-IB32-16	DI	24 VDC energized	XV-60201	XV-60201_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
86	C2S03-X2	C2/S3	C2S03,17	1756-IB32-17	DI	24 VDC energized	XV-60201	XV-60201_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
87	C2S07-X1	C2/S7	C2S07,03	1756-OB32-3	DO	24 VDC energized	XV-60201	XV-60201_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
88	C2S03-X2	C2/S3	C2S03,20	1756-IB32-20	DI	-	XV-60261	XV-60261_DI_1	325-01-600-PD-02	-	Spray Dryer / 7th
89	C2S03-X2	C2/S3	C2S03,21	1756-IB32-21	DI	-	XV-60261	XV-60261_DI_2	325-01-600-PD-02	-	Spray Dryer / 7th
90	C2S07-X1	C2/S7	C2S07,04	1756-OB32-4	DO	-	XV-60261	XV-60261_DO_1	325-01-600-PD-02	-	Spray Dryer / 7th
91	C2S03-X2	C2/S3	C2S03,24	1756-IB32-24	DI	24 VDC energized,...	XV-60261FA	XV-60261FA_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
92	C2S03-X2	C2/S3	C2S03,25	1756-IB32-25	DI	24 VDC energized,...	XV-60261FA	XV-60261FA_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
93	C2S07-X1	C2/S7	C2S07,05	1756-OB32-5	DO	24 VDC energized,...	XV-60261FA	XV-60261FA_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th

ENCLOSURE: JB-607 | TYPE: Field Junction Box (Standard) | LOCATION: Spray Dryer 7th Floor | SIZE: 800-600-250 mm

SUMMARY: Total Channels: 195 | Active: 151 | Spare: 44 (22.6%) | DI: 93 | DO: 64 | AI: 32 | AO: 5 | BUS: 1

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
94	C2S03-X2	C2/S3	C2S03,28	1756-IB32-28	DI	24 VDC energized,...	XV-60261FB	XV-60261FB_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
95	C2S03-X2	C2/S3	C2S03,29	1756-IB32-29	DI	24 VDC energized,...	XV-60261FB	XV-60261FB_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
96	C2S07-X1	C2/S7	C2S07,06	1756-OB32-6	DO	24 VDC energized,...	XV-60261FB	XV-60261FB_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
97	C2S04-X1	C2/S4	C2S04,00	1756-IB32-0	DI	24 VDC energized,...	XV-60261FC	XV-60261FC_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
98	C2S04-X1	C2/S4	C2S04,01	1756-IB32-1	DI	24 VDC energized,...	XV-60261FC	XV-60261FC_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
99	C2S07-X1	C2/S7	C2S07,07	1756-OB32-7	DO	24 VDC energized,...	XV-60261FC	XV-60261FC_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
100	C2S04-X1	C2/S4	C2S04,04	1756-IB32-4	DI	24 VDC energized,...	XV-60261FD	XV-60261FD_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
101	C2S04-X1	C2/S4	C2S04,05	1756-IB32-5	DI	24 VDC energized,...	XV-60261FD	XV-60261FD_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
102	C2S07-X1	C2/S7	C2S07,08	1756-OB32-8	DO	24 VDC energized,...	XV-60261FD	XV-60261FD_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
103	C2S04-X1	C2/S4	C2S04,08	1756-IB32-8	DI	24 VDC energized,...	XV-60261SA	XV-60261SA_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
104	C2S04-X1	C2/S4	C2S04,09	1756-IB32-9	DI	24 VDC energized,...	XV-60261SA	XV-60261SA_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
105	C2S07-X1	C2/S7	C2S07,09	1756-OB32-9	DO	24 VDC energized,...	XV-60261SA	XV-60261SA_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
106	C2S04-X1	C2/S4	C2S04,10	1756-IB32-10	DI	24 VDC energized,...	XV-60261SB	XV-60261SB_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
107	C2S04-X1	C2/S4	C2S04,11	1756-IB32-11	DI	24 VDC energized,...	XV-60261SB	XV-60261SB_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
108	C2S07-X1	C2/S7	C2S07,10	1756-OB32-10	DO	24 VDC energized,...	XV-60261SB	XV-60261SB_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
109	C2S04-X1	C2/S4	C2S04,12	1756-IB32-12	DI	24 VDC energized,...	XV-60261SC	XV-60261SC_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
110	C2S04-X1	C2/S4	C2S04,13	1756-IB32-13	DI	24 VDC energized,...	XV-60261SC	XV-60261SC_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
111	C2S07-X1	C2/S7	C2S07,11	1756-OB32-11	DO	24 VDC energized,...	XV-60261SC	XV-60261SC_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
112	C2S04-X1	C2/S4	C2S04,14	1756-IB32-14	DI	24 VDC energized,...	XV-60261SD	XV-60261SD_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
113	C2S04-X1	C2/S4	C2S04,15	1756-IB32-15	DI	24 VDC energized,...	XV-60261SD	XV-60261SD_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
114	C2S07-X1	C2/S7	C2S07,12	1756-OB32-12	DO	24 VDC energized,...	XV-60261SD	XV-60261SD_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
115	C2S04-X2	C2/S4	C2S04,16	1756-IB32-16	DI	-	XV-60262	XV-60262_DI_1	325-01-600-PD-02	-	Spray Dryer / 7th
116	C2S04-X2	C2/S4	C2S04,17	1756-IB32-17	DI	-	XV-60262	XV-60262_DI_2	325-01-600-PD-02	-	Spray Dryer / 7th
117	C2S07-X1	C2/S7	C2S07,13	1756-OB32-13	DO	-	XV-60262	XV-60262_DO_1	325-01-600-PD-02	-	Spray Dryer / 7th
118	C2S04-X2	C2/S4	C2S04,18	1756-IB32-18	DI	24 VDC energized,...	XV-60262FE	XV-60262FE_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
119	C2S04-X2	C2/S4	C2S04,19	1756-IB32-19	DI	24 VDC energized,...	XV-60262FE	XV-60262FE_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
120	C2S07-X1	C2/S7	C2S07,14	1756-OB32-14	DO	24 VDC energized,...	XV-60262FE	XV-60262FE_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
121	C2S04-X2	C2/S4	C2S04,20	1756-IB32-20	DI	24 VDC energized,...	XV-60262FF	XV-60262FF_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
122	C2S04-X2	C2/S4	C2S04,21	1756-IB32-21	DI	24 VDC energized,...	XV-60262FF	XV-60262FF_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
123	C2S07-X1	C2/S7	C2S07,15	1756-OB32-15	DO	24 VDC energized,...	XV-60262FF	XV-60262FF_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
124	C2S04-X2	C2/S4	C2S04,22	1756-IB32-22	DI	24 VDC energized,...	XV-60262FG	XV-60262FG_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th

ENCLOSURE: JB-607 | TYPE: Field Junction Box (Standard) | LOCATION: Spray Dryer 7th Floor | SIZE: 800-600-250 mm

SUMMARY: Total Channels: 195 | Active: 151 | Spare: 44 (22.6%) | DI: 93 | DO: 64 | AI: 32 | AO: 5 | BUS: 1

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
125	C2S04-X2	C2/S4	C2S04,23	1756-IB32-23	DI	24 VDC energized,...	XV-60262FG	XV-60262FG_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
126	C2S07-X2	C2/S7	C2S07,16	1756-OB32-16	DO	24 VDC energized,...	XV-60262FG	XV-60262FG_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
127	C2S04-X2	C2/S4	C2S04,24	1756-IB32-24	DI	24 VDC energized,...	XV-60262FH	XV-60262FH_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
128	C2S04-X2	C2/S4	C2S04,25	1756-IB32-25	DI	24 VDC energized,...	XV-60262FH	XV-60262FH_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
129	C2S07-X2	C2/S7	C2S07,17	1756-OB32-17	DO	24 VDC energized,...	XV-60262FH	XV-60262FH_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
130	C2S04-X2	C2/S4	C2S04,26	1756-IB32-26	DI	24 VDC energized,...	XV-60262SE	XV-60262SE_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
131	C2S04-X2	C2/S4	C2S04,27	1756-IB32-27	DI	24 VDC energized,...	XV-60262SE	XV-60262SE_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
132	C2S07-X2	C2/S7	C2S07,18	1756-OB32-18	DO	24 VDC energized,...	XV-60262SE	XV-60262SE_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
133	C2S04-X2	C2/S4	C2S04,28	1756-IB32-28	DI	24 VDC energized,...	XV-60262SF	XV-60262SF_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
134	C2S04-X2	C2/S4	C2S04,29	1756-IB32-29	DI	24 VDC energized,...	XV-60262SF	XV-60262SF_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
135	C2S07-X2	C2/S7	C2S07,19	1756-OB32-19	DO	24 VDC energized,...	XV-60262SF	XV-60262SF_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
136	C2S04-X2	C2/S4	C2S04,30	1756-IB32-30	DI	24 VDC energized,...	XV-60262SG	XV-60262SG_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
137	C2S04-X2	C2/S4	C2S04,31	1756-IB32-31	DI	24 VDC energized,...	XV-60262SG	XV-60262SG_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
138	C2S07-X2	C2/S7	C2S07,20	1756-OB32-20	DO	24 VDC energized,...	XV-60262SG	XV-60262SG_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
139	C2S05-X1	C2/S5	C2S05,00	1756-IB32-0	DI	24 VDC energized,...	XV-60262SH	XV-60262SH_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
140	C2S05-X1	C2/S5	C2S05,01	1756-IB32-1	DI	24 VDC energized,...	XV-60262SH	XV-60262SH_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
141	C2S07-X2	C2/S7	C2S07,21	1756-OB32-21	DO	24 VDC energized,...	XV-60262SH	XV-60262SH_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
142	C2S05-X1	C2/S5	C2S05,02	1756-IB32-2	DI	-	XV-60263	XV-60263_DI_1	325-01-600-PD-02	-	Spray Dryer / 7th
143	C2S05-X1	C2/S5	C2S05,03	1756-IB32-3	DI	-	XV-60263	XV-60263_DI_2	325-01-600-PD-02	-	Spray Dryer / 7th
144	C2S07-X2	C2/S7	C2S07,22	1756-OB32-22	DO	-	XV-60263	XV-60263_DO_1	325-01-600-PD-02	-	Spray Dryer / 7th
145	C2S05-X1	C2/S5	C2S05,04	1756-IB32-4	DI	24 VDC energized,...	XV-60263FJ	XV-60263FJ_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
146	C2S05-X1	C2/S5	C2S05,05	1756-IB32-5	DI	24 VDC energized,...	XV-60263FJ	XV-60263FJ_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
147	C2S07-X2	C2/S7	C2S07,23	1756-OB32-23	DO	24 VDC energized,...	XV-60263FJ	XV-60263FJ_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
148	C2S05-X1	C2/S5	C2S05,06	1756-IB32-6	DI	24 VDC energized,...	XV-60263FK	XV-60263FK_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
149	C2S05-X1	C2/S5	C2S05,07	1756-IB32-7	DI	24 VDC energized,...	XV-60263FK	XV-60263FK_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
150	C2S07-X2	C2/S7	C2S07,24	1756-OB32-24	DO	24 VDC energized,...	XV-60263FK	XV-60263FK_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
151	C2S05-X1	C2/S5	C2S05,08	1756-IB32-8	DI	24 VDC energized,...	XV-60263FL	XV-60263FL_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
152	C2S05-X1	C2/S5	C2S05,09	1756-IB32-9	DI	24 VDC energized,...	XV-60263FL	XV-60263FL_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
153	C2S07-X2	C2/S7	C2S07,25	1756-OB32-25	DO	24 VDC energized,...	XV-60263FL	XV-60263FL_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
154	C2S05-X1	C2/S5	C2S05,10	1756-IB32-10	DI	24 VDC energized,...	XV-60263FM	XV-60263FM_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
155	C2S05-X1	C2/S5	C2S05,11	1756-IB32-11	DI	24 VDC energized,...	XV-60263FM	XV-60263FM_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th

ENCLOSURE: JB-607 | TYPE: Field Junction Box (Standard) | LOCATION: Spray Dryer 7th Floor | SIZE: 800-600-250 mm

SUMMARY: Total Channels: 195 | Active: 151 | Spare: 44 (22.6%) | DI: 93 | DO: 64 | AI: 32 | AO: 5 | BUS: 1

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
156	C2S07-X2	C2/S7	C2S07,26	1756-OB32-26	DO	24 VDC energized,...	XV-60263FM	XV-60263FM_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
157	C2S05-X1	C2/S5	C2S05,12	1756-IB32-12	DI	24 VDC energized,...	XV-60263SJ	XV-60263SJ_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
158	C2S05-X1	C2/S5	C2S05,13	1756-IB32-13	DI	24 VDC energized,...	XV-60263SJ	XV-60263SJ_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
159	C2S07-X2	C2/S7	C2S07,27	1756-OB32-27	DO	24 VDC energized,...	XV-60263SJ	XV-60263SJ_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
160	C2S05-X1	C2/S5	C2S05,14	1756-IB32-14	DI	24 VDC energized,...	XV-60263SK	XV-60263SK_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
161	C2S05-X1	C2/S5	C2S05,15	1756-IB32-15	DI	24 VDC energized,...	XV-60263SK	XV-60263SK_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
162	C2S07-X2	C2/S7	C2S07,28	1756-OB32-28	DO	24 VDC energized,...	XV-60263SK	XV-60263SK_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
163	C2S05-X2	C2/S5	C2S05,16	1756-IB32-16	DI	24 VDC energized,...	XV-60263SL	XV-60263SL_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
164	C2S05-X2	C2/S5	C2S05,17	1756-IB32-17	DI	24 VDC energized,...	XV-60263SL	XV-60263SL_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
165	C2S07-X2	C2/S7	C2S07,29	1756-OB32-29	DO	24 VDC energized,...	XV-60263SL	XV-60263SL_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
166	C2S05-X2	C2/S5	C2S05,18	1756-IB32-18	DI	24 VDC energized,...	XV-60263SM	XV-60263SM_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
167	C2S05-X2	C2/S5	C2S05,19	1756-IB32-19	DI	24 VDC energized,...	XV-60263SM	XV-60263SM_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
168	C2S07-X2	C2/S7	C2S07,30	1756-OB32-30	DO	24 VDC energized,...	XV-60263SM	XV-60263SM_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
169	C2S03-X1	C2/S3	C2S03,10	1756-IB32-10	DI	-	XV-60264	XV-60264_DI_1	325-01-600-PD-02	-	Spray Dryer / 7th
170	C2S03-X1	C2/S3	C2S03,11	1756-IB32-11	DI	-	XV-60264	XV-60264_DI_2	325-01-600-PD-02	-	Spray Dryer / 7th
171	C2S08-X1	C2/S8	C2S08,00	1756-OB32-0	DO	-	XV-60264	XV-60264_DO_1	325-01-600-PD-02	-	Spray Dryer / 7th
172	C2S03-X1	C2/S3	C2S03,12	1756-IB32-12	DI	24 VDC energized,...	XV-60264FN	XV-60264FN_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
173	C2S03-X1	C2/S3	C2S03,13	1756-IB32-13	DI	24 VDC energized,...	XV-60264FN	XV-60264FN_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
174	C2S08-X1	C2/S8	C2S08,01	1756-OB32-1	DO	24 VDC energized,...	XV-60264FN	XV-60264FN_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
175	C2S03-X1	C2/S3	C2S03,14	1756-IB32-14	DI	24 VDC energized,...	XV-60264FP	XV-60264FP_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
176	C2S03-X1	C2/S3	C2S03,15	1756-IB32-15	DI	24 VDC energized,...	XV-60264FP	XV-60264FP_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
177	C2S08-X1	C2/S8	C2S08,02	1756-OB32-2	DO	24 VDC energized,...	XV-60264FP	XV-60264FP_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
178	C2S03-X2	C2/S3	C2S03,18	1756-IB32-18	DI	24 VDC energized,...	XV-60264FQ	XV-60264FQ_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
179	C2S03-X2	C2/S3	C2S03,19	1756-IB32-19	DI	24 VDC energized,...	XV-60264FQ	XV-60264FQ_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
180	C2S08-X1	C2/S8	C2S08,03	1756-OB32-3	DO	24 VDC energized,...	XV-60264FQ	XV-60264FQ_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
181	C2S03-X2	C2/S3	C2S03,22	1756-IB32-22	DI	24 VDC energized,...	XV-60264FR	XV-60264FR_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
182	C2S03-X2	C2/S3	C2S03,23	1756-IB32-23	DI	24 VDC energized,...	XV-60264FR	XV-60264FR_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
183	C2S08-X1	C2/S8	C2S08,04	1756-OB32-4	DO	24 VDC energized,...	XV-60264FR	XV-60264FR_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
184	C2S03-X2	C2/S3	C2S03,26	1756-IB32-26	DI	24 VDC energized,...	XV-60264SN	XV-60264SN_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
185	C2S03-X2	C2/S3	C2S03,27	1756-IB32-27	DI	24 VDC energized,...	XV-60264SN	XV-60264SN_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
186	C2S08-X1	C2/S8	C2S08,05	1756-OB32-5	DO	24 VDC energized,...	XV-60264SN	XV-60264SN_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th

ENCLOSURE: JB-607 | TYPE: Field Junction Box (Standard) | LOCATION: Spray Dryer 7th Floor | SIZE: 800-600-250 mm

SUMMARY: Total Channels: 195 | Active: 151 | Spare: 44 (22.6%) | DI: 93 | DO: 64 | AI: 32 | AO: 5 | BUS: 1

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
187	C2S03-X2	C2/S3	C2S03,30	1756-IB32-30	DI	24 VDC energized,...	XV-60264SP	XV-60264SP_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
188	C2S03-X2	C2/S3	C2S03,31	1756-IB32-31	DI	24 VDC energized,...	XV-60264SP	XV-60264SP_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
189	C2S08-X1	C2/S8	C2S08,06	1756-OB32-6	DO	24 VDC energized,...	XV-60264SP	XV-60264SP_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
190	C2S04-X1	C2/S4	C2S04,02	1756-IB32-2	DI	24 VDC energized,...	XV-60264SQ	XV-60264SQ_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
191	C2S04-X1	C2/S4	C2S04,03	1756-IB32-3	DI	24 VDC energized,...	XV-60264SQ	XV-60264SQ_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
192	C2S08-X1	C2/S8	C2S08,07	1756-OB32-7	DO	24 VDC energized,...	XV-60264SQ	XV-60264SQ_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
193	C2S04-X1	C2/S4	C2S04,06	1756-IB32-6	DI	24 VDC energized,...	XV-60264SR	XV-60264SR_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
194	C2S04-X1	C2/S4	C2S04,07	1756-IB32-7	DI	24 VDC energized,...	XV-60264SR	XV-60264SR_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
195	C2S08-X1	C2/S8	C2S08,08	1756-OB32-8	DO	24 VDC energized,...	XV-60264SR	XV-60264SR_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th

ENCLOSURE: JB-608 | TYPE: Field Junction Box (Standard) | LOCATION: Spray Dryer 8th Floor | SIZE: 300-200-150 mm

SUMMARY: Total Channels: 6 | Active: 1 | Spare: 5 (83.3%) | DI: 0 | DO: 0 | AI: 6 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
1	C4S05-X1	C4/S5	C4S05,03	1756-IF16-3	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
2	C4S05-X1	C4/S5	C4S05,04	1756-IF16-4	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
3	C4S05-X1	C4/S5	C4S05,05	1756-IF16-5	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
4	C4S05-X1	C4/S5	C4S05,06	1756-IF16-6	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
5	C4S05-X1	C4/S5	C4S05,07	1756-IF16-7	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
6	C4S05-X1	C4/S5	C4S05,02	1756-IF16-2	AI	4 - 20 mA	TT-60245	TT-60245_AI_1	3-25-01-602-PD-05	0	Spray Dryer / 8th

ENCLOSURE: JB-612 | TYPE: Field Junction Box (Standard) | LOCATION: Packing Tower 2th Floor | SIZE: 450-300-150 mm

SUMMARY: Total Channels: 57 | Active: 37 | Spare: 20 (35.1%) | DI: 32 | DO: 16 | AI: 8 | AO: 0 | BUS: 1

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
1	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	Communication S...	Communication Signa...	325-01-613-PD-02	-	Packing Tower / ...
2	C4S02-X1	C4/S2	C4S02,00	1756-IB32-0	DI	Dry Contact	PSL-61305	PSL-61305_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
3	C4S02-X1	C4/S2	C4S02,01	1756-IB32-1	DI	Dry Contact	PSL-61306	PSL-61306_DI_1	3-25-01-613-PD-05	0	Packing Tower / ...
4	C4S05-X1	C4/S5	C4S05,08	1756-IF16-8	AI	4 - 20 mA	PT-61302	PT-61302_AI_1	3-25-01-613-PD-03	Pressure Transmitter	Packing Tower / ...
5	C4S05-X1	C4/S5	C4S05,12	1756-IF16-12	AI	4 - 20 mA	PT-61302	PT-61302_AI_1	3-25-01-613-PD-03	Pressure Transmitter	Packing Tower / ...
6	C4S05-X1	C4/S5	C4S05,09	1756-IF16-9	AI	4 - 20 mA	PT-61309	PT-61309_AI_1	3-25-01-613-PD-04	Pressure Transmitter	Packing Tower / ...
7	C4S05-X1	C4/S5	C4S05,13	1756-IF16-13	AI	4 - 20 mA	PT-61309	PT-61309_AI_1	3-25-01-613-PD-04	Pressure Transmitter	Packing Tower / ...
8	C4S02-X1	C4/S2	C4S02,02	1756-IB32-2	DI	-	PVM-61301	PVM-61301_DI_1	325-01-613-PD-03	-	Packing Tower / ...
9	C4S02-X1	C4/S2	C4S02,03	1756-IB32-3	DI	-	PVM-61301	PVM-61301_DI_2	325-01-613-PD-03	-	Packing Tower / ...
10	C4S04-X2	C4/S4	C4S04,16	1756-OB32-16	DO	-	PVM-61301	PVM-61301_DO_1	325-01-613-PD-03	-	Packing Tower / ...
11	C4S04-X2	C4/S4	C4S04,17	1756-OB32-17	DO	-	PVM-61301	PVM-61301_DO_2	325-01-613-PD-03	-	Packing Tower / ...
12	C4S02-X2	C4/S2	C4S02,17	1756-IB32-17	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
13	C4S02-X2	C4/S2	C4S02,18	1756-IB32-18	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
14	C4S02-X2	C4/S2	C4S02,19	1756-IB32-19	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
15	C4S02-X2	C4/S2	C4S02,20	1756-IB32-20	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
16	C4S02-X2	C4/S2	C4S02,21	1756-IB32-21	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
17	C4S02-X2	C4/S2	C4S02,22	1756-IB32-22	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
18	C4S02-X2	C4/S2	C4S02,23	1756-IB32-23	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
19	C4S02-X2	C4/S2	C4S02,24	1756-IB32-24	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
20	C4S02-X2	C4/S2	C4S02,25	1756-IB32-25	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
21	C4S02-X2	C4/S2	C4S02,26	1756-IB32-26	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
22	C4S02-X2	C4/S2	C4S02,27	1756-IB32-27	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
23	C4S02-X2	C4/S2	C4S02,28	1756-IB32-28	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
24	C4S02-X2	C4/S2	C4S02,29	1756-IB32-29	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
25	C4S02-X2	C4/S2	C4S02,30	1756-IB32-30	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
26	C4S02-X2	C4/S2	C4S02,31	1756-IB32-31	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
27	C4S04-X2	C4/S4	C4S04,31	1756-OB32-31	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	Packing Tower
28	C4S05-X1	C4/S5	C4S05,10	1756-IF16-10	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
29	C4S05-X1	C4/S5	C4S05,11	1756-IF16-11	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
30	C4S05-X1	C4/S5	C4S05,14	1756-IF16-14	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
31	C4S05-X1	C4/S5	C4S05,15	1756-IF16-15	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-

ENCLOSURE: JB-612 | TYPE: Field Junction Box (Standard) | LOCATION: Packing Tower 2th Floor | SIZE: 450-300-150 mm

SUMMARY: Total Channels: 57 | Active: 37 | Spare: 20 (35.1%) | DI: 32 | DO: 16 | AI: 8 | AO: 0 | BUS: 1

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
32	C4S04-X2	C4/S4	C4S04,18	1756-OB32-18	DO	-	SV-61307	SV-61307_DO_1	3-25-01-613-PD-01	-	Packing Tower / ...
33	C4S04-X2	C4/S4	C4S04,19	1756-OB32-19	DO	24 VDC energized	SV-61308	SV-61308_DO_1	325-01-613-PD-03	0	Packing Tower / ...
34	C4S04-X2	C4/S4	C4S04,20	1756-OB32-20	DO	24 VDC energized	SV-61309	SV-61309_DO_1	3-25-01-613-PD-03	0	Packing Tower / ...
35	C4S04-X2	C4/S4	C4S04,21	1756-OB32-21	DO	24 VDC energized	SV-61310	SV-61310_DO_1	325-01-613-PD-05	0	Packing Tower / ...
36	C4S04-X2	C4/S4	C4S04,22	1756-OB32-22	DO	24 VDC energized	SV-61311	SV-61311_DO_1	3-25-01-613-PD-05	0	Packing Tower / ...
37	C4S02-X1	C4/S2	C4S02,04	1756-IB32-4	DI	Dry Contact	XA-61301A	XA-61301A_DI_1	325-01-613-PD-02	0	Packing Tower / ...
38	C4S02-X1	C4/S2	C4S02,05	1756-IB32-5	DI	Dry Contact	XA-61301B	XA-61301B_DI_1	325-01-613-PD-02	0	Packing Tower / ...
39	C4S02-X1	C4/S2	C4S02,06	1756-IB32-6	DI	Dry Contact	XA-61301C	XA-61301C_DI_1	325-01-613-PD-02	0	Packing Tower / ...
40	C4S02-X1	C4/S2	C4S02,07	1756-IB32-7	DI	Dry Contact	XA-61301D	XA-61301D_DI_1	325-01-613-PD-02	0	Packing Tower / ...
41	C4S02-X1	C4/S2	C4S02,08	1756-IB32-8	DI	Dry Contact	XA-61301E	XA-61301E_DI_1	325-01-613-PD-02	0	Packing Tower / ...
42	C4S02-X1	C4/S2	C4S02,09	1756-IB32-9	DI	Dry Contact	XA-61301F	XA-61301F_DI_1	325-01-613-PD-02	0	Packing Tower / ...
43	C4S02-X1	C4/S2	C4S02,10	1756-IB32-10	DI	Dry Contact	XA-61301G	XA-61301G_DI_1	325-01-613-PD-02	0	Packing Tower / ...
44	C4S02-X1	C4/S2	C4S02,11	1756-IB32-11	DI	Dry Contact	XA-61301H	XA-61301H_DI_1	325-01-613-PD-02	0	Packing Tower / ...
45	C4S02-X1	C4/S2	C4S02,12	1756-IB32-12	DI	Dry Contact	XA-61301J	XA-61301J_DI_1	325-01-613-PD-02	0	Packing Tower / ...
46	C4S04-X2	C4/S4	C4S04,23	1756-OB32-23	DO	24 VDC energized	XS-61301A	XS-61301A_DO_1	325-01-613-PD-02	0	Packing Tower / ...
47	C4S04-X2	C4/S4	C4S04,24	1756-OB32-24	DO	24 VDC energized	XS-61301B	XS-61301B_DO_1	325-01-613-PD-02	0	Packing Tower / ...
48	C4S04-X2	C4/S4	C4S04,25	1756-OB32-25	DO	24 VDC energized	XS-61301C	XS-61301C_DO_1	325-01-613-PD-02	0	Packing Tower / ...
49	C4S04-X2	C4/S4	C4S04,26	1756-OB32-26	DO	24 VDC energized	XS-61301D	XS-61301D_DO_1	325-01-613-PD-02	0	Packing Tower / ...
50	C4S04-X2	C4/S4	C4S04,27	1756-OB32-27	DO	24 VDC energized	XS-61301E	XS-61301E_DO_1	325-01-613-PD-02	0	Packing Tower / ...
51	C4S04-X2	C4/S4	C4S04,28	1756-OB32-28	DO	24 VDC energized	XS-61301F	XS-61301F_DO_1	325-01-613-PD-02	0	Packing Tower / ...
52	C4S02-X1	C4/S2	C4S02,13	1756-IB32-13	DI	24 VDC energized	XV-61302	XV-61302_DI_1	3-25-01-613-PD-02	0	Packing Tower / ...
53	C4S02-X1	C4/S2	C4S02,14	1756-IB32-14	DI	24 VDC energized	XV-61302	XV-61302_DI_2	3-25-01-613-PD-02	0	Packing Tower / ...
54	C4S04-X2	C4/S4	C4S04,29	1756-OB32-29	DO	24 VDC energized	XV-61302	XV-61302_DO_1	3-25-01-613-PD-02	0	Packing Tower / ...
55	C4S02-X1	C4/S2	C4S02,15	1756-IB32-15	DI	24 VDC energized	XV-61303	XV-61303_DI_1	3-25-01-613-PD-02	0	Packing Tower / ...
56	C4S02-X2	C4/S2	C4S02,16	1756-IB32-16	DI	24 VDC energized	XV-61303	XV-61303_DI_2	3-25-01-613-PD-02	0	Packing Tower / ...
57	C4S04-X2	C4/S4	C4S04,30	1756-OB32-30	DO	24 VDC energized	XV-61303	XV-61303_DO_1	3-25-01-613-PD-02	0	Packing Tower / ...

ENCLOSURE: JB-618 | TYPE: Field Junction Box (Standard) | LOCATION: Packing Tower 8th Floor | SIZE: 450-300-150 mm

SUMMARY: Total Channels: 52 | Active: 25 | Spare: 27 (51.9%) | DI: 16 | DO: 32 | AI: 4 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
1	C3S01-X2	C3/S1	C3S01,16	1756-IB32-16	DI	24 VDC energized	DV-61301	DV-61301_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...
2	C3S01-X2	C3/S1	C3S01,17	1756-IB32-17	DI	24 VDC energized	DV-61301	DV-61301_DI_2	3-25-01-613-PD-01	0	Packing Tower / ...
3	C3S03-X1	C3/S3	C3S03,00	1756-OB32-0	DO	24 VDC energized	DV-61301	DV-61301_DO_1	3-25-01-613-PD-01	0	Packing Tower / ...
4	C3S01-X2	C3/S1	C3S01,18	1756-IB32-18	DI	24 VDC energized	DV-61302	DV-61302_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...
5	C3S01-X2	C3/S1	C3S01,19	1756-IB32-19	DI	24 VDC energized	DV-61302	DV-61302_DI_2	3-25-01-613-PD-01	0	Packing Tower / ...
6	C3S03-X1	C3/S3	C3S03,01	1756-OB32-1	DO	24 VDC energized	DV-61302	DV-61302_DO_1	3-25-01-613-PD-01	0	Packing Tower / ...
7	C3S01-X2	C3/S1	C3S01,20	1756-IB32-20	DI	Dry Contact	LS-61303	LS-61303_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...
8	C3S01-X2	C3/S1	C3S01,21	1756-IB32-21	DI	Dry Contact	PSL-61301	PSL-61301_DI_1	325-01-613-PD-01	0	Packing Tower / ...
9	C3S01-X2	C3/S1	C3S01,22	1756-IB32-22	DI	Dry Contact	PSL-61302	PSL-61302_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...
10	C3S02-X2	C3/S2	C3S02,23	1756-IB32-23	DI	Dry Contact	PSL-61311	PSL-61311_DI_1	3-25-01-613-PD-04	0	Packing Tower / ...
11	C3S05-X1	C3/S5	C3S05,00	1756-IF16-0	AI	4 - 20 mA	PT-61303	PT-61303_AI_1	3-25-01-613-PD-01	Pressure Transmitter	Packing Tower / ...
12	C3S05-X1	C3/S5	C3S05,01	1756-IF16-1	AI	-	PT-61306	PT-61306_AI_1	3-25-01-613-PD-01	-	Packing Tower / ...
13	C3S01-X2	C3/S1	C3S01,28	1756-IB32-28	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Packing Tower
14	C3S01-X2	C3/S1	C3S01,29	1756-IB32-29	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Packing Tower
15	C3S01-X2	C3/S1	C3S01,30	1756-IB32-30	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Packing Tower
16	C3S01-X2	C3/S1	C3S01,31	1756-IB32-31	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Packing Tower
17	C3S03-X1	C3/S3	C3S03,09	1756-OB32-9	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
18	C3S03-X1	C3/S3	C3S03,10	1756-OB32-10	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
19	C3S03-X1	C3/S3	C3S03,11	1756-OB32-11	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
20	C3S03-X1	C3/S3	C3S03,12	1756-OB32-12	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
21	C3S03-X1	C3/S3	C3S03,13	1756-OB32-13	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
22	C3S03-X1	C3/S3	C3S03,14	1756-OB32-14	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
23	C3S03-X1	C3/S3	C3S03,15	1756-OB32-15	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
24	C3S03-X2	C3/S3	C3S03,16	1756-OB32-16	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
25	C3S03-X2	C3/S3	C3S03,17	1756-OB32-17	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
26	C3S03-X2	C3/S3	C3S03,18	1756-OB32-18	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
27	C3S03-X2	C3/S3	C3S03,19	1756-OB32-19	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
28	C3S03-X2	C3/S3	C3S03,20	1756-OB32-20	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
29	C3S03-X2	C3/S3	C3S03,21	1756-OB32-21	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
30	C3S03-X2	C3/S3	C3S03,22	1756-OB32-22	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
31	C3S03-X2	C3/S3	C3S03,23	1756-OB32-23	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-

ENCLOSURE: JB-618 | TYPE: Field Junction Box (Standard) | LOCATION: Packing Tower 8th Floor | SIZE: 450-300-150 mm

SUMMARY: Total Channels: 52 | Active: 25 | Spare: 27 (51.9%) | DI: 16 | DO: 32 | AI: 4 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
32	C3S03-X2	C3/S3	C3S03,24	1756-OB32-24	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
33	C3S03-X2	C3/S3	C3S03,25	1756-OB32-25	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
34	C3S03-X2	C3/S3	C3S03,26	1756-OB32-26	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
35	C3S03-X2	C3/S3	C3S03,27	1756-OB32-27	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
36	C3S03-X2	C3/S3	C3S03,28	1756-OB32-28	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
37	C3S03-X2	C3/S3	C3S03,29	1756-OB32-29	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
38	C3S03-X2	C3/S3	C3S03,30	1756-OB32-30	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
39	C3S03-X2	C3/S3	C3S03,31	1756-OB32-31	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
40	C3S03-X1	C3/S3	C3S03,02	1756-OB32-2	DO	24 VDC energized	SV-61301	SV-61301_DO_1	325-01-613-PD-01	0	Packing Tower / ...
41	C3S03-X1	C3/S3	C3S03,03	1756-OB32-3	DO	24 VDC energized	SV-61302	SV-61302_DO_1	3-25-01-613-PD-01	0	Packing Tower / ...
42	C3S03-X1	C3/S3	C3S03,04	1756-OB32-4	DO	24 VDC energized	SV-61303	SV-61303_DO_1	3-25-01-613-PD-01	0	Packing Tower / ...
43	C3S02-X2	C3/S2	C3S02,24	1756-IB32-24	DI	24 VDC energized	SV-61304	SV-61304_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...
44	C3S02-X2	C3/S2	C3S02,25	1756-IB32-25	DI	24 VDC energized	SV-61304	SV-61304_DI_2	3-25-01-613-PD-01	0	Packing Tower / ...
45	C3S03-X1	C3/S3	C3S03,05	1756-OB32-5	DO	24 VDC energized	SV-61304	SV-61304_DO_1	3-25-01-613-PD-01	0	Packing Tower / ...
46	C3S03-X1	C3/S3	C3S03,06	1756-OB32-6	DO	24 VDC energized	SV-61305	SV-61305_DO_1	3-25-01-613-PD-01	0	Packing Tower / ...
47	C3S03-X1	C3/S3	C3S03,07	1756-OB32-7	DO	-	SV-61306	SV-61306_DO_1	3-25-01-613-PD-01	-	Packing Tower / ...
48	C3S05-X1	C3/S5	C3S05,02	1756-IF16-2	AI	-	TT-61303	TT-61303_AI_1	3-25-01-613-PD-01	-	Packing Tower / ...
49	C3S05-X1	C3/S5	C3S05,03	1756-IF16-3	AI	-	TT-61304	TT-61304_AI_1	3-25-01-613-PD-01	-	Packing Tower / ...
50	C3S02-X2	C3/S2	C3S02,26	1756-IB32-26	DI	24 VDC energized	XV-61301	XV-61301_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...
51	C3S02-X2	C3/S2	C3S02,27	1756-IB32-27	DI	24 VDC energized	XV-61301	XV-61301_DI_2	3-25-01-613-PD-01	0	Packing Tower / ...
52	C3S03-X1	C3/S3	C3S03,08	1756-OB32-8	DO	24 VDC energized	XV-61301	XV-61301_DO_1	3-25-01-613-PD-01	0	Packing Tower / ...

ENCLOSURE: MCC | TYPE: Motor Control Center Enclosure (MCC) | LOCATION: MCC Room | SIZE: Draw-out Switchgear Panel mm

SUMMARY: Total Channels: 237 | Active: 169 | Spare: 68 (28.7%) | DI: 125 | DO: 95 | AI: 0 | AO: 0 | BUS: 17

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
1	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	ATY-40201	ATY-40201_BUS_1	3-25-01-402-PD-01	Tank Agitator	PH Adjustment / ...
2	C7S01-	C7/S1	C7S01,08	-	DI	24 VDC energized	ATY-40201	ATY-40201_DI_1	3-25-01-402-PD-01	Tank Agitator	PH Adjustment / ...
3	C7S01-	C7/S1	C7S01,09	-	DI	24 VDC energized	ATY-40201	ATY-40201_DI_2	3-25-01-402-PD-01	Tank Agitator	PH Adjustment / ...
4	C7S01-	C7/S1	C7S01,10	-	DI	24 VDC energized	ATY-40201	ATY-40201_DI_3	3-25-01-402-PD-01	Tank Agitator	PH Adjustment / ...
5	C7S05-	C7/S5	C7S05,08	-	DO	24 VDC energized	ATY-40201	ATY-40201_DO_1	3-25-01-402-PD-01	Tank Agitator	PH Adjustment / ...
6	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	ATY-40202	ATY-40202_BUS_1	3-25-01-402-PD-01	Tank Agitator	PH Adjustment / ...
7	C7S01-	C7/S1	C7S01,11	-	DI	24 VDC energized	ATY-40202	ATY-40202_DI_1	3-25-01-402-PD-01	Tank Agitator	PH Adjustment / ...
8	C7S01-	C7/S1	C7S01,12	-	DI	24 VDC energized	ATY-40202	ATY-40202_DI_2	3-25-01-402-PD-01	Tank Agitator	PH Adjustment / ...
9	C7S01-	C7/S1	C7S01,13	-	DI	24 VDC energized	ATY-40202	ATY-40202_DI_3	3-25-01-402-PD-01	Tank Agitator	PH Adjustment / ...
10	C7S05-	C7/S5	C7S05,09	-	DO	24 VDC energized	ATY-40202	ATY-40202_DO_1	3-25-01-402-PD-01	Tank Agitator	PH Adjustment / ...
11	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	ATY-40203	ATY-40203_BUS_1	3-25-01-402-PD-02	Tank Agitator	Infeed Tank / 1st
12	C7S01-	C7/S1	C7S01,14	-	DI	24 VDC energized	ATY-40203	ATY-40203_DI_1	3-25-01-402-PD-02	Tank Agitator	Infeed Tank / 1st
13	C7S01-	C7/S1	C7S01,15	-	DI	24 VDC energized	ATY-40203	ATY-40203_DI_2	3-25-01-402-PD-02	Tank Agitator	Infeed Tank / 1st
14	C7S01-	C7/S1	C7S01,16	-	DI	24 VDC energized	ATY-40203	ATY-40203_DI_3	3-25-01-402-PD-02	Tank Agitator	Infeed Tank / 1st
15	C7S05-	C7/S5	C7S05,10	-	DO	24 VDC energized	ATY-40203	ATY-40203_DO_1	3-25-01-402-PD-02	Tank Agitator	Infeed Tank / 1st
16	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	BFY-60206	BFY-60206_BUS_1	325-01-600-PD-08	0	Spray Dryer / 1st
17	C7S01-	C7/S1	C7S01,26	-	DI	24 VDC energized	BFY-60206	BFY-60206_DI_1	325-01-600-PD-08	0	Spray Dryer / 1st
18	C7S05-	C7/S5	C7S05,14	-	DO	24 VDC energized	BFY-60206	BFY-60206_DO_1	325-01-600-PD-08	0	Spray Dryer / 1st
19	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	BFY-60210	BFY-60210_BUS_1	325-01-600-PD-03	0	Spray Dryer / 5th
20	C7S02-	C7/S2	C7S02,11	-	DI	24 VDC energized	BFY-60210	BFY-60210_DI_1	325-01-600-PD-03	0	Spray Dryer / 5th
21	C7S05-	C7/S5	C7S05,30	-	DO	24 VDC energized	BFY-60210	BFY-60210_DO_1	325-01-600-PD-03	0	Spray Dryer / 5th
22	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	BFY-60211	BFY-60211_BUS_1	325-01-600-PD-03	0	Spray Dryer / 5th
23	C7S02-	C7/S2	C7S02,12	-	DI	24 VDC energized	BFY-60211	BFY-60211_DI_1	325-01-600-PD-03	0	Spray Dryer / 5th
24	C7S05-	C7/S5	C7S05,31	-	DO	24 VDC energized	BFY-60211	BFY-60211_DO_1	325-01-600-PD-03	0	Spray Dryer / 5th
25	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	BFY-60220	BFY-60220_BUS_1	325-01-600-PD-04	0	Spray Dryer / 7th
26	C7S02-	C7/S2	C7S02,17	-	DI	24 VDC energized	BFY-60220	BFY-60220_DI_1	325-01-600-PD-04	0	Spray Dryer / 7th
27	C7S06-	C7/S6	C7S06,07	-	DO	24 VDC energized	BFY-60220	BFY-60220_DO_1	325-01-600-PD-04	0	Spray Dryer / 7th
28	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	BFY-60240	BFY-60240_BUS_1	325-01-600-PD-05	0	Spray Dryer / 5th
29	C7S02-	C7/S2	C7S02,13	-	DI	24 VDC energized	BFY-60240	BFY-60240_DI_1	325-01-600-PD-05	0	Spray Dryer / 5th
30	C7S06-	C7/S6	C7S06,00	-	DO	24 VDC energized	BFY-60240	BFY-60240_DO_1	325-01-600-PD-05	0	Spray Dryer / 5th
31	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	BFY-61301	BFY-61301_BUS_1	325-01-613-PD-01	0	Packing Tower / ...

ENCLOSURE: MCC | TYPE: Motor Control Center Enclosure (MCC) | LOCATION: MCC Room | SIZE: Draw-out Switchgear Panel mm

SUMMARY: Total Channels: 237 | Active: 169 | Spare: 68 (28.7%) | DI: 125 | DO: 95 | AI: 0 | AO: 0 | BUS: 17

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
32	C7S03-	C7/S3	C7S03,08	-	DI	24 VDC energized	BFY-61301	BFY-61301_DI_1	325-01-613-PD-01	0	Packing Tower / ...
33	C7S06-	C7/S6	C7S06,19	-	DO	24 VDC energized	BFY-61301	BFY-61301_DO_1	325-01-613-PD-01	0	Packing Tower / ...
34	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	BFY-61302	BFY-61302_BUS_1	325-01-613-PD-05	0	Packing Tower / ...
35	C7S02-	C7/S2	C7S02,18	-	DI	24 VDC energized	BFY-61302	BFY-61302_DI_1	325-01-613-PD-05	0	Packing Tower / ...
36	C7S06-	C7/S6	C7S06,10	-	DO	24 VDC energized	BFY-61302	BFY-61302_DO_1	325-01-613-PD-05	0	Packing Tower / ...
37	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	BFY-61303	BFY-61303_BUS_1	325-01-613-PD-01	0	Packing Tower / ...
38	C7S03-	C7/S3	C7S03,09	-	DI	24 VDC energized	BFY-61303	BFY-61303_DI_1	325-01-613-PD-01	0	Packing Tower / ...
39	C7S06-	C7/S6	C7S06,20	-	DO	24 VDC energized	BFY-61303	BFY-61303_DO_1	325-01-613-PD-01	0	Packing Tower / ...
40	C7S03-	C7/S3	C7S03,10	-	DI	24 VDC energized	BLM-61302	BLM-61302_DI_1	325-01-613-PD-01	0	Packing Tower / ...
41	C7S03-	C7/S3	C7S03,11	-	DI	24 VDC energized	BLM-61302	BLM-61302_DI_2	325-01-613-PD-01	0	Packing Tower / ...
42	C7S06-	C7/S6	C7S06,21	-	DO	24 VDC energized	BLM-61302	BLM-61302_DO_1	325-01-613-PD-01	0	Packing Tower / ...
43	C7S06-	C7/S6	C7S06,22	-	DO	24 VDC energized	BLM-61302	BLM-61302_DO_2	325-01-613-PD-01	0	Packing Tower / ...
44	C7S03-	C7/S3	C7S03,12	-	DI	Dry Contact	HS-61307A	HS-61307A_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
45	C7S03-	C7/S3	C7S03,13	-	DI	Dry Contact	HS-61307B	HS-61307B_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
46	C7S03-	C7/S3	C7S03,14	-	DI	Dry Contact	HS-61307C	HS-61307C_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
47	C7S03-	C7/S3	C7S03,15	-	DI	Dry Contact	HS-61307D	HS-61307D_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
48	C7S03-	C7/S3	C7S03,16	-	DI	Dry Contact	HS-61307E	HS-61307E_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
49	C7S02-	C7/S2	C7S02,19	-	DI	Dry Contact	HS-61307F	HS-61307F_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
50	C7S02-	C7/S2	C7S02,20	-	DI	Dry Contact	HS-61307G	HS-61307G_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
51	C7S02-	C7/S2	C7S02,21	-	DI	Dry Contact	HS-61307H	HS-61307H_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
52	C7S02-	C7/S2	C7S02,22	-	DI	Dry Contact	HS-61307I	HS-61307I_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
53	C7S02-	C7/S2	C7S02,23	-	DI	Dry Contact	HS-61307J	HS-61307J_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
54	C7S02-	C7/S2	C7S02,24	-	DI	Dry Contact	HS-61307K	HS-61307K_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
55	C7S02-	C7/S2	C7S02,25	-	DI	Dry Contact	HS-61307L	HS-61307L_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
56	C7S02-	C7/S2	C7S02,26	-	DI	Dry Contact	HS-61307M	HS-61307M_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
57	C7S02-	C7/S2	C7S02,27	-	DI	Dry Contact	HS-61307N	HS-61307N_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
58	C7S02-	C7/S2	C7S02,28	-	DI	Dry Contact	HS-61307O	HS-61307O_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
59	C7S02-	C7/S2	C7S02,29	-	DI	Dry Contact	HS-61307P	HS-61307P_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
60	C7S02-	C7/S2	C7S02,30	-	DI	Dry Contact	HS-61307Q	HS-61307Q_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
61	C7S02-	C7/S2	C7S02,31	-	DI	Dry Contact	HS-61307R	HS-61307R_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
62	C6S05-	C6/S5	C6S05,00	-	DO	-	PCM-2030	PCM-2030_DO_1	3-25-01-202-PD-01	-	Slurry - Out Buildi...

ENCLOSURE: MCC | TYPE: Motor Control Center Enclosure (MCC) | LOCATION: MCC Room | SIZE: Draw-out Switchgear Panel mm

SUMMARY: Total Channels: 237 | Active: 169 | Spare: 68 (28.7%) | DI: 125 | DO: 95 | AI: 0 | AO: 0 | BUS: 17

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
63	C6S05-	C6/S5	C6S05,01	-	DO	-	PCM-2030	PCM-2030_DO_2	3-25-01-202-PD-01	-	Slurry - Out Buildi...
64	C6S06-	C6/S6	C6S06,00	-	DI	-	PCM-2030	PCM-2030_DI_1	3-25-01-202-PD-01	-	Slurry - Out Buildi...
65	C6S06-	C6/S6	C6S06,01	-	DI	-	PCM-2030	PCM-2030_DI_2	3-25-01-202-PD-01	-	Slurry - Out Buildi...
66	C6S05-	C6/S5	C6S05,02	-	DO	24 VDC energized	PCM-2031	PCM-2031_DO_1	3-25-01-202-PD-01	0	Slurry - Out Buildi...
67	C6S05-	C6/S5	C6S05,03	-	DO	24 VDC energized	PCM-2031	PCM-2031_DO_2	3-25-01-202-PD-01	0	Slurry - Out Buildi...
68	C6S06-	C6/S6	C6S06,02	-	DI	24 VDC energized	PCM-2031	PCM-2031_DI_1	3-25-01-202-PD-01	0	Slurry - Out Buildi...
69	C6S06-	C6/S6	C6S06,03	-	DI	24 VDC energized	PCM-2031	PCM-2031_DI_2	3-25-01-202-PD-01	0	Slurry - Out Buildi...
70	C7S01-	C7/S1	C7S01,27	-	DI	-	PCM-60205-2	PCM-60205-2_DI_1	325-01-600-PD-01	-	Spray Dryer / 1st
71	C7S01-	C7/S1	C7S01,28	-	DI	-	PCM-60205-2	PCM-60205-2_DI_2	325-01-600-PD-01	-	Spray Dryer / 1st
72	C7S05-	C7/S5	C7S05,15	-	DO	-	PCM-60205-2	PCM-60205-2_DO_1	325-01-600-PD-01	-	Spray Dryer / 1st
73	C7S05-	C7/S5	C7S05,16	-	DO	-	PCM-60205-2	PCM-60205-2_DO_2	325-01-600-PD-01	-	Spray Dryer / 1st
74	C7S01-	C7/S1	C7S01,29	-	DI	-	PCM-60205-3	PCM-60205-3_DI_1	325-01-600-PD-01	-	Spray Dryer / 1st
75	C7S01-	C7/S1	C7S01,30	-	DI	-	PCM-60205-3	PCM-60205-3_DI_2	325-01-600-PD-01	-	Spray Dryer / 1st
76	C7S05-	C7/S5	C7S05,17	-	DO	-	PCM-60205-3	PCM-60205-3_DO_1	325-01-600-PD-01	-	Spray Dryer / 1st
77	C7S05-	C7/S5	C7S05,18	-	DO	-	PCM-60205-3	PCM-60205-3_DO_2	325-01-600-PD-01	-	Spray Dryer / 1st
78	C7S01-	C7/S1	C7S01,31	-	DI	-	PCM-60205-4	PCM-60205-4_DI_1	325-01-600-PD-01	-	Spray Dryer / 1st
79	C7S02-	C7/S2	C7S02,00	-	DI	-	PCM-60205-4	PCM-60205-4_DI_2	325-01-600-PD-01	-	Spray Dryer / 1st
80	C7S05-	C7/S5	C7S05,19	-	DO	-	PCM-60205-4	PCM-60205-4_DO_1	325-01-600-PD-01	-	Spray Dryer / 1st
81	C7S05-	C7/S5	C7S05,20	-	DO	-	PCM-60205-4	PCM-60205-4_DO_2	325-01-600-PD-01	-	Spray Dryer / 1st
82	C7S02-	C7/S2	C7S02,01	-	DI	-	PCM-60205-5	PCM-60205-5_DI_1	325-01-600-PD-01	-	Spray Dryer / 1st
83	C7S02-	C7/S2	C7S02,02	-	DI	-	PCM-60205-5	PCM-60205-5_DI_2	325-01-600-PD-01	-	Spray Dryer / 1st
84	C7S05-	C7/S5	C7S05,21	-	DO	-	PCM-60205-5	PCM-60205-5_DO_1	325-01-600-PD-01	-	Spray Dryer / 1st
85	C7S05-	C7/S5	C7S05,22	-	DO	-	PCM-60205-5	PCM-60205-5_DO_2	325-01-600-PD-01	-	Spray Dryer / 1st
86	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	PCY-40201	PCY-40201_BUS_1	3-25-01-402-PD-01	PUMP	PH Adjustment / ...
87	C7S01-	C7/S1	C7S01,17	-	DI	24 VDC energized	PCY-40201	PCY-40201_DI_1	3-25-01-402-PD-01	PUMP	PH Adjustment / ...
88	C7S01-	C7/S1	C7S01,18	-	DI	24 VDC energized	PCY-40201	PCY-40201_DI_2	3-25-01-402-PD-01	PUMP	PH Adjustment / ...
89	C7S01-	C7/S1	C7S01,19	-	DI	24 VDC energized	PCY-40201	PCY-40201_DI_3	3-25-01-402-PD-01	PUMP	PH Adjustment / ...
90	C7S05-	C7/S5	C7S05,11	-	DO	24 VDC energized	PCY-40201	PCY-40201_DO_1	3-25-01-402-PD-01	PUMP	PH Adjustment / ...
91	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	PCY-40202	PCY-40202_BUS_1	3-25-01-402-PD-01	PUMP	PH Adjustment / ...
92	C7S01-	C7/S1	C7S01,20	-	DI	24 VDC energized	PCY-40202	PCY-40202_DI_1	3-25-01-402-PD-01	PUMP	PH Adjustment / ...
93	C7S01-	C7/S1	C7S01,21	-	DI	24 VDC energized	PCY-40202	PCY-40202_DI_2	3-25-01-402-PD-01	PUMP	PH Adjustment / ...

ENCLOSURE: MCC | TYPE: Motor Control Center Enclosure (MCC) | LOCATION: MCC Room | SIZE: Draw-out Switchgear Panel mm

SUMMARY: Total Channels: 237 | Active: 169 | Spare: 68 (28.7%) | DI: 125 | DO: 95 | AI: 0 | AO: 0 | BUS: 17

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
94	C7S01-	C7/S1	C7S01,22	-	DI	24 VDC energized	PCY-40202	PCY-40202_DI_3	3-25-01-402-PD-01	PUMP	PH Adjustment / ...
95	C7S05-	C7/S5	C7S05,12	-	DO	24 VDC energized	PCY-40202	PCY-40202_DO_1	3-25-01-402-PD-01	PUMP	PH Adjustment / ...
96	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	PCY-40203	PCY-40203_BUS_1	3-25-01-402-PD-02	PUMP	Infeed Tank / 1st
97	C7S01-	C7/S1	C7S01,23	-	DI	24 VDC energized	PCY-40203	PCY-40203_DI_1	3-25-01-402-PD-02	PUMP	Infeed Tank / 1st
98	C7S01-	C7/S1	C7S01,24	-	DI	24 VDC energized	PCY-40203	PCY-40203_DI_2	3-25-01-402-PD-02	PUMP	Infeed Tank / 1st
99	C7S01-	C7/S1	C7S01,25	-	DI	24 VDC energized	PCY-40203	PCY-40203_DI_3	3-25-01-402-PD-02	PUMP	Infeed Tank / 1st
100	C7S05-	C7/S5	C7S05,13	-	DO	24 VDC energized	PCY-40203	PCY-40203_DO_1	3-25-01-402-PD-02	PUMP	Infeed Tank / 1st
101	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	PCY-60215	PCY-60215_BUS_1	325-01-600-PD-03	PUMP	Spray Dryer / 5th
102	C7S02-	C7/S2	C7S02,14	-	DI	24 VDC energized	PCY-60215	PCY-60215_DI_1	325-01-600-PD-03	PUMP	Spray Dryer / 5th
103	C7S02-	C7/S2	C7S02,15	-	DI	24 VDC energized	PCY-60215	PCY-60215_DI_2	325-01-600-PD-03	PUMP	Spray Dryer / 5th
104	C7S02-	C7/S2	C7S02,16	-	DI	24 VDC energized	PCY-60215	PCY-60215_DI_3	325-01-600-PD-03	PUMP	Spray Dryer / 5th
105	C7S06-	C7/S6	C7S06,01	-	DO	24 VDC energized	PCY-60215	PCY-60215_DO_1	325-01-600-PD-03	PUMP	Spray Dryer / 5th
106	C6S05-	C6/S5	C6S05,04	-	DO	24 VDC energized	PCY-814201	PCY-814201_DO_1	3-25-01-810-PD-01	PUMP	CIP Water Syste...
107	C6S06-	C6/S6	C6S06,04	-	DI	24 VDC energized	PCY-814201	PCY-814201_DI_1	3-25-01-810-PD-01	PUMP	CIP Water Syste...
108	C6S06-	C6/S6	C6S06,05	-	DI	24 VDC energized	PCY-814201	PCY-814201_DI_2	3-25-01-810-PD-01	PUMP	CIP Water Syste...
109	C6S06-	C6/S6	C6S06,06	-	DI	24 VDC energized	PCY-814201	PCY-814201_DI_3	3-25-01-810-PD-01	PUMP	CIP Water Syste...
110	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	PCY-814201	PCY-814201_BUS_1	3-25-01-810-PD-01	PUMP	CIP Water Syste...
111	C6S05-	C6/S5	C6S05,05	-	DO	24 VDC energized	PCY-814202	PCY-814202_DO_1	3-25-01-810-PD-01	PUMP	CIP Water Syste...
112	C6S06-	C6/S6	C6S06,07	-	DI	24 VDC energized	PCY-814202	PCY-814202_DI_1	3-25-01-810-PD-01	PUMP	CIP Water Syste...
113	C6S06-	C6/S6	C6S06,08	-	DI	24 VDC energized	PCY-814202	PCY-814202_DI_2	3-25-01-810-PD-01	PUMP	CIP Water Syste...
114	C6S06-	C6/S6	C6S06,09	-	DI	24 VDC energized	PCY-814202	PCY-814202_DI_3	3-25-01-810-PD-01	PUMP	CIP Water Syste...
115	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	PCY-814202	PCY-814202_BUS_1	3-25-01-810-PD-01	PUMP	CIP Water Syste...
116	C7S02-	C7/S2	C7S02,05	-	DI	24 VDC energized	RVM-60201	RVM-60201_DI_1	325-01-600-PD-08	0	Spray Dryer / 1st
117	C7S02-	C7/S2	C7S02,06	-	DI	24 VDC energized	RVM-60201	RVM-60201_DI_2	325-01-600-PD-08	0	Spray Dryer / 1st
118	C7S05-	C7/S5	C7S05,23	-	DO	24 VDC energized	RVM-60201	RVM-60201_DO_1	325-01-600-PD-08	0	Spray Dryer / 1st
119	C7S05-	C7/S5	C7S05,24	-	DO	24 VDC energized	RVM-60201	RVM-60201_DO_2	325-01-600-PD-08	0	Spray Dryer / 1st
120	C7S02-	C7/S2	C7S02,07	-	DI	24 VDC energized	RVM-60202	RVM-60202_DI_1	325-01-600-PD-08	0	Spray Dryer / 1st
121	C7S02-	C7/S2	C7S02,08	-	DI	24 VDC energized	RVM-60202	RVM-60202_DI_2	325-01-600-PD-08	0	Spray Dryer / 1st
122	C7S05-	C7/S5	C7S05,25	-	DO	24 VDC energized	RVM-60202	RVM-60202_DO_1	325-01-600-PD-08	0	Spray Dryer / 1st
123	C7S05-	C7/S5	C7S05,26	-	DO	24 VDC energized	RVM-60202	RVM-60202_DO_2	325-01-600-PD-08	0	Spray Dryer / 1st
124	C7S02-	C7/S2	C7S02,09	-	DI	24 VDC energized	RVM-60203	RVM-60203_DI_1	325-01-600-PD-08	0	Spray Dryer / 1st

ENCLOSURE: MCC | TYPE: Motor Control Center Enclosure (MCC) | LOCATION: MCC Room | SIZE: Draw-out Switchgear Panel mm

SUMMARY: Total Channels: 237 | Active: 169 | Spare: 68 (28.7%) | DI: 125 | DO: 95 | AI: 0 | AO: 0 | BUS: 17

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
125	C7S02-	C7/S2	C7S02,10	-	DI	24 VDC energized	RVM-60203	RVM-60203_DI_2	325-01-600-PD-08	0	Spray Dryer / 1st
126	C7S05-	C7/S5	C7S05,27	-	DO	24 VDC energized	RVM-60203	RVM-60203_DO_1	325-01-600-PD-08	0	Spray Dryer / 1st
127	C7S05-	C7/S5	C7S05,28	-	DO	24 VDC energized	RVM-60203	RVM-60203_DO_2	325-01-600-PD-08	0	Spray Dryer / 1st
128	C7S03-	C7/S3	C7S03,17	-	DI	24 VDC energized	RVM-60204	RVM-60204_DI_1	325-01-600-PD-08	0	Packing Tower / ...
129	C7S03-	C7/S3	C7S03,18	-	DI	24 VDC energized	RVM-60204	RVM-60204_DI_2	325-01-600-PD-08	0	Packing Tower / ...
130	C7S06-	C7/S6	C7S06,23	-	DO	24 VDC energized	RVM-60204	RVM-60204_DO_1	325-01-600-PD-08	0	Packing Tower / ...
131	C7S06-	C7/S6	C7S06,24	-	DO	24 VDC energized	RVM-60204	RVM-60204_DO_2	325-01-600-PD-08	0	Packing Tower / ...
132	C7S03-	C7/S3	C7S03,19	-	DI	24 VDC energized	RVM-61301	RVM-61301_DI_1	325-01-613-PD-01	0	Packing Tower / ...
133	C7S03-	C7/S3	C7S03,20	-	DI	24 VDC energized	RVM-61301	RVM-61301_DI_2	325-01-613-PD-01	0	Packing Tower / ...
134	C7S06-	C7/S6	C7S06,25	-	DO	24 VDC energized	RVM-61301	RVM-61301_DO_1	325-01-613-PD-01	0	Packing Tower / ...
135	C7S06-	C7/S6	C7S06,26	-	DO	24 VDC energized	RVM-61301	RVM-61301_DO_2	325-01-613-PD-01	0	Packing Tower / ...
136	C7S03-	C7/S3	C7S03,00	-	DI	24 VDC energized	RVM-61302	RVM-61302_DI_1	325-01-613-PD-03	0	Packing Tower / ...
137	C7S03-	C7/S3	C7S03,01	-	DI	24 VDC energized	RVM-61302	RVM-61302_DI_2	325-01-613-PD-03	0	Packing Tower / ...
138	C7S06-	C7/S6	C7S06,11	-	DO	24 VDC energized	RVM-61302	RVM-61302_DO_1	325-01-613-PD-03	0	Packing Tower / ...
139	C7S06-	C7/S6	C7S06,12	-	DO	24 VDC energized	RVM-61302	RVM-61302_DO_2	325-01-613-PD-03	0	Packing Tower / ...
140	C7S03-	C7/S3	C7S03,02	-	DI	24 VDC energized	RVM-61303	RVM-61303_DI_1	325-01-613-PD-05	0	Packing Tower / ...
141	C7S03-	C7/S3	C7S03,03	-	DI	24 VDC energized	RVM-61303	RVM-61303_DI_2	325-01-613-PD-05	0	Packing Tower / ...
142	C7S06-	C7/S6	C7S06,13	-	DO	24 VDC energized	RVM-61303	RVM-61303_DO_1	325-01-613-PD-05	0	Packing Tower / ...
143	C7S06-	C7/S6	C7S06,14	-	DO	24 VDC energized	RVM-61303	RVM-61303_DO_2	325-01-613-PD-05	0	Packing Tower / ...
144	C7S03-	C7/S3	C7S03,21	-	DI	24 VDC energized	RVM-61304	RVM-61304_DI_1	325-01-613-PD-01	0	Packing Tower / ...
145	C7S03-	C7/S3	C7S03,22	-	DI	24 VDC energized	RVM-61304	RVM-61304_DI_2	325-01-613-PD-01	0	Packing Tower / ...
146	C7S06-	C7/S6	C7S06,27	-	DO	24 VDC energized	RVM-61304	RVM-61304_DO_1	325-01-613-PD-01	0	Packing Tower / ...
147	C7S06-	C7/S6	C7S06,28	-	DO	24 VDC energized	RVM-61304	RVM-61304_DO_2	325-01-613-PD-01	0	Packing Tower / ...
148	C7S03-	C7/S3	C7S03,23	-	DI	24 VDC energized	RVM-61305	RVM-61305_DI_1	325-01-613-PD-01	0	Packing Tower / ...
149	C7S03-	C7/S3	C7S03,24	-	DI	24 VDC energized	RVM-61305	RVM-61305_DI_2	325-01-613-PD-01	0	Packing Tower / ...
150	C7S06-	C7/S6	C7S06,29	-	DO	24 VDC energized	RVM-61305	RVM-61305_DO_1	325-01-613-PD-01	0	Packing Tower / ...
151	C7S06-	C7/S6	C7S06,30	-	DO	24 VDC energized	RVM-61305	RVM-61305_DO_2	325-01-613-PD-01	0	Packing Tower / ...
152	C7S03-	C7/S3	C7S03,04	-	DI	24 VDC energized	SCM-61301	SCM-61301_DI_1	325-01-613-PD-01	0	Packing Tower / ...
153	C7S03-	C7/S3	C7S03,05	-	DI	24 VDC energized	SCM-61301	SCM-61301_DI_2	325-01-613-PD-01	0	Packing Tower / ...
154	C7S06-	C7/S6	C7S06,15	-	DO	24 VDC energized	SCM-61301	SCM-61301_DO_1	325-01-613-PD-01	0	Packing Tower / ...
155	C7S06-	C7/S6	C7S06,16	-	DO	24 VDC energized	SCM-61301	SCM-61301_DO_2	325-01-613-PD-01	0	Packing Tower / ...

ENCLOSURE: MCC | TYPE: Motor Control Center Enclosure (MCC) | LOCATION: MCC Room | SIZE: Draw-out Switchgear Panel mm

SUMMARY: Total Channels: 237 | Active: 169 | Spare: 68 (28.7%) | DI: 125 | DO: 95 | AI: 0 | AO: 0 | BUS: 17

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
156	C7S03-	C7/S3	C7S03,06	-	DI	24 VDC energized	SCM-61302	SCM-61302_DI_2	325-01-613-PD-01	0	Packing Tower / ...
157	C7S03-	C7/S3	C7S03,07	-	DI	24 VDC energized	SCM-61302	SCM-61302_DI_1	325-01-613-PD-01	0	Packing Tower / ...
158	C7S06-	C7/S6	C7S06,17	-	DO	24 VDC energized	SCM-61302	SCM-61302_DO_1	325-01-613-PD-01	0	Packing Tower / ...
159	C7S06-	C7/S6	C7S06,18	-	DO	24 VDC energized	SCM-61302	SCM-61302_DO_2	325-01-613-PD-01	0	Packing Tower / ...
160	C7S01-	C7/S1	C7S01,00	-	DI	-	Spare	Spare_DI_0	3-25-01-402-PD-01	Spare I/O Point	PH Adjustment / ...
161	C7S01-	C7/S1	C7S01,01	-	DI	-	Spare	Spare_DI_0	3-25-01-402-PD-01	Spare I/O Point	PH Adjustment / ...
162	C7S01-	C7/S1	C7S01,02	-	DI	-	Spare	Spare_DI_0	3-25-01-402-PD-01	Spare I/O Point	PH Adjustment / ...
163	C7S01-	C7/S1	C7S01,03	-	DI	-	Spare	Spare_DI_0	3-25-01-402-PD-01	Spare I/O Point	PH Adjustment / ...
164	C7S01-	C7/S1	C7S01,04	-	DI	-	Spare	Spare_DI_0	3-25-01-402-PD-01	Spare I/O Point	PH Adjustment / ...
165	C7S01-	C7/S1	C7S01,05	-	DI	-	Spare	Spare_DI_0	3-25-01-402-PD-01	Spare I/O Point	PH Adjustment / ...
166	C7S01-	C7/S1	C7S01,06	-	DI	-	Spare	Spare_DI_0	3-25-01-402-PD-01	Spare I/O Point	PH Adjustment / ...
167	C7S01-	C7/S1	C7S01,07	-	DI	-	Spare	Spare_DI_0	3-25-01-402-PD-01	Spare I/O Point	PH Adjustment / ...
168	C7S04-	C7/S4	C7S04,04	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
169	C7S04-	C7/S4	C7S04,05	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
170	C7S04-	C7/S4	C7S04,06	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
171	C7S04-	C7/S4	C7S04,07	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
172	C7S04-	C7/S4	C7S04,08	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
173	C7S04-	C7/S4	C7S04,09	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
174	C7S04-	C7/S4	C7S04,10	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
175	C7S04-	C7/S4	C7S04,11	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
176	C7S04-	C7/S4	C7S04,12	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
177	C7S04-	C7/S4	C7S04,13	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
178	C7S04-	C7/S4	C7S04,14	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
179	C7S04-	C7/S4	C7S04,15	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
180	C7S04-	C7/S4	C7S04,16	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
181	C7S04-	C7/S4	C7S04,17	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
182	C7S04-	C7/S4	C7S04,18	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
183	C7S04-	C7/S4	C7S04,19	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
184	C7S04-	C7/S4	C7S04,20	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
185	C7S04-	C7/S4	C7S04,21	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
186	C7S04-	C7/S4	C7S04,22	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-

ENCLOSURE: MCC | TYPE: Motor Control Center Enclosure (MCC) | LOCATION: MCC Room | SIZE: Draw-out Switchgear Panel mm

SUMMARY: Total Channels: 237 | Active: 169 | Spare: 68 (28.7%) | DI: 125 | DO: 95 | AI: 0 | AO: 0 | BUS: 17

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
187	C7S04-	C7/S4	C7S04,23	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
188	C7S04-	C7/S4	C7S04,24	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
189	C7S04-	C7/S4	C7S04,25	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
190	C7S04-	C7/S4	C7S04,26	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
191	C7S04-	C7/S4	C7S04,27	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
192	C7S04-	C7/S4	C7S04,28	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
193	C7S04-	C7/S4	C7S04,29	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
194	C7S04-	C7/S4	C7S04,30	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
195	C7S04-	C7/S4	C7S04,31	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
196	C7S05-	C7/S5	C7S05,00	-	DO	-	Spare	Spare_DO_0	3-25-01-402-PD-01	Spare I/O Point	PH Adjustment / ...
197	C7S05-	C7/S5	C7S05,01	-	DO	-	Spare	Spare_DO_0	3-25-01-402-PD-01	Spare I/O Point	PH Adjustment / ...
198	C7S05-	C7/S5	C7S05,02	-	DO	-	Spare	Spare_DO_0	3-25-01-402-PD-01	Spare I/O Point	PH Adjustment / ...
199	C7S05-	C7/S5	C7S05,03	-	DO	-	Spare	Spare_DO_0	3-25-01-402-PD-01	Spare I/O Point	PH Adjustment / ...
200	C7S05-	C7/S5	C7S05,04	-	DO	-	Spare	Spare_DO_0	3-25-01-402-PD-01	Spare I/O Point	PH Adjustment / ...
201	C7S05-	C7/S5	C7S05,05	-	DO	-	Spare	Spare_DO_0	3-25-01-402-PD-01	Spare I/O Point	PH Adjustment / ...
202	C7S05-	C7/S5	C7S05,06	-	DO	-	Spare	Spare_DO_0	3-25-01-402-PD-01	Spare I/O Point	PH Adjustment / ...
203	C7S05-	C7/S5	C7S05,07	-	DO	-	Spare	Spare_DO_0	3-25-01-402-PD-01	Spare I/O Point	PH Adjustment / ...
204	C7S07-	C7/S7	C7S07,08	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
205	C7S07-	C7/S7	C7S07,09	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
206	C7S07-	C7/S7	C7S07,10	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
207	C7S07-	C7/S7	C7S07,11	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
208	C7S07-	C7/S7	C7S07,12	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
209	C7S07-	C7/S7	C7S07,13	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
210	C7S07-	C7/S7	C7S07,14	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
211	C7S07-	C7/S7	C7S07,15	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
212	C7S07-	C7/S7	C7S07,16	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
213	C7S07-	C7/S7	C7S07,17	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
214	C7S07-	C7/S7	C7S07,18	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
215	C7S07-	C7/S7	C7S07,19	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
216	C7S07-	C7/S7	C7S07,20	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
217	C7S07-	C7/S7	C7S07,21	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-

ENCLOSURE: MCC | TYPE: Motor Control Center Enclosure (MCC) | LOCATION: MCC Room | SIZE: Draw-out Switchgear Panel mm

SUMMARY: Total Channels: 237 | Active: 169 | Spare: 68 (28.7%) | DI: 125 | DO: 95 | AI: 0 | AO: 0 | BUS: 17

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
218	C7S07-	C7/S7	C7S07,22	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
219	C7S07-	C7/S7	C7S07,23	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
220	C7S07-	C7/S7	C7S07,24	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
221	C7S07-	C7/S7	C7S07,25	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
222	C7S07-	C7/S7	C7S07,26	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
223	C7S07-	C7/S7	C7S07,27	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
224	C7S07-	C7/S7	C7S07,28	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
225	C7S07-	C7/S7	C7S07,29	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
226	C7S07-	C7/S7	C7S07,30	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
227	C7S07-	C7/S7	C7S07,31	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
228	C7S05-	C7/S5	C7S05,29	-	DO	0	XS-60205	XS-60205_DO_1	325-01-600-PD-01	0	Spray Dryer / 1st
229	C7S06-	C7/S6	C7S06,02	-	DO	Dry Contact	XS-60240A	XS-60240A_DO_1	325-01-600-PD-05	0	Spray Dryer / 4th
230	C7S06-	C7/S6	C7S06,03	-	DO	Dry Contact	XS-60241A	XS-60241A_DO_1	325-01-600-PD-05	0	Spray Dryer / 4th
231	C7S06-	C7/S6	C7S06,04	-	DO	Dry Contact	XS-60242A	XS-60242A_DO_1	325-01-600-PD-05	0	Spray Dryer / 3rd
232	C7S06-	C7/S6	C7S06,04	-	DO	Dry Contact	XS-60243A	XS-60243A_DO_1	325-01-600-PD-05	0	Spray Dryer / 4th
233	C7S06-	C7/S6	C7S06,06	-	DO	24 VDC energized	XS-60260	XS-60260_DO_1	325-01-600-PD-05	0	Spray Dryer / 6th
234	C6S05-	C6/S5	C6S05,06	-	DO	24 VDC energized	XS-80305	XS-80305_DO_1	325-01-803-PD-02	0	LPG System / 1st
235	C6S05-	C6/S5	C6S05,07	-	DO	24 VDC energized	XS-80306	XS-80306_DO_1	325-01-803-PD-02	Pressure Transmitter	LPG System / 1st
236	C7S06-	C7/S6	C7S06,08	-	DO	Dry Contact	XS-FH-60210A	XS-FH-60210A_DO_1	325-01-600-PD-06	0	Spray Dryer / 7th
237	C7S06-	C7/S6	C7S06,09	-	DO	Dry Contact	XS-FH-60210B	XS-FH-60210B_DO_1	325-01-600-PD-06	0	Spray Dryer / 7th

ENCLOSURE: RIO-200 | TYPE: Remote I/O Enclosure (RIO Panel) | LOCATION: Slurry - Out Building 2nd Floor | SIZE: 800-1000-400 mm

SUMMARY: Total Channels: 112 | Active: 57 | Spare: 55 (49.1%) | DI: 64 | DO: 32 | AI: 16 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
1	C5S04-X1	C5/S4	C5S04,00	1756-IF16-0	AI	-	EXT-BIILER	EXT-BIILER_AI_1	External Remote S...	-	Boiler System / 1st
2	C5S01-X1	C5/S1	C5S01,00	1756-IB32-0	DI	-	FS-20201	FS-20201_DI_1	3-25-01-202-PD-01	-	Slurry - Out Buildi...
3	C5S01-X1	C5/S1	C5S01,01	1756-IB32-1	DI	4 - 20 mA,Pulse	FT-913201	FT-913201_DI_1	3-25-01-913-PD-02	0	LPG System / 1st
4	C5S04-X1	C5/S4	C5S04,01	1756-IF16-1	AI	4 - 20 mA,Pulse	FT-913201	FT-913201_AI_1	3-25-01-913-PD-02	0	LPG System / 1st
5	C5S04-X1	C5/S4	C5S04,02	1756-IF16-2	AI	4 - 20 mA,Pulse	FT-913201	FT-913201_AI_2	3-25-01-913-PD-02	0	LPG System / 1st
6	C5S01-X1	C5/S1	C5S01,02	1756-IB32-2	DI	4 - 20 mA,Pulse	FT-936201	FT-936201_DI_1	3-25-01-930-PD-08	0	Process Water / ...
7	C5S04-X1	C5/S4	C5S04,03	1756-IF16-3	AI	4 - 20 mA,Pulse	FT-936201	FT-936201_AI_1	3-25-01-930-PD-08	0	Process Water / ...
8	C5S01-X1	C5/S1	C5S01,03	1756-IB32-3	DI	4 - 20 mA,Pulse	FT-936202	FT-936202_DI_1	3-25-01-930-PD-07	0	Process Water / ...
9	C5S04-X1	C5/S4	C5S04,04	1756-IF16-4	AI	4 - 20 mA,Pulse	FT-936202	FT-936202_AI_1	3-25-01-930-PD-07	0	Process Water / ...
10	C5S01-X1	C5/S1	C5S01,07	1756-IB32-7	DI	Dry Contact	HV-20204	HV-20204_DI_1	3-25-01-202-PD-01	Manual Valve With Position Switch	Slurry - Out Buildi...
11	C5S01-X1	C5/S1	C5S01,08	1756-IB32-8	DI	Dry Contact	HV-20205	HV-20205_DI_1	3-25-01-202-PD-01	Manual Valve With Position Switch	Slurry - Out Buildi...
12	C5S01-X1	C5/S1	C5S01,09	1756-IB32-9	DI	Dry Contact	HV-20206	HV-20206_DI_1	3-25-01-202-PD-01	Manual Valve With Position Switch	Slurry - Out Buildi...
13	C5S01-X1	C5/S1	C5S01,10	1756-IB32-10	DI	Dry Contact	HV-20207	HV-20207_DI_1	3-25-01-202-PD-01	Manual Valve With Position Switch	Slurry - Out Buildi...
14	C5S01-X1	C5/S1	C5S01,11	1756-IB32-11	DI	Dry Contact	HV-20208	HV-20208_DI_1	3-25-01-202-PD-02	Manual Valve With Position Switch	Slurry - Out Buildi...
15	C5S01-X1	C5/S1	C5S01,12	1756-IB32-12	DI	Dry Contact	HV-20209	HV-20209_DI_1	3-25-01-202-PD-02	Manual Valve With Position Switch	Slurry - Out Buildi...
16	C5S01-X1	C5/S1	C5S01,13	1756-IB32-13	DI	Dry Contact	HV-20210	HV-20210_DI_1	3-25-01-202-PD-02	Manual Valve With Position Switch	Slurry - Out Buildi...
17	C5S01-X1	C5/S1	C5S01,04	1756-IB32-4	DI	Dry Contact	LSL-814201	LSL-814201_DI_1	3-25-01-814-PD-01	0	CIP Water Syste...
18	C5S04-X1	C5/S4	C5S04,05	1756-IF16-5	AI	4 - 20 mA	LT-913201	LT-913201_AI_1	3-25-01-913-PD-01	Level Transmitter	LPG System / 1st
19	C5S01-X1	C5/S1	C5S01,05	1756-IB32-5	DI	-	PK-913201	PK-913201_DI_1	-	-	LPG System / 1st
20	C5S01-X1	C5/S1	C5S01,06	1756-IB32-6	DI	-	PK-913202	PK-913202_DI_1	-	-	LPG System / 1st
21	C5S04-X1	C5/S4	C5S04,06	1756-IF16-6	AI	4 - 20 mA	PT-913201	PT-913201_AI_1	3-25-01-913-PD-02	Pressure Transmitter	LPG System / 1st
22	C5S02-X1	C5/S2	C5S02,08	1756-IB32-8	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
23	C5S02-X1	C5/S2	C5S02,09	1756-IB32-9	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
24	C5S02-X1	C5/S2	C5S02,10	1756-IB32-10	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
25	C5S02-X1	C5/S2	C5S02,11	1756-IB32-11	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
26	C5S02-X1	C5/S2	C5S02,12	1756-IB32-12	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
27	C5S02-X1	C5/S2	C5S02,13	1756-IB32-13	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
28	C5S02-X1	C5/S2	C5S02,14	1756-IB32-14	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
29	C5S02-X1	C5/S2	C5S02,15	1756-IB32-15	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
30	C5S02-X2	C5/S2	C5S02,16	1756-IB32-16	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
31	C5S02-X2	C5/S2	C5S02,17	1756-IB32-17	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-

ENCLOSURE: RIO-200 | TYPE: Remote I/O Enclosure (RIO Panel) | LOCATION: Slurry - Out Building 2nd Floor | SIZE: 800-1000-400 mm

SUMMARY: Total Channels: 112 | Active: 57 | Spare: 55 (49.1%) | DI: 64 | DO: 32 | AI: 16 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
32	C5S02-X2	C5/S2	C5S02,18	1756-IB32-18	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
33	C5S02-X2	C5/S2	C5S02,19	1756-IB32-19	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
34	C5S02-X2	C5/S2	C5S02,20	1756-IB32-20	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
35	C5S02-X2	C5/S2	C5S02,21	1756-IB32-21	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
36	C5S02-X2	C5/S2	C5S02,22	1756-IB32-22	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
37	C5S02-X2	C5/S2	C5S02,23	1756-IB32-23	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
38	C5S02-X2	C5/S2	C5S02,24	1756-IB32-24	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
39	C5S02-X2	C5/S2	C5S02,25	1756-IB32-25	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
40	C5S02-X2	C5/S2	C5S02,26	1756-IB32-26	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
41	C5S02-X2	C5/S2	C5S02,27	1756-IB32-27	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
42	C5S02-X2	C5/S2	C5S02,28	1756-IB32-28	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
43	C5S02-X2	C5/S2	C5S02,29	1756-IB32-29	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
44	C5S02-X2	C5/S2	C5S02,30	1756-IB32-30	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
45	C5S02-X2	C5/S2	C5S02,31	1756-IB32-31	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
46	C5S03-X1	C5/S3	C5S03,08	1756-OB32-8	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
47	C5S03-X1	C5/S3	C5S03,09	1756-OB32-9	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
48	C5S03-X1	C5/S3	C5S03,10	1756-OB32-10	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
49	C5S03-X1	C5/S3	C5S03,11	1756-OB32-11	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
50	C5S03-X1	C5/S3	C5S03,12	1756-OB32-12	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
51	C5S03-X1	C5/S3	C5S03,13	1756-OB32-13	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
52	C5S03-X1	C5/S3	C5S03,14	1756-OB32-14	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
53	C5S03-X1	C5/S3	C5S03,15	1756-OB32-15	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
54	C5S03-X2	C5/S3	C5S03,16	1756-OB32-16	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
55	C5S03-X2	C5/S3	C5S03,17	1756-OB32-17	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
56	C5S03-X2	C5/S3	C5S03,18	1756-OB32-18	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
57	C5S03-X2	C5/S3	C5S03,19	1756-OB32-19	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
58	C5S03-X2	C5/S3	C5S03,20	1756-OB32-20	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
59	C5S03-X2	C5/S3	C5S03,21	1756-OB32-21	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
60	C5S03-X2	C5/S3	C5S03,22	1756-OB32-22	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
61	C5S03-X2	C5/S3	C5S03,23	1756-OB32-23	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
62	C5S03-X2	C5/S3	C5S03,24	1756-OB32-24	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-

ENCLOSURE: RIO-200 | TYPE: Remote I/O Enclosure (RIO Panel) | LOCATION: Slurry - Out Building 2nd Floor | SIZE: 800-1000-400 mm

SUMMARY: Total Channels: 112 | Active: 57 | Spare: 55 (49.1%) | DI: 64 | DO: 32 | AI: 16 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
63	C5S03-X2	C5/S3	C5S03,25	1756-OB32-25	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
64	C5S03-X2	C5/S3	C5S03,26	1756-OB32-26	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
65	C5S03-X2	C5/S3	C5S03,27	1756-OB32-27	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
66	C5S03-X2	C5/S3	C5S03,28	1756-OB32-28	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
67	C5S03-X2	C5/S3	C5S03,29	1756-OB32-29	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
68	C5S03-X2	C5/S3	C5S03,30	1756-OB32-30	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
69	C5S03-X2	C5/S3	C5S03,31	1756-OB32-31	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
70	C5S04-X1	C5/S4	C5S04,09	1756-IF16-9	AI	-	Spare	Spare_AI_0	3-25-01-913-PD-02	Spare I/O Point	LPG System / 1st
71	C5S04-X1	C5/S4	C5S04,10	1756-IF16-10	AI	-	Spare	Spare_AI_0	3-25-01-913-PD-02	Spare I/O Point	LPG System / 1st
72	C5S04-X1	C5/S4	C5S04,11	1756-IF16-11	AI	-	Spare	Spare_AI_0	3-25-01-913-PD-02	Spare I/O Point	LPG System / 1st
73	C5S04-X1	C5/S4	C5S04,12	1756-IF16-12	AI	-	Spare	Spare_AI_0	3-25-01-913-PD-02	Spare I/O Point	LPG System / 1st
74	C5S04-X1	C5/S4	C5S04,13	1756-IF16-13	AI	-	Spare	Spare_AI_0	3-25-01-913-PD-02	Spare I/O Point	LPG System / 1st
75	C5S04-X1	C5/S4	C5S04,14	1756-IF16-14	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
76	C5S04-X1	C5/S4	C5S04,15	1756-IF16-15	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
77	C5S01-X1	C5/S1	C5S01,14	1756-IB32-14	DI	Dry Contact	XA-80305A	XA-80305A_DI_1	325-01-803-PD-02	0	LPG System / 1st
78	C5S01-X1	C5/S1	C5S01,15	1756-IB32-15	DI	Dry Contact	XA-80305B	XA-80305B_DI_1	325-01-803-PD-02	0	LPG System / 1st
79	C5S01-X2	C5/S1	C5S01,16	1756-IB32-16	DI	Dry Contact	XA-80305C	XA-80305C_DI_1	325-01-803-PD-02	0	LPG System / 1st
80	C5S01-X2	C5/S1	C5S01,17	1756-IB32-17	DI	Dry Contact	XA-80305D	XA-80305D_DI_1	325-01-803-PD-02	0	LPG System / 1st
81	C5S01-X2	C5/S1	C5S01,18	1756-IB32-18	DI	Dry Contact	XA-80305E	XA-80305E_DI_1	325-01-803-PD-02	0	LPG System / 1st
82	C5S01-X2	C5/S1	C5S01,19	1756-IB32-19	DI	Dry Contact	XA-80305F	XA-80305F_DI_1	325-01-803-PD-02	0	LPG System / 1st
83	C5S01-X2	C5/S1	C5S01,20	1756-IB32-20	DI	Dry Contact	XA-80306A	XA-80306A_DI_1	325-01-803-PD-02	0	LPG System / 1st
84	C5S01-X2	C5/S1	C5S01,21	1756-IB32-21	DI	Dry Contact	XA-80306B	XA-80306B_DI_1	325-01-803-PD-02	0	LPG System / 1st
85	C5S01-X2	C5/S1	C5S01,22	1756-IB32-22	DI	Dry Contact	XA-80306C	XA-80306C_DI_1	325-01-803-PD-02	0	LPG System / 1st
86	C5S01-X2	C5/S1	C5S01,23	1756-IB32-23	DI	Dry Contact	XA-80306D	XA-80306D_DI_1	325-01-803-PD-02	0	LPG System / 1st
87	C5S01-X2	C5/S1	C5S01,24	1756-IB32-24	DI	Dry Contact	XA-80306E	XA-80306E_DI_1	325-01-803-PD-02	0	LPG System / 1st
88	C5S01-X2	C5/S1	C5S01,25	1756-IB32-25	DI	Dry Contact	XA-80306F	XA-80306F_DI_1	325-01-803-PD-02	0	LPG System / 1st
89	C5S03-X1	C5/S3	C5S03,00	1756-OB32-0	DO	4 - 20 mA	XA-92201	XA-92201_DO_1	3-25-01-922-PD-03	0	Boiler System / 1st
90	C5S04-X1	C5/S4	C5S04,07	1756-IF16-7	AI	4 - 20 mA	XT-92201	XT-92201_AI_1	3-25-01-922-PD-03	0	Boiler System / 1st
91	C5S01-X2	C5/S1	C5S01,26	1756-IB32-26	DI	24 VDC energized	XV-20201	XV-20201_DI_1	3-25-01-202-PD-01	0	Slurry - Out Buildi...
92	C5S01-X2	C5/S1	C5S01,27	1756-IB32-27	DI	24 VDC energized	XV-20201	XV-20201_DI_2	3-25-01-202-PD-01	0	Slurry - Out Buildi...
93	C5S03-X1	C5/S3	C5S03,01	1756-OB32-1	DO	24 VDC energized	XV-20201	XV-20201_DO_1	3-25-01-202-PD-01	0	Slurry - Out Buildi...

ENCLOSURE: RIO-200 | TYPE: Remote I/O Enclosure (RIO Panel) | LOCATION: Slurry - Out Building 2nd Floor | SIZE: 800-1000-400 mm

SUMMARY: Total Channels: 112 | Active: 57 | Spare: 55 (49.1%) | DI: 64 | DO: 32 | AI: 16 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
94	C5S01-X2	C5/S1	C5S01,28	1756-IB32-28	DI	24 VDC energized	XV-20202	XV-20202_DI_1	3-25-01-202-PD-01	0	Slurry - Out Buildi...
95	C5S01-X2	C5/S1	C5S01,29	1756-IB32-29	DI	24 VDC energized	XV-20202	XV-20202_DI_2	3-25-01-202-PD-01	0	Slurry - Out Buildi...
96	C5S03-X1	C5/S3	C5S03,02	1756-OB32-2	DO	24 VDC energized	XV-20202	XV-20202_DO_1	3-25-01-202-PD-01	0	Slurry - Out Buildi...
97	C5S01-X2	C5/S1	C5S01,30	1756-IB32-30	DI	24 VDC energized	XV-20203	XV-20203_DI_1	3-25-01-202-PD-01	0	Slurry - Out Buildi...
98	C5S01-X2	C5/S1	C5S01,31	1756-IB32-31	DI	24 VDC energized	XV-20203	XV-20203_DI_2	3-25-01-202-PD-01	0	Slurry - Out Buildi...
99	C5S03-X1	C5/S3	C5S03,03	1756-OB32-3	DO	24 VDC energized	XV-20203	XV-20203_DO_1	3-25-01-202-PD-01	0	Slurry - Out Buildi...
100	C5S02-X1	C5/S2	C5S02,00	1756-IB32-0	DI	24 VDC energized	XV-20211	XV-20211_DI_1	3-25-01-202-PD-01	0	Slurry - Out Buildi...
101	C5S02-X1	C5/S2	C5S02,01	1756-IB32-1	DI	24 VDC energized	XV-20211	XV-20211_DI_2	3-25-01-202-PD-01	0	Slurry - Out Buildi...
102	C5S03-X1	C5/S3	C5S03,04	1756-OB32-4	DO	24 VDC energized	XV-20211	XV-20211_DO_1	3-25-01-202-PD-01	0	Slurry - Out Buildi...
103	C5S02-X1	C5/S2	C5S02,02	1756-IB32-2	DI	24 VDC energized	XV-20212	XV-20212_DI_1	3-25-01-202-PD-01	0	Slurry - Out Buildi...
104	C5S02-X1	C5/S2	C5S02,03	1756-IB32-3	DI	24 VDC energized	XV-20212	XV-20212_DI_2	3-25-01-202-PD-01	0	Slurry - Out Buildi...
105	C5S03-X1	C5/S3	C5S03,05	1756-OB32-5	DO	24 VDC energized	XV-20212	XV-20212_DO_1	3-25-01-202-PD-01	0	Slurry - Out Buildi...
106	C5S02-X1	C5/S2	C5S02,04	1756-IB32-4	DI	24 VDC energized	XV-20213	XV-20213_DI_1	3-25-01-202-PD-01	0	Slurry - Out Buildi...
107	C5S02-X1	C5/S2	C5S02,05	1756-IB32-5	DI	24 VDC energized	XV-20213	XV-20213_DI_2	3-25-01-202-PD-01	0	Slurry - Out Buildi...
108	C5S03-X1	C5/S3	C5S03,06	1756-OB32-6	DO	24 VDC energized	XV-20213	XV-20213_DO_1	3-25-01-202-PD-01	0	Slurry - Out Buildi...
109	C5S02-X1	C5/S2	C5S02,06	1756-IB32-6	DI	24 VDC energized	XV-913201	XV-913201_DI_1	3-25-01-913-PD-02	0	LPG System / 1st
110	C5S02-X1	C5/S2	C5S02,07	1756-IB32-7	DI	24 VDC energized	XV-913201	XV-913201_DI_1	3-25-01-913-PD-02	0	LPG System / 1st
111	C5S03-X1	C5/S3	C5S03,07	1756-OB32-7	DO	24 VDC energized	XV-913201	XV-913201_DO_1	3-25-01-913-PD-02	0	LPG System / 1st
112	C5S04-X1	C5/S4	C5S04,08	1756-IF16-8	AI	24 VDC energized	XV-913201	XV-913201_AI_1	3-25-01-913-PD-02	0	LPG System / 1st