

ENCLOSURE: IS-JB-603 | TYPE: Intrinsically Safe Junction Box (Ex i / LS) | LOCATION: Spray Dryer 3rd Floor | SIZE: 300-200-150 mm

SUMMARY: Total Channels: 32 | Active: 22 | Spare: 10 (31.2%) | DI: 16 | DO: 0 | AI: 16 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
1	C3S01-X1	C3/S1	C3S01,00	1756-IB32-0	DI	-	AT-40201	AT-40201_DI_1	-	-	Spray Dryer / 3rd
2	C3S01-X1	C3/S1	C3S01,01	1756-IB32-1	DI	-	AT-40202	AT-40202_DI_1	-	-	Spray Dryer / 3rd
3	C3S01-X1	C3/S1	C3S01,02	1756-IB32-2	DI	-	AT-40203	AT-40203_DI_1	-	-	Spray Dryer / 3rd
4	C3S01-X1	C3/S1	C3S01,03	1756-IB32-3	DI	Dry Contact	LSH-60230	LSH-60230_DI_1	3-25-01-602-PD-04	0	Spray Dryer / 1st
5	C3S01-X1	C3/S1	C3S01,04	1756-IB32-4	DI	Dry Contact	LSH-60231	LSH-60231_DI_1	3-25-01-602-PD-04	0	Spray Dryer / 1st
6	C3S01-X1	C3/S1	C3S01,05	1756-IB32-5	DI	Dry Contact	LSH-60240	LSH-60240_DI_1	3-25-01-602-PD-05	0	Spray Dryer / 1st
7	C3S01-X1	C3/S1	C3S01,06	1756-IB32-6	DI	-	PD-60202	PD-60202_DI_1	-	-	Spray Dryer / 3rd
8	C3S04-X1	C3/S4	C3S04,00	1756-IF16-0	AI	4 - 20 mA	PT-60230	PT-60230_AI_1	3-25-01-602-PD-04	Pressure Transmitter	Spray Dryer / 4th
9	C3S04-X1	C3/S4	C3S04,01	1756-IF16-1	AI	4 - 20 mA	PT-60231	PT-60231_AI_1	3-25-01-602-PD-04	Pressure Transmitter	Spray Dryer / 4th
10	C3S01-X1	C3/S1	C3S01,07	1756-IB32-7	DI	-	RV-60204	RV-60204_DI_1	-	-	Spray Dryer / 3rd
11	C3S01-X1	C3/S1	C3S01,15	1756-IB32-15	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
12	C3S04-X1	C3/S4	C3S04,07	1756-IF16-7	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
13	C3S04-X1	C3/S4	C3S04,08	1756-IF16-8	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
14	C3S04-X1	C3/S4	C3S04,09	1756-IF16-9	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
15	C3S04-X1	C3/S4	C3S04,10	1756-IF16-10	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
16	C3S04-X1	C3/S4	C3S04,11	1756-IF16-11	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
17	C3S04-X1	C3/S4	C3S04,12	1756-IF16-12	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
18	C3S04-X1	C3/S4	C3S04,13	1756-IF16-13	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
19	C3S04-X1	C3/S4	C3S04,14	1756-IF16-14	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
20	C3S04-X1	C3/S4	C3S04,15	1756-IF16-15	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
21	C3S04-X1	C3/S4	C3S04,02	1756-IF16-2	AI	4 - 20 mA	TT-60224	TT-60224_AI_1	3-25-01-602-PD-04	0	Spray Dryer / 4th
22	C3S04-X1	C3/S4	C3S04,03	1756-IF16-3	AI	4 - 20 mA	TT-60225	TT-60225_AI_1	3-25-01-602-PD-04	0	Spray Dryer / 3rd
23	C3S04-X1	C3/S4	C3S04,04	1756-IF16-4	AI	4 - 20 mA	TT-60226	TT-60226_AI_1	3-25-01-602-PD-04	0	Spray Dryer / 2nd
24	C3S04-X1	C3/S4	C3S04,05	1756-IF16-5	AI	4 - 20 mA	TT-60227	TT-60227_AI_1	3-25-01-602-PD-04	0	Spray Dryer / 1st
25	C3S04-X1	C3/S4	C3S04,06	1756-IF16-6	AI	4 - 20 mA	TT-60230	TT-60230_AI_1	3-25-01-602-PD-04	0	Spray Dryer / 3rd
26	C3S01-X1	C3/S1	C3S01,08	1756-IB32-8	DI	Dry Contact	ZS-60201C	ZS-60201C_DI_1	3-25-01-602-PD-04	0	Spray Dryer / 4th
27	C3S01-X1	C3/S1	C3S01,09	1756-IB32-9	DI	Dry Contact	ZS-60201D	ZS-60201D_DI_1	3-25-01-602-PD-04	0	Spray Dryer / 4th
28	C3S01-X1	C3/S1	C3S01,10	1756-IB32-10	DI	Dry Contact	ZS-60201E	ZS-60201E_DI_1	3-25-01-602-PD-04	0	Spray Dryer / 1st
29	C3S01-X1	C3/S1	C3S01,11	1756-IB32-11	DI	Dry Contact	ZS-60229	ZS-60229_DI_1	3-25-01-602-PD-04	0	Spray Dryer / 4th
30	C3S01-X1	C3/S1	C3S01,12	1756-IB32-12	DI	Dry Contact	ZS-60230	ZS-60230_DI_1	3-25-01-602-PD-04	0	Spray Dryer / 4th
31	C3S01-X1	C3/S1	C3S01,13	1756-IB32-13	DI	Dry Contact	ZS-60231A	ZS-60231A_DI_1	3-25-01-602-PD-05	0	Spray Dryer / 4th

ENCLOSURE: IS-JB-603 | TYPE: Intrinsically Safe Junction Box (Ex i / LS) | LOCATION: Spray Dryer 3rd Floor | SIZE: 300-200-150 mm

SUMMARY: Total Channels: 32 | Active: 22 | Spare: 10 (31.2%) | DI: 16 | DO: 0 | AI: 16 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
32	C3S01-X1	C3/S1	C3S01,14	1756-IB32-14	DI	Dry Contact	ZS-60231B	ZS-60231B_DI_1	3-25-01-602-PD-05	0	Spray Dryer / 4th