

ENCLOSURE: IS-JB-608 | TYPE: Intrinsically Safe Junction Box (Ex i / LS) | LOCATION: Spray Dryer 8th Floor | SIZE: 300-200-150 mm

SUMMARY: Total Channels: 32 | Active: 14 | Spare: 18 (56.2%) | DI: 16 | DO: 8 | AI: 8 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
1	C4S06-X1	C4/S6	C4S06,00	1756-IF16-0	AI	4 - 20 mA	PT-60220	PT-60220_AI_1	3-25-01-602-PD-04	Pressure Transmitter	Spray Dryer / 6th
2	C4S01-X2	C4/S1	C4S01,23	1756-IB32-23	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
3	C4S01-X2	C4/S1	C4S01,24	1756-IB32-24	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
4	C4S01-X2	C4/S1	C4S01,25	1756-IB32-25	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
5	C4S01-X2	C4/S1	C4S01,26	1756-IB32-26	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
6	C4S01-X2	C4/S1	C4S01,27	1756-IB32-27	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
7	C4S01-X2	C4/S1	C4S01,28	1756-IB32-28	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
8	C4S01-X2	C4/S1	C4S01,29	1756-IB32-29	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
9	C4S01-X2	C4/S1	C4S01,30	1756-IB32-30	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
10	C4S01-X2	C4/S1	C4S01,31	1756-IB32-31	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
11	C4S04-X1	C4/S4	C4S04,09	1756-OB32-9	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
12	C4S04-X1	C4/S4	C4S04,10	1756-OB32-10	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
13	C4S04-X1	C4/S4	C4S04,11	1756-OB32-11	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
14	C4S04-X1	C4/S4	C4S04,12	1756-OB32-12	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
15	C4S04-X1	C4/S4	C4S04,13	1756-OB32-13	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
16	C4S04-X1	C4/S4	C4S04,14	1756-OB32-14	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
17	C4S04-X1	C4/S4	C4S04,15	1756-OB32-15	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
18	C4S05-X1	C4/S5	C4S05,06	1756-IF16-6	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
19	C4S05-X1	C4/S5	C4S05,07	1756-IF16-7	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
20	C4S06-X1	C4/S6	C4S06,01	1756-IF16-1	AI	4 - 20 mA	TT-60220	TT-60220_AI_1	3-25-01-602-PD-04	0	Spray Dryer / 6th
21	C4S06-X1	C4/S6	C4S06,02	1756-IF16-2	AI	4 - 20 mA	TT-60221	TT-60221_AI_1	3-25-01-602-PD-04	0	Spray Dryer / 6th
22	C4S06-X1	C4/S6	C4S06,03	1756-IF16-3	AI	4 - 20 mA	TT-60222	TT-60222_AI_1	3-25-01-602-PD-04	0	Spray Dryer / 5th
23	C4S06-X1	C4/S6	C4S06,04	1756-IF16-4	AI	4 - 20 mA	TT-60223	TT-60223_AI_1	3-25-01-602-PD-04	0	Spray Dryer / 5th
24	C4S04-X1	C4/S4	C4S04,08	1756-OB32-8	DO	4 - 20 mA	XA-60201	XA-60201_DO_1	3-25-01-602-PD-03	0	Spray Dryer / 5th
25	C4S06-X1	C4/S6	C4S06,05	1756-IF16-5	AI	4 - 20 mA	XT-60201	XT-60201_AI_1	3-25-01-602-PD-03	0	Spray Dryer / 5th
26	C4S01-X2	C4/S1	C4S01,16	1756-IB32-16	DI	Dry Contact	ZS-60201A	ZS-60201A_DI_1	3-25-01-602-PD-04	0	Spray Dryer / 6th
27	C4S01-X2	C4/S1	C4S01,17	1756-IB32-17	DI	Dry Contact	ZS-60201B	ZS-60201B_DI_1	3-25-01-602-PD-04	0	Spray Dryer / 6th
28	C4S01-X2	C4/S1	C4S01,18	1756-IB32-18	DI	Dry Contact	ZS-60231C	ZS-60231C_DI_1	3-25-01-602-PD-04	0	Spray Dryer / 5th
29	C4S01-X2	C4/S1	C4S01,19	1756-IB32-19	DI	Dry Contact	ZS-60231D	ZS-60231D_DI_1	3-25-01-602-PD-04	0	Spray Dryer / 5th
30	C4S01-X2	C4/S1	C4S01,20	1756-IB32-20	DI	Dry Contact	ZS-60231E	ZS-60231E_DI_1	3-25-01-602-PD-05	0	Spray Dryer / 5th
31	C4S01-X2	C4/S1	C4S01,21	1756-IB32-21	DI	Dry Contact	ZS-60231F	ZS-60231F_DI_1	3-25-01-602-PD-05	0	Spray Dryer / 5th

ENCLOSURE: IS-JB-608 | TYPE: Intrinsically Safe Junction Box (Ex i / LS) | LOCATION: Spray Dryer 8th Floor | SIZE: 300-200-150 mm

SUMMARY: Total Channels: 32 | Active: 14 | Spare: 18 (56.2%) | DI: 16 | DO: 8 | AI: 8 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
32	C4S01-X2	C4/S1	C4S01,22	1756-IB32-22	DI	Dry Contact	ZS-60240	ZS-60240_DI_1	3-25-01-602-PD-05	0	Spray Dryer / 6th