

ENCLOSURE: IS-JB-612 | TYPE: Intrinsically Safe Junction Box (Ex i / LS) | LOCATION: Packing Tower 2th Floor | SIZE: 300-200-150 mm

SUMMARY: Total Channels: 41 | Active: 17 | Spare: 24 (58.5%) | DI: 31 | DO: 0 | AI: 10 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
1	C4S06-X1	C4/S6	C4S06,06	1756-IF16-6	AI	4 - 20 mA	DPT-61310	DPT-61310_AI_1	3-25-01-613-PD-03	Differential Pressure Transmitter	Packing Tower / ...
2	C4S06-X1	C4/S6	C4S06,07	1756-IF16-7	AI	-	DPT-61312	DPT-61312_AI_1	3-25-01-613-PD-05	-	Packing Tower / ...
3	C4S03-X1	C4/S3	C4S03,00	1756-IB32-0	DI	Dry Contact	ISV-61303	ISV-61303_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
4	C4S03-X1	C4/S3	C4S03,01	1756-IB32-1	DI	Dry Contact	ISV-61304	ISV-61304_DI_1	3-25-01-613-PD-05	0	Packing Tower / ...
5	C4S03-X1	C4/S3	C4S03,02	1756-IB32-2	DI	Dry Contact	LSH-61304	LSH-61304_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
6	C4S03-X1	C4/S3	C4S03,03	1756-IB32-3	DI	Dry Contact	LSH-61305	LSH-61305_DI_1	3-25-01-613-PD-05	0	Packing Tower / ...
7	C4S03-X1	C4/S3	C4S03,04	1756-IB32-4	DI	Dry Contact	LSH-61307	LSH-61307_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...
8	C4S03-X1	C4/S3	C4S03,05	1756-IB32-5	DI	Dry Contact	LSH-61312	LSH-61312_DI_1	3-25-01-613-PD-05	0	Packing Tower / ...
9	C4S03-X1	C4/S3	C4S03,06	1756-IB32-6	DI	Dry Contact	PSE-61302	PSE-61302_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
10	C4S03-X1	C4/S3	C4S03,07	1756-IB32-7	DI	Dry Contact	PSE-61303	PSE-61303_DI_1	3-25-01-613-PD-05	0	Packing Tower / ...
11	C4S03-X1	C4/S3	C4S03,09	1756-IB32-9	DI	-	RV-61301	RV-61301_DI_1	-	-	Packing Tower / ...
12	C4S03-X1	C4/S3	C4S03,10	1756-IB32-10	DI	-	RV-61304	RV-61304_DI_1	-	-	Packing Tower / ...
13	C4S03-X1	C4/S3	C4S03,11	1756-IB32-11	DI	-	RV-61305	RV-61305_DI_1	-	-	Packing Tower / ...
14	C4S03-X1	C4/S3	C4S03,12	1756-IB32-12	DI	-	SC-61301	SC-61301_DI_1	-	-	Packing Tower / ...
15	C4S03-X1	C4/S3	C4S03,13	1756-IB32-13	DI	-	SC-61302	SC-61302_DI_1	-	-	Packing Tower / ...
16	C4S03-X2	C4/S3	C4S03,16	1756-IB32-16	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
17	C4S03-X2	C4/S3	C4S03,17	1756-IB32-17	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
18	C4S03-X2	C4/S3	C4S03,18	1756-IB32-18	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
19	C4S03-X2	C4/S3	C4S03,19	1756-IB32-19	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
20	C4S03-X2	C4/S3	C4S03,20	1756-IB32-20	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
21	C4S03-X2	C4/S3	C4S03,21	1756-IB32-21	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
22	C4S03-X2	C4/S3	C4S03,22	1756-IB32-22	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
23	C4S03-X2	C4/S3	C4S03,23	1756-IB32-23	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
24	C4S03-X2	C4/S3	C4S03,24	1756-IB32-24	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
25	C4S03-X2	C4/S3	C4S03,25	1756-IB32-25	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
26	C4S03-X2	C4/S3	C4S03,26	1756-IB32-26	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
27	C4S03-X2	C4/S3	C4S03,27	1756-IB32-27	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
28	C4S03-X2	C4/S3	C4S03,28	1756-IB32-28	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
29	C4S03-X2	C4/S3	C4S03,29	1756-IB32-29	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
30	C4S03-X2	C4/S3	C4S03,30	1756-IB32-30	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
31	C4S03-X2	C4/S3	C4S03,31	1756-IB32-31	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-

ENCLOSURE: IS-JB-612 | TYPE: Intrinsically Safe Junction Box (Ex i / LS) | LOCATION: Packing Tower 2th Floor | SIZE: 300-200-150 mm

SUMMARY: Total Channels: 41 | Active: 17 | Spare: 24 (58.5%) | DI: 31 | DO: 0 | AI: 10 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
32	C4S05-X1	C4/S5	C4S05,14	1756-IF16-14	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
33	C4S05-X1	C4/S5	C4S05,14	1756-IF16-14	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
34	C4S05-X1	C4/S5	C4S05,14	1756-IF16-14	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
35	C4S05-X1	C4/S5	C4S05,14	1756-IF16-14	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
36	C4S05-X1	C4/S5	C4S05,14	1756-IF16-14	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
37	C4S05-X1	C4/S5	C4S05,14	1756-IF16-14	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
38	C4S05-X1	C4/S5	C4S05,14	1756-IF16-14	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
39	C4S05-X1	C4/S5	C4S05,14	1756-IF16-14	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
40	C4S03-X1	C4/S3	C4S03,14	1756-IB32-14	DI	Dry Contact	ZS-61312	ZS-61312_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...
41	C4S03-X1	C4/S3	C4S03,15	1756-IB32-15	DI	Dry Contact	ZS-61313	ZS-61313_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...