

ENCLOSURE: IS-JB-618 | TYPE: Intrinsically Safe Junction Box (Ex i / LS) | LOCATION: Packing Tower 8th Floor | SIZE: 450-300-150 mm

SUMMARY: Total Channels: 44 | Active: 22 | Spare: 22 (50.0%) | DI: 32 | DO: 0 | AI: 12 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
1	C3S05-X1	C3/S5	C3S05,04	1756-IF16-4	AI	4 - 20 mA	DPT-61301	DPT-61301_AI_1	3-25-01-613-PD-01	Differential Pressure Transmitter	Packing Tower / ...
2	C3S05-X1	C3/S5	C3S05,05	1756-IF16-5	AI	4 - 20 mA	DPT-61302	DPT-61302_AI_1	3-25-01-613-PD-01	Differential Pressure Transmitter	Packing Tower / ...
3	C3S02-X1	C3/S2	C3S02,00	1756-IB32-0	DI	-	ISV-61301	ISV-61301_DI_1	3-25-01-613-PD-01	-	Packing Tower / ...
4	C3S02-X1	C3/S2	C3S02,01	1756-IB32-1	DI	Dry Contact	LSH-61301	LSH-61301_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...
5	C3S02-X1	C3/S2	C3S02,02	1756-IB32-2	DI	-	LSH-61303	LSH-61303_DI_1	325-01-613-PD-01	-	Packing Tower / ...
6	C3S02-X1	C3/S2	C3S02,03	1756-IB32-3	DI	Dry Contact	LSH-61306	LSH-61306_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...
7	C3S02-X1	C3/S2	C3S02,04	1756-IB32-4	DI	Dry Contact	LSH-61308	LSH-61308_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...
8	C3S02-X1	C3/S2	C3S02,05	1756-IB32-5	DI	Dry Contact	LSL-61302	LSL-61302_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...
9	C3S05-X1	C3/S5	C3S05,06	1756-IF16-6	AI	4 - 20 mA	LT-61301	LT-61301_AI_1	3-25-01-613-PD-01	Level Transmitter	Packing Tower / ...
10	C3S02-X1	C3/S2	C3S02,06	1756-IB32-6	DI	Dry Contact	PSE-61300	PSE-61300_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...
11	C3S02-X1	C3/S2	C3S02,07	1756-IB32-7	DI	Dry Contact	PSE-61301	PSE-61301_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...
12	C3S02-X1	C3/S2	C3S02,08	1756-IB32-8	DI	Dry Contact	PSE-61304	PSE-61304_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...
13	C3S02-X1	C3/S2	C3S02,09	1756-IB32-9	DI	-	PSV-61301A	PSV-61301A_DI_1	325-01-613-PD-01	-	Packing Tower / ...
14	C3S02-X1	C3/S2	C3S02,10	1756-IB32-10	DI	-	PSV-61301B	PSV-61301B_DI_1	325-01-613-PD-01	-	Packing Tower / ...
15	C3S05-X1	C3/S5	C3S05,07	1756-IF16-7	AI	4 - 20 mA	PT-61301	PT-61301_AI_1	3-25-01-613-PD-01	Pressure Transmitter	Packing Tower / ...
16	C3S05-X1	C3/S5	C3S05,08	1756-IF16-8	AI	4 - 20 mA	PT-61303	PT-61303_AI_1	3-25-01-613-PD-01	Pressure Transmitter	Packing Tower / ...
17	C3S05-X1	C3/S5	C3S05,09	1756-IF16-9	AI	4 - 20 mA	PT-61304	PT-61304_AI_1	3-25-01-613-PD-01	Pressure Transmitter	Packing Tower / ...
18	C3S05-X1	C3/S5	C3S05,10	1756-IF16-10	AI	4 - 20 mA	PT-61305	PT-61305_AI_1	3-25-01-613-PD-01	Pressure Transmitter	Packing Tower / ...
19	C3S02-X1	C3/S2	C3S02,13	1756-IB32-13	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
20	C3S02-X1	C3/S2	C3S02,14	1756-IB32-14	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
21	C3S02-X1	C3/S2	C3S02,15	1756-IB32-15	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
22	C3S02-X2	C3/S2	C3S02,16	1756-IB32-16	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
23	C3S02-X2	C3/S2	C3S02,17	1756-IB32-17	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
24	C3S02-X2	C3/S2	C3S02,18	1756-IB32-18	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
25	C3S02-X2	C3/S2	C3S02,19	1756-IB32-19	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
26	C3S02-X2	C3/S2	C3S02,20	1756-IB32-20	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
27	C3S02-X2	C3/S2	C3S02,21	1756-IB32-21	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
28	C3S02-X2	C3/S2	C3S02,22	1756-IB32-22	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
29	C3S02-X2	C3/S2	C3S02,23	1756-IB32-23	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
30	C3S02-X2	C3/S2	C3S02,24	1756-IB32-24	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
31	C3S02-X2	C3/S2	C3S02,25	1756-IB32-25	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...

ENCLOSURE: IS-JB-618 | TYPE: Intrinsically Safe Junction Box (Ex i / LS) | LOCATION: Packing Tower 8th Floor | SIZE: 450-300-150 mm

SUMMARY: Total Channels: 44 | Active: 22 | Spare: 22 (50.0%) | DI: 32 | DO: 0 | AI: 12 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
32	C3S02-X2	C3/S2	C3S02,26	1756-IB32-26	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
33	C3S02-X2	C3/S2	C3S02,27	1756-IB32-27	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
34	C3S02-X2	C3/S2	C3S02,28	1756-IB32-28	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
35	C3S02-X2	C3/S2	C3S02,29	1756-IB32-29	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
36	C3S02-X2	C3/S2	C3S02,30	1756-IB32-30	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
37	C3S02-X2	C3/S2	C3S02,31	1756-IB32-31	DI	-	Spare	Spare_DI_0	3-25-01-613-PD-01	Spare I/O Point	Packing Tower / ...
38	C3S05-X1	C3/S5	C3S05,13	1756-IF16-13	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
39	C3S05-X1	C3/S5	C3S05,14	1756-IF16-14	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
40	C3S05-X1	C3/S5	C3S05,15	1756-IF16-15	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
41	C3S05-X1	C3/S5	C3S05,11	1756-IF16-11	AI	4 - 20 mA	TT-61301	TT-61301_AI_1	3-25-01-613-PD-01	0	Packing Tower / ...
42	C3S05-X1	C3/S5	C3S05,12	1756-IF16-12	AI	4 - 20 mA	TT-61302	TT-61302_AI_1	3-25-01-613-PD-01	0	Packing Tower / ...
43	C3S02-X1	C3/S2	C3S02,11	1756-IB32-11	DI	Dry Contact	ZS-61310	ZS-61310_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...
44	C3S02-X1	C3/S2	C3S02,12	1756-IB32-12	DI	Dry Contact	ZS-61311	ZS-61311_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...