

ENCLOSURE: JB-401 | TYPE: Field Junction Box (Standard) | LOCATION: Infeed 2nd Floor | SIZE: 800-600-250 mm

SUMMARY: Total Channels: 112 | Active: 85 | Spare: 27 (24.1%) | DI: 64 | DO: 32 | AI: 16 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
1	C1S03-X2	C1/S3	C1S03,16	1756-IB32-16	DI	Dry Contact	FSL-40201	FSL-40201_DI_1	3-25-01-402-PD-01	Flow Switch	PH Adjustment / ...
2	C1S03-X2	C1/S3	C1S03,17	1756-IB32-17	DI	Dry Contact	FSL-40202	FSL-40202_DI_1	3-25-01-402-PD-01	Flow Switch	PH Adjustment / ...
3	C1S09-X1	C1/S9	C1S09,00	1756-IF16-0	AI	4 - 20 mA,Pulse	FT-40201	FT-40201_AI_1	3-25-01-402-PD-02	Coriolis Flow Transmitter	Infeed Tank / 1st
4	C1S09-X1	C1/S9	C1S09,01	1756-IF16-1	AI	4 - 20 mA,Pulse	FT-40201	FT-40201_AI_2	3-25-01-402-PD-02	Coriolis Flow Transmitter	Infeed Tank / 1st
5	C1S03-X2	C1/S3	C1S03,18	1756-IB32-18	DI	4 - 20 mA,Pulse	FT-40201	FT-40201_DI_1	3-25-01-402-PD-02	Coriolis Flow Transmitter	Infeed Tank / 1st
6	C1S09-X1	C1/S9	C1S09,02	1756-IF16-2	AI	4 - 20 mA,Pulse	FT-40202	FT-40202_AI_1	3-25-01-402-PD-02	Magnetic Flow Transmitter	Infeed Tank / 1st
7	C1S03-X2	C1/S3	C1S03,19	1756-IB32-19	DI	4 - 20 mA,Pulse	FT-40202	FT-40202_DI_1	3-25-01-402-PD-02	Magnetic Flow Transmitter	Infeed Tank / 1st
8	C1S03-X2	C1/S3	C1S03,20	1756-IB32-20	DI	Dry Contact	HV-40201	HV-40201_DI_1	3-25-01-402-PD-01	Manual Valve With Position Switch	PH Adjustment / ...
9	C1S03-X2	C1/S3	C1S03,21	1756-IB32-21	DI	Dry Contact	HV-40202	HV-40202_DI_1	3-25-01-402-PD-01	Manual Valve With Position Switch	PH Adjustment / ...
10	C1S03-X2	C1/S3	C1S03,22	1756-IB32-22	DI	Dry Contact	HV-40203	HV-40203_DI_1	3-25-01-402-PD-01	Manual Valve With Position Switch	PH Adjustment / ...
11	C1S03-X2	C1/S3	C1S03,23	1756-IB32-23	DI	Dry Contact	HV-40204	HV-40204_DI_1	3-25-01-402-PD-01	Manual Valve With Position Switch	PH Adjustment / ...
12	C1S03-X2	C1/S3	C1S03,24	1756-IB32-24	DI	Dry Contact	HV-40205	HV-40205_DI_1	3-25-01-402-PD-02	Manual Valve With Position Switch	Infeed Tank / 1st
13	C1S03-X2	C1/S3	C1S03,25	1756-IB32-25	DI	Dry Contact	HV-40206	HV-40206_DI_1	3-25-01-402-PD-02	Manual Valve With Position Switch	Infeed Tank / 1st
14	C1S09-X1	C1/S9	C1S09,04	1756-IF16-4	AI	4 - 20 mA	LT-40201	LT-40201_AI_1	3-25-01-402-PD-01	Level Transmitter	PH Adjustment / ...
15	C1S09-X1	C1/S9	C1S09,05	1756-IF16-5	AI	4 - 20 mA	LT-40202	LT-40202_AI_1	3-25-01-402-PD-01	Level Transmitter	PH Adjustment / ...
16	C1S09-X1	C1/S9	C1S09,03	1756-IF16-3	AI	4 - 20 mA	LT-40203	LT-40203_AI_1	3-25-01-402-PD-02	Level Transmitter	Infeed Tank / 1st
17	C1S09-X1	C1/S9	C1S09,06	1756-IF16-6	AI	4 - 20 mA	pHT-40201	pHT-40201_AI_1	3-25-01-402-PD-01	PH Transmitter	PH Adjustment / ...
18	C1S09-X1	C1/S9	C1S09,07	1756-IF16-7	AI	4 - 20 mA	pHT-40202	pHT-40202_AI_1	3-25-01-402-PD-01	PH Transmitter	PH Adjustment / ...
19	C1S09-X1	C1/S9	C1S09,08	1756-IF16-8	AI	4 - 20 mA	PT-40201	PT-40201_AI_1	3-25-01-402-PD-02	Pressure Transmitter	Infeed Tank / 1st
20	C1S09-X1	C1/S9	C1S09,09	1756-IF16-9	AI	4 - 20 mA	PT-40202	PT-40202_AI_1	3-25-01-402-PD-02	Pressure Transmitter	Infeed Tank / 1st
21	C1S09-X1	C1/S9	C1S09,10	1756-IF16-10	AI	4 - 20 mA	PT-60202	PT-60202_AI_1	3-25-01-602-PD-01	Pressure Transmitter	Infeed Tank / 1st
22	C1S09-X1	C1/S9	C1S09,11	1756-IF16-11	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
23	C1S09-X1	C1/S9	C1S09,12	1756-IF16-12	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
24	C1S09-X1	C1/S9	C1S09,13	1756-IF16-13	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
25	C1S09-X1	C1/S9	C1S09,14	1756-IF16-14	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
26	C1S09-X1	C1/S9	C1S09,15	1756-IF16-15	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
27	C1S05-X1	C1/S5	C1S05,02	1756-IB32-2	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
28	C1S05-X1	C1/S5	C1S05,03	1756-IB32-3	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
29	C1S05-X1	C1/S5	C1S05,04	1756-IB32-4	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
30	C1S05-X1	C1/S5	C1S05,05	1756-IB32-5	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
31	C1S05-X1	C1/S5	C1S05,06	1756-IB32-6	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-

ENCLOSURE: JB-401 | TYPE: Field Junction Box (Standard) | LOCATION: Infeed 2nd Floor | SIZE: 800-600-250 mm

SUMMARY: Total Channels: 112 | Active: 85 | Spare: 27 (24.1%) | DI: 64 | DO: 32 | AI: 16 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
32	C1S05-X1	C1/S5	C1S05,07	1756-IB32-7	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
33	C1S05-X1	C1/S5	C1S05,08	1756-IB32-8	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
34	C1S05-X1	C1/S5	C1S05,09	1756-IB32-9	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
35	C1S05-X1	C1/S5	C1S05,10	1756-IB32-10	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
36	C1S05-X1	C1/S5	C1S05,11	1756-IB32-11	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
37	C1S05-X1	C1/S5	C1S05,12	1756-IB32-12	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
38	C1S05-X1	C1/S5	C1S05,13	1756-IB32-13	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
39	C1S05-X1	C1/S5	C1S05,14	1756-IB32-14	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
40	C1S05-X1	C1/S5	C1S05,15	1756-IB32-15	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
41	C1S08-X1	C1/S8	C1S08,08	1756-OB32-8	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
42	C1S08-X1	C1/S8	C1S08,09	1756-OB32-9	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
43	C1S08-X1	C1/S8	C1S08,10	1756-OB32-10	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
44	C1S08-X1	C1/S8	C1S08,11	1756-OB32-11	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
45	C1S08-X1	C1/S8	C1S08,12	1756-OB32-12	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
46	C1S08-X1	C1/S8	C1S08,13	1756-OB32-13	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
47	C1S08-X1	C1/S8	C1S08,14	1756-OB32-14	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
48	C1S08-X1	C1/S8	C1S08,15	1756-OB32-15	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
49	C1S07-X2	C1/S7	C1S07,24	1756-OB32-24	DO	24 VDC energized	SV-40201	SV-40201_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
50	C1S07-X2	C1/S7	C1S07,25	1756-OB32-25	DO	24 VDC energized	SV-40202	SV-40202_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
51	C1S07-X2	C1/S7	C1S07,26	1756-OB32-26	DO	24 VDC energized	SV-40203	SV-40203_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
52	C1S07-X2	C1/S7	C1S07,27	1756-OB32-27	DO	24 VDC energized	SV-40204	SV-40204_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
53	C1S03-X2	C1/S3	C1S03,26	1756-IB32-26	DI	24 VDC energized	XV-40201A	XV-40201A_DI_1	3-25-01-402-PD-01	0	PH Adjustment / ...
54	C1S03-X2	C1/S3	C1S03,27	1756-IB32-27	DI	24 VDC energized	XV-40201A	XV-40201A_DI_2	3-25-01-402-PD-01	0	PH Adjustment / ...
55	C1S07-X2	C1/S7	C1S07,28	1756-OB32-28	DO	24 VDC energized	XV-40201A	XV-40201A_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
56	C1S03-X2	C1/S3	C1S03,28	1756-IB32-28	DI	24 VDC energized	XV-40201B	XV-40201B_DI_1	3-25-01-402-PD-01	0	PH Adjustment / ...
57	C1S03-X2	C1/S3	C1S03,29	1756-IB32-29	DI	24 VDC energized	XV-40201B	XV-40201B_DI_2	3-25-01-402-PD-01	0	PH Adjustment / ...
58	C1S07-X2	C1/S7	C1S07,29	1756-OB32-29	DO	24 VDC energized	XV-40201B	XV-40201B_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
59	C1S03-X2	C1/S3	C1S03,30	1756-IB32-30	DI	24 VDC energized	XV-40201C	XV-40201C_DI_1	3-25-01-402-PD-01	0	PH Adjustment / ...
60	C1S03-X2	C1/S3	C1S03,31	1756-IB32-31	DI	24 VDC energized	XV-40201C	XV-40201C_DI_2	3-25-01-402-PD-01	0	PH Adjustment / ...
61	C1S07-X2	C1/S7	C1S07,30	1756-OB32-30	DO	24 VDC energized	XV-40201C	XV-40201C_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
62	C1S04-X1	C1/S4	C1S04,00	1756-IB32-0	DI	24 VDC energized	XV-40201D	XV-40201D_DI_1	3-25-01-402-PD-01	0	PH Adjustment / ...

ENCLOSURE: JB-401 | TYPE: Field Junction Box (Standard) | LOCATION: Infeed 2nd Floor | SIZE: 800-600-250 mm

SUMMARY: Total Channels: 112 | Active: 85 | Spare: 27 (24.1%) | DI: 64 | DO: 32 | AI: 16 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
63	C1S04-X1	C1/S4	C1S04,01	1756-IB32-1	DI	24 VDC energized	XV-40201D	XV-40201D_DI_2	3-25-01-402-PD-01	0	PH Adjustment / ...
64	C1S07-X2	C1/S7	C1S07,31	1756-OB32-31	DO	24 VDC energized	XV-40201D	XV-40201D_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
65	C1S04-X1	C1/S4	C1S04,02	1756-IB32-2	DI	24 VDC energized	XV-40201E	XV-40201E_DI_1	3-25-01-402-PD-01	0	PH Adjustment / ...
66	C1S04-X1	C1/S4	C1S04,03	1756-IB32-3	DI	24 VDC energized	XV-40201E	XV-40201E_DI_2	3-25-01-402-PD-01	0	PH Adjustment / ...
67	C1S08-X1	C1/S8	C1S08,00	1756-OB32-0	DO	24 VDC energized	XV-40201E	XV-40201E_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
68	C1S04-X1	C1/S4	C1S04,04	1756-IB32-4	DI	24 VDC energized	XV-40201F	XV-40201F_DI_1	3-25-01-402-PD-01	0	PH Adjustment / ...
69	C1S04-X1	C1/S4	C1S04,05	1756-IB32-5	DI	24 VDC energized	XV-40201F	XV-40201F_DI_2	3-25-01-402-PD-01	0	PH Adjustment / ...
70	C1S08-X1	C1/S8	C1S08,01	1756-OB32-1	DO	24 VDC energized	XV-40201F	XV-40201F_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
71	C1S04-X1	C1/S4	C1S04,06	1756-IB32-6	DI	24 VDC energized	XV-40201G	XV-40201G_DI_1	3-25-01-402-PD-01	0	PH Adjustment / ...
72	C1S04-X1	C1/S4	C1S04,07	1756-IB32-7	DI	24 VDC energized	XV-40201G	XV-40201G_DI_2	3-25-01-402-PD-01	0	PH Adjustment / ...
73	C1S08-X1	C1/S8	C1S08,02	1756-OB32-2	DO	24 VDC energized	XV-40201G	XV-40201G_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
74	C1S04-X1	C1/S4	C1S04,08	1756-IB32-8	DI	24 VDC energized	XV-40201H	XV-40201H_DI_1	3-25-01-402-PD-01	0	PH Adjustment / ...
75	C1S04-X1	C1/S4	C1S04,09	1756-IB32-9	DI	24 VDC energized	XV-40201H	XV-40201H_DI_2	3-25-01-402-PD-01	0	PH Adjustment / ...
76	C1S08-X1	C1/S8	C1S08,03	1756-OB32-3	DO	24 VDC energized	XV-40201H	XV-40201H_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
77	C1S04-X2	C1/S4	C1S04,19	1756-IB32-19	DI	24 VDC energized	XV-40202A	XV-40202A_DI_1	3-25-01-402-PD-01	0	PH Adjustment / ...
78	C1S04-X1	C1/S4	C1S04,11	1756-IB32-11	DI	24 VDC energized	XV-40202A	XV-40202A_DI_2	3-25-01-402-PD-01	0	PH Adjustment / ...
79	C1S08-X1	C1/S8	C1S08,04	1756-OB32-4	DO	24 VDC energized	XV-40202A	XV-40202A_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
80	C1S04-X1	C1/S4	C1S04,12	1756-IB32-12	DI	24 VDC energized	XV-40202B	XV-40202B_DI_1	3-25-01-402-PD-01	0	PH Adjustment / ...
81	C1S04-X1	C1/S4	C1S04,13	1756-IB32-13	DI	24 VDC energized	XV-40202B	XV-40202B_DI_2	3-25-01-402-PD-01	0	PH Adjustment / ...
82	C1S08-X1	C1/S8	C1S08,05	1756-OB32-5	DO	24 VDC energized	XV-40202B	XV-40202B_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
83	C1S04-X1	C1/S4	C1S04,14	1756-IB32-14	DI	24 VDC energized	XV-40202C	XV-40202C_DI_1	3-25-01-402-PD-01	0	PH Adjustment / ...
84	C1S04-X1	C1/S4	C1S04,15	1756-IB32-15	DI	24 VDC energized	XV-40202C	XV-40202C_DI_2	3-25-01-402-PD-01	0	PH Adjustment / ...
85	C1S08-X1	C1/S8	C1S08,06	1756-OB32-6	DO	24 VDC energized	XV-40202C	XV-40202C_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
86	C1S04-X2	C1/S4	C1S04,16	1756-IB32-16	DI	24 VDC energized	XV-40202D	XV-40202D_DI_1	3-25-01-402-PD-01	0	PH Adjustment / ...
87	C1S04-X2	C1/S4	C1S04,17	1756-IB32-17	DI	24 VDC energized	XV-40202D	XV-40202D_DI_2	3-25-01-402-PD-01	0	PH Adjustment / ...
88	C1S08-X1	C1/S8	C1S08,07	1756-OB32-7	DO	24 VDC energized	XV-40202D	XV-40202D_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
89	C1S04-X2	C1/S4	C1S04,18	1756-IB32-18	DI	24 VDC energized	XV-40202E	XV-40202E_DI_1	3-25-01-402-PD-01	0	PH Adjustment / ...
90	C1S04-X2	C1/S4	C1S04,19	1756-IB32-19	DI	24 VDC energized	XV-40202E	XV-40202E_DI_2	3-25-01-402-PD-01	0	PH Adjustment / ...
91	C1S07-X2	C1/S7	C1S07,16	1756-OB32-16	DO	24 VDC energized	XV-40202E	XV-40202E_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
92	C1S04-X2	C1/S4	C1S04,20	1756-IB32-20	DI	24 VDC energized	XV-40202F	XV-40202F_DI_1	3-25-01-402-PD-01	0	PH Adjustment / ...
93	C1S04-X2	C1/S4	C1S04,21	1756-IB32-21	DI	24 VDC energized	XV-40202F	XV-40202F_DI_2	3-25-01-402-PD-01	0	PH Adjustment / ...

ENCLOSURE: JB-401 | TYPE: Field Junction Box (Standard) | LOCATION: Infeed 2nd Floor | SIZE: 800-600-250 mm

SUMMARY: Total Channels: 112 | Active: 85 | Spare: 27 (24.1%) | DI: 64 | DO: 32 | AI: 16 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
94	C1S07-X2	C1/S7	C1S07,17	1756-OB32-17	DO	24 VDC energized	XV-40202F	XV-40202F_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
95	C1S04-X2	C1/S4	C1S04,22	1756-IB32-22	DI	24 VDC energized	XV-40202G	XV-40202G_DI_1	3-25-01-402-PD-01	0	PH Adjustment / ...
96	C1S04-X2	C1/S4	C1S04,23	1756-IB32-23	DI	24 VDC energized	XV-40202G	XV-40202G_DI_2	3-25-01-402-PD-01	0	PH Adjustment / ...
97	C1S07-X2	C1/S7	C1S07,18	1756-OB32-18	DO	24 VDC energized	XV-40202G	XV-40202G_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
98	C1S04-X2	C1/S4	C1S04,24	1756-IB32-24	DI	24 VDC energized	XV-40202H	XV-40202H_DI_1	3-25-01-402-PD-01	0	PH Adjustment / ...
99	C1S04-X2	C1/S4	C1S04,25	1756-IB32-25	DI	24 VDC energized	XV-40202H	XV-40202H_DI_2	3-25-01-402-PD-01	0	PH Adjustment / ...
100	C1S07-X2	C1/S7	C1S07,19	1756-OB32-19	DO	24 VDC energized	XV-40202H	XV-40202H_DO_1	3-25-01-402-PD-01	0	PH Adjustment / ...
101	C1S04-X2	C1/S4	C1S04,26	1756-IB32-26	DI	24 VDC energized	XV-40203B	XV-40203B_DI_1	3-25-01-402-PD-02	0	Infeed Tank / 1st
102	C1S04-X2	C1/S4	C1S04,27	1756-IB32-27	DI	24 VDC energized	XV-40203B	XV-40203B_DI_2	3-25-01-402-PD-02	0	Infeed Tank / 1st
103	C1S07-X2	C1/S7	C1S07,20	1756-OB32-20	DO	24 VDC energized	XV-40203B	XV-40203B_DO_1	3-25-01-402-PD-02	0	Infeed Tank / 1st
104	C1S04-X2	C1/S4	C1S04,28	1756-IB32-28	DI	24 VDC energized	XV-40203C	XV-40203C_DI_1	3-25-01-402-PD-02	0	Infeed Tank / 1st
105	C1S04-X2	C1/S4	C1S04,29	1756-IB32-29	DI	24 VDC energized	XV-40203C	XV-40203C_DI_2	3-25-01-402-PD-02	0	Infeed Tank / 1st
106	C1S07-X2	C1/S7	C1S07,21	1756-OB32-21	DO	24 VDC energized	XV-40203C	XV-40203C_DO_1	3-25-01-402-PD-02	0	Infeed Tank / 1st
107	C1S04-X2	C1/S4	C1S04,30	1756-IB32-30	DI	24 VDC energized	XV-40203D	XV-40203D_DI_1	3-25-01-402-PD-02	0	Infeed Tank / 1st
108	C1S04-X2	C1/S4	C1S04,31	1756-IB32-31	DI	24 VDC energized	XV-40203D	XV-40203D_DI_2	3-25-01-402-PD-02	0	Infeed Tank / 1st
109	C1S07-X2	C1/S7	C1S07,22	1756-OB32-22	DO	24 VDC energized	XV-40203D	XV-40203D_DO_1	3-25-01-402-PD-02	0	Infeed Tank / 1st
110	C1S05-X1	C1/S5	C1S05,00	1756-IB32-0	DI	24 VDC energized	XV-40203E	XV-40203E_DI_1	3-25-01-402-PD-02	0	Infeed Tank / 1st
111	C1S05-X1	C1/S5	C1S05,01	1756-IB32-1	DI	24 VDC energized	XV-40203E	XV-40203E_DI_2	3-25-01-402-PD-02	0	Infeed Tank / 1st
112	C1S07-X2	C1/S7	C1S07,23	1756-OB32-23	DO	24 VDC energized	XV-40203E	XV-40203E_DO_1	3-25-01-402-PD-02	0	Infeed Tank / 1st