

ENCLOSURE: JB-601 | TYPE: Field Junction Box (Standard) | LOCATION: Spray Dryer 1st Floor | SIZE: 500-400-200 mm

SUMMARY: Total Channels: 85 | Active: 58 | Spare: 27 (31.8%) | DI: 51 | DO: 17 | AI: 16 | AO: 0 | BUS: 1

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
1	C1S10-X1	C1/S10	C1S10,00	1756-IF16-0	AI	4 - 20 mA	DPI-60240	DPI-60240_AI_1	325-01-600-PD-05	0	Spray Dryer / 1st
2	C1S10-X1	C1/S10	C1S10,01	1756-IF16-1	AI	4 - 20 mA	DPT-60202	DPT-60202_AI_1	3-25-01-602-PD-08	Differential Pressure Transmitt	Spray Dryer / 1st
3	C1S05-X2	C1/S5	C1S05,16	1756-IB32-16	DI	0	ES-60202	ES-60202_DI_1	325-01-600-PD-01	0	Spray Dryer / 1st
4	C1S05-X2	C1/S5	C1S05,17	1756-IB32-17	DI	0	FS-60205	FS-60205_DI_1	3-25-01-602-PD-01	Flow Switch	Spray Dryer / 1st
5	C1S10-X1	C1/S10	C1S10,02	1756-IF16-2	AI	4 - 20 mA	FT-60201	FT-60201_AI_1	3-25-01-602-PD-08	0	Spray Dryer / 1st
6	C1S10-X1	C1/S10	C1S10,03	1756-IF16-3	AI	4 - 20 mA	FT-60204	FT-60204_AI_1	3-25-01-602-PD-10	0	Spray Dryer / 1st
7	C1S10-X1	C1/S10	C1S10,04	1756-IF16-4	AI	4 - 20 mA	FT-61307	FT-61307_AI_1	3-25-01-613-PD-04	0	Spray Dryer / 1st
8	C1S05-X2	C1/S5	C1S05,18	1756-IB32-18	DI	Dry Contact	LSL-60201	LSL-60201_DI_1	3-25-01-602-PD-11	0	Spray Dryer / 1st
9	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	PCY-60205	PCY-60205_BUS_1	325-01-600-PD-01	-	Spray Dryer / 1st
10	C7S02-	C7/S2	C7S02,03	-	DI	-	PCY-60205	PCY-60205_DI_1	325-01-600-PD-01	-	Spray Dryer / 1st
11	C7S02-	C7/S2	C7S02,04	-	DI	-	PCY-60205	PCY-60205_DI_2	325-01-600-PD-01	-	Spray Dryer / 1st
12	C7S03-	C7/S3	C7S03,25	-	DI	-	PCY-60205	PCY-60205_DI_3	325-01-600-PD-01	-	Spray Dryer / 1st
13	C7S06-	C7/S6	C7S06,31	-	DO	-	PCY-60205	PCY-60205_DO_1	325-01-600-PD-01	-	Spray Dryer / 1st
14	C1S10-X1	C1/S10	C1S10,05	1756-IF16-5	AI	4 - 20 mA	PT-60203	PT-60203_AI_1	3-25-01-602-PD-08	Pressure Transmitter	Spray Dryer / 1st
15	C1S10-X1	C1/S10	C1S10,06	1756-IF16-6	AI	4 - 20 mA	PT-60204	PT-60204_AI_1	3-25-01-602-PD-10	Pressure Transmitter	Spray Dryer / 1st
16	C1S10-X1	C1/S10	C1S10,07	1756-IF16-7	AI	4 - 20 mA	PT-60205	PT-60205_AI_1	3-25-01-602-PD-01	Pressure Transmitter	Spray Dryer / 1st
17	C1S05-X2	C1/S5	C1S05,26	1756-IB32-26	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
18	C1S05-X2	C1/S5	C1S05,27	1756-IB32-27	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
19	C1S05-X2	C1/S5	C1S05,28	1756-IB32-28	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
20	C1S05-X2	C1/S5	C1S05,29	1756-IB32-29	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
21	C1S05-X2	C1/S5	C1S05,30	1756-IB32-30	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
22	C1S05-X2	C1/S5	C1S05,31	1756-IB32-31	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
23	C1S06-X2	C1/S6	C1S06,23	1756-IB32-23	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer / 1st
24	C1S06-X2	C1/S6	C1S06,24	1756-IB32-24	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer / 1st
25	C1S06-X2	C1/S6	C1S06,25	1756-IB32-25	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer / 1st
26	C1S06-X2	C1/S6	C1S06,26	1756-IB32-26	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer / 1st
27	C1S06-X2	C1/S6	C1S06,27	1756-IB32-27	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer / 1st
28	C1S06-X2	C1/S6	C1S06,28	1756-IB32-28	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer / 1st
29	C1S06-X2	C1/S6	C1S06,29	1756-IB32-29	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer / 1st
30	C1S06-X2	C1/S6	C1S06,30	1756-IB32-30	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer / 1st
31	C1S06-X2	C1/S6	C1S06,31	1756-IB32-31	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer / 1st

ENCLOSURE: JB-601 | TYPE: Field Junction Box (Standard) | LOCATION: Spray Dryer 1st Floor | SIZE: 500-400-200 mm

SUMMARY: Total Channels: 85 | Active: 58 | Spare: 27 (31.8%) | DI: 51 | DO: 17 | AI: 16 | AO: 0 | BUS: 1

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
32	C1S08-X2	C1/S8	C1S08,28	1756-OB32-28	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
33	C1S08-X2	C1/S8	C1S08,29	1756-OB32-29	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
34	C1S08-X2	C1/S8	C1S08,30	1756-OB32-30	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
35	C1S08-X2	C1/S8	C1S08,31	1756-OB32-31	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
36	C1S10-X1	C1/S10	C1S10,08	1756-IF16-8	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
37	C1S10-X1	C1/S10	C1S10,09	1756-IF16-9	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
38	C1S10-X1	C1/S10	C1S10,10	1756-IF16-10	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
39	C1S10-X1	C1/S10	C1S10,11	1756-IF16-11	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
40	C1S10-X1	C1/S10	C1S10,12	1756-IF16-12	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
41	C1S10-X1	C1/S10	C1S10,13	1756-IF16-13	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
42	C1S10-X1	C1/S10	C1S10,14	1756-IF16-14	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
43	C1S10-X1	C1/S10	C1S10,15	1756-IF16-15	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
44	C1S05-X2	C1/S5	C1S05,19	1756-IB32-19	DI	24 VDC energized	SV-60201	SV-60201_DI_1	3-25-01-602-PD-08	0	Spray Dryer / 1st
45	C1S05-X2	C1/S5	C1S05,20	1756-IB32-20	DI	24 VDC energized	SV-60201	SV-60201_DI_2	3-25-01-602-PD-08	0	Spray Dryer / 1st
46	C1S08-X2	C1/S8	C1S08,16	1756-OB32-16	DO	24 VDC energized	SV-60201	SV-60201_DO_1	3-25-01-602-PD-08	0	Spray Dryer / 1st
47	C1S05-X2	C1/S5	C1S05,21	1756-IB32-21	DI	24 VDC energized	SV-60202	SV-60202_DI_1	3-25-01-602-PD-08	0	Spray Dryer / 1st
48	C1S05-X2	C1/S5	C1S05,22	1756-IB32-22	DI	24 VDC energized	SV-60202	SV-60202_DI_2	3-25-01-602-PD-08	0	Spray Dryer / 1st
49	C1S08-X2	C1/S8	C1S08,17	1756-OB32-17	DO	24 VDC energized	SV-60202	SV-60202_DO_1	3-25-01-602-PD-08	0	Spray Dryer / 1st
50	C1S05-X2	C1/S5	C1S05,23	1756-IB32-23	DI	24 VDC energized	SV-60203	SV-60203_DI_1	3-25-01-602-PD-08	0	Spray Dryer / 1st
51	C1S05-X2	C1/S5	C1S05,24	1756-IB32-24	DI	24 VDC energized	SV-60203	SV-60203_DI_2	3-25-01-602-PD-08	0	Spray Dryer / 1st
52	C1S08-X2	C1/S8	C1S08,19	1756-OB32-19	DO	24 VDC energized	SV-60203	SV-60203_DO_1	3-25-01-602-PD-08	0	Spray Dryer / 1st
53	C1S08-X2	C1/S8	C1S08,18	1756-OB32-18	DO	24 VDC energized	SV-60230	SV-60230_DO_1	3-25-01-602-PD-04	0	Spray Dryer / 1st
54	C1S08-X2	C1/S8	C1S08,21	1756-OB32-21	DO	24 VDC energized	SV-60231	SV-60231_DO_1	3-25-01-602-PD-04	0	Spray Dryer / 1st
55	C1S08-X2	C1/S8	C1S08,20	1756-OB32-20	DO	24 VDC energized	SV-60240A	SV-60240A_DO_1	3-25-01-602-PD-05	0	Spray Dryer / 1st
56	C1S08-X2	C1/S8	C1S08,22	1756-OB32-22	DO	24 VDC energized	SV-60240B	SV-60240B_DO_1	3-25-01-602-PD-05	0	Spray Dryer / 1st
57	C1S08-X2	C1/S8	C1S08,23	1756-OB32-23	DO	24 VDC energized	SV-60240C	SV-60240C_DO_1	3-25-01-602-PD-05	0	Spray Dryer / 1st
58	C1S05-X2	C1/S5	C1S05,25	1756-IB32-25	DI	Dry Contact	VS-60205	VS-60205_DI_1	3-25-01-602-PD-01	Vibration Switch	Spray Dryer / 1st
59	C1S06-X1	C1/S6	C1S06,00	1756-IB32-0	DI	Dry Contact	XA-60202A	XA-60202A_DI_1	325-01-600-PD-08	0	Spray Dryer / 1st
60	C1S06-X1	C1/S6	C1S06,01	1756-IB32-1	DI	Dry Contact	XA-60202B	XA-60202B_DI_1	325-01-600-PD-08	0	Spray Dryer / 1st
61	C1S06-X1	C1/S6	C1S06,02	1756-IB32-2	DI	Dry Contact	XA-60202C	XA-60202C_DI_1	325-01-600-PD-08	0	Spray Dryer / 1st
62	C1S06-X1	C1/S6	C1S06,03	1756-IB32-3	DI	Dry Contact	XA-60202D	XA-60202D_DI_1	325-01-600-PD-08	0	Spray Dryer / 1st

ENCLOSURE: JB-601 | TYPE: Field Junction Box (Standard) | LOCATION: Spray Dryer 1st Floor | SIZE: 500-400-200 mm

SUMMARY: Total Channels: 85 | Active: 58 | Spare: 27 (31.8%) | DI: 51 | DO: 17 | AI: 16 | AO: 0 | BUS: 1

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
63	C1S06-X1	C1/S6	C1S06,04	1756-IB32-4	DI	Dry Contact	XA-60202E	XA-60202E_DI_1	325-01-600-PD-08	0	Spray Dryer / 1st
64	C1S06-X1	C1/S6	C1S06,05	1756-IB32-5	DI	Dry Contact	XA-60202F	XA-60202F_DI_1	325-01-600-PD-08	0	Spray Dryer / 1st
65	C1S06-X1	C1/S6	C1S06,06	1756-IB32-6	DI	Dry Contact	XA-60202G	XA-60202G_DI_1	325-01-600-PD-08	0	Spray Dryer / 1st
66	C1S06-X1	C1/S6	C1S06,07	1756-IB32-7	DI	Dry Contact	XA-60202H	XA-60202H_DI_1	325-01-600-PD-08	0	Spray Dryer / 1st
67	C1S06-X1	C1/S6	C1S06,08	1756-IB32-8	DI	-	XA-60202I	XA-60202I_DI_1	325-01-600-PD-08	-	Spray Dryer / 1st
68	C1S06-X1	C1/S6	C1S06,09	1756-IB32-9	DI	Dry Contact	XA-60202J	XA-60202J_DI_1	325-01-600-PD-08	0	Spray Dryer / 1st
69	C1S06-X1	C1/S6	C1S06,10	1756-IB32-10	DI	Dry Contact	XA-60202K	XA-60202K_DI_1	325-01-600-PD-08	0	Spray Dryer / 1st
70	C1S06-X1	C1/S6	C1S06,11	1756-IB32-11	DI	Dry Contact	XA-60202L	XA-60202L_DI_1	325-01-600-PD-08	0	Spray Dryer / 1st
71	C1S06-X1	C1/S6	C1S06,12	1756-IB32-12	DI	Dry Contact	XA-60202M	XA-60202M_DI_1	325-01-600-PD-08	0	Spray Dryer / 1st
72	C1S06-X1	C1/S6	C1S06,13	1756-IB32-13	DI	24 VDC energized	XV-60202	XV-60202_DI_1	3-25-01-602-PD-11	0	Spray Dryer / 1st
73	C1S06-X1	C1/S6	C1S06,14	1756-IB32-14	DI	24 VDC energized	XV-60202	XV-60202_DI_2	3-25-01-602-PD-11	0	Spray Dryer / 1st
74	C1S08-X2	C1/S8	C1S08,26	1756-OB32-26	DO	24 VDC energized	XV-60202	XV-60202_DO_1	3-25-01-602-PD-11	0	Spray Dryer / 1st
75	C1S06-X1	C1/S6	C1S06,15	1756-IB32-15	DI	24 VDC energized,...	XV-60205A	XV-60205A_DI_1	3-25-01-602-PD-01	0	Spray Dryer / 1st
76	C1S06-X2	C1/S6	C1S06,16	1756-IB32-16	DI	24 VDC energized,...	XV-60205A	XV-60205A_DI_2	3-25-01-602-PD-01	0	Spray Dryer / 1st
77	C1S08-X2	C1/S8	C1S08,27	1756-OB32-27	DO	24 VDC energized,...	XV-60205A	XV-60205A_DO_1	3-25-01-602-PD-01	0	Spray Dryer / 1st
78	C1S06-X2	C1/S6	C1S06,17	1756-IB32-17	DI	-	XV-60240D	XV-60240D_DI_1	325-01-600-PD-05	-	Spray Dryer / 1st
79	C1S06-X2	C1/S6	C1S06,18	1756-IB32-18	DI	-	XV-60240D	XV-60240D_DI_2	3-25-01-602-PD-05	-	Spray Dryer / 1st
80	C1S06-X2	C1/S6	C1S06,19	1756-IB32-19	DI	-	XV-60240D	XV-60240D_DI_1	325-01-600-PD-05	-	Spray Dryer / 1st
81	C1S06-X2	C1/S6	C1S06,20	1756-IB32-20	DI	-	XV-60240D	XV-60240D_DI_2	3-25-01-602-PD-05	-	Spray Dryer / 1st
82	C1S08-X2	C1/S8	C1S08,24	1756-OB32-24	DO	-	XV-60240D	XV-60240D_DO_1	325-01-600-PD-05	-	Spray Dryer / 1st
83	C1S08-X2	C1/S8	C1S08,25	1756-OB32-25	DO	24 VDC energized	XV-60251	XV-60251_DO_1	3-25-01-602-PD-01	0	Infeed Tank / 1st
84	C1S06-X2	C1/S6	C1S06,21	1756-IB32-21	DI	0	YA-60205	YA-60205_DI_1	325-01-600-PD-01	0	Spray Dryer / 1st
85	C1S06-X2	C1/S6	C1S06,22	1756-IB32-22	DI	0	YI-60205	YI-60205_DI_1	325-01-600-PD-01	0	Spray Dryer / 1st