

ENCLOSURE: JB-602 | TYPE: Field Junction Box (Standard) | LOCATION: Spray Dryer 3rd Floor | SIZE: 800-600-250 mm

SUMMARY: Total Channels: 82 | Active: 57 | Spare: 25 (30.5%) | DI: 32 | DO: 16 | AI: 32 | AO: 2 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
1	C2S10-X1	C2/S10	C2S10,00	1756-IF16-0	AI	4 - 20 mA	AT-60241	AT-60241_AI_1	3-25-01-602-PD-05	Dust Analyzer Transmitter	Spray Dryer / 5th
2	C2S10-X1	C2/S10	C2S10,01	1756-IF16-1	AI	4 - 20 mA	DPT-60203	DPT-60203_AI_1	3-25-01-602-PD-03	Differential Pressure Transmitter	Spray Dryer / 5th
3	C2S02-X1	C2/S2	C2S02,00	1756-IB32-0	DI	4 - 20 mA	FT-60202	FT-60202_DI_1	3-25-01-602-PD-09	0	Spray Dryer / 5th
4	C2S10-X1	C2/S10	C2S10,02	1756-IF16-2	AI	4 - 20 mA	FT-60202	FT-60202_AI_1	3-25-01-602-PD-09	0	Spray Dryer / 5th
5	C2S11-X1	C2/S11	C2S11,09	1756-IF16-9	AI	4 - 20 mA	FT-60210	FT-60210_AI_1	3-25-01-602-PD-03	0	Spray Dryer / 5th
6	C2S11-X1	C2/S11	C2S11,11	1756-IF16-11	AI	4 - 20 mA	FT-60210	FT-60210_AI_2	3-25-01-602-PD-03	0	Spray Dryer / 5th
7	C2S11-X1	C2/S11	C2S11,10	1756-IF16-10	AI	4 - 20 mA	FT-60211	FT-60211_AI_1	3-25-01-602-PD-03	0	Spray Dryer / 5th
8	C2S11-X1	C2/S11	C2S11,12	1756-IF16-12	AI	4 - 20 mA	FT-60211	FT-60211_AI_2	3-25-01-602-PD-03	0	Spray Dryer / 5th
9	C2S02-X1	C2/S2	C2S02,01	1756-IB32-1	DI	Dry Contact	LSH-60251	LSH-60251_DI_1	3-25-01-602-PD-04	0	Spray Dryer / 4th
10	C2S02-X1	C2/S2	C2S02,02	1756-IB32-2	DI	Dry Contact	PSL-60220	PSL-60220_DI_1	3-25-01-602-PD-04	0	Spray Dryer / 5th
11	C2S10-X1	C2/S10	C2S10,03	1756-IF16-3	AI	4 - 20 mA	PT-60210	PT-60210_AI_1	3-25-01-602-PD-03	Pressure Transmitter	Spray Dryer / 5th
12	C2S10-X1	C2/S10	C2S10,04	1756-IF16-4	AI	4 - 20 mA	PT-60215	PT-60215_AI_1	3-25-01-602-PD-03	Pressure Transmitter	Spray Dryer / 5th
13	C2S10-X1	C2/S10	C2S10,05	1756-IF16-5	AI	4 - 20 mA	PT-60216	PT-60216_AI_1	3-25-01-602-PD-03	Pressure Transmitter	Spray Dryer / 5th
14	C2S10-X1	C2/S10	C2S10,06	1756-IF16-6	AI	4 - 20 mA	PT-60240	PT-60240_AI_1	3-25-01-602-PD-05	Pressure Transmitter	Spray Dryer / 5th
15	C2S10-X1	C2/S10	C2S10,07	1756-IF16-7	AI	4 - 20 mA	PT-60241	PT-60241_AI_1	3-25-01-602-PD-05	Pressure Transmitter	Spray Dryer / 5th
16	C2S02-X2	C2/S2	C2S02,23	1756-IB32-23	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
17	C2S02-X2	C2/S2	C2S02,24	1756-IB32-24	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
18	C2S02-X2	C2/S2	C2S02,25	1756-IB32-25	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
19	C2S02-X2	C2/S2	C2S02,26	1756-IB32-26	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
20	C2S02-X2	C2/S2	C2S02,27	1756-IB32-27	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
21	C2S02-X2	C2/S2	C2S02,28	1756-IB32-28	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
22	C2S02-X2	C2/S2	C2S02,29	1756-IB32-29	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
23	C2S02-X2	C2/S2	C2S02,30	1756-IB32-30	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
24	C2S02-X2	C2/S2	C2S02,31	1756-IB32-31	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
25	C2S06-X2	C2/S6	C2S06,19	1756-OB32-19	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	Spray Dryer
26	C2S06-X2	C2/S6	C2S06,20	1756-OB32-20	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	Spray Dryer
27	C2S06-X2	C2/S6	C2S06,21	1756-OB32-21	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	Spray Dryer
28	C2S06-X2	C2/S6	C2S06,22	1756-OB32-22	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	Spray Dryer
29	C2S06-X2	C2/S6	C2S06,23	1756-OB32-23	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	Spray Dryer
30	C2S06-X2	C2/S6	C2S06,24	1756-OB32-24	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	Spray Dryer
31	C2S06-X2	C2/S6	C2S06,25	1756-OB32-25	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	Spray Dryer

ENCLOSURE: JB-602 | TYPE: Field Junction Box (Standard) | LOCATION: Spray Dryer 3rd Floor | SIZE: 800-600-250 mm

SUMMARY: Total Channels: 82 | Active: 57 | Spare: 25 (30.5%) | DI: 32 | DO: 16 | AI: 32 | AO: 2 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
32	C2S06-X2	C2/S6	C2S06,26	1756-OB32-26	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	Spray Dryer
33	C2S06-X2	C2/S6	C2S06,27	1756-OB32-27	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	Spray Dryer
34	C2S06-X2	C2/S6	C2S06,28	1756-OB32-28	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	Spray Dryer
35	C2S06-X2	C2/S6	C2S06,29	1756-OB32-29	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	Spray Dryer
36	C2S06-X2	C2/S6	C2S06,30	1756-OB32-30	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	Spray Dryer
37	C2S06-X2	C2/S6	C2S06,31	1756-OB32-31	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	Spray Dryer
38	C2S11-X1	C2/S11	C2S11,13	1756-IF16-13	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
39	C2S11-X1	C2/S11	C2S11,14	1756-IF16-14	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
40	C2S11-X1	C2/S11	C2S11,15	1756-IF16-15	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
41	C2S02-X1	C2/S2	C2S02,03	1756-IB32-3	DI	Dry Contact	TSH-60230	TSH-60230_DI_1	3-25-01-602-PD-04	0	Spray Dryer / 3rd
42	C2S02-X1	C2/S2	C2S02,04	1756-IB32-4	DI	Dry Contact	TSH-60240	TSH-60240_DI_1	3-25-01-602-PD-05	0	Spray Dryer / 5th
43	C2S02-X1	C2/S2	C2S02,05	1756-IB32-5	DI	Dry Contact	TSH-60241A	TSH-60241A_DI_1	3-25-01-602-PD-05	0	Spray Dryer / 4th
44	C2S02-X1	C2/S2	C2S02,06	1756-IB32-6	DI	Dry Contact	TSH-60242A	TSH-60242A_DI_1	3-25-01-602-PD-05	0	Spray Dryer / 3rd
45	C2S02-X1	C2/S2	C2S02,07	1756-IB32-7	DI	Dry Contact	TSH-60243A	TSH-60243A_DI_1	3-25-01-602-PD-05	0	Spray Dryer / 4th
46	C2S02-X1	C2/S2	C2S02,08	1756-IB32-8	DI	Dry Contact	TSL-60241B	TSL-60241B_DI_1	3-25-01-602-PD-05	0	Spray Dryer / 4th
47	C2S02-X1	C2/S2	C2S02,09	1756-IB32-9	DI	Dry Contact	TSL-60242B	TSL-60242B_DI_1	3-25-01-602-PD-05	0	Spray Dryer / 3rd
48	C2S02-X1	C2/S2	C2S02,10	1756-IB32-10	DI	Dry Contact	TSL-60243B	TSL-60243B_DI_1	3-25-01-602-PD-05	0	Spray Dryer / 4th
49	C2S10-X1	C2/S10	C2S10,08	1756-IF16-8	AI	4 - 20 mA	TT-60210	TT-60210_AI_1	3-25-01-602-PD-03	0	Spray Dryer / 5th
50	C2S10-X1	C2/S10	C2S10,09	1756-IF16-9	AI	-	TT-60210A	TT-60210A_AI_1	325-01-600-PD-03	-	Spray Dryer / 5th
51	C2S10-X1	C2/S10	C2S10,10	1756-IF16-10	AI	-	TT-60210B	TT-60210B_AI_1	325-01-600-PD-03	-	Spray Dryer / 5th
52	C2S10-X1	C2/S10	C2S10,11	1756-IF16-11	AI	4 - 20 mA	TT-60211	TT-60211_AI_1	3-25-01-602-PD-03	0	Spray Dryer / 5th
53	C2S10-X1	C2/S10	C2S10,12	1756-IF16-12	AI	4 - 20 mA	TT-60212A	TT-60212A_AI_1	3-25-01-602-PD-03	0	Spray Dryer / 5th
54	C2S10-X1	C2/S10	C2S10,13	1756-IF16-13	AI	4 - 20 mA	TT-60212B	TT-60212B_AI_1	3-25-01-602-PD-03	0	Spray Dryer / 5th
55	C2S10-X1	C2/S10	C2S10,14	1756-IF16-14	AI	4 - 20 mA	TT-60214	TT-60214_AI_1	3-25-01-602-PD-03	0	Spray Dryer / 5th
56	C2S10-X1	C2/S10	C2S10,15	1756-IF16-15	AI	4 - 20 mA	TT-60215A	TT-60215A_AI_1	3-25-01-602-PD-03	0	Spray Dryer / 5th
57	C2S11-X1	C2/S11	C2S11,00	1756-IF16-0	AI	4 - 20 mA	TT-60215B	TT-60215B_AI_1	3-25-01-602-PD-03	0	Spray Dryer / 5th
58	C2S11-X1	C2/S11	C2S11,01	1756-IF16-1	AI	4 - 20 mA	TT-60216	TT-60216_AI_1	3-25-01-602-PD-03	0	Spray Dryer / 5th
59	C2S11-X1	C2/S11	C2S11,02	1756-IF16-2	AI	4 - 20 mA	TT-60240	TT-60240_AI_1	3-25-01-602-PD-05	0	Spray Dryer / 5th
60	C2S11-X1	C2/S11	C2S11,03	1756-IF16-3	AI	4 - 20 mA	TT-60241A	TT-60241A_AI_1	3-25-01-602-PD-05	0	Spray Dryer / 5th
61	C2S11-X1	C2/S11	C2S11,04	1756-IF16-4	AI	4 - 20 mA	TT-60241B	TT-60241B_AI_1	3-25-01-602-PD-05	0	Spray Dryer / 5th
62	C3S13-X1	C3/S13	C3S13,01	1756-OF8-1	AO	-	TV-60202	TV-60202_AO_1	3-25-01-602-PD-07	-	Spray Dryer / 3rd

ENCLOSURE: JB-602 | TYPE: Field Junction Box (Standard) | LOCATION: Spray Dryer 3rd Floor | SIZE: 800-600-250 mm

SUMMARY: Total Channels: 82 | Active: 57 | Spare: 25 (30.5%) | DI: 32 | DO: 16 | AI: 32 | AO: 2 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
63	C3S13-X1	C3/S13	C3S13,02	1756-OF8-2	AO	-	TV-60214	TV-60214_AO_1	3-25-01-602-PD-03	-	Spray Dryer / 5th
64	C2S11-X1	C2/S11	C2S11,05	1756-IF16-5	AI	4 - 20 mA	VT-60210A	VT-60210A_AI_1	3-25-01-602-PD-03	0	Spray Dryer / 5th
65	C2S11-X1	C2/S11	C2S11,06	1756-IF16-6	AI	4 - 20 mA	VT-60210B	VT-60210B_AI_1	3-25-01-602-PD-03	0	Spray Dryer / 5th
66	C2S11-X1	C2/S11	C2S11,07	1756-IF16-7	AI	4 - 20 mA	VT-60241A	VT-60241A_AI_1	3-25-01-602-PD-05	0	Spray Dryer / 5th
67	C2S11-X1	C2/S11	C2S11,08	1756-IF16-8	AI	4 - 20 mA	VT-60241B	VT-60241B_AI_1	3-25-01-602-PD-05	0	Spray Dryer / 5th
68	C2S02-X1	C2/S2	C2S02,11	1756-IB32-11	DI	Dry Contact	XA-60240A	XA-60240A_DI_1	325-01-600-PD-05	0	Spray Dryer / 4th
69	C2S02-X1	C2/S2	C2S02,12	1756-IB32-12	DI	Dry Contact	XA-60240B	XA-60240B_DI_1	325-01-600-PD-05	0	Spray Dryer / 4th
70	C2S02-X1	C2/S2	C2S02,13	1756-IB32-13	DI	Dry Contact	XA-60241A	XA-60241A_DI_1	325-01-600-PD-05	0	Spray Dryer / 4th
71	C2S02-X1	C2/S2	C2S02,14	1756-IB32-14	DI	Dry Contact	XA-60241B	XA-60241B_DI_1	325-01-600-PD-05	0	Spray Dryer / 4th
72	C2S02-X1	C2/S2	C2S02,15	1756-IB32-15	DI	Dry Contact	XA-60242A	XA-60242A_DI_1	325-01-600-PD-05	0	Spray Dryer / 3rd
73	C2S02-X2	C2/S2	C2S02,16	1756-IB32-16	DI	Dry Contact	XA-60242B	XA-60242B_DI_1	325-01-600-PD-05	0	Spray Dryer / 3rd
74	C2S02-X2	C2/S2	C2S02,17	1756-IB32-17	DI	Dry Contact	XA-60243A	XA-60243A_DI_1	325-01-600-PD-05	0	Spray Dryer / 4th
75	C2S02-X2	C2/S2	C2S02,18	1756-IB32-18	DI	Dry Contact	XA-60243B	XA-60243B_DI_1	325-01-600-PD-05	0	Spray Dryer / 4th
76	C2S06-X2	C2/S6	C2S06,16	1756-OB32-16	DO	Dry Contact	XS-60240B	XS-60240B_DO_1	325-01-600-PD-05	0	Spray Dryer / 4th
77	C2S02-X2	C2/S2	C2S02,19	1756-IB32-19	DI	24 VDC energized	XV-60214	XV-60214_DI_1	3-25-01-602-PD-03	0	Spray Dryer / 5th
78	C2S02-X2	C2/S2	C2S02,20	1756-IB32-20	DI	24 VDC energized	XV-60214	XV-60214_DI_2	3-25-01-602-PD-03	0	Spray Dryer / 5th
79	C2S06-X2	C2/S6	C2S06,17	1756-OB32-17	DO	24 VDC energized	XV-60214	XV-60214_DO_1	3-25-01-602-PD-03	0	Spray Dryer / 5th
80	C2S02-X2	C2/S2	C2S02,21	1756-IB32-21	DI	24 VDC energized,...	XV-60241	XV-60241_DI_1	3-25-01-602-PD-05	0	Spray Dryer / 5th
81	C2S02-X2	C2/S2	C2S02,22	1756-IB32-22	DI	24 VDC energized,...	XV-60241	XV-60241_DI_2	3-25-01-602-PD-05	0	Spray Dryer / 5th
82	C2S06-X2	C2/S6	C2S06,18	1756-OB32-18	DO	24 VDC energized,...	XV-60241	XV-60241_DO_1	3-25-01-602-PD-05	0	Spray Dryer / 5th