

ENCLOSURE: JB-607 | TYPE: Field Junction Box (Standard) | LOCATION: Spray Dryer 7th Floor | SIZE: 800-600-250 mm

SUMMARY: Total Channels: 195 | Active: 151 | Spare: 44 (22.6%) | DI: 93 | DO: 64 | AI: 32 | AO: 5 | BUS: 1

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
1	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	COM-FH-60210B	COM-FH-60210B_BUS...	325-01-600-PD-06	0	Spray Dryer / 7th
2	C2S12-X1	C2/S12	C2S12,00	1756-IF16-0	AI	4 - 20 mA	FT-60207	FT-60207_AI_1	3-25-01-602-PD-07	0	Spray Dryer / 7th
3	C2S12-X1	C2/S12	C2S12,01	1756-IF16-1	AI	4 - 20 mA	FT-60221	FT-60221_AI_1	3-25-01-602-PD-04	0	Spray Dryer / 7th
4	C2S12-X1	C2/S12	C2S12,02	1756-IF16-2	AI	4 - 20 mA	FT-60261FA	FT-60261FA_AI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
5	C2S12-X1	C2/S12	C2S12,03	1756-IF16-3	AI	4 - 20 mA	FT-60261FB	FT-60261FB_AI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
6	C2S12-X1	C2/S12	C2S12,04	1756-IF16-4	AI	4 - 20 mA	FT-60261FC	FT-60261FC_AI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
7	C2S12-X1	C2/S12	C2S12,05	1756-IF16-5	AI	4 - 20 mA	FT-60261FD	FT-60261FD_AI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
8	C2S12-X1	C2/S12	C2S12,06	1756-IF16-6	AI	4 - 20 mA	FT-60262FE	FT-60262FE_AI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
9	C2S12-X1	C2/S12	C2S12,07	1756-IF16-7	AI	4 - 20 mA	FT-60262FF	FT-60262FF_AI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
10	C2S12-X1	C2/S12	C2S12,08	1756-IF16-8	AI	4 - 20 mA	FT-60262FG	FT-60262FG_AI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
11	C2S12-X1	C2/S12	C2S12,09	1756-IF16-9	AI	4 - 20 mA	FT-60262FH	FT-60262FH_AI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
12	C2S12-X1	C2/S12	C2S12,10	1756-IF16-10	AI	4 - 20 mA	FT-60263FJ	FT-60263FJ_AI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
13	C2S12-X1	C2/S12	C2S12,11	1756-IF16-11	AI	4 - 20 mA	FT-60263FK	FT-60263FK_AI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
14	C2S12-X1	C2/S12	C2S12,12	1756-IF16-12	AI	4 - 20 mA	FT-60263FL	FT-60263FL_AI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
15	C2S12-X1	C2/S12	C2S12,13	1756-IF16-13	AI	4 - 20 mA	FT-60263FM	FT-60263FM_AI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
16	C2S12-X1	C2/S12	C2S12,14	1756-IF16-14	AI	4 - 20 mA	FT-60264FN	FT-60264FN_AI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
17	C2S12-X1	C2/S12	C2S12,15	1756-IF16-15	AI	4 - 20 mA	FT-60264FP	FT-60264FP_AI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
18	C2S13-X1	C2/S13	C2S13,00	1756-IF16-0	AI	4 - 20 mA	FT-60264FQ	FT-60264FQ_AI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
19	C2S13-X1	C2/S13	C2S13,01	1756-IF16-1	AI	4 - 20 mA	FT-60264FR	FT-60264FR_AI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
20	C2S13-X1	C2/S13	C2S13,02	1756-IF16-2	AI	4 - 20 mA	PT-60201	PT-60201_AI_1	3-25-01-602-PD-02	Pressure Transmitter	Spray Dryer / 7th
21	C2S13-X1	C2/S13	C2S13,03	1756-IF16-3	AI	4 - 20 mA	PT-60207	PT-60207_AI_1	3-25-01-602-PD-07	Pressure Transmitter	Spray Dryer / 7th
22	C2S13-X1	C2/S13	C2S13,04	1756-IF16-4	AI	4 - 20 mA	PT-60221	PT-60221_AI_1	3-25-01-602-PD-04	Pressure Transmitter	Spray Dryer / 7th
23	C2S13-X1	C2/S13	C2S13,05	1756-IF16-5	AI	4 - 20 mA	PT-60221	PT-60221_AI_1	3-25-01-602-PD-04	Pressure Transmitter	Spray Dryer / 7th
24	C3S13-X1	C3/S13	C3S13,03	1756-OF8-3	AO	-	PV-60201	PV-60201_AO_1	3-25-01-602-PD-02	-	Spray Dryer / 7th
25	C2S05-X2	C2/S5	C2S05,20	1756-IB32-20	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer
26	C2S05-X2	C2/S5	C2S05,21	1756-IB32-21	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer
27	C2S05-X2	C2/S5	C2S05,22	1756-IB32-22	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer
28	C2S05-X2	C2/S5	C2S05,23	1756-IB32-23	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer
29	C2S05-X2	C2/S5	C2S05,24	1756-IB32-24	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer
30	C2S05-X2	C2/S5	C2S05,25	1756-IB32-25	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer
31	C2S05-X2	C2/S5	C2S05,26	1756-IB32-26	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer

ENCLOSURE: JB-607 | TYPE: Field Junction Box (Standard) | LOCATION: Spray Dryer 7th Floor | SIZE: 800-600-250 mm

SUMMARY: Total Channels: 195 | Active: 151 | Spare: 44 (22.6%) | DI: 93 | DO: 64 | AI: 32 | AO: 5 | BUS: 1

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
32	C2S05-X2	C2/S5	C2S05,27	1756-IB32-27	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer
33	C2S05-X2	C2/S5	C2S05,28	1756-IB32-28	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer
34	C2S05-X2	C2/S5	C2S05,29	1756-IB32-29	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer
35	C2S05-X2	C2/S5	C2S05,30	1756-IB32-30	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer
36	C2S05-X2	C2/S5	C2S05,31	1756-IB32-31	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Spray Dryer
37	C2S07-X2	C2/S7	C2S07,31	1756-OB32-31	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
38	C2S08-X1	C2/S8	C2S08,09	1756-OB32-9	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
39	C2S08-X1	C2/S8	C2S08,10	1756-OB32-10	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
40	C2S08-X1	C2/S8	C2S08,11	1756-OB32-11	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
41	C2S08-X1	C2/S8	C2S08,12	1756-OB32-12	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
42	C2S08-X1	C2/S8	C2S08,13	1756-OB32-13	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
43	C2S08-X1	C2/S8	C2S08,14	1756-OB32-14	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
44	C2S08-X1	C2/S8	C2S08,15	1756-OB32-15	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
45	C2S08-X2	C2/S8	C2S08,16	1756-OB32-16	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
46	C2S08-X2	C2/S8	C2S08,17	1756-OB32-17	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
47	C2S08-X2	C2/S8	C2S08,18	1756-OB32-18	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
48	C2S08-X2	C2/S8	C2S08,19	1756-OB32-19	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
49	C2S08-X2	C2/S8	C2S08,20	1756-OB32-20	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
50	C2S08-X2	C2/S8	C2S08,21	1756-OB32-21	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
51	C2S08-X2	C2/S8	C2S08,22	1756-OB32-22	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
52	C2S08-X2	C2/S8	C2S08,23	1756-OB32-23	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
53	C2S08-X2	C2/S8	C2S08,24	1756-OB32-24	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
54	C2S08-X2	C2/S8	C2S08,25	1756-OB32-25	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
55	C2S08-X2	C2/S8	C2S08,26	1756-OB32-26	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
56	C2S08-X2	C2/S8	C2S08,27	1756-OB32-27	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
57	C2S08-X2	C2/S8	C2S08,28	1756-OB32-28	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
58	C2S08-X2	C2/S8	C2S08,29	1756-OB32-29	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
59	C2S08-X2	C2/S8	C2S08,30	1756-OB32-30	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
60	C2S08-X2	C2/S8	C2S08,31	1756-OB32-31	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
61	C2S13-X1	C2/S13	C2S13,11	1756-IF16-11	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
62	C2S13-X1	C2/S13	C2S13,12	1756-IF16-12	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-

ENCLOSURE: JB-607 | TYPE: Field Junction Box (Standard) | LOCATION: Spray Dryer 7th Floor | SIZE: 800-600-250 mm

SUMMARY: Total Channels: 195 | Active: 151 | Spare: 44 (22.6%) | DI: 93 | DO: 64 | AI: 32 | AO: 5 | BUS: 1

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
63	C2S13-X1	C2/S13	C2S13,13	1756-IF16-13	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
64	C2S13-X1	C2/S13	C2S13,14	1756-IF16-14	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
65	C2S13-X1	C2/S13	C2S13,15	1756-IF16-15	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
66	C3S13-X1	C3/S13	C3S13,05	1756-OF8-5	AO	-	Spare	Spare_AO_0	-	Spare I/O Point	-
67	C3S13-X1	C3/S13	C3S13,06	1756-OF8-6	AO	-	Spare	Spare_AO_0	-	Spare I/O Point	-
68	C3S13-X1	C3/S13	C3S13,07	1756-OF8-7	AO	-	Spare	Spare_AO_0	-	Spare I/O Point	-
69	C2S03-X1	C2/S3	C2S03,08	1756-IB32-8	DI	24 VDC energized	SV-60207	SV-60207_DI_1	3-25-01-602-PD-07	0	Spray Dryer / 7th
70	C2S03-X1	C2/S3	C2S03,09	1756-IB32-9	DI	24 VDC energized	SV-60207	SV-60207_DI_2	3-25-01-602-PD-07	0	Spray Dryer / 7th
71	C2S07-X1	C2/S7	C2S07,00	1756-OB32-0	DO	24 VDC energized	SV-60207	SV-60207_DO_1	3-25-01-602-PD-07	0	Spray Dryer / 7th
72	C2S13-X1	C2/S13	C2S13,06	1756-IF16-6	AI	4 - 20 mA	TI-FH-60210	TI-FH-60210_AI_1	325-01-600-PD-06	0	Spray Dryer / 7th
73	C2S13-X1	C2/S13	C2S13,07	1756-IF16-7	AI	4 - 20 mA	TT-60201	TT-60201_AI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
74	C2S13-X1	C2/S13	C2S13,08	1756-IF16-8	AI	4 - 20 mA	TT-60202	TT-60202_AI_1	3-25-01-602-PD-07	0	Spray Dryer / 7th
75	C2S13-X1	C2/S13	C2S13,09	1756-IF16-9	AI	4 - 20 mA	TT-60207	TT-60207_AI_1	3-25-01-602-PD-07	0	Spray Dryer / 7th
76	C2S13-X1	C2/S13	C2S13,10	1756-IF16-10	AI	4 - 20 mA	UY-FH-60210A	UY-FH-60210A_AI_1	325-01-600-PD-06	0	Spray Dryer / 7th
77	C3S13-X1	C3/S13	C3S13,04	1756-OF8-4	AO	4 - 20 mA	UY-FH-60210B	UY-FH-60210B_AO_1	325-01-600-PD-06	0	Spray Dryer / 7th
78	C2S03-X1	C2/S3	C2S03,00	1756-IB32-0	DI	Dry Contact	XA-FH-60210A	XA-FH-60210A_DI_1	325-01-600-PD-06	0	Spray Dryer / 7th
79	C2S03-X1	C2/S3	C2S03,01	1756-IB32-1	DI	Dry Contact	XA-FH-60210B	XA-FH-60210B_DI_1	325-01-600-PD-06	0	Spray Dryer / 7th
80	C2S03-X1	C2/S3	C2S03,02	1756-IB32-2	DI	Dry Contact	XA-FH-60210C	XA-FH-60210C_DI_1	325-01-600-PD-06	0	Spray Dryer / 7th
81	C2S03-X1	C2/S3	C2S03,03	1756-IB32-3	DI	Dry Contact	XA-FH-60210D	XA-FH-60210D_DI_1	325-01-600-PD-06	0	Spray Dryer / 7th
82	C2S03-X1	C2/S3	C2S03,04	1756-IB32-4	DI	Dry Contact	XA-FH-60210E	XA-FH-60210E_DI_1	325-01-600-PD-06	0	Spray Dryer / 7th
83	C2S07-X1	C2/S7	C2S07,01	1756-OB32-1	DO	Dry Contact	XS-FH-60210C	XS-FH-60210C_DO_1	325-01-600-PD-06	0	Spray Dryer / 7th
84	C2S07-X1	C2/S7	C2S07,02	1756-OB32-2	DO	Dry Contact	XS-FH-60210D	XS-FH-60210D_DO_1	325-01-600-PD-06	0	Spray Dryer / 7th
85	C2S03-X2	C2/S3	C2S03,16	1756-IB32-16	DI	24 VDC energized	XV-60201	XV-60201_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
86	C2S03-X2	C2/S3	C2S03,17	1756-IB32-17	DI	24 VDC energized	XV-60201	XV-60201_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
87	C2S07-X1	C2/S7	C2S07,03	1756-OB32-3	DO	24 VDC energized	XV-60201	XV-60201_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
88	C2S03-X2	C2/S3	C2S03,20	1756-IB32-20	DI	-	XV-60261	XV-60261_DI_1	325-01-600-PD-02	-	Spray Dryer / 7th
89	C2S03-X2	C2/S3	C2S03,21	1756-IB32-21	DI	-	XV-60261	XV-60261_DI_2	325-01-600-PD-02	-	Spray Dryer / 7th
90	C2S07-X1	C2/S7	C2S07,04	1756-OB32-4	DO	-	XV-60261	XV-60261_DO_1	325-01-600-PD-02	-	Spray Dryer / 7th
91	C2S03-X2	C2/S3	C2S03,24	1756-IB32-24	DI	24 VDC energized,...	XV-60261FA	XV-60261FA_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
92	C2S03-X2	C2/S3	C2S03,25	1756-IB32-25	DI	24 VDC energized,...	XV-60261FA	XV-60261FA_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
93	C2S07-X1	C2/S7	C2S07,05	1756-OB32-5	DO	24 VDC energized,...	XV-60261FA	XV-60261FA_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th

ENCLOSURE: JB-607 | TYPE: Field Junction Box (Standard) | LOCATION: Spray Dryer 7th Floor | SIZE: 800-600-250 mm

SUMMARY: Total Channels: 195 | Active: 151 | Spare: 44 (22.6%) | DI: 93 | DO: 64 | AI: 32 | AO: 5 | BUS: 1

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
94	C2S03-X2	C2/S3	C2S03,28	1756-IB32-28	DI	24 VDC energized,...	XV-60261FB	XV-60261FB_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
95	C2S03-X2	C2/S3	C2S03,29	1756-IB32-29	DI	24 VDC energized,...	XV-60261FB	XV-60261FB_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
96	C2S07-X1	C2/S7	C2S07,06	1756-OB32-6	DO	24 VDC energized,...	XV-60261FB	XV-60261FB_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
97	C2S04-X1	C2/S4	C2S04,00	1756-IB32-0	DI	24 VDC energized,...	XV-60261FC	XV-60261FC_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
98	C2S04-X1	C2/S4	C2S04,01	1756-IB32-1	DI	24 VDC energized,...	XV-60261FC	XV-60261FC_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
99	C2S07-X1	C2/S7	C2S07,07	1756-OB32-7	DO	24 VDC energized,...	XV-60261FC	XV-60261FC_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
100	C2S04-X1	C2/S4	C2S04,04	1756-IB32-4	DI	24 VDC energized,...	XV-60261FD	XV-60261FD_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
101	C2S04-X1	C2/S4	C2S04,05	1756-IB32-5	DI	24 VDC energized,...	XV-60261FD	XV-60261FD_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
102	C2S07-X1	C2/S7	C2S07,08	1756-OB32-8	DO	24 VDC energized,...	XV-60261FD	XV-60261FD_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
103	C2S04-X1	C2/S4	C2S04,08	1756-IB32-8	DI	24 VDC energized,...	XV-60261SA	XV-60261SA_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
104	C2S04-X1	C2/S4	C2S04,09	1756-IB32-9	DI	24 VDC energized,...	XV-60261SA	XV-60261SA_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
105	C2S07-X1	C2/S7	C2S07,09	1756-OB32-9	DO	24 VDC energized,...	XV-60261SA	XV-60261SA_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
106	C2S04-X1	C2/S4	C2S04,10	1756-IB32-10	DI	24 VDC energized,...	XV-60261SB	XV-60261SB_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
107	C2S04-X1	C2/S4	C2S04,11	1756-IB32-11	DI	24 VDC energized,...	XV-60261SB	XV-60261SB_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
108	C2S07-X1	C2/S7	C2S07,10	1756-OB32-10	DO	24 VDC energized,...	XV-60261SB	XV-60261SB_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
109	C2S04-X1	C2/S4	C2S04,12	1756-IB32-12	DI	24 VDC energized,...	XV-60261SC	XV-60261SC_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
110	C2S04-X1	C2/S4	C2S04,13	1756-IB32-13	DI	24 VDC energized,...	XV-60261SC	XV-60261SC_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
111	C2S07-X1	C2/S7	C2S07,11	1756-OB32-11	DO	24 VDC energized,...	XV-60261SC	XV-60261SC_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
112	C2S04-X1	C2/S4	C2S04,14	1756-IB32-14	DI	24 VDC energized,...	XV-60261SD	XV-60261SD_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
113	C2S04-X1	C2/S4	C2S04,15	1756-IB32-15	DI	24 VDC energized,...	XV-60261SD	XV-60261SD_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
114	C2S07-X1	C2/S7	C2S07,12	1756-OB32-12	DO	24 VDC energized,...	XV-60261SD	XV-60261SD_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
115	C2S04-X2	C2/S4	C2S04,16	1756-IB32-16	DI	-	XV-60262	XV-60262_DI_1	325-01-600-PD-02	-	Spray Dryer / 7th
116	C2S04-X2	C2/S4	C2S04,17	1756-IB32-17	DI	-	XV-60262	XV-60262_DI_2	325-01-600-PD-02	-	Spray Dryer / 7th
117	C2S07-X1	C2/S7	C2S07,13	1756-OB32-13	DO	-	XV-60262	XV-60262_DO_1	325-01-600-PD-02	-	Spray Dryer / 7th
118	C2S04-X2	C2/S4	C2S04,18	1756-IB32-18	DI	24 VDC energized,...	XV-60262FE	XV-60262FE_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
119	C2S04-X2	C2/S4	C2S04,19	1756-IB32-19	DI	24 VDC energized,...	XV-60262FE	XV-60262FE_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
120	C2S07-X1	C2/S7	C2S07,14	1756-OB32-14	DO	24 VDC energized,...	XV-60262FE	XV-60262FE_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
121	C2S04-X2	C2/S4	C2S04,20	1756-IB32-20	DI	24 VDC energized,...	XV-60262FF	XV-60262FF_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
122	C2S04-X2	C2/S4	C2S04,21	1756-IB32-21	DI	24 VDC energized,...	XV-60262FF	XV-60262FF_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
123	C2S07-X1	C2/S7	C2S07,15	1756-OB32-15	DO	24 VDC energized,...	XV-60262FF	XV-60262FF_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
124	C2S04-X2	C2/S4	C2S04,22	1756-IB32-22	DI	24 VDC energized,...	XV-60262FG	XV-60262FG_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th

ENCLOSURE: JB-607 | TYPE: Field Junction Box (Standard) | LOCATION: Spray Dryer 7th Floor | SIZE: 800-600-250 mm

SUMMARY: Total Channels: 195 | Active: 151 | Spare: 44 (22.6%) | DI: 93 | DO: 64 | AI: 32 | AO: 5 | BUS: 1

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
125	C2S04-X2	C2/S4	C2S04,23	1756-IB32-23	DI	24 VDC energized,...	XV-60262FG	XV-60262FG_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
126	C2S07-X2	C2/S7	C2S07,16	1756-OB32-16	DO	24 VDC energized,...	XV-60262FG	XV-60262FG_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
127	C2S04-X2	C2/S4	C2S04,24	1756-IB32-24	DI	24 VDC energized,...	XV-60262FH	XV-60262FH_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
128	C2S04-X2	C2/S4	C2S04,25	1756-IB32-25	DI	24 VDC energized,...	XV-60262FH	XV-60262FH_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
129	C2S07-X2	C2/S7	C2S07,17	1756-OB32-17	DO	24 VDC energized,...	XV-60262FH	XV-60262FH_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
130	C2S04-X2	C2/S4	C2S04,26	1756-IB32-26	DI	24 VDC energized,...	XV-60262SE	XV-60262SE_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
131	C2S04-X2	C2/S4	C2S04,27	1756-IB32-27	DI	24 VDC energized,...	XV-60262SE	XV-60262SE_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
132	C2S07-X2	C2/S7	C2S07,18	1756-OB32-18	DO	24 VDC energized,...	XV-60262SE	XV-60262SE_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
133	C2S04-X2	C2/S4	C2S04,28	1756-IB32-28	DI	24 VDC energized,...	XV-60262SF	XV-60262SF_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
134	C2S04-X2	C2/S4	C2S04,29	1756-IB32-29	DI	24 VDC energized,...	XV-60262SF	XV-60262SF_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
135	C2S07-X2	C2/S7	C2S07,19	1756-OB32-19	DO	24 VDC energized,...	XV-60262SF	XV-60262SF_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
136	C2S04-X2	C2/S4	C2S04,30	1756-IB32-30	DI	24 VDC energized,...	XV-60262SG	XV-60262SG_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
137	C2S04-X2	C2/S4	C2S04,31	1756-IB32-31	DI	24 VDC energized,...	XV-60262SG	XV-60262SG_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
138	C2S07-X2	C2/S7	C2S07,20	1756-OB32-20	DO	24 VDC energized,...	XV-60262SG	XV-60262SG_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
139	C2S05-X1	C2/S5	C2S05,00	1756-IB32-0	DI	24 VDC energized,...	XV-60262SH	XV-60262SH_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
140	C2S05-X1	C2/S5	C2S05,01	1756-IB32-1	DI	24 VDC energized,...	XV-60262SH	XV-60262SH_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
141	C2S07-X2	C2/S7	C2S07,21	1756-OB32-21	DO	24 VDC energized,...	XV-60262SH	XV-60262SH_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
142	C2S05-X1	C2/S5	C2S05,02	1756-IB32-2	DI	-	XV-60263	XV-60263_DI_1	325-01-600-PD-02	-	Spray Dryer / 7th
143	C2S05-X1	C2/S5	C2S05,03	1756-IB32-3	DI	-	XV-60263	XV-60263_DI_2	325-01-600-PD-02	-	Spray Dryer / 7th
144	C2S07-X2	C2/S7	C2S07,22	1756-OB32-22	DO	-	XV-60263	XV-60263_DO_1	325-01-600-PD-02	-	Spray Dryer / 7th
145	C2S05-X1	C2/S5	C2S05,04	1756-IB32-4	DI	24 VDC energized,...	XV-60263FJ	XV-60263FJ_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
146	C2S05-X1	C2/S5	C2S05,05	1756-IB32-5	DI	24 VDC energized,...	XV-60263FJ	XV-60263FJ_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
147	C2S07-X2	C2/S7	C2S07,23	1756-OB32-23	DO	24 VDC energized,...	XV-60263FJ	XV-60263FJ_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
148	C2S05-X1	C2/S5	C2S05,06	1756-IB32-6	DI	24 VDC energized,...	XV-60263FK	XV-60263FK_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
149	C2S05-X1	C2/S5	C2S05,07	1756-IB32-7	DI	24 VDC energized,...	XV-60263FK	XV-60263FK_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
150	C2S07-X2	C2/S7	C2S07,24	1756-OB32-24	DO	24 VDC energized,...	XV-60263FK	XV-60263FK_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
151	C2S05-X1	C2/S5	C2S05,08	1756-IB32-8	DI	24 VDC energized,...	XV-60263FL	XV-60263FL_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
152	C2S05-X1	C2/S5	C2S05,09	1756-IB32-9	DI	24 VDC energized,...	XV-60263FL	XV-60263FL_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
153	C2S07-X2	C2/S7	C2S07,25	1756-OB32-25	DO	24 VDC energized,...	XV-60263FL	XV-60263FL_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
154	C2S05-X1	C2/S5	C2S05,10	1756-IB32-10	DI	24 VDC energized,...	XV-60263FM	XV-60263FM_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
155	C2S05-X1	C2/S5	C2S05,11	1756-IB32-11	DI	24 VDC energized,...	XV-60263FM	XV-60263FM_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th

ENCLOSURE: JB-607 | TYPE: Field Junction Box (Standard) | LOCATION: Spray Dryer 7th Floor | SIZE: 800-600-250 mm

SUMMARY: Total Channels: 195 | Active: 151 | Spare: 44 (22.6%) | DI: 93 | DO: 64 | AI: 32 | AO: 5 | BUS: 1

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
156	C2S07-X2	C2/S7	C2S07,26	1756-OB32-26	DO	24 VDC energized,...	XV-60263FM	XV-60263FM_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
157	C2S05-X1	C2/S5	C2S05,12	1756-IB32-12	DI	24 VDC energized,...	XV-60263SJ	XV-60263SJ_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
158	C2S05-X1	C2/S5	C2S05,13	1756-IB32-13	DI	24 VDC energized,...	XV-60263SJ	XV-60263SJ_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
159	C2S07-X2	C2/S7	C2S07,27	1756-OB32-27	DO	24 VDC energized,...	XV-60263SJ	XV-60263SJ_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
160	C2S05-X1	C2/S5	C2S05,14	1756-IB32-14	DI	24 VDC energized,...	XV-60263SK	XV-60263SK_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
161	C2S05-X1	C2/S5	C2S05,15	1756-IB32-15	DI	24 VDC energized,...	XV-60263SK	XV-60263SK_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
162	C2S07-X2	C2/S7	C2S07,28	1756-OB32-28	DO	24 VDC energized,...	XV-60263SK	XV-60263SK_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
163	C2S05-X2	C2/S5	C2S05,16	1756-IB32-16	DI	24 VDC energized,...	XV-60263SL	XV-60263SL_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
164	C2S05-X2	C2/S5	C2S05,17	1756-IB32-17	DI	24 VDC energized,...	XV-60263SL	XV-60263SL_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
165	C2S07-X2	C2/S7	C2S07,29	1756-OB32-29	DO	24 VDC energized,...	XV-60263SL	XV-60263SL_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
166	C2S05-X2	C2/S5	C2S05,18	1756-IB32-18	DI	24 VDC energized,...	XV-60263SM	XV-60263SM_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
167	C2S05-X2	C2/S5	C2S05,19	1756-IB32-19	DI	24 VDC energized,...	XV-60263SM	XV-60263SM_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
168	C2S07-X2	C2/S7	C2S07,30	1756-OB32-30	DO	24 VDC energized,...	XV-60263SM	XV-60263SM_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
169	C2S03-X1	C2/S3	C2S03,10	1756-IB32-10	DI	-	XV-60264	XV-60264_DI_1	325-01-600-PD-02	-	Spray Dryer / 7th
170	C2S03-X1	C2/S3	C2S03,11	1756-IB32-11	DI	-	XV-60264	XV-60264_DI_2	325-01-600-PD-02	-	Spray Dryer / 7th
171	C2S08-X1	C2/S8	C2S08,00	1756-OB32-0	DO	-	XV-60264	XV-60264_DO_1	325-01-600-PD-02	-	Spray Dryer / 7th
172	C2S03-X1	C2/S3	C2S03,12	1756-IB32-12	DI	24 VDC energized,...	XV-60264FN	XV-60264FN_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
173	C2S03-X1	C2/S3	C2S03,13	1756-IB32-13	DI	24 VDC energized,...	XV-60264FN	XV-60264FN_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
174	C2S08-X1	C2/S8	C2S08,01	1756-OB32-1	DO	24 VDC energized,...	XV-60264FN	XV-60264FN_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
175	C2S03-X1	C2/S3	C2S03,14	1756-IB32-14	DI	24 VDC energized,...	XV-60264FP	XV-60264FP_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
176	C2S03-X1	C2/S3	C2S03,15	1756-IB32-15	DI	24 VDC energized,...	XV-60264FP	XV-60264FP_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
177	C2S08-X1	C2/S8	C2S08,02	1756-OB32-2	DO	24 VDC energized,...	XV-60264FP	XV-60264FP_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
178	C2S03-X2	C2/S3	C2S03,18	1756-IB32-18	DI	24 VDC energized,...	XV-60264FQ	XV-60264FQ_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
179	C2S03-X2	C2/S3	C2S03,19	1756-IB32-19	DI	24 VDC energized,...	XV-60264FQ	XV-60264FQ_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
180	C2S08-X1	C2/S8	C2S08,03	1756-OB32-3	DO	24 VDC energized,...	XV-60264FQ	XV-60264FQ_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
181	C2S03-X2	C2/S3	C2S03,22	1756-IB32-22	DI	24 VDC energized,...	XV-60264FR	XV-60264FR_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
182	C2S03-X2	C2/S3	C2S03,23	1756-IB32-23	DI	24 VDC energized,...	XV-60264FR	XV-60264FR_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
183	C2S08-X1	C2/S8	C2S08,04	1756-OB32-4	DO	24 VDC energized,...	XV-60264FR	XV-60264FR_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
184	C2S03-X2	C2/S3	C2S03,26	1756-IB32-26	DI	24 VDC energized,...	XV-60264SN	XV-60264SN_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
185	C2S03-X2	C2/S3	C2S03,27	1756-IB32-27	DI	24 VDC energized,...	XV-60264SN	XV-60264SN_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
186	C2S08-X1	C2/S8	C2S08,05	1756-OB32-5	DO	24 VDC energized,...	XV-60264SN	XV-60264SN_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th

ENCLOSURE: JB-607 | TYPE: Field Junction Box (Standard) | LOCATION: Spray Dryer 7th Floor | SIZE: 800-600-250 mm

SUMMARY: Total Channels: 195 | Active: 151 | Spare: 44 (22.6%) | DI: 93 | DO: 64 | AI: 32 | AO: 5 | BUS: 1

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
187	C2S03-X2	C2/S3	C2S03,30	1756-IB32-30	DI	24 VDC energized,...	XV-60264SP	XV-60264SP_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
188	C2S03-X2	C2/S3	C2S03,31	1756-IB32-31	DI	24 VDC energized,...	XV-60264SP	XV-60264SP_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
189	C2S08-X1	C2/S8	C2S08,06	1756-OB32-6	DO	24 VDC energized,...	XV-60264SP	XV-60264SP_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
190	C2S04-X1	C2/S4	C2S04,02	1756-IB32-2	DI	24 VDC energized,...	XV-60264SQ	XV-60264SQ_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
191	C2S04-X1	C2/S4	C2S04,03	1756-IB32-3	DI	24 VDC energized,...	XV-60264SQ	XV-60264SQ_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
192	C2S08-X1	C2/S8	C2S08,07	1756-OB32-7	DO	24 VDC energized,...	XV-60264SQ	XV-60264SQ_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
193	C2S04-X1	C2/S4	C2S04,06	1756-IB32-6	DI	24 VDC energized,...	XV-60264SR	XV-60264SR_DI_1	3-25-01-602-PD-02	0	Spray Dryer / 7th
194	C2S04-X1	C2/S4	C2S04,07	1756-IB32-7	DI	24 VDC energized,...	XV-60264SR	XV-60264SR_DI_2	3-25-01-602-PD-02	0	Spray Dryer / 7th
195	C2S08-X1	C2/S8	C2S08,08	1756-OB32-8	DO	24 VDC energized,...	XV-60264SR	XV-60264SR_DO_1	3-25-01-602-PD-02	0	Spray Dryer / 7th