

ENCLOSURE: JB-612 | TYPE: Field Junction Box (Standard) | LOCATION: Packing Tower 2th Floor | SIZE: 450-300-150 mm

SUMMARY: Total Channels: 57 | Active: 37 | Spare: 20 (35.1%) | DI: 32 | DO: 16 | AI: 8 | AO: 0 | BUS: 1

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
1	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	Communication S...	Communication Signa...	325-01-613-PD-02	-	Packing Tower / ...
2	C4S02-X1	C4/S2	C4S02,00	1756-IB32-0	DI	Dry Contact	PSL-61305	PSL-61305_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
3	C4S02-X1	C4/S2	C4S02,01	1756-IB32-1	DI	Dry Contact	PSL-61306	PSL-61306_DI_1	3-25-01-613-PD-05	0	Packing Tower / ...
4	C4S05-X1	C4/S5	C4S05,08	1756-IF16-8	AI	4 - 20 mA	PT-61302	PT-61302_AI_1	3-25-01-613-PD-03	Pressure Transmitter	Packing Tower / ...
5	C4S05-X1	C4/S5	C4S05,12	1756-IF16-12	AI	4 - 20 mA	PT-61302	PT-61302_AI_1	3-25-01-613-PD-03	Pressure Transmitter	Packing Tower / ...
6	C4S05-X1	C4/S5	C4S05,09	1756-IF16-9	AI	4 - 20 mA	PT-61309	PT-61309_AI_1	3-25-01-613-PD-04	Pressure Transmitter	Packing Tower / ...
7	C4S05-X1	C4/S5	C4S05,13	1756-IF16-13	AI	4 - 20 mA	PT-61309	PT-61309_AI_1	3-25-01-613-PD-04	Pressure Transmitter	Packing Tower / ...
8	C4S02-X1	C4/S2	C4S02,02	1756-IB32-2	DI	-	PVM-61301	PVM-61301_DI_1	325-01-613-PD-03	-	Packing Tower / ...
9	C4S02-X1	C4/S2	C4S02,03	1756-IB32-3	DI	-	PVM-61301	PVM-61301_DI_2	325-01-613-PD-03	-	Packing Tower / ...
10	C4S04-X2	C4/S4	C4S04,16	1756-OB32-16	DO	-	PVM-61301	PVM-61301_DO_1	325-01-613-PD-03	-	Packing Tower / ...
11	C4S04-X2	C4/S4	C4S04,17	1756-OB32-17	DO	-	PVM-61301	PVM-61301_DO_2	325-01-613-PD-03	-	Packing Tower / ...
12	C4S02-X2	C4/S2	C4S02,17	1756-IB32-17	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
13	C4S02-X2	C4/S2	C4S02,18	1756-IB32-18	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
14	C4S02-X2	C4/S2	C4S02,19	1756-IB32-19	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
15	C4S02-X2	C4/S2	C4S02,20	1756-IB32-20	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
16	C4S02-X2	C4/S2	C4S02,21	1756-IB32-21	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
17	C4S02-X2	C4/S2	C4S02,22	1756-IB32-22	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
18	C4S02-X2	C4/S2	C4S02,23	1756-IB32-23	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
19	C4S02-X2	C4/S2	C4S02,24	1756-IB32-24	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
20	C4S02-X2	C4/S2	C4S02,25	1756-IB32-25	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
21	C4S02-X2	C4/S2	C4S02,26	1756-IB32-26	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
22	C4S02-X2	C4/S2	C4S02,27	1756-IB32-27	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
23	C4S02-X2	C4/S2	C4S02,28	1756-IB32-28	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
24	C4S02-X2	C4/S2	C4S02,29	1756-IB32-29	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
25	C4S02-X2	C4/S2	C4S02,30	1756-IB32-30	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
26	C4S02-X2	C4/S2	C4S02,31	1756-IB32-31	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
27	C4S04-X2	C4/S4	C4S04,31	1756-OB32-31	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	Packing Tower
28	C4S05-X1	C4/S5	C4S05,10	1756-IF16-10	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
29	C4S05-X1	C4/S5	C4S05,11	1756-IF16-11	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
30	C4S05-X1	C4/S5	C4S05,14	1756-IF16-14	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
31	C4S05-X1	C4/S5	C4S05,15	1756-IF16-15	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-

ENCLOSURE: JB-612 | TYPE: Field Junction Box (Standard) | LOCATION: Packing Tower 2th Floor | SIZE: 450-300-150 mm

SUMMARY: Total Channels: 57 | Active: 37 | Spare: 20 (35.1%) | DI: 32 | DO: 16 | AI: 8 | AO: 0 | BUS: 1

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
32	C4S04-X2	C4/S4	C4S04,18	1756-OB32-18	DO	-	SV-61307	SV-61307_DO_1	3-25-01-613-PD-01	-	Packing Tower / ...
33	C4S04-X2	C4/S4	C4S04,19	1756-OB32-19	DO	24 VDC energized	SV-61308	SV-61308_DO_1	325-01-613-PD-03	0	Packing Tower / ...
34	C4S04-X2	C4/S4	C4S04,20	1756-OB32-20	DO	24 VDC energized	SV-61309	SV-61309_DO_1	3-25-01-613-PD-03	0	Packing Tower / ...
35	C4S04-X2	C4/S4	C4S04,21	1756-OB32-21	DO	24 VDC energized	SV-61310	SV-61310_DO_1	325-01-613-PD-05	0	Packing Tower / ...
36	C4S04-X2	C4/S4	C4S04,22	1756-OB32-22	DO	24 VDC energized	SV-61311	SV-61311_DO_1	3-25-01-613-PD-05	0	Packing Tower / ...
37	C4S02-X1	C4/S2	C4S02,04	1756-IB32-4	DI	Dry Contact	XA-61301A	XA-61301A_DI_1	325-01-613-PD-02	0	Packing Tower / ...
38	C4S02-X1	C4/S2	C4S02,05	1756-IB32-5	DI	Dry Contact	XA-61301B	XA-61301B_DI_1	325-01-613-PD-02	0	Packing Tower / ...
39	C4S02-X1	C4/S2	C4S02,06	1756-IB32-6	DI	Dry Contact	XA-61301C	XA-61301C_DI_1	325-01-613-PD-02	0	Packing Tower / ...
40	C4S02-X1	C4/S2	C4S02,07	1756-IB32-7	DI	Dry Contact	XA-61301D	XA-61301D_DI_1	325-01-613-PD-02	0	Packing Tower / ...
41	C4S02-X1	C4/S2	C4S02,08	1756-IB32-8	DI	Dry Contact	XA-61301E	XA-61301E_DI_1	325-01-613-PD-02	0	Packing Tower / ...
42	C4S02-X1	C4/S2	C4S02,09	1756-IB32-9	DI	Dry Contact	XA-61301F	XA-61301F_DI_1	325-01-613-PD-02	0	Packing Tower / ...
43	C4S02-X1	C4/S2	C4S02,10	1756-IB32-10	DI	Dry Contact	XA-61301G	XA-61301G_DI_1	325-01-613-PD-02	0	Packing Tower / ...
44	C4S02-X1	C4/S2	C4S02,11	1756-IB32-11	DI	Dry Contact	XA-61301H	XA-61301H_DI_1	325-01-613-PD-02	0	Packing Tower / ...
45	C4S02-X1	C4/S2	C4S02,12	1756-IB32-12	DI	Dry Contact	XA-61301J	XA-61301J_DI_1	325-01-613-PD-02	0	Packing Tower / ...
46	C4S04-X2	C4/S4	C4S04,23	1756-OB32-23	DO	24 VDC energized	XS-61301A	XS-61301A_DO_1	325-01-613-PD-02	0	Packing Tower / ...
47	C4S04-X2	C4/S4	C4S04,24	1756-OB32-24	DO	24 VDC energized	XS-61301B	XS-61301B_DO_1	325-01-613-PD-02	0	Packing Tower / ...
48	C4S04-X2	C4/S4	C4S04,25	1756-OB32-25	DO	24 VDC energized	XS-61301C	XS-61301C_DO_1	325-01-613-PD-02	0	Packing Tower / ...
49	C4S04-X2	C4/S4	C4S04,26	1756-OB32-26	DO	24 VDC energized	XS-61301D	XS-61301D_DO_1	325-01-613-PD-02	0	Packing Tower / ...
50	C4S04-X2	C4/S4	C4S04,27	1756-OB32-27	DO	24 VDC energized	XS-61301E	XS-61301E_DO_1	325-01-613-PD-02	0	Packing Tower / ...
51	C4S04-X2	C4/S4	C4S04,28	1756-OB32-28	DO	24 VDC energized	XS-61301F	XS-61301F_DO_1	325-01-613-PD-02	0	Packing Tower / ...
52	C4S02-X1	C4/S2	C4S02,13	1756-IB32-13	DI	24 VDC energized	XV-61302	XV-61302_DI_1	3-25-01-613-PD-02	0	Packing Tower / ...
53	C4S02-X1	C4/S2	C4S02,14	1756-IB32-14	DI	24 VDC energized	XV-61302	XV-61302_DI_2	3-25-01-613-PD-02	0	Packing Tower / ...
54	C4S04-X2	C4/S4	C4S04,29	1756-OB32-29	DO	24 VDC energized	XV-61302	XV-61302_DO_1	3-25-01-613-PD-02	0	Packing Tower / ...
55	C4S02-X1	C4/S2	C4S02,15	1756-IB32-15	DI	24 VDC energized	XV-61303	XV-61303_DI_1	3-25-01-613-PD-02	0	Packing Tower / ...
56	C4S02-X2	C4/S2	C4S02,16	1756-IB32-16	DI	24 VDC energized	XV-61303	XV-61303_DI_2	3-25-01-613-PD-02	0	Packing Tower / ...
57	C4S04-X2	C4/S4	C4S04,30	1756-OB32-30	DO	24 VDC energized	XV-61303	XV-61303_DO_1	3-25-01-613-PD-02	0	Packing Tower / ...