

ENCLOSURE: JB-618 | TYPE: Field Junction Box (Standard) | LOCATION: Packing Tower 8th Floor | SIZE: 450-300-150 mm

SUMMARY: Total Channels: 52 | Active: 25 | Spare: 27 (51.9%) | DI: 16 | DO: 32 | AI: 4 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
1	C3S01-X2	C3/S1	C3S01,16	1756-IB32-16	DI	24 VDC energized	DV-61301	DV-61301_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...
2	C3S01-X2	C3/S1	C3S01,17	1756-IB32-17	DI	24 VDC energized	DV-61301	DV-61301_DI_2	3-25-01-613-PD-01	0	Packing Tower / ...
3	C3S03-X1	C3/S3	C3S03,00	1756-OB32-0	DO	24 VDC energized	DV-61301	DV-61301_DO_1	3-25-01-613-PD-01	0	Packing Tower / ...
4	C3S01-X2	C3/S1	C3S01,18	1756-IB32-18	DI	24 VDC energized	DV-61302	DV-61302_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...
5	C3S01-X2	C3/S1	C3S01,19	1756-IB32-19	DI	24 VDC energized	DV-61302	DV-61302_DI_2	3-25-01-613-PD-01	0	Packing Tower / ...
6	C3S03-X1	C3/S3	C3S03,01	1756-OB32-1	DO	24 VDC energized	DV-61302	DV-61302_DO_1	3-25-01-613-PD-01	0	Packing Tower / ...
7	C3S01-X2	C3/S1	C3S01,20	1756-IB32-20	DI	Dry Contact	LS-61303	LS-61303_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...
8	C3S01-X2	C3/S1	C3S01,21	1756-IB32-21	DI	Dry Contact	PSL-61301	PSL-61301_DI_1	325-01-613-PD-01	0	Packing Tower / ...
9	C3S01-X2	C3/S1	C3S01,22	1756-IB32-22	DI	Dry Contact	PSL-61302	PSL-61302_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...
10	C3S02-X2	C3/S2	C3S02,23	1756-IB32-23	DI	Dry Contact	PSL-61311	PSL-61311_DI_1	3-25-01-613-PD-04	0	Packing Tower / ...
11	C3S05-X1	C3/S5	C3S05,00	1756-IF16-0	AI	4 - 20 mA	PT-61303	PT-61303_AI_1	3-25-01-613-PD-01	Pressure Transmitter	Packing Tower / ...
12	C3S05-X1	C3/S5	C3S05,01	1756-IF16-1	AI	-	PT-61306	PT-61306_AI_1	3-25-01-613-PD-01	-	Packing Tower / ...
13	C3S01-X2	C3/S1	C3S01,28	1756-IB32-28	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Packing Tower
14	C3S01-X2	C3/S1	C3S01,29	1756-IB32-29	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Packing Tower
15	C3S01-X2	C3/S1	C3S01,30	1756-IB32-30	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Packing Tower
16	C3S01-X2	C3/S1	C3S01,31	1756-IB32-31	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	Packing Tower
17	C3S03-X1	C3/S3	C3S03,09	1756-OB32-9	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
18	C3S03-X1	C3/S3	C3S03,10	1756-OB32-10	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
19	C3S03-X1	C3/S3	C3S03,11	1756-OB32-11	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
20	C3S03-X1	C3/S3	C3S03,12	1756-OB32-12	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
21	C3S03-X1	C3/S3	C3S03,13	1756-OB32-13	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
22	C3S03-X1	C3/S3	C3S03,14	1756-OB32-14	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
23	C3S03-X1	C3/S3	C3S03,15	1756-OB32-15	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
24	C3S03-X2	C3/S3	C3S03,16	1756-OB32-16	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
25	C3S03-X2	C3/S3	C3S03,17	1756-OB32-17	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
26	C3S03-X2	C3/S3	C3S03,18	1756-OB32-18	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
27	C3S03-X2	C3/S3	C3S03,19	1756-OB32-19	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
28	C3S03-X2	C3/S3	C3S03,20	1756-OB32-20	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
29	C3S03-X2	C3/S3	C3S03,21	1756-OB32-21	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
30	C3S03-X2	C3/S3	C3S03,22	1756-OB32-22	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
31	C3S03-X2	C3/S3	C3S03,23	1756-OB32-23	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-

ENCLOSURE: JB-618 | TYPE: Field Junction Box (Standard) | LOCATION: Packing Tower 8th Floor | SIZE: 450-300-150 mm

SUMMARY: Total Channels: 52 | Active: 25 | Spare: 27 (51.9%) | DI: 16 | DO: 32 | AI: 4 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
32	C3S03-X2	C3/S3	C3S03,24	1756-OB32-24	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
33	C3S03-X2	C3/S3	C3S03,25	1756-OB32-25	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
34	C3S03-X2	C3/S3	C3S03,26	1756-OB32-26	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
35	C3S03-X2	C3/S3	C3S03,27	1756-OB32-27	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
36	C3S03-X2	C3/S3	C3S03,28	1756-OB32-28	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
37	C3S03-X2	C3/S3	C3S03,29	1756-OB32-29	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
38	C3S03-X2	C3/S3	C3S03,30	1756-OB32-30	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
39	C3S03-X2	C3/S3	C3S03,31	1756-OB32-31	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
40	C3S03-X1	C3/S3	C3S03,02	1756-OB32-2	DO	24 VDC energized	SV-61301	SV-61301_DO_1	325-01-613-PD-01	0	Packing Tower / ...
41	C3S03-X1	C3/S3	C3S03,03	1756-OB32-3	DO	24 VDC energized	SV-61302	SV-61302_DO_1	3-25-01-613-PD-01	0	Packing Tower / ...
42	C3S03-X1	C3/S3	C3S03,04	1756-OB32-4	DO	24 VDC energized	SV-61303	SV-61303_DO_1	3-25-01-613-PD-01	0	Packing Tower / ...
43	C3S02-X2	C3/S2	C3S02,24	1756-IB32-24	DI	24 VDC energized	SV-61304	SV-61304_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...
44	C3S02-X2	C3/S2	C3S02,25	1756-IB32-25	DI	24 VDC energized	SV-61304	SV-61304_DI_2	3-25-01-613-PD-01	0	Packing Tower / ...
45	C3S03-X1	C3/S3	C3S03,05	1756-OB32-5	DO	24 VDC energized	SV-61304	SV-61304_DO_1	3-25-01-613-PD-01	0	Packing Tower / ...
46	C3S03-X1	C3/S3	C3S03,06	1756-OB32-6	DO	24 VDC energized	SV-61305	SV-61305_DO_1	3-25-01-613-PD-01	0	Packing Tower / ...
47	C3S03-X1	C3/S3	C3S03,07	1756-OB32-7	DO	-	SV-61306	SV-61306_DO_1	3-25-01-613-PD-01	-	Packing Tower / ...
48	C3S05-X1	C3/S5	C3S05,02	1756-IF16-2	AI	-	TT-61303	TT-61303_AI_1	3-25-01-613-PD-01	-	Packing Tower / ...
49	C3S05-X1	C3/S5	C3S05,03	1756-IF16-3	AI	-	TT-61304	TT-61304_AI_1	3-25-01-613-PD-01	-	Packing Tower / ...
50	C3S02-X2	C3/S2	C3S02,26	1756-IB32-26	DI	24 VDC energized	XV-61301	XV-61301_DI_1	3-25-01-613-PD-01	0	Packing Tower / ...
51	C3S02-X2	C3/S2	C3S02,27	1756-IB32-27	DI	24 VDC energized	XV-61301	XV-61301_DI_2	3-25-01-613-PD-01	0	Packing Tower / ...
52	C3S03-X1	C3/S3	C3S03,08	1756-OB32-8	DO	24 VDC energized	XV-61301	XV-61301_DO_1	3-25-01-613-PD-01	0	Packing Tower / ...