

ENCLOSURE: MCC | TYPE: Motor Control Center Enclosure (MCC) | LOCATION: MCC Room | SIZE: Draw-out Switchgear Panel mm

SUMMARY: Total Channels: 237 | Active: 169 | Spare: 68 (28.7%) | DI: 125 | DO: 95 | AI: 0 | AO: 0 | BUS: 17

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
1	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	ATY-40201	ATY-40201_BUS_1	3-25-01-402-PD-01	Tank Agitator	PH Adjustment / ...
2	C7S01-	C7/S1	C7S01,08	-	DI	24 VDC energized	ATY-40201	ATY-40201_DI_1	3-25-01-402-PD-01	Tank Agitator	PH Adjustment / ...
3	C7S01-	C7/S1	C7S01,09	-	DI	24 VDC energized	ATY-40201	ATY-40201_DI_2	3-25-01-402-PD-01	Tank Agitator	PH Adjustment / ...
4	C7S01-	C7/S1	C7S01,10	-	DI	24 VDC energized	ATY-40201	ATY-40201_DI_3	3-25-01-402-PD-01	Tank Agitator	PH Adjustment / ...
5	C7S05-	C7/S5	C7S05,08	-	DO	24 VDC energized	ATY-40201	ATY-40201_DO_1	3-25-01-402-PD-01	Tank Agitator	PH Adjustment / ...
6	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	ATY-40202	ATY-40202_BUS_1	3-25-01-402-PD-01	Tank Agitator	PH Adjustment / ...
7	C7S01-	C7/S1	C7S01,11	-	DI	24 VDC energized	ATY-40202	ATY-40202_DI_1	3-25-01-402-PD-01	Tank Agitator	PH Adjustment / ...
8	C7S01-	C7/S1	C7S01,12	-	DI	24 VDC energized	ATY-40202	ATY-40202_DI_2	3-25-01-402-PD-01	Tank Agitator	PH Adjustment / ...
9	C7S01-	C7/S1	C7S01,13	-	DI	24 VDC energized	ATY-40202	ATY-40202_DI_3	3-25-01-402-PD-01	Tank Agitator	PH Adjustment / ...
10	C7S05-	C7/S5	C7S05,09	-	DO	24 VDC energized	ATY-40202	ATY-40202_DO_1	3-25-01-402-PD-01	Tank Agitator	PH Adjustment / ...
11	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	ATY-40203	ATY-40203_BUS_1	3-25-01-402-PD-02	Tank Agitator	Infeed Tank / 1st
12	C7S01-	C7/S1	C7S01,14	-	DI	24 VDC energized	ATY-40203	ATY-40203_DI_1	3-25-01-402-PD-02	Tank Agitator	Infeed Tank / 1st
13	C7S01-	C7/S1	C7S01,15	-	DI	24 VDC energized	ATY-40203	ATY-40203_DI_2	3-25-01-402-PD-02	Tank Agitator	Infeed Tank / 1st
14	C7S01-	C7/S1	C7S01,16	-	DI	24 VDC energized	ATY-40203	ATY-40203_DI_3	3-25-01-402-PD-02	Tank Agitator	Infeed Tank / 1st
15	C7S05-	C7/S5	C7S05,10	-	DO	24 VDC energized	ATY-40203	ATY-40203_DO_1	3-25-01-402-PD-02	Tank Agitator	Infeed Tank / 1st
16	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	BFY-60206	BFY-60206_BUS_1	325-01-600-PD-08	0	Spray Dryer / 1st
17	C7S01-	C7/S1	C7S01,26	-	DI	24 VDC energized	BFY-60206	BFY-60206_DI_1	325-01-600-PD-08	0	Spray Dryer / 1st
18	C7S05-	C7/S5	C7S05,14	-	DO	24 VDC energized	BFY-60206	BFY-60206_DO_1	325-01-600-PD-08	0	Spray Dryer / 1st
19	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	BFY-60210	BFY-60210_BUS_1	325-01-600-PD-03	0	Spray Dryer / 5th
20	C7S02-	C7/S2	C7S02,11	-	DI	24 VDC energized	BFY-60210	BFY-60210_DI_1	325-01-600-PD-03	0	Spray Dryer / 5th
21	C7S05-	C7/S5	C7S05,30	-	DO	24 VDC energized	BFY-60210	BFY-60210_DO_1	325-01-600-PD-03	0	Spray Dryer / 5th
22	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	BFY-60211	BFY-60211_BUS_1	325-01-600-PD-03	0	Spray Dryer / 5th
23	C7S02-	C7/S2	C7S02,12	-	DI	24 VDC energized	BFY-60211	BFY-60211_DI_1	325-01-600-PD-03	0	Spray Dryer / 5th
24	C7S05-	C7/S5	C7S05,31	-	DO	24 VDC energized	BFY-60211	BFY-60211_DO_1	325-01-600-PD-03	0	Spray Dryer / 5th
25	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	BFY-60220	BFY-60220_BUS_1	325-01-600-PD-04	0	Spray Dryer / 7th
26	C7S02-	C7/S2	C7S02,17	-	DI	24 VDC energized	BFY-60220	BFY-60220_DI_1	325-01-600-PD-04	0	Spray Dryer / 7th
27	C7S06-	C7/S6	C7S06,07	-	DO	24 VDC energized	BFY-60220	BFY-60220_DO_1	325-01-600-PD-04	0	Spray Dryer / 7th
28	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	BFY-60240	BFY-60240_BUS_1	325-01-600-PD-05	0	Spray Dryer / 5th
29	C7S02-	C7/S2	C7S02,13	-	DI	24 VDC energized	BFY-60240	BFY-60240_DI_1	325-01-600-PD-05	0	Spray Dryer / 5th
30	C7S06-	C7/S6	C7S06,00	-	DO	24 VDC energized	BFY-60240	BFY-60240_DO_1	325-01-600-PD-05	0	Spray Dryer / 5th
31	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	BFY-61301	BFY-61301_BUS_1	325-01-613-PD-01	0	Packing Tower / ...

ENCLOSURE: MCC | TYPE: Motor Control Center Enclosure (MCC) | LOCATION: MCC Room | SIZE: Draw-out Switchgear Panel mm

SUMMARY: Total Channels: 237 | Active: 169 | Spare: 68 (28.7%) | DI: 125 | DO: 95 | AI: 0 | AO: 0 | BUS: 17

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
32	C7S03-	C7/S3	C7S03,08	-	DI	24 VDC energized	BFY-61301	BFY-61301_DI_1	325-01-613-PD-01	0	Packing Tower / ...
33	C7S06-	C7/S6	C7S06,19	-	DO	24 VDC energized	BFY-61301	BFY-61301_DO_1	325-01-613-PD-01	0	Packing Tower / ...
34	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	BFY-61302	BFY-61302_BUS_1	325-01-613-PD-05	0	Packing Tower / ...
35	C7S02-	C7/S2	C7S02,18	-	DI	24 VDC energized	BFY-61302	BFY-61302_DI_1	325-01-613-PD-05	0	Packing Tower / ...
36	C7S06-	C7/S6	C7S06,10	-	DO	24 VDC energized	BFY-61302	BFY-61302_DO_1	325-01-613-PD-05	0	Packing Tower / ...
37	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	BFY-61303	BFY-61303_BUS_1	325-01-613-PD-01	0	Packing Tower / ...
38	C7S03-	C7/S3	C7S03,09	-	DI	24 VDC energized	BFY-61303	BFY-61303_DI_1	325-01-613-PD-01	0	Packing Tower / ...
39	C7S06-	C7/S6	C7S06,20	-	DO	24 VDC energized	BFY-61303	BFY-61303_DO_1	325-01-613-PD-01	0	Packing Tower / ...
40	C7S03-	C7/S3	C7S03,10	-	DI	24 VDC energized	BLM-61302	BLM-61302_DI_1	325-01-613-PD-01	0	Packing Tower / ...
41	C7S03-	C7/S3	C7S03,11	-	DI	24 VDC energized	BLM-61302	BLM-61302_DI_2	325-01-613-PD-01	0	Packing Tower / ...
42	C7S06-	C7/S6	C7S06,21	-	DO	24 VDC energized	BLM-61302	BLM-61302_DO_1	325-01-613-PD-01	0	Packing Tower / ...
43	C7S06-	C7/S6	C7S06,22	-	DO	24 VDC energized	BLM-61302	BLM-61302_DO_2	325-01-613-PD-01	0	Packing Tower / ...
44	C7S03-	C7/S3	C7S03,12	-	DI	Dry Contact	HS-61307A	HS-61307A_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
45	C7S03-	C7/S3	C7S03,13	-	DI	Dry Contact	HS-61307B	HS-61307B_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
46	C7S03-	C7/S3	C7S03,14	-	DI	Dry Contact	HS-61307C	HS-61307C_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
47	C7S03-	C7/S3	C7S03,15	-	DI	Dry Contact	HS-61307D	HS-61307D_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
48	C7S03-	C7/S3	C7S03,16	-	DI	Dry Contact	HS-61307E	HS-61307E_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
49	C7S02-	C7/S2	C7S02,19	-	DI	Dry Contact	HS-61307F	HS-61307F_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
50	C7S02-	C7/S2	C7S02,20	-	DI	Dry Contact	HS-61307G	HS-61307G_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
51	C7S02-	C7/S2	C7S02,21	-	DI	Dry Contact	HS-61307H	HS-61307H_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
52	C7S02-	C7/S2	C7S02,22	-	DI	Dry Contact	HS-61307I	HS-61307I_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
53	C7S02-	C7/S2	C7S02,23	-	DI	Dry Contact	HS-61307J	HS-61307J_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
54	C7S02-	C7/S2	C7S02,24	-	DI	Dry Contact	HS-61307K	HS-61307K_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
55	C7S02-	C7/S2	C7S02,25	-	DI	Dry Contact	HS-61307L	HS-61307L_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
56	C7S02-	C7/S2	C7S02,26	-	DI	Dry Contact	HS-61307M	HS-61307M_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
57	C7S02-	C7/S2	C7S02,27	-	DI	Dry Contact	HS-61307N	HS-61307N_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
58	C7S02-	C7/S2	C7S02,28	-	DI	Dry Contact	HS-61307O	HS-61307O_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
59	C7S02-	C7/S2	C7S02,29	-	DI	Dry Contact	HS-61307P	HS-61307P_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
60	C7S02-	C7/S2	C7S02,30	-	DI	Dry Contact	HS-61307Q	HS-61307Q_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
61	C7S02-	C7/S2	C7S02,31	-	DI	Dry Contact	HS-61307R	HS-61307R_DI_1	3-25-01-613-PD-03	0	Packing Tower / ...
62	C6S05-	C6/S5	C6S05,00	-	DO	-	PCM-2030	PCM-2030_DO_1	3-25-01-202-PD-01	-	Slurry - Out Buildi...

ENCLOSURE: MCC | TYPE: Motor Control Center Enclosure (MCC) | LOCATION: MCC Room | SIZE: Draw-out Switchgear Panel mm

SUMMARY: Total Channels: 237 | Active: 169 | Spare: 68 (28.7%) | DI: 125 | DO: 95 | AI: 0 | AO: 0 | BUS: 17

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
63	C6S05-	C6/S5	C6S05,01	-	DO	-	PCM-2030	PCM-2030_DO_2	3-25-01-202-PD-01	-	Slurry - Out Buildi...
64	C6S06-	C6/S6	C6S06,00	-	DI	-	PCM-2030	PCM-2030_DI_1	3-25-01-202-PD-01	-	Slurry - Out Buildi...
65	C6S06-	C6/S6	C6S06,01	-	DI	-	PCM-2030	PCM-2030_DI_2	3-25-01-202-PD-01	-	Slurry - Out Buildi...
66	C6S05-	C6/S5	C6S05,02	-	DO	24 VDC energized	PCM-2031	PCM-2031_DO_1	3-25-01-202-PD-01	0	Slurry - Out Buildi...
67	C6S05-	C6/S5	C6S05,03	-	DO	24 VDC energized	PCM-2031	PCM-2031_DO_2	3-25-01-202-PD-01	0	Slurry - Out Buildi...
68	C6S06-	C6/S6	C6S06,02	-	DI	24 VDC energized	PCM-2031	PCM-2031_DI_1	3-25-01-202-PD-01	0	Slurry - Out Buildi...
69	C6S06-	C6/S6	C6S06,03	-	DI	24 VDC energized	PCM-2031	PCM-2031_DI_2	3-25-01-202-PD-01	0	Slurry - Out Buildi...
70	C7S01-	C7/S1	C7S01,27	-	DI	-	PCM-60205-2	PCM-60205-2_DI_1	325-01-600-PD-01	-	Spray Dryer / 1st
71	C7S01-	C7/S1	C7S01,28	-	DI	-	PCM-60205-2	PCM-60205-2_DI_2	325-01-600-PD-01	-	Spray Dryer / 1st
72	C7S05-	C7/S5	C7S05,15	-	DO	-	PCM-60205-2	PCM-60205-2_DO_1	325-01-600-PD-01	-	Spray Dryer / 1st
73	C7S05-	C7/S5	C7S05,16	-	DO	-	PCM-60205-2	PCM-60205-2_DO_2	325-01-600-PD-01	-	Spray Dryer / 1st
74	C7S01-	C7/S1	C7S01,29	-	DI	-	PCM-60205-3	PCM-60205-3_DI_1	325-01-600-PD-01	-	Spray Dryer / 1st
75	C7S01-	C7/S1	C7S01,30	-	DI	-	PCM-60205-3	PCM-60205-3_DI_2	325-01-600-PD-01	-	Spray Dryer / 1st
76	C7S05-	C7/S5	C7S05,17	-	DO	-	PCM-60205-3	PCM-60205-3_DO_1	325-01-600-PD-01	-	Spray Dryer / 1st
77	C7S05-	C7/S5	C7S05,18	-	DO	-	PCM-60205-3	PCM-60205-3_DO_2	325-01-600-PD-01	-	Spray Dryer / 1st
78	C7S01-	C7/S1	C7S01,31	-	DI	-	PCM-60205-4	PCM-60205-4_DI_1	325-01-600-PD-01	-	Spray Dryer / 1st
79	C7S02-	C7/S2	C7S02,00	-	DI	-	PCM-60205-4	PCM-60205-4_DI_2	325-01-600-PD-01	-	Spray Dryer / 1st
80	C7S05-	C7/S5	C7S05,19	-	DO	-	PCM-60205-4	PCM-60205-4_DO_1	325-01-600-PD-01	-	Spray Dryer / 1st
81	C7S05-	C7/S5	C7S05,20	-	DO	-	PCM-60205-4	PCM-60205-4_DO_2	325-01-600-PD-01	-	Spray Dryer / 1st
82	C7S02-	C7/S2	C7S02,01	-	DI	-	PCM-60205-5	PCM-60205-5_DI_1	325-01-600-PD-01	-	Spray Dryer / 1st
83	C7S02-	C7/S2	C7S02,02	-	DI	-	PCM-60205-5	PCM-60205-5_DI_2	325-01-600-PD-01	-	Spray Dryer / 1st
84	C7S05-	C7/S5	C7S05,21	-	DO	-	PCM-60205-5	PCM-60205-5_DO_1	325-01-600-PD-01	-	Spray Dryer / 1st
85	C7S05-	C7/S5	C7S05,22	-	DO	-	PCM-60205-5	PCM-60205-5_DO_2	325-01-600-PD-01	-	Spray Dryer / 1st
86	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	PCY-40201	PCY-40201_BUS_1	3-25-01-402-PD-01	PUMP	PH Adjustment / ...
87	C7S01-	C7/S1	C7S01,17	-	DI	24 VDC energized	PCY-40201	PCY-40201_DI_1	3-25-01-402-PD-01	PUMP	PH Adjustment / ...
88	C7S01-	C7/S1	C7S01,18	-	DI	24 VDC energized	PCY-40201	PCY-40201_DI_2	3-25-01-402-PD-01	PUMP	PH Adjustment / ...
89	C7S01-	C7/S1	C7S01,19	-	DI	24 VDC energized	PCY-40201	PCY-40201_DI_3	3-25-01-402-PD-01	PUMP	PH Adjustment / ...
90	C7S05-	C7/S5	C7S05,11	-	DO	24 VDC energized	PCY-40201	PCY-40201_DO_1	3-25-01-402-PD-01	PUMP	PH Adjustment / ...
91	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	PCY-40202	PCY-40202_BUS_1	3-25-01-402-PD-01	PUMP	PH Adjustment / ...
92	C7S01-	C7/S1	C7S01,20	-	DI	24 VDC energized	PCY-40202	PCY-40202_DI_1	3-25-01-402-PD-01	PUMP	PH Adjustment / ...
93	C7S01-	C7/S1	C7S01,21	-	DI	24 VDC energized	PCY-40202	PCY-40202_DI_2	3-25-01-402-PD-01	PUMP	PH Adjustment / ...

ENCLOSURE: MCC | TYPE: Motor Control Center Enclosure (MCC) | LOCATION: MCC Room | SIZE: Draw-out Switchgear Panel mm

SUMMARY: Total Channels: 237 | Active: 169 | Spare: 68 (28.7%) | DI: 125 | DO: 95 | AI: 0 | AO: 0 | BUS: 17

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
94	C7S01-	C7/S1	C7S01,22	-	DI	24 VDC energized	PCY-40202	PCY-40202_DI_3	3-25-01-402-PD-01	PUMP	PH Adjustment / ...
95	C7S05-	C7/S5	C7S05,12	-	DO	24 VDC energized	PCY-40202	PCY-40202_DO_1	3-25-01-402-PD-01	PUMP	PH Adjustment / ...
96	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	PCY-40203	PCY-40203_BUS_1	3-25-01-402-PD-02	PUMP	Infeed Tank / 1st
97	C7S01-	C7/S1	C7S01,23	-	DI	24 VDC energized	PCY-40203	PCY-40203_DI_1	3-25-01-402-PD-02	PUMP	Infeed Tank / 1st
98	C7S01-	C7/S1	C7S01,24	-	DI	24 VDC energized	PCY-40203	PCY-40203_DI_2	3-25-01-402-PD-02	PUMP	Infeed Tank / 1st
99	C7S01-	C7/S1	C7S01,25	-	DI	24 VDC energized	PCY-40203	PCY-40203_DI_3	3-25-01-402-PD-02	PUMP	Infeed Tank / 1st
100	C7S05-	C7/S5	C7S05,13	-	DO	24 VDC energized	PCY-40203	PCY-40203_DO_1	3-25-01-402-PD-02	PUMP	Infeed Tank / 1st
101	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	PCY-60215	PCY-60215_BUS_1	325-01-600-PD-03	PUMP	Spray Dryer / 5th
102	C7S02-	C7/S2	C7S02,14	-	DI	24 VDC energized	PCY-60215	PCY-60215_DI_1	325-01-600-PD-03	PUMP	Spray Dryer / 5th
103	C7S02-	C7/S2	C7S02,15	-	DI	24 VDC energized	PCY-60215	PCY-60215_DI_2	325-01-600-PD-03	PUMP	Spray Dryer / 5th
104	C7S02-	C7/S2	C7S02,16	-	DI	24 VDC energized	PCY-60215	PCY-60215_DI_3	325-01-600-PD-03	PUMP	Spray Dryer / 5th
105	C7S06-	C7/S6	C7S06,01	-	DO	24 VDC energized	PCY-60215	PCY-60215_DO_1	325-01-600-PD-03	PUMP	Spray Dryer / 5th
106	C6S05-	C6/S5	C6S05,04	-	DO	24 VDC energized	PCY-814201	PCY-814201_DO_1	3-25-01-810-PD-01	PUMP	CIP Water Syste...
107	C6S06-	C6/S6	C6S06,04	-	DI	24 VDC energized	PCY-814201	PCY-814201_DI_1	3-25-01-810-PD-01	PUMP	CIP Water Syste...
108	C6S06-	C6/S6	C6S06,05	-	DI	24 VDC energized	PCY-814201	PCY-814201_DI_2	3-25-01-810-PD-01	PUMP	CIP Water Syste...
109	C6S06-	C6/S6	C6S06,06	-	DI	24 VDC energized	PCY-814201	PCY-814201_DI_3	3-25-01-810-PD-01	PUMP	CIP Water Syste...
110	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	PCY-814201	PCY-814201_BUS_1	3-25-01-810-PD-01	PUMP	CIP Water Syste...
111	C6S05-	C6/S5	C6S05,05	-	DO	24 VDC energized	PCY-814202	PCY-814202_DO_1	3-25-01-810-PD-01	PUMP	CIP Water Syste...
112	C6S06-	C6/S6	C6S06,07	-	DI	24 VDC energized	PCY-814202	PCY-814202_DI_1	3-25-01-810-PD-01	PUMP	CIP Water Syste...
113	C6S06-	C6/S6	C6S06,08	-	DI	24 VDC energized	PCY-814202	PCY-814202_DI_2	3-25-01-810-PD-01	PUMP	CIP Water Syste...
114	C6S06-	C6/S6	C6S06,09	-	DI	24 VDC energized	PCY-814202	PCY-814202_DI_3	3-25-01-810-PD-01	PUMP	CIP Water Syste...
115	C7S00-	C7/S0	C7S00,00	-	BUS	BUS	PCY-814202	PCY-814202_BUS_1	3-25-01-810-PD-01	PUMP	CIP Water Syste...
116	C7S02-	C7/S2	C7S02,05	-	DI	24 VDC energized	RVM-60201	RVM-60201_DI_1	325-01-600-PD-08	0	Spray Dryer / 1st
117	C7S02-	C7/S2	C7S02,06	-	DI	24 VDC energized	RVM-60201	RVM-60201_DI_2	325-01-600-PD-08	0	Spray Dryer / 1st
118	C7S05-	C7/S5	C7S05,23	-	DO	24 VDC energized	RVM-60201	RVM-60201_DO_1	325-01-600-PD-08	0	Spray Dryer / 1st
119	C7S05-	C7/S5	C7S05,24	-	DO	24 VDC energized	RVM-60201	RVM-60201_DO_2	325-01-600-PD-08	0	Spray Dryer / 1st
120	C7S02-	C7/S2	C7S02,07	-	DI	24 VDC energized	RVM-60202	RVM-60202_DI_1	325-01-600-PD-08	0	Spray Dryer / 1st
121	C7S02-	C7/S2	C7S02,08	-	DI	24 VDC energized	RVM-60202	RVM-60202_DI_2	325-01-600-PD-08	0	Spray Dryer / 1st
122	C7S05-	C7/S5	C7S05,25	-	DO	24 VDC energized	RVM-60202	RVM-60202_DO_1	325-01-600-PD-08	0	Spray Dryer / 1st
123	C7S05-	C7/S5	C7S05,26	-	DO	24 VDC energized	RVM-60202	RVM-60202_DO_2	325-01-600-PD-08	0	Spray Dryer / 1st
124	C7S02-	C7/S2	C7S02,09	-	DI	24 VDC energized	RVM-60203	RVM-60203_DI_1	325-01-600-PD-08	0	Spray Dryer / 1st

ENCLOSURE: MCC | TYPE: Motor Control Center Enclosure (MCC) | LOCATION: MCC Room | SIZE: Draw-out Switchgear Panel mm

SUMMARY: Total Channels: 237 | Active: 169 | Spare: 68 (28.7%) | DI: 125 | DO: 95 | AI: 0 | AO: 0 | BUS: 17

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
125	C7S02-	C7/S2	C7S02,10	-	DI	24 VDC energized	RVM-60203	RVM-60203_DI_2	325-01-600-PD-08	0	Spray Dryer / 1st
126	C7S05-	C7/S5	C7S05,27	-	DO	24 VDC energized	RVM-60203	RVM-60203_DO_1	325-01-600-PD-08	0	Spray Dryer / 1st
127	C7S05-	C7/S5	C7S05,28	-	DO	24 VDC energized	RVM-60203	RVM-60203_DO_2	325-01-600-PD-08	0	Spray Dryer / 1st
128	C7S03-	C7/S3	C7S03,17	-	DI	24 VDC energized	RVM-60204	RVM-60204_DI_1	325-01-600-PD-08	0	Packing Tower / ...
129	C7S03-	C7/S3	C7S03,18	-	DI	24 VDC energized	RVM-60204	RVM-60204_DI_2	325-01-600-PD-08	0	Packing Tower / ...
130	C7S06-	C7/S6	C7S06,23	-	DO	24 VDC energized	RVM-60204	RVM-60204_DO_1	325-01-600-PD-08	0	Packing Tower / ...
131	C7S06-	C7/S6	C7S06,24	-	DO	24 VDC energized	RVM-60204	RVM-60204_DO_2	325-01-600-PD-08	0	Packing Tower / ...
132	C7S03-	C7/S3	C7S03,19	-	DI	24 VDC energized	RVM-61301	RVM-61301_DI_1	325-01-613-PD-01	0	Packing Tower / ...
133	C7S03-	C7/S3	C7S03,20	-	DI	24 VDC energized	RVM-61301	RVM-61301_DI_2	325-01-613-PD-01	0	Packing Tower / ...
134	C7S06-	C7/S6	C7S06,25	-	DO	24 VDC energized	RVM-61301	RVM-61301_DO_1	325-01-613-PD-01	0	Packing Tower / ...
135	C7S06-	C7/S6	C7S06,26	-	DO	24 VDC energized	RVM-61301	RVM-61301_DO_2	325-01-613-PD-01	0	Packing Tower / ...
136	C7S03-	C7/S3	C7S03,00	-	DI	24 VDC energized	RVM-61302	RVM-61302_DI_1	325-01-613-PD-03	0	Packing Tower / ...
137	C7S03-	C7/S3	C7S03,01	-	DI	24 VDC energized	RVM-61302	RVM-61302_DI_2	325-01-613-PD-03	0	Packing Tower / ...
138	C7S06-	C7/S6	C7S06,11	-	DO	24 VDC energized	RVM-61302	RVM-61302_DO_1	325-01-613-PD-03	0	Packing Tower / ...
139	C7S06-	C7/S6	C7S06,12	-	DO	24 VDC energized	RVM-61302	RVM-61302_DO_2	325-01-613-PD-03	0	Packing Tower / ...
140	C7S03-	C7/S3	C7S03,02	-	DI	24 VDC energized	RVM-61303	RVM-61303_DI_1	325-01-613-PD-05	0	Packing Tower / ...
141	C7S03-	C7/S3	C7S03,03	-	DI	24 VDC energized	RVM-61303	RVM-61303_DI_2	325-01-613-PD-05	0	Packing Tower / ...
142	C7S06-	C7/S6	C7S06,13	-	DO	24 VDC energized	RVM-61303	RVM-61303_DO_1	325-01-613-PD-05	0	Packing Tower / ...
143	C7S06-	C7/S6	C7S06,14	-	DO	24 VDC energized	RVM-61303	RVM-61303_DO_2	325-01-613-PD-05	0	Packing Tower / ...
144	C7S03-	C7/S3	C7S03,21	-	DI	24 VDC energized	RVM-61304	RVM-61304_DI_1	325-01-613-PD-01	0	Packing Tower / ...
145	C7S03-	C7/S3	C7S03,22	-	DI	24 VDC energized	RVM-61304	RVM-61304_DI_2	325-01-613-PD-01	0	Packing Tower / ...
146	C7S06-	C7/S6	C7S06,27	-	DO	24 VDC energized	RVM-61304	RVM-61304_DO_1	325-01-613-PD-01	0	Packing Tower / ...
147	C7S06-	C7/S6	C7S06,28	-	DO	24 VDC energized	RVM-61304	RVM-61304_DO_2	325-01-613-PD-01	0	Packing Tower / ...
148	C7S03-	C7/S3	C7S03,23	-	DI	24 VDC energized	RVM-61305	RVM-61305_DI_1	325-01-613-PD-01	0	Packing Tower / ...
149	C7S03-	C7/S3	C7S03,24	-	DI	24 VDC energized	RVM-61305	RVM-61305_DI_2	325-01-613-PD-01	0	Packing Tower / ...
150	C7S06-	C7/S6	C7S06,29	-	DO	24 VDC energized	RVM-61305	RVM-61305_DO_1	325-01-613-PD-01	0	Packing Tower / ...
151	C7S06-	C7/S6	C7S06,30	-	DO	24 VDC energized	RVM-61305	RVM-61305_DO_2	325-01-613-PD-01	0	Packing Tower / ...
152	C7S03-	C7/S3	C7S03,04	-	DI	24 VDC energized	SCM-61301	SCM-61301_DI_1	325-01-613-PD-01	0	Packing Tower / ...
153	C7S03-	C7/S3	C7S03,05	-	DI	24 VDC energized	SCM-61301	SCM-61301_DI_2	325-01-613-PD-01	0	Packing Tower / ...
154	C7S06-	C7/S6	C7S06,15	-	DO	24 VDC energized	SCM-61301	SCM-61301_DO_1	325-01-613-PD-01	0	Packing Tower / ...
155	C7S06-	C7/S6	C7S06,16	-	DO	24 VDC energized	SCM-61301	SCM-61301_DO_2	325-01-613-PD-01	0	Packing Tower / ...

ENCLOSURE: MCC | TYPE: Motor Control Center Enclosure (MCC) | LOCATION: MCC Room | SIZE: Draw-out Switchgear Panel mm

SUMMARY: Total Channels: 237 | Active: 169 | Spare: 68 (28.7%) | DI: 125 | DO: 95 | AI: 0 | AO: 0 | BUS: 17

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
156	C7S03-	C7/S3	C7S03,06	-	DI	24 VDC energized	SCM-61302	SCM-61302_DI_2	325-01-613-PD-01	0	Packing Tower / ...
157	C7S03-	C7/S3	C7S03,07	-	DI	24 VDC energized	SCM-61302	SCM-61302_DI_1	325-01-613-PD-01	0	Packing Tower / ...
158	C7S06-	C7/S6	C7S06,17	-	DO	24 VDC energized	SCM-61302	SCM-61302_DO_1	325-01-613-PD-01	0	Packing Tower / ...
159	C7S06-	C7/S6	C7S06,18	-	DO	24 VDC energized	SCM-61302	SCM-61302_DO_2	325-01-613-PD-01	0	Packing Tower / ...
160	C7S01-	C7/S1	C7S01,00	-	DI	-	Spare	Spare_DI_0	3-25-01-402-PD-01	Spare I/O Point	PH Adjustment / ...
161	C7S01-	C7/S1	C7S01,01	-	DI	-	Spare	Spare_DI_0	3-25-01-402-PD-01	Spare I/O Point	PH Adjustment / ...
162	C7S01-	C7/S1	C7S01,02	-	DI	-	Spare	Spare_DI_0	3-25-01-402-PD-01	Spare I/O Point	PH Adjustment / ...
163	C7S01-	C7/S1	C7S01,03	-	DI	-	Spare	Spare_DI_0	3-25-01-402-PD-01	Spare I/O Point	PH Adjustment / ...
164	C7S01-	C7/S1	C7S01,04	-	DI	-	Spare	Spare_DI_0	3-25-01-402-PD-01	Spare I/O Point	PH Adjustment / ...
165	C7S01-	C7/S1	C7S01,05	-	DI	-	Spare	Spare_DI_0	3-25-01-402-PD-01	Spare I/O Point	PH Adjustment / ...
166	C7S01-	C7/S1	C7S01,06	-	DI	-	Spare	Spare_DI_0	3-25-01-402-PD-01	Spare I/O Point	PH Adjustment / ...
167	C7S01-	C7/S1	C7S01,07	-	DI	-	Spare	Spare_DI_0	3-25-01-402-PD-01	Spare I/O Point	PH Adjustment / ...
168	C7S04-	C7/S4	C7S04,04	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
169	C7S04-	C7/S4	C7S04,05	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
170	C7S04-	C7/S4	C7S04,06	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
171	C7S04-	C7/S4	C7S04,07	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
172	C7S04-	C7/S4	C7S04,08	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
173	C7S04-	C7/S4	C7S04,09	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
174	C7S04-	C7/S4	C7S04,10	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
175	C7S04-	C7/S4	C7S04,11	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
176	C7S04-	C7/S4	C7S04,12	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
177	C7S04-	C7/S4	C7S04,13	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
178	C7S04-	C7/S4	C7S04,14	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
179	C7S04-	C7/S4	C7S04,15	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
180	C7S04-	C7/S4	C7S04,16	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
181	C7S04-	C7/S4	C7S04,17	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
182	C7S04-	C7/S4	C7S04,18	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
183	C7S04-	C7/S4	C7S04,19	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
184	C7S04-	C7/S4	C7S04,20	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
185	C7S04-	C7/S4	C7S04,21	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
186	C7S04-	C7/S4	C7S04,22	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-

ENCLOSURE: MCC | TYPE: Motor Control Center Enclosure (MCC) | LOCATION: MCC Room | SIZE: Draw-out Switchgear Panel mm

SUMMARY: Total Channels: 237 | Active: 169 | Spare: 68 (28.7%) | DI: 125 | DO: 95 | AI: 0 | AO: 0 | BUS: 17

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
187	C7S04-	C7/S4	C7S04,23	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
188	C7S04-	C7/S4	C7S04,24	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
189	C7S04-	C7/S4	C7S04,25	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
190	C7S04-	C7/S4	C7S04,26	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
191	C7S04-	C7/S4	C7S04,27	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
192	C7S04-	C7/S4	C7S04,28	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
193	C7S04-	C7/S4	C7S04,29	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
194	C7S04-	C7/S4	C7S04,30	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
195	C7S04-	C7/S4	C7S04,31	-	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
196	C7S05-	C7/S5	C7S05,00	-	DO	-	Spare	Spare_DO_0	3-25-01-402-PD-01	Spare I/O Point	PH Adjustment / ...
197	C7S05-	C7/S5	C7S05,01	-	DO	-	Spare	Spare_DO_0	3-25-01-402-PD-01	Spare I/O Point	PH Adjustment / ...
198	C7S05-	C7/S5	C7S05,02	-	DO	-	Spare	Spare_DO_0	3-25-01-402-PD-01	Spare I/O Point	PH Adjustment / ...
199	C7S05-	C7/S5	C7S05,03	-	DO	-	Spare	Spare_DO_0	3-25-01-402-PD-01	Spare I/O Point	PH Adjustment / ...
200	C7S05-	C7/S5	C7S05,04	-	DO	-	Spare	Spare_DO_0	3-25-01-402-PD-01	Spare I/O Point	PH Adjustment / ...
201	C7S05-	C7/S5	C7S05,05	-	DO	-	Spare	Spare_DO_0	3-25-01-402-PD-01	Spare I/O Point	PH Adjustment / ...
202	C7S05-	C7/S5	C7S05,06	-	DO	-	Spare	Spare_DO_0	3-25-01-402-PD-01	Spare I/O Point	PH Adjustment / ...
203	C7S05-	C7/S5	C7S05,07	-	DO	-	Spare	Spare_DO_0	3-25-01-402-PD-01	Spare I/O Point	PH Adjustment / ...
204	C7S07-	C7/S7	C7S07,08	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
205	C7S07-	C7/S7	C7S07,09	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
206	C7S07-	C7/S7	C7S07,10	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
207	C7S07-	C7/S7	C7S07,11	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
208	C7S07-	C7/S7	C7S07,12	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
209	C7S07-	C7/S7	C7S07,13	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
210	C7S07-	C7/S7	C7S07,14	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
211	C7S07-	C7/S7	C7S07,15	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
212	C7S07-	C7/S7	C7S07,16	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
213	C7S07-	C7/S7	C7S07,17	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
214	C7S07-	C7/S7	C7S07,18	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
215	C7S07-	C7/S7	C7S07,19	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
216	C7S07-	C7/S7	C7S07,20	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
217	C7S07-	C7/S7	C7S07,21	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-

ENCLOSURE: MCC | TYPE: Motor Control Center Enclosure (MCC) | LOCATION: MCC Room | SIZE: Draw-out Switchgear Panel mm

SUMMARY: Total Channels: 237 | Active: 169 | Spare: 68 (28.7%) | DI: 125 | DO: 95 | AI: 0 | AO: 0 | BUS: 17

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
218	C7S07-	C7/S7	C7S07,22	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
219	C7S07-	C7/S7	C7S07,23	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
220	C7S07-	C7/S7	C7S07,24	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
221	C7S07-	C7/S7	C7S07,25	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
222	C7S07-	C7/S7	C7S07,26	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
223	C7S07-	C7/S7	C7S07,27	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
224	C7S07-	C7/S7	C7S07,28	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
225	C7S07-	C7/S7	C7S07,29	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
226	C7S07-	C7/S7	C7S07,30	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
227	C7S07-	C7/S7	C7S07,31	-	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
228	C7S05-	C7/S5	C7S05,29	-	DO	0	XS-60205	XS-60205_DO_1	325-01-600-PD-01	0	Spray Dryer / 1st
229	C7S06-	C7/S6	C7S06,02	-	DO	Dry Contact	XS-60240A	XS-60240A_DO_1	325-01-600-PD-05	0	Spray Dryer / 4th
230	C7S06-	C7/S6	C7S06,03	-	DO	Dry Contact	XS-60241A	XS-60241A_DO_1	325-01-600-PD-05	0	Spray Dryer / 4th
231	C7S06-	C7/S6	C7S06,04	-	DO	Dry Contact	XS-60242A	XS-60242A_DO_1	325-01-600-PD-05	0	Spray Dryer / 3rd
232	C7S06-	C7/S6	C7S06,04	-	DO	Dry Contact	XS-60243A	XS-60243A_DO_1	325-01-600-PD-05	0	Spray Dryer / 4th
233	C7S06-	C7/S6	C7S06,06	-	DO	24 VDC energized	XS-60260	XS-60260_DO_1	325-01-600-PD-05	0	Spray Dryer / 6th
234	C6S05-	C6/S5	C6S05,06	-	DO	24 VDC energized	XS-80305	XS-80305_DO_1	325-01-803-PD-02	0	LPG System / 1st
235	C6S05-	C6/S5	C6S05,07	-	DO	24 VDC energized	XS-80306	XS-80306_DO_1	325-01-803-PD-02	Pressure Transmitter	LPG System / 1st
236	C7S06-	C7/S6	C7S06,08	-	DO	Dry Contact	XS-FH-60210A	XS-FH-60210A_DO_1	325-01-600-PD-06	0	Spray Dryer / 7th
237	C7S06-	C7/S6	C7S06,09	-	DO	Dry Contact	XS-FH-60210B	XS-FH-60210B_DO_1	325-01-600-PD-06	0	Spray Dryer / 7th