

ENCLOSURE: RIO-200 | TYPE: Remote I/O Enclosure (RIO Panel) | LOCATION: Slurry - Out Building 2nd Floor | SIZE: 800-1000-400 mm

SUMMARY: Total Channels: 112 | Active: 57 | Spare: 55 (49.1%) | DI: 64 | DO: 32 | AI: 16 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
1	C5S04-X1	C5/S4	C5S04,00	1756-IF16-0	AI	-	EXT-BIILER	EXT-BIILER_AI_1	External Remote S...	-	Boiler System / 1st
2	C5S01-X1	C5/S1	C5S01,00	1756-IB32-0	DI	-	FS-20201	FS-20201_DI_1	3-25-01-202-PD-01	-	Slurry - Out Buildi...
3	C5S01-X1	C5/S1	C5S01,01	1756-IB32-1	DI	4 - 20 mA,Pulse	FT-913201	FT-913201_DI_1	3-25-01-913-PD-02	0	LPG System / 1st
4	C5S04-X1	C5/S4	C5S04,01	1756-IF16-1	AI	4 - 20 mA,Pulse	FT-913201	FT-913201_AI_1	3-25-01-913-PD-02	0	LPG System / 1st
5	C5S04-X1	C5/S4	C5S04,02	1756-IF16-2	AI	4 - 20 mA,Pulse	FT-913201	FT-913201_AI_2	3-25-01-913-PD-02	0	LPG System / 1st
6	C5S01-X1	C5/S1	C5S01,02	1756-IB32-2	DI	4 - 20 mA,Pulse	FT-936201	FT-936201_DI_1	3-25-01-930-PD-08	0	Process Water / ...
7	C5S04-X1	C5/S4	C5S04,03	1756-IF16-3	AI	4 - 20 mA,Pulse	FT-936201	FT-936201_AI_1	3-25-01-930-PD-08	0	Process Water / ...
8	C5S01-X1	C5/S1	C5S01,03	1756-IB32-3	DI	4 - 20 mA,Pulse	FT-936202	FT-936202_DI_1	3-25-01-930-PD-07	0	Process Water / ...
9	C5S04-X1	C5/S4	C5S04,04	1756-IF16-4	AI	4 - 20 mA,Pulse	FT-936202	FT-936202_AI_1	3-25-01-930-PD-07	0	Process Water / ...
10	C5S01-X1	C5/S1	C5S01,07	1756-IB32-7	DI	Dry Contact	HV-20204	HV-20204_DI_1	3-25-01-202-PD-01	Manual Valve With Position Switch	Slurry - Out Buildi...
11	C5S01-X1	C5/S1	C5S01,08	1756-IB32-8	DI	Dry Contact	HV-20205	HV-20205_DI_1	3-25-01-202-PD-01	Manual Valve With Position Switch	Slurry - Out Buildi...
12	C5S01-X1	C5/S1	C5S01,09	1756-IB32-9	DI	Dry Contact	HV-20206	HV-20206_DI_1	3-25-01-202-PD-01	Manual Valve With Position Switch	Slurry - Out Buildi...
13	C5S01-X1	C5/S1	C5S01,10	1756-IB32-10	DI	Dry Contact	HV-20207	HV-20207_DI_1	3-25-01-202-PD-01	Manual Valve With Position Switch	Slurry - Out Buildi...
14	C5S01-X1	C5/S1	C5S01,11	1756-IB32-11	DI	Dry Contact	HV-20208	HV-20208_DI_1	3-25-01-202-PD-02	Manual Valve With Position Switch	Slurry - Out Buildi...
15	C5S01-X1	C5/S1	C5S01,12	1756-IB32-12	DI	Dry Contact	HV-20209	HV-20209_DI_1	3-25-01-202-PD-02	Manual Valve With Position Switch	Slurry - Out Buildi...
16	C5S01-X1	C5/S1	C5S01,13	1756-IB32-13	DI	Dry Contact	HV-20210	HV-20210_DI_1	3-25-01-202-PD-02	Manual Valve With Position Switch	Slurry - Out Buildi...
17	C5S01-X1	C5/S1	C5S01,04	1756-IB32-4	DI	Dry Contact	LSL-814201	LSL-814201_DI_1	3-25-01-814-PD-01	0	CIP Water Syste...
18	C5S04-X1	C5/S4	C5S04,05	1756-IF16-5	AI	4 - 20 mA	LT-913201	LT-913201_AI_1	3-25-01-913-PD-01	Level Transmitter	LPG System / 1st
19	C5S01-X1	C5/S1	C5S01,05	1756-IB32-5	DI	-	PK-913201	PK-913201_DI_1	-	-	LPG System / 1st
20	C5S01-X1	C5/S1	C5S01,06	1756-IB32-6	DI	-	PK-913202	PK-913202_DI_1	-	-	LPG System / 1st
21	C5S04-X1	C5/S4	C5S04,06	1756-IF16-6	AI	4 - 20 mA	PT-913201	PT-913201_AI_1	3-25-01-913-PD-02	Pressure Transmitter	LPG System / 1st
22	C5S02-X1	C5/S2	C5S02,08	1756-IB32-8	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
23	C5S02-X1	C5/S2	C5S02,09	1756-IB32-9	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
24	C5S02-X1	C5/S2	C5S02,10	1756-IB32-10	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
25	C5S02-X1	C5/S2	C5S02,11	1756-IB32-11	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
26	C5S02-X1	C5/S2	C5S02,12	1756-IB32-12	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
27	C5S02-X1	C5/S2	C5S02,13	1756-IB32-13	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
28	C5S02-X1	C5/S2	C5S02,14	1756-IB32-14	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
29	C5S02-X1	C5/S2	C5S02,15	1756-IB32-15	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
30	C5S02-X2	C5/S2	C5S02,16	1756-IB32-16	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
31	C5S02-X2	C5/S2	C5S02,17	1756-IB32-17	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-

ENCLOSURE: RIO-200 | TYPE: Remote I/O Enclosure (RIO Panel) | LOCATION: Slurry - Out Building 2nd Floor | SIZE: 800-1000-400 mm

SUMMARY: Total Channels: 112 | Active: 57 | Spare: 55 (49.1%) | DI: 64 | DO: 32 | AI: 16 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
32	C5S02-X2	C5/S2	C5S02,18	1756-IB32-18	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
33	C5S02-X2	C5/S2	C5S02,19	1756-IB32-19	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
34	C5S02-X2	C5/S2	C5S02,20	1756-IB32-20	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
35	C5S02-X2	C5/S2	C5S02,21	1756-IB32-21	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
36	C5S02-X2	C5/S2	C5S02,22	1756-IB32-22	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
37	C5S02-X2	C5/S2	C5S02,23	1756-IB32-23	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
38	C5S02-X2	C5/S2	C5S02,24	1756-IB32-24	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
39	C5S02-X2	C5/S2	C5S02,25	1756-IB32-25	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
40	C5S02-X2	C5/S2	C5S02,26	1756-IB32-26	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
41	C5S02-X2	C5/S2	C5S02,27	1756-IB32-27	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
42	C5S02-X2	C5/S2	C5S02,28	1756-IB32-28	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
43	C5S02-X2	C5/S2	C5S02,29	1756-IB32-29	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
44	C5S02-X2	C5/S2	C5S02,30	1756-IB32-30	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
45	C5S02-X2	C5/S2	C5S02,31	1756-IB32-31	DI	-	Spare	Spare_DI_0	-	Spare I/O Point	-
46	C5S03-X1	C5/S3	C5S03,08	1756-OB32-8	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
47	C5S03-X1	C5/S3	C5S03,09	1756-OB32-9	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
48	C5S03-X1	C5/S3	C5S03,10	1756-OB32-10	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
49	C5S03-X1	C5/S3	C5S03,11	1756-OB32-11	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
50	C5S03-X1	C5/S3	C5S03,12	1756-OB32-12	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
51	C5S03-X1	C5/S3	C5S03,13	1756-OB32-13	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
52	C5S03-X1	C5/S3	C5S03,14	1756-OB32-14	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
53	C5S03-X1	C5/S3	C5S03,15	1756-OB32-15	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
54	C5S03-X2	C5/S3	C5S03,16	1756-OB32-16	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
55	C5S03-X2	C5/S3	C5S03,17	1756-OB32-17	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
56	C5S03-X2	C5/S3	C5S03,18	1756-OB32-18	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
57	C5S03-X2	C5/S3	C5S03,19	1756-OB32-19	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
58	C5S03-X2	C5/S3	C5S03,20	1756-OB32-20	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
59	C5S03-X2	C5/S3	C5S03,21	1756-OB32-21	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
60	C5S03-X2	C5/S3	C5S03,22	1756-OB32-22	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
61	C5S03-X2	C5/S3	C5S03,23	1756-OB32-23	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
62	C5S03-X2	C5/S3	C5S03,24	1756-OB32-24	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-

ENCLOSURE: RIO-200 | TYPE: Remote I/O Enclosure (RIO Panel) | LOCATION: Slurry - Out Building 2nd Floor | SIZE: 800-1000-400 mm

SUMMARY: Total Channels: 112 | Active: 57 | Spare: 55 (49.1%) | DI: 64 | DO: 32 | AI: 16 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
63	C5S03-X2	C5/S3	C5S03,25	1756-OB32-25	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
64	C5S03-X2	C5/S3	C5S03,26	1756-OB32-26	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
65	C5S03-X2	C5/S3	C5S03,27	1756-OB32-27	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
66	C5S03-X2	C5/S3	C5S03,28	1756-OB32-28	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
67	C5S03-X2	C5/S3	C5S03,29	1756-OB32-29	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
68	C5S03-X2	C5/S3	C5S03,30	1756-OB32-30	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
69	C5S03-X2	C5/S3	C5S03,31	1756-OB32-31	DO	-	Spare	Spare_DO_0	-	Spare I/O Point	-
70	C5S04-X1	C5/S4	C5S04,09	1756-IF16-9	AI	-	Spare	Spare_AI_0	3-25-01-913-PD-02	Spare I/O Point	LPG System / 1st
71	C5S04-X1	C5/S4	C5S04,10	1756-IF16-10	AI	-	Spare	Spare_AI_0	3-25-01-913-PD-02	Spare I/O Point	LPG System / 1st
72	C5S04-X1	C5/S4	C5S04,11	1756-IF16-11	AI	-	Spare	Spare_AI_0	3-25-01-913-PD-02	Spare I/O Point	LPG System / 1st
73	C5S04-X1	C5/S4	C5S04,12	1756-IF16-12	AI	-	Spare	Spare_AI_0	3-25-01-913-PD-02	Spare I/O Point	LPG System / 1st
74	C5S04-X1	C5/S4	C5S04,13	1756-IF16-13	AI	-	Spare	Spare_AI_0	3-25-01-913-PD-02	Spare I/O Point	LPG System / 1st
75	C5S04-X1	C5/S4	C5S04,14	1756-IF16-14	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
76	C5S04-X1	C5/S4	C5S04,15	1756-IF16-15	AI	-	Spare	Spare_AI_0	-	Spare I/O Point	-
77	C5S01-X1	C5/S1	C5S01,14	1756-IB32-14	DI	Dry Contact	XA-80305A	XA-80305A_DI_1	325-01-803-PD-02	0	LPG System / 1st
78	C5S01-X1	C5/S1	C5S01,15	1756-IB32-15	DI	Dry Contact	XA-80305B	XA-80305B_DI_1	325-01-803-PD-02	0	LPG System / 1st
79	C5S01-X2	C5/S1	C5S01,16	1756-IB32-16	DI	Dry Contact	XA-80305C	XA-80305C_DI_1	325-01-803-PD-02	0	LPG System / 1st
80	C5S01-X2	C5/S1	C5S01,17	1756-IB32-17	DI	Dry Contact	XA-80305D	XA-80305D_DI_1	325-01-803-PD-02	0	LPG System / 1st
81	C5S01-X2	C5/S1	C5S01,18	1756-IB32-18	DI	Dry Contact	XA-80305E	XA-80305E_DI_1	325-01-803-PD-02	0	LPG System / 1st
82	C5S01-X2	C5/S1	C5S01,19	1756-IB32-19	DI	Dry Contact	XA-80305F	XA-80305F_DI_1	325-01-803-PD-02	0	LPG System / 1st
83	C5S01-X2	C5/S1	C5S01,20	1756-IB32-20	DI	Dry Contact	XA-80306A	XA-80306A_DI_1	325-01-803-PD-02	0	LPG System / 1st
84	C5S01-X2	C5/S1	C5S01,21	1756-IB32-21	DI	Dry Contact	XA-80306B	XA-80306B_DI_1	325-01-803-PD-02	0	LPG System / 1st
85	C5S01-X2	C5/S1	C5S01,22	1756-IB32-22	DI	Dry Contact	XA-80306C	XA-80306C_DI_1	325-01-803-PD-02	0	LPG System / 1st
86	C5S01-X2	C5/S1	C5S01,23	1756-IB32-23	DI	Dry Contact	XA-80306D	XA-80306D_DI_1	325-01-803-PD-02	0	LPG System / 1st
87	C5S01-X2	C5/S1	C5S01,24	1756-IB32-24	DI	Dry Contact	XA-80306E	XA-80306E_DI_1	325-01-803-PD-02	0	LPG System / 1st
88	C5S01-X2	C5/S1	C5S01,25	1756-IB32-25	DI	Dry Contact	XA-80306F	XA-80306F_DI_1	325-01-803-PD-02	0	LPG System / 1st
89	C5S03-X1	C5/S3	C5S03,00	1756-OB32-0	DO	4 - 20 mA	XA-92201	XA-92201_DO_1	3-25-01-922-PD-03	0	Boiler System / 1st
90	C5S04-X1	C5/S4	C5S04,07	1756-IF16-7	AI	4 - 20 mA	XT-92201	XT-92201_AI_1	3-25-01-922-PD-03	0	Boiler System / 1st
91	C5S01-X2	C5/S1	C5S01,26	1756-IB32-26	DI	24 VDC energized	XV-20201	XV-20201_DI_1	3-25-01-202-PD-01	0	Slurry - Out Buildi...
92	C5S01-X2	C5/S1	C5S01,27	1756-IB32-27	DI	24 VDC energized	XV-20201	XV-20201_DI_2	3-25-01-202-PD-01	0	Slurry - Out Buildi...
93	C5S03-X1	C5/S3	C5S03,01	1756-OB32-1	DO	24 VDC energized	XV-20201	XV-20201_DO_1	3-25-01-202-PD-01	0	Slurry - Out Buildi...

ENCLOSURE: RIO-200 | TYPE: Remote I/O Enclosure (RIO Panel) | LOCATION: Slurry - Out Building 2nd Floor | SIZE: 800-1000-400 mm

SUMMARY: Total Channels: 112 | Active: 57 | Spare: 55 (49.1%) | DI: 64 | DO: 32 | AI: 16 | AO: 0 | BUS: 0

No.	Terminal	Rack/Slot	Channel	I/O Module	Type	Signal Characteristic	Instrument Tag	PLC Tag Name	P&ID No.	Service / Equipment Description	Zone / Floor
94	C5S01-X2	C5/S1	C5S01,28	1756-IB32-28	DI	24 VDC energized	XV-20202	XV-20202_DI_1	3-25-01-202-PD-01	0	Slurry - Out Buildi...
95	C5S01-X2	C5/S1	C5S01,29	1756-IB32-29	DI	24 VDC energized	XV-20202	XV-20202_DI_2	3-25-01-202-PD-01	0	Slurry - Out Buildi...
96	C5S03-X1	C5/S3	C5S03,02	1756-OB32-2	DO	24 VDC energized	XV-20202	XV-20202_DO_1	3-25-01-202-PD-01	0	Slurry - Out Buildi...
97	C5S01-X2	C5/S1	C5S01,30	1756-IB32-30	DI	24 VDC energized	XV-20203	XV-20203_DI_1	3-25-01-202-PD-01	0	Slurry - Out Buildi...
98	C5S01-X2	C5/S1	C5S01,31	1756-IB32-31	DI	24 VDC energized	XV-20203	XV-20203_DI_2	3-25-01-202-PD-01	0	Slurry - Out Buildi...
99	C5S03-X1	C5/S3	C5S03,03	1756-OB32-3	DO	24 VDC energized	XV-20203	XV-20203_DO_1	3-25-01-202-PD-01	0	Slurry - Out Buildi...
100	C5S02-X1	C5/S2	C5S02,00	1756-IB32-0	DI	24 VDC energized	XV-20211	XV-20211_DI_1	3-25-01-202-PD-01	0	Slurry - Out Buildi...
101	C5S02-X1	C5/S2	C5S02,01	1756-IB32-1	DI	24 VDC energized	XV-20211	XV-20211_DI_2	3-25-01-202-PD-01	0	Slurry - Out Buildi...
102	C5S03-X1	C5/S3	C5S03,04	1756-OB32-4	DO	24 VDC energized	XV-20211	XV-20211_DO_1	3-25-01-202-PD-01	0	Slurry - Out Buildi...
103	C5S02-X1	C5/S2	C5S02,02	1756-IB32-2	DI	24 VDC energized	XV-20212	XV-20212_DI_1	3-25-01-202-PD-01	0	Slurry - Out Buildi...
104	C5S02-X1	C5/S2	C5S02,03	1756-IB32-3	DI	24 VDC energized	XV-20212	XV-20212_DI_2	3-25-01-202-PD-01	0	Slurry - Out Buildi...
105	C5S03-X1	C5/S3	C5S03,05	1756-OB32-5	DO	24 VDC energized	XV-20212	XV-20212_DO_1	3-25-01-202-PD-01	0	Slurry - Out Buildi...
106	C5S02-X1	C5/S2	C5S02,04	1756-IB32-4	DI	24 VDC energized	XV-20213	XV-20213_DI_1	3-25-01-202-PD-01	0	Slurry - Out Buildi...
107	C5S02-X1	C5/S2	C5S02,05	1756-IB32-5	DI	24 VDC energized	XV-20213	XV-20213_DI_2	3-25-01-202-PD-01	0	Slurry - Out Buildi...
108	C5S03-X1	C5/S3	C5S03,06	1756-OB32-6	DO	24 VDC energized	XV-20213	XV-20213_DO_1	3-25-01-202-PD-01	0	Slurry - Out Buildi...
109	C5S02-X1	C5/S2	C5S02,06	1756-IB32-6	DI	24 VDC energized	XV-913201	XV-913201_DI_1	3-25-01-913-PD-02	0	LPG System / 1st
110	C5S02-X1	C5/S2	C5S02,07	1756-IB32-7	DI	24 VDC energized	XV-913201	XV-913201_DI_1	3-25-01-913-PD-02	0	LPG System / 1st
111	C5S03-X1	C5/S3	C5S03,07	1756-OB32-7	DO	24 VDC energized	XV-913201	XV-913201_DO_1	3-25-01-913-PD-02	0	LPG System / 1st
112	C5S04-X1	C5/S4	C5S04,08	1756-IF16-8	AI	24 VDC energized	XV-913201	XV-913201_AI_1	3-25-01-913-PD-02	0	LPG System / 1st