

A

B

C

D

E

F

MAJOR HARDWARE BILL OF MATERIALS (BOM) - ENCLOSURES, PLC HARDWARE & ACCESSORIES								
Item	Part Number / Catalog	Manufacturer	Component Description	Installed Location	Qty	Spare Qty	Technical Specifications / Ratings	Remarks
1	VX 8806.500	Rittal	Industrial Bayed Enclosure Suite (4 bays)	M1, M2, M3, M4	4	-	800x2000x800 mm, IP54, Sheet Steel RAL 7035	Complete with side panels &
2	1756-A13	Rockwell Automation	ControlLogix 13-Slot Chassis	M1, M2, M3, M4	4	-	Standard backplane, horizontal mounting	Chassis C1, C2, C3, C4
3	1756-PA72	Rockwell Automation	ControlLogix Power Supply	M1, M2, M3, M4	4	1	85-265V AC, 72W output @ 60 deg C	One supply per chassis
4	1756-L950TPSXT	Rockwell Automation	ControlLogix 5580 Controller	Panel M1 (C1S01)	1	1	Extreme environment, 50MB memory, 1Gbps ETH	Master Plant Controller
5	1756-EN2TR	Rockwell Automation	EtherNet/IP Dual-Port DLR Comm Module	M2, M3, M4	3	1	10/100 Mbps, 128 TCP connections, DLR ring	I/O Remote Adapter modules
6	1756-IB32	Rockwell Automation	32-Point 24VDC Digital Input Module	M1, M2, M3, M4	14	2	24VDC Sink/Source, 10-31.2VDC, Isolated groups	544 total DI channels availa
7	1756-OB32	Rockwell Automation	32-Point 24VDC Digital Output Module	M1, M2, M3, M4	7	1	24VDC Source, 10-31.2VDC, 0.5A per point	224 total DO channels availa
8	1756-IF16	Rockwell Automation	16-Point Analog Input Module	M1, M2, M3, M4	11	1	Current / Voltage (4-20mA, 0-10V), 16-bit resolution	176 total AI channels availa
9	1756-OF8	Rockwell Automation	8-Point Analog Output Module	Panel M3 (C3S13)	1	1	Current / Voltage (4-20mA, 0-10V), 15-bit resolution	8 total AO channels availabl
10	1756-N2	Rockwell Automation	ControlLogix Slot Filler Plate	M1, M3, M4	17	-	Chassis slot cover plate for dust/cooling protection	Covers unpopulated slots
11	QUINT4-PS/1AC/24DC/20	Phoenix Contact	Primary Switched Redundant 24VDC Power Supply	Panel M1	2	1	Input 100-240VAC, Output 24VDC 20A, SFB Technology	Primary/Secondary Redundant
12	QUINT4-DIODE/40	Phoenix Contact	Diode Redundancy Module	Panel M1	1	-	Redundancy decoupling module 2x 20A / 1x 40A	Decouples PS1 & PS2
13	Stratix 5700	Rockwell Automation	Industrial Managed Ethernet Switch	Panel M1	1	-	16 Ports 10/100 Mbps, DLR, CIP Sync, VLAN support	Panel Network Backbone
14	KFD2-STC4-Ex1	Pepperl+Fuchs	Intrinsically Safe SMART Transmitter Isolator	Panel M3, M4	38	5	Ex-ia IIC, 4-20mA current repeater with HART support	For IS-JB-603, 608, 612, 618
15	KFD2-SL2-Ex2	Pepperl+Fuchs	Intrinsically Safe Digital Switch Isolator	Panel M3, M4	46	6	Ex-ia IIC, Dual-channel dry contact / NAMUR sensor	For IS Level & Limit Switche
16	Finder 38.51	Finder	Interposing Relay Module (DO Isolation)	M1, M2, M3, M4	120	15	24VDC Coil, 1 CO 6A contact, LED indicator	DIN Rail mount relay interfa
17	WDU 2.5 / WDU 4	Weidmuller	Feed-Through Terminal Blocks (Gray)	M1, M2, M3, M4	950	100	800V, 24A, Screw connection, multi-tier	Standard Field Wiring
18	WDU 2.5 BL	Weidmuller	Intrinsically Safe Terminal Blocks (Blue)	Panel M3, M4	320	50	Ex-i Blue colored terminal blocks for hazardous area	IS Field Wiring Only
19	SK 3328.540	Rittal	Roof Mounted Cooling Unit / Fans	M1, M2, M3, M4	4	-	230V, 50/60Hz, 1500W cooling capacity / high flow	Temperature maintenance < 35

INGREDION (THAILAND) CO., LTD. KALASIN STARCH PLANT - JET COOKER PROJECT				AEC INDUSTRIAL ENGINEERING SYSTEMS INTEGRATION & AUTOMATION	
4-PANEL SUITE - COMPLETE BILL OF MATERIALS (BOM) & SPECIFICATION MAIN CONTROL CABINET CA1 / MOTOR CONTROL PANELS M1...M4				DOC NO: CA1-DWG-PL-007 REV: 3.6	DATE: 2026-09-07
SCALE: N/A	DRAWN: AEC-ENG		STATUS:		SHEET:
PROJECT: JET COOKER	CHECKED: LEAD-PE		APPROVED		7 / 7

A

B

C

D

E

F