


TEMPLATE TYP-05: DIFF. PRESSURE TRANSMITTER

TYPICAL TAGS: DPT-60201 / DPT-60901

SERVICE: Filter Differential Pressure / Orifice Flow Drop | PLC I/O: 1756-IF16 (16-Point Diff Analog Input)


SECTION A: PROCESS PIPING & MECHANICAL HOOK-UP



MECHANICAL HOOK-UP SPECIFICATION

Process Connection:	1/4" NPT Female w/ 5-Valve M..
Mounting Type:	Direct Flanged / 2" Pipe Stand
Enclosure Rating:	NEMA 4X / IP66/68 Dual-Compa..
Hazardous Class:	ATEX II 1/2G Ex ia IIC T6 Ga..
Process Medium:	Starch Slurry / Saturated St..
Ambient Temp Range:	-20°C to +60°C Operating

SECTION B: ELECTRICAL LOOP WIRING SCHEMATIC (FIELD TO PLC)



ELECTRICAL & SIGNAL LOOP SPECIFICATIONS

Signal Protocol:	4-20mA HART Process Delta-P (0-500 mbar)
Power Supply:	24V DC via 1756-IF16 Analog Input Loop
Field Cable Type:	1Px1.5mm ² Twisted Shielded (Belden 876..
Destination JB:	JB-602 / IS-JB-603
Marshalling Cabinet:	CA1 / Master Control Panel (Bay M1..M4)
Barrier / Isolation:	937THAITXPDC1 (IS Repeater Barrier)
PLC Module:	1756-IF16 (16-Point Diff Analog Input)

SECTION C: BILL OF MATERIALS (BOM) & NOTES

MANUFACTURER: ENDRESS+HAUSER

MODEL: Deltabar PMD55B (Piezoresistive / Ceramic)

SERVICE: Filter Differential Pressure / Orifice Flow Drop

ITEM	MATERIAL / COMPONENT DESCRIPTION	SPEC / MODEL	QTY
1	Deltabar PMD55B Transmitter E+H Ceramic / SS316 Diaphragm		1 EA
2	5-Valve Manifold DA63M (Flange SS316 Integrated Bleed Valves		1 EA
3	2" Pipe Mounting Bracket Kit SS304 Stanchion Bracket & U-Bolt		1 SET
4	Cable Gland M20x1.5 Ex d/e IP6 Nickel-Plated Brass Armored Glan		1 EA
5	Impulse Tubing 1/2" OD x 0.049 ASTM A269 Seamless SS316		AR

ENGINEERING INSTALLATION NOTES

- Mount transmitter below process tapping points for liquid service to maintain filled impulse lines.
- 5-valve manifold sequence: Open equalizing, open HP & LP blocks, close equalizing, check zero.
- Connect 2-wire loop to PLC 1756-IF16 terminals: (+) to 24V loop power, (-) to Channel Input.

INGREDION (THAILAND) CO., LTD.
KALASIN STARCH PLANT - JET COOKER PROJECTAEC INDUSTRIAL ENGINEERING
SYSTEMS INTEGRATION & AUTOMATIONDIFFERENTIAL PRESSURE TRANSMITTER HOOK-UP & LOOP DIAGRAM
INSTRUMENT HOOK-UP & TYPICAL LOOP DIAGRAMDWG NO: KAL-JC-TYP-005
REV: 3.6 DATE: 2026-09-08DRAWN: AEC-ENG
CHECKED: LEAD-PESTATUS: APPROVED
SCALE: N.T.S.PROJECT NO:
R5THS00138-JCSHEET NO:
07 / 25