

MODULE: 1756-IB32 CHASSIS: C1 SLOT: 6 TYPE: DI TERMINAL STRIP: C1S06-X1 POINTS: 32								RATING: 24V DC SINK/SOURCE PANEL: CA1 / MOTOR CONTROL							
PT	PLC ADDR	TB PIN	INTERNAL / BARRIER		FIELD DEST	TAG NUMBER	SERVICE / INSTRUMENT DESCRIPTION	PT	PLC ADDR	TB PIN	INTERNAL / BARRIER		FIELD DEST	TAG NUMBER	SERVICE / INSTRUMENT DESCRIPTION
01	C1S06,01	X1:02		FUSE 1492-JD3FB (1A)	JB-601	XA-60202B	General Fault Controlled Stop for XSUP-5.. P&ID: 325-01-600-PD-08	17	C1S06,17	X1:18		FUSE 1492-JD3FB (1A)	JB-601	XV-60240D	Instrument XV-60240D P&ID: 325-01-600-PD-05
02	C1S06,02	X1:03		FUSE 1492-JD3FB (1A)	JB-601	XA-60202C	General Armed Status Indicator for XSUP-.. P&ID: 325-01-600-PD-08	18	C1S06,18	X1:19		FUSE 1492-JD3FB (1A)	JB-601	XV-60240D	Instrument XV-60240D P&ID: 325-01-600-PD-08
03	C1S06,03	X1:04		FUSE 1492-JD3FB (1A)	JB-601	XA-60202D	Power Fault Status Indicator for XSUP-56.. P&ID: 325-01-600-PD-08	19	C1S06,19	X1:20		FUSE 1492-JD3FB (1A)	JB-601	XV-60240D	Instrument XV-60240D P&ID: 325-01-600-PD-05
04	C1S06,04	X1:05		FUSE 1492-JD3FB (1A)	JB-601	XA-60202E	Dryer CHAM-21 Emergency Stop Actuation f.. P&ID: 325-01-600-PD-08	20	C1S06,20	X1:21		FUSE 1492-JD3FB (1A)	JB-601	XV-60240D	Instrument XV-60240D P&ID: 325-01-600-PD-08
05	C1S06,05	X1:06		FUSE 1492-JD3FB (1A)	JB-601	XA-60202F	CHAM-21 Controlled Stop Trouble (No Prot.. P&ID: 325-01-600-PD-08	21	C1S06,21	X1:22		FUSE 1492-JD3FB (1A)	JB-601	YA-60205	Fault Command P&ID: 325-01-600-PD-01
06	C1S06,06	X1:07		FUSE 1492-JD3FB (1A)	JB-601	XA-60202G	CYCL-21/22 Emergency Stop Actuation for .. P&ID: 325-01-600-PD-08	22	C1S06,22	X1:23		FUSE 1492-JD3FB (1A)	JB-601	YI-60205	Run Command P&ID: 325-01-600-PD-01
07	C1S06,07	X1:08		FUSE 1492-JD3FB (1A)	JB-601	XA-60202H	CYCL-21/22 Controlled Stop Trouble (No P.. P&ID: 325-01-600-PD-08	23	C1S06,23	X1:24		FUSE 1492-JD3FB (1A)	JB-601	SPARE	Spare I/O Channel
08	C1S06,08	X1:09		FUSE 1492-JD3FB (1A)	JB-601	XA-60202I	Instrument XA-60202I P&ID: 325-01-600-PD-08	24	C1S06,24	X1:25		FUSE 1492-JD3FB (1A)	JB-601	SPARE	Spare I/O Channel
09	C1S06,09	X1:10		FUSE 1492-JD3FB (1A)	JB-601	XA-60202J	BGHS-21 Emergency Stop Actuation for XSU.. P&ID: 325-01-600-PD-08	25	C1S06,25	X1:26		FUSE 1492-JD3FB (1A)	JB-601	SPARE	Spare I/O Channel
10	C1S06,10	X1:11		FUSE 1492-JD3FB (1A)	JB-601	XA-60202K	BGHS-21 Controlled Stop Trouble (No Prot.. P&ID: 325-01-600-PD-08	26	C1S06,26	X1:27		FUSE 1492-JD3FB (1A)	JB-601	SPARE	Spare I/O Channel
11	C1S06,11	X1:12		FUSE 1492-JD3FB (1A)	JB-601	XA-60202L	CYCL-31 Emergency Stop Actuation for XSU.. P&ID: 325-01-600-PD-08	27	C1S06,27	X1:28		FUSE 1492-JD3FB (1A)	JB-601	SPARE	Spare I/O Channel
12	C1S06,12	X1:13		FUSE 1492-JD3FB (1A)	JB-601	XA-60202M	CYCL-31 Controlled Stop Trouble (No Prot.. P&ID: 325-01-600-PD-08	28	C1S06,28	X1:29		FUSE 1492-JD3FB (1A)	JB-601	SPARE	Spare I/O Channel
13	C1S06,13	X1:14		FUSE 1492-JD3FB (1A)	JB-601	XV-60202	High Pressure Water On/Off Valve for Dra.. P&ID: 325-01-600-PD-11	29	C1S06,29	X1:30		FUSE 1492-JD3FB (1A)	JB-601	SPARE	Spare I/O Channel
14	C1S06,14	X1:15		FUSE 1492-JD3FB (1A)	JB-601	XV-60202	High Pressure Water On/Off Valve for Dra.. P&ID: 325-01-600-PD-11	30	C1S06,30	X1:31		FUSE 1492-JD3FB (1A)	JB-601	SPARE	Spare I/O Channel
15	C1S06,15	X1:16		FUSE 1492-JD3FB (1A)	JB-601	XV-60205A	Cooling Water On/Off Valve for Cooling W.. P&ID: 325-01-600-PD-01	31	C1S06,31	X1:32		FUSE 1492-JD3FB (1A)	JB-601	SPARE	Spare I/O Channel
16	C1S06,16	X1:17		FUSE 1492-JD3FB (1A)	JB-601	XV-60205A	Cooling Water On/Off Valve for Cooling W.. P&ID: 325-01-600-PD-01		C1S06,00	X1:--		FUSE 1492-JD3FB (1A)	JB-601	XA-60202A	General Alarm Emergency Stop Actuation f.. P&ID: 325-01-600-PD-08
INGREDION (THAILAND) CO., LTD. KALASIN STARCH PLANT - JET COOKER PROJECT								AEC INDUSTRIAL ENGINEERING SYSTEMS INTEGRATION & AUTOMATION							
CHASSIS C1 SLOT 6 - 1756-IB32 (DI) WIRING SCHEMATIC MAIN CONTROL CABINET CA1 / CONTROLLOGIX 1756								DWG NO: KAL-JC-WIR-20004 REV: 3.6 DATE: 2026-09-08							
DRAWN: AEC-ENG CHECKED: LEAD-PE				STATUS: APPROVED SCALE: N.T.S.				PROJECT NO: R5THS00138-JC		SHEET NO: 07 / 40					