

MODULE: 1756-OB32 CHASSIS: C2 SLOT: 7 TYPE: DO TERMINAL STRIP: C2S07-X1 POINTS: 32								RATING: 24V DC SINK/SOURCE PANEL: CA1 / MOTOR CONTROL							
PT	PLC ADDR	TB PIN		INTERNAL / BARRIER	FIELD DEST	TAG NUMBER	SERVICE / INSTRUMENT DESCRIPTION	PT	PLC ADDR	TB PIN		INTERNAL / BARRIER	FIELD DEST	TAG NUMBER	SERVICE / INSTRUMENT DESCRIPTION
01	C2S07,01	X1:02		RELAY 700-HL (24VDC)	JB-607	XS-FH-60210C	Command Remote Reset for AHTR-21 P&ID: 325-01-600-PD-06	17	C2S07,17	X1:18		RELAY 700-HL (24VDC)	JB-607	XV-60262FH	Feed Slurry On/Off Valve for Nozzle #8 (.. P&ID: 325-01-600-PD-02
02	C2S07,02	X1:03		RELAY 700-HL (24VDC)	JB-607	XS-FH-60210D	Spare P&ID: 325-01-600-PD-06	18	C2S07,18	X1:19		RELAY 700-HL (24VDC)	JB-607	XV-60262SE	Steam On/Off Valve for Nozzle #5 (ATVM-1.. P&ID: 325-01-600-PD-02
03	C2S07,03	X1:04		RELAY 700-HL (24VDC)	JB-607	XV-60201	Steam feed to Spray dryer P&ID: 325-01-600-PD-02	19	C2S07,19	X1:20		RELAY 700-HL (24VDC)	JB-607	XV-60262SF	Steam On/Off Valve for Nozzle #6 (ATVM-1.. P&ID: 325-01-600-PD-02
04	C2S07,04	X1:05		RELAY 700-HL (24VDC)	JB-607	XV-60261	Instrument XV-60261 P&ID: 325-01-600-PD-02	20	C2S07,20	X1:21		RELAY 700-HL (24VDC)	JB-607	XV-60262SG	Steam On/Off Valve for Nozzle #7 (ATVM-1.. P&ID: 325-01-600-PD-02
05	C2S07,05	X1:06		RELAY 700-HL (24VDC)	JB-607	XV-60261FA	Feed Slurry On/Off Valve for Nozzle #1 (.. P&ID: 325-01-600-PD-02	21	C2S07,21	X1:22		RELAY 700-HL (24VDC)	JB-607	XV-60262SH	Steam On/Off Valve for Nozzle #8 (ATVM-1.. P&ID: 325-01-600-PD-02
06	C2S07,06	X1:07		RELAY 700-HL (24VDC)	JB-607	XV-60261FB	Feed Slurry On/Off Valve for Nozzle #2 (.. P&ID: 325-01-600-PD-02	22	C2S07,22	X1:23		RELAY 700-HL (24VDC)	JB-607	XV-60263	Instrument XV-60263 P&ID: 325-01-600-PD-02
07	C2S07,07	X1:08		RELAY 700-HL (24VDC)	JB-607	XV-60261FC	Feed Slurry On/Off Valve for Nozzle #3 (.. P&ID: 325-01-600-PD-02	23	C2S07,23	X1:24		RELAY 700-HL (24VDC)	JB-607	XV-60263FJ	Feed Slurry On/Off Valve for Nozzle #9 (.. P&ID: 325-01-600-PD-02
08	C2S07,08	X1:09		RELAY 700-HL (24VDC)	JB-607	XV-60261FD	Feed Slurry On/Off Valve for Nozzle #4 (.. P&ID: 325-01-600-PD-02	24	C2S07,24	X1:25		RELAY 700-HL (24VDC)	JB-607	XV-60263FK	Feed Slurry On/Off Valve for Nozzle #10 .. P&ID: 325-01-600-PD-02
09	C2S07,09	X1:10		RELAY 700-HL (24VDC)	JB-607	XV-60261SA	Steam On/Off Valve for Nozzle #1 (ATVM-1.. P&ID: 325-01-600-PD-02	25	C2S07,25	X1:26		RELAY 700-HL (24VDC)	JB-607	XV-60263FL	Feed Slurry On/Off Valve for Nozzle #11 .. P&ID: 325-01-600-PD-02
10	C2S07,10	X1:11		RELAY 700-HL (24VDC)	JB-607	XV-60261SB	Steam On/Off Valve for Nozzle #2 (ATVM-1.. P&ID: 325-01-600-PD-02	26	C2S07,26	X1:27		RELAY 700-HL (24VDC)	JB-607	XV-60263FM	Feed Slurry On/Off Valve for Nozzle #12 .. P&ID: 325-01-600-PD-02
11	C2S07,11	X1:12		RELAY 700-HL (24VDC)	JB-607	XV-60261SC	Steam On/Off Valve for Nozzle #3 (ATVM-1.. P&ID: 325-01-600-PD-02	27	C2S07,27	X1:28		RELAY 700-HL (24VDC)	JB-607	XV-60263SJ	Steam On/Off Valve for Nozzle #9 (ATVM-1.. P&ID: 325-01-600-PD-02
12	C2S07,12	X1:13		RELAY 700-HL (24VDC)	JB-607	XV-60261SD	Steam On/Off Valve for Nozzle #4 (ATVM-1.. P&ID: 325-01-600-PD-02	28	C2S07,28	X1:29		RELAY 700-HL (24VDC)	JB-607	XV-60263SK	Steam On/Off Valve for Nozzle #10 (ATVM-.. P&ID: 325-01-600-PD-02
13	C2S07,13	X1:14		RELAY 700-HL (24VDC)	JB-607	XV-60262	Instrument XV-60262 P&ID: 325-01-600-PD-02	29	C2S07,29	X1:30		RELAY 700-HL (24VDC)	JB-607	XV-60263SL	Steam On/Off Valve for Nozzle #11 (ATVM-.. P&ID: 325-01-600-PD-02
14	C2S07,14	X1:15		RELAY 700-HL (24VDC)	JB-607	XV-60262FE	Feed Slurry On/Off Valve for Nozzle #5 (.. P&ID: 325-01-600-PD-02	30	C2S07,30	X1:31		RELAY 700-HL (24VDC)	JB-607	XV-60263SM	Steam On/Off Valve for Nozzle #12 (ATVM-.. P&ID: 325-01-600-PD-02
15	C2S07,15	X1:16		RELAY 700-HL (24VDC)	JB-607	XV-60262FF	Feed Slurry On/Off Valve for Nozzle #6 (.. P&ID: 325-01-600-PD-02	31	C2S07,31	X1:32		RELAY 700-HL (24VDC)	JB-607	SPARE	Spare I/O Channel
16	C2S07,16	X1:17		RELAY 700-HL (24VDC)	JB-607	XV-60262FG	Feed Slurry On/Off Valve for Nozzle #7 (.. P&ID: 325-01-600-PD-02		C2S07,00	X1:--		RELAY 700-HL (24VDC)	JB-607	SV-60207	Instr. Air On/Off Valve for Camera #4 (A.. P&ID: 325-01-600-PD-07
INGREDION (THAILAND) CO., LTD. KALASIN STARCH PLANT - JET COOKER PROJECT												AEC INDUSTRIAL ENGINEERING SYSTEMS INTEGRATION & AUTOMATION			
CHASSIS C2 SLOT 7 - 1756-OB32 (DO) WIRING SCHEMATIC MAIN CONTROL CABINET CA1 / CONTROLLOGIX 1756												DWG NO: KAL-JC-WIR-20015 REV: 3.6 DATE: 2026-09-08			
DRAWN: AEC-ENG CHECKED: LEAD-PE						STATUS: APPROVED SCALE: N.T.S.						PROJECT NO: R5THS00138-JC		SHEET NO: 18 / 40	