

MODULE: 1756-OB32 CHASSIS: C2 SLOT: 8 TYPE: DO TERMINAL STRIP: C2S08-X1 POINTS: 32								RATING: 24V DC SINK/SOURCE PANEL: CA1 / MOTOR CONTROL							
PT	PLC ADDR	TB PIN		INTERNAL / BARRIER	FIELD DEST	TAG NUMBER	SERVICE / INSTRUMENT DESCRIPTION	PT	PLC ADDR	TB PIN		INTERNAL / BARRIER	FIELD DEST	TAG NUMBER	SERVICE / INSTRUMENT DESCRIPTION
01	C2S08,01	X1:02		RELAY 700-HL (24VDC)	JB-607	XV-60264FN	Feed Slurry On/Off Valve for Nozzle #13 .. P&ID: 325-01-600-PD-02	17	C2S08,17	X1:18		RELAY 700-HL (24VDC)	JB-607	SPARE	Spare I/O Channel
02	C2S08,02	X1:03		RELAY 700-HL (24VDC)	JB-607	XV-60264FP	Feed Slurry On/Off Valve for Nozzle #14 .. P&ID: 325-01-600-PD-02	18	C2S08,18	X1:19		RELAY 700-HL (24VDC)	JB-607	SPARE	Spare I/O Channel
03	C2S08,03	X1:04		RELAY 700-HL (24VDC)	JB-607	XV-60264FQ	Feed Slurry On/Off Valve for Nozzle #15 .. P&ID: 325-01-600-PD-02	19	C2S08,19	X1:20		RELAY 700-HL (24VDC)	JB-607	SPARE	Spare I/O Channel
04	C2S08,04	X1:05		RELAY 700-HL (24VDC)	JB-607	XV-60264FR	Feed Slurry On/Off Valve for Nozzle #16 .. P&ID: 325-01-600-PD-02	20	C2S08,20	X1:21		RELAY 700-HL (24VDC)	JB-607	SPARE	Spare I/O Channel
05	C2S08,05	X1:06		RELAY 700-HL (24VDC)	JB-607	XV-60264SN	Steam On/Off Valve for Nozzle #13 (ATVM-.. P&ID: 325-01-600-PD-02	21	C2S08,21	X1:22		RELAY 700-HL (24VDC)	JB-607	SPARE	Spare I/O Channel
06	C2S08,06	X1:07		RELAY 700-HL (24VDC)	JB-607	XV-60264SP	Steam On/Off Valve for Nozzle #14 (ATVM-.. P&ID: 325-01-600-PD-02	22	C2S08,22	X1:23		RELAY 700-HL (24VDC)	JB-607	SPARE	Spare I/O Channel
07	C2S08,07	X1:08		RELAY 700-HL (24VDC)	JB-607	XV-60264SQ	Steam On/Off Valve for Nozzle #15 (ATVM-.. P&ID: 325-01-600-PD-02	23	C2S08,23	X1:24		RELAY 700-HL (24VDC)	JB-607	SPARE	Spare I/O Channel
08	C2S08,08	X1:09		RELAY 700-HL (24VDC)	JB-607	XV-60264SR	Steam On/Off Valve for Nozzle #16 (ATVM-.. P&ID: 325-01-600-PD-02	24	C2S08,24	X1:25		RELAY 700-HL (24VDC)	JB-607	SPARE	Spare I/O Channel
09	C2S08,09	X1:10		RELAY 700-HL (24VDC)	JB-607	SPARE	Spare I/O Channel	25	C2S08,25	X1:26		RELAY 700-HL (24VDC)	JB-607	SPARE	Spare I/O Channel
10	C2S08,10	X1:11		RELAY 700-HL (24VDC)	JB-607	SPARE	Spare I/O Channel	26	C2S08,26	X1:27		RELAY 700-HL (24VDC)	JB-607	SPARE	Spare I/O Channel
11	C2S08,11	X1:12		RELAY 700-HL (24VDC)	JB-607	SPARE	Spare I/O Channel	27	C2S08,27	X1:28		RELAY 700-HL (24VDC)	JB-607	SPARE	Spare I/O Channel
12	C2S08,12	X1:13		RELAY 700-HL (24VDC)	JB-607	SPARE	Spare I/O Channel	28	C2S08,28	X1:29		RELAY 700-HL (24VDC)	JB-607	SPARE	Spare I/O Channel
13	C2S08,13	X1:14		RELAY 700-HL (24VDC)	JB-607	SPARE	Spare I/O Channel	29	C2S08,29	X1:30		RELAY 700-HL (24VDC)	JB-607	SPARE	Spare I/O Channel
14	C2S08,14	X1:15		RELAY 700-HL (24VDC)	JB-607	SPARE	Spare I/O Channel	30	C2S08,30	X1:31		RELAY 700-HL (24VDC)	JB-607	SPARE	Spare I/O Channel
15	C2S08,15	X1:16		RELAY 700-HL (24VDC)	JB-607	SPARE	Spare I/O Channel	31	C2S08,31	X1:32		RELAY 700-HL (24VDC)	JB-607	SPARE	Spare I/O Channel
16	C2S08,16	X1:17		RELAY 700-HL (24VDC)	JB-607	SPARE	Spare I/O Channel		C2S08,00	X1:--		RELAY 700-HL (24VDC)	JB-607	XV-60264	Instrument XV-60264 P&ID: 325-01-600-PD-02
INGREDION (THAILAND) CO., LTD. KALASIN STARCH PLANT - JET COOKER PROJECT												AEC INDUSTRIAL ENGINEERING SYSTEMS INTEGRATION & AUTOMATION			
CHASSIS C2 SLOT 8 - 1756-OB32 (DO) WIRING SCHEMATIC MAIN CONTROL CABINET CA1 / CONTROLLOGIX 1756												DWG NO: KAL-JC-WIR-20016 REV: 3.6 DATE: 2026-09-08			
DRAWN: AEC-ENG CHECKED: LEAD-PE						STATUS: APPROVED SCALE: N.T.S.						PROJECT NO: R5THS00138-JC		SHEET NO: 19 / 40	