

MODULE: 1756-IF16 CHASSIS: C2 SLOT: 10 TYPE: AI TERMINAL STRIP: C2S10-X1 POINTS: 16							RATING: 4-20mA CURRENT LOOP (ISOLATED) PANEL: CA1 / MOTOR CONTROL	
PT	PLC ADDR	TB PIN	INTERNAL / BARRIER		FIELD DEST	TAG NUMBER	SERVICE / INSTRUMENT DESCRIPTION	
01	C2S10,01	X1:02		LOOP POWERED (2-W)	JB-602	DPT-60203	Gas Pressure Differential Transmitter f.. P&ID: 325-01-600-PD-03	
02	C2S10,02	X1:03		LOOP POWERED (2-W)	JB-602	FT-60202	Steam feed to Spray dryer P&ID: 325-01-600-PD-09	
03	C2S10,03	X1:04		LOOP POWERED (2-W)	JB-602	PT-60210	Gas Pressure Transmitter for Hot Air Duc.. P&ID: 325-01-600-PD-03	
04	C2S10,04	X1:05		LOOP POWERED (2-W)	JB-602	PT-60215	15% Polypropylene Glycol Pressure Indica.. P&ID: 325-01-600-PD-03	
05	C2S10,05	X1:06		LOOP POWERED (2-W)	JB-602	PT-60216	Gas Pressure Transmitter for Combustion .. P&ID: 325-01-600-PD-03	
06	C2S10,06	X1:07		LOOP POWERED (2-W)	JB-602	PT-60240	Gas Pressure Transmitter for Bag House E.. P&ID: 325-01-600-PD-05	
07	C2S10,07	X1:08		LOOP POWERED (2-W)	JB-602	PT-60241	Gas Pressure Transmitter for Exhaust Fan.. P&ID: 325-01-600-PD-05	
08	C2S10,08	X1:09		LOOP POWERED (2-W)	JB-602	TT-60210	Gas Temperature Element for Hot Air Duct.. P&ID: 325-01-600-PD-03	
09	C2S10,09	X1:10		LOOP POWERED (2-W)	JB-602	TT-60210A	Instrument TT-60210A P&ID: 325-01-600-PD-03	
10	C2S10,10	X1:11		LOOP POWERED (2-W)	JB-602	TT-60210B	Instrument TT-60210B P&ID: 325-01-600-PD-03	
11	C2S10,11	X1:12		LOOP POWERED (2-W)	JB-602	TT-60211	Gas Temperature Element for Hot Air Duct.. P&ID: 325-01-600-PD-03	
12	C2S10,12	X1:13		LOOP POWERED (2-W)	JB-602	TT-60212A	Bearing Temperature Transmitter for Main.. P&ID: 325-01-600-PD-03	
13	C2S10,13	X1:14		LOOP POWERED (2-W)	JB-602	TT-60212B	Bearing Temperature Transmitter for Main.. P&ID: 325-01-600-PD-03	
14	C2S10,14	X1:15		LOOP POWERED (2-W)	JB-602	TT-60214	Steam Temperature Transmitter for Cold A.. P&ID: 325-01-600-PD-03	
15	C2S10,15	X1:16		LOOP POWERED (2-W)	JB-602	TT-60215A	Liquid Temperature Transmitter for Heat .. P&ID: 325-01-600-PD-03	
	C2S10,00	X1:--		LOOP POWERED (2-W)	JB-602	AT-60241	Dust Analyzer Transmitter for Exhaust Du.. P&ID: 325-01-600-PD-05	

INGREDION (THAILAND) CO., LTD. KALASIN STARCH PLANT - JET COOKER PROJECT		AEC INDUSTRIAL ENGINEERING SYSTEMS INTEGRATION & AUTOMATION	
CHASSIS C2 SLOT 10 - 1756-IF16 (AI) WIRING SCHEMATIC MAIN CONTROL CABINET CA1 / CONTROLLOGIX 1756		DWG NO: KAL-JC-WIR-20018 REV: 3.6 DATE: 2026-09-08	
DRAWN: AEC-ENG CHECKED: LEAD-PE	STATUS: APPROVED SCALE: N.T.S.	PROJECT NO: R5THS00138-JC	SHEET NO: 21 / 40