MODULE: 1756-IF16 | CHASSIS: C2 | SLOT: 12 | TYPE: AI | TERMINAL STRIP: C2S12-X1 | POINTS: 16

RATING: 4-20mA CURRENT LOOP (ISOLATED) | PANEL: CA1 / MOTOR CONTROL

PT	PLC ADDR	TB PIN	INTERNAL / BARRIER	FIELD DEST	TAG NUMBER	SERVICE / INSTRUMENT DESCRIPTION
01	C2S12,01	**X1:02**	LOOP POWERED (2-W)	**JB-607**	**FT-60221**	Cool air Flow P&ID: 325-01-600-PD-04
02	C2S12,02	**X1:03**	LOOP POWERED (2-W)	**JB-607**	**FT-60261FA**	Feed Slurry Flow Transmitter for Nozzle .. P&ID: 325-01-600-PD-02
03	C2S12,03	**X1:04**	LOOP POWERED (2-W)	**JB-607**	**FT-60261FB**	Feed Slurry Flow Transmitter for Nozzle .. P&ID: 325-01-600-PD-02
04	C2S12,04	**X1:05**	LOOP POWERED (2-W)	**JB-607**	**FT-60261FC**	Feed Slurry Flow Transmitter for Nozzle .. P&ID: 325-01-600-PD-02
05	C2S12,05	**X1:06**	LOOP POWERED (2-W)	**JB-607**	**FT-60261FD**	Feed Slurry Flow Transmitter for Nozzle .. P&ID: 325-01-600-PD-02
06	C2S12,06	**X1:07**	LOOP POWERED (2-W)	**JB-607**	**FT-60262FE**	Feed Slurry Flow Transmitter for Nozzle .. P&ID: 325-01-600-PD-02
07	C2S12,07	**X1:08**	LOOP POWERED (2-W)	**JB-607**	**FT-60262FF**	Feed Slurry Flow Transmitter for Nozzle .. P&ID: 325-01-600-PD-02
08	C2S12,08	**X1:09**	LOOP POWERED (2-W)	**JB-607**	**FT-60262FG**	Feed Slurry Flow Transmitter for Nozzle .. P&ID: 325-01-600-PD-02
09	C2S12,09	**X1:10**	LOOP POWERED (2-W)	**JB-607**	**FT-60262FH**	Feed Slurry Flow Transmitter for Nozzle .. P&ID: 325-01-600-PD-02
10	C2S12,10	**X1:11**	LOOP POWERED (2-W)	**JB-607**	**FT-60263FJ**	Feed Slurry Flow Transmitter for Nozzle .. P&ID: 325-01-600-PD-02
11	C2S12,11	**X1:12**	LOOP POWERED (2-W)	**JB-607**	**FT-60263FK**	Feed Slurry Flow Transmitter for Nozzle .. P&ID: 325-01-600-PD-02
12	C2S12,12	**X1:13**	LOOP POWERED (2-W)	**JB-607**	**FT-60263FL**	Feed Slurry Flow Transmitter for Nozzle .. P&ID: 325-01-600-PD-02
13	C2S12,13	**X1:14**	LOOP POWERED (2-W)	**JB-607**	**FT-60263FM**	Feed Slurry Flow Transmitter for Nozzle .. P&ID: 325-01-600-PD-02
14	C2S12,14	**X1:15**	LOOP POWERED (2-W)	**JB-607**	**FT-60264FN**	Feed Slurry Flow Transmitter for Nozzle .. P&ID: 325-01-600-PD-02
15	C2S12,15	**X1:16**	LOOP POWERED (2-W)	**JB-607**	**FT-60264FP**	Feed Slurry Flow Transmitter for Nozzle .. P&ID: 325-01-600-PD-02
	C2S12,00	**X1:--**	LOOP POWERED (2-W)	**JB-607**	**FT-60207**	Instr. Air Flow Transmitter for Camera #.. P&ID: 325-01-600-PD-07

INGREDION (THAILAND) CO., LTD.
KALASIN STARCH PLANT - JET COOKER PROJECT

AEC INDUSTRIAL ENGINEERING
SYSTEMS INTEGRATION & AUTOMATION

CHASSIS C2 SLOT 12 - 1756-IF16 (AI) WIRING SCHEMATIC
MAIN CONTROL CABINET CA1 / CONTROLLOGIX 1756

DWG NO: KAL-JC-WIR-20020
REV: 3.6 DATE: 2026-09-08

DRAWN: AEC-ENG
CHECKED: LEAD-PE

STATUS: APPROVED
SCALE: N.T.S.

PROJECT NO: R5THS00138-JC

SHEET NO: 23 / 40