

MODULE: 1756-IF16 CHASSIS: C2 SLOT: 13 TYPE: AI TERMINAL STRIP: C2S13-X1 POINTS: 16							RATING: 4-20mA CURRENT LOOP (ISOLATED) PANEL: CA1 / MOTOR CONTROL	
PT	PLC ADDR	TB PIN	INTERNAL / BARRIER		FIELD DEST	TAG NUMBER	SERVICE / INSTRUMENT DESCRIPTION	
01	C2S13,01	X1:02		LOOP POWERED (2-W)	JB-607	FT-60264FR	Feed Slurry Flow Transmitter for Nozzle .. P&ID: 325-01-600-PD-02	
02	C2S13,02	X1:03		LOOP POWERED (2-W)	JB-607	PT-60201	Steam feed to Spray dryer P&ID: 3-25-01-602-PD-02	
03	C2S13,03	X1:04		LOOP POWERED (2-W)	JB-607	PT-60207	Instr. Air Pressure Transmitter for Came.. P&ID: 325-01-600-PD-07	
04	C2S13,04	X1:05		LOOP POWERED (2-W)	JB-607	PT-60221	Gas Pressure Transmitter for Cooling Air.. P&ID: 325-01-600-PD-02	
05	C2S13,05	X1:06		LOOP POWERED (2-W)	JB-607	PT-60221	Gas Pressure Transmitter for Cooling Air.. P&ID: 325-01-600-PD-04	
06	C2S13,06	X1:07		LOOP POWERED (2-W)	JB-607	TI-FH-60210	Gas Burner Firing Rate Temp Signal to AH.. P&ID: 325-01-600-PD-06	
07	C2S13,07	X1:08		LOOP POWERED (2-W)	JB-607	TT-60201	Steam feed to Spray dryer P&ID: 325-01-600-PD-02	
08	C2S13,08	X1:09		LOOP POWERED (2-W)	JB-607	TT-60202	Compress air temp to camera P&ID: 325-01-600-PD-07	
09	C2S13,09	X1:10		LOOP POWERED (2-W)	JB-607	TT-60207	Instr. Air Temperature Transmitter for A.. P&ID: 325-01-600-PD-07	
10	C2S13,10	X1:11		LOOP POWERED (2-W)	JB-607	UY-FH-60210A	Comb fan VFD Speed Control P&ID: 325-01-600-PD-06	
11	C2S13,11	X1:12		LOOP POWERED (2-W)	JB-607	SPARE	Spare I/O Channel	
12	C2S13,12	X1:13		LOOP POWERED (2-W)	JB-607	SPARE	Spare I/O Channel	
13	C2S13,13	X1:14		LOOP POWERED (2-W)	JB-607	SPARE	Spare I/O Channel	
14	C2S13,14	X1:15		LOOP POWERED (2-W)	JB-607	SPARE	Spare I/O Channel	
15	C2S13,15	X1:16		LOOP POWERED (2-W)	JB-607	SPARE	Spare I/O Channel	
	C2S13,00	X1:--		LOOP POWERED (2-W)	JB-607	FT-60264FQ	Feed Slurry Flow Transmitter for Nozzle .. P&ID: 325-01-600-PD-02	

INGREDION (THAILAND) CO., LTD. KALASIN STARCH PLANT - JET COOKER PROJECT		AEC INDUSTRIAL ENGINEERING SYSTEMS INTEGRATION & AUTOMATION	
CHASSIS C2 SLOT 13 - 1756-IF16 (AI) WIRING SCHEMATIC MAIN CONTROL CABINET CA1 / CONTROLLOGIX 1756		DWG NO: KAL-JC-WIR-20021 REV: 3.6 DATE: 2026-09-08	
DRAWN: AEC-ENG CHECKED: LEAD-PE	STATUS: APPROVED SCALE: N.T.S.	PROJECT NO: R5THS00138-JC	SHEET NO: 24 / 40