MODULE: 1756-IB32 | CHASSIS: C3 | SLOT: 2 | TYPE: DI | TERMINAL STRIP: C3S02-X1 | POINTS: 37

RATING: 24V DC SINK/SOURCE | PANEL: CA1 / MOTOR CONTROL

PT	PLC ADDR	TB PIN	INTERNAL / BARRIER	FIELD DEST	TAG NUMBER	SERVICE / INSTRUMENT DESCRIPTION
01	C3S02,01	X1:02	IS-BARRIER (937T)	IS-JB-618	LSH-61301	Level alarm high P&ID: 325-01-613-PD-01
02	C3S02,02	X1:03	IS-BARRIER (937T)	IS-JB-618	LSH-61303	Instrument LSH-61303 P&ID: 325-01-613-PD-01
03	C3S02,03	X1:04	IS-BARRIER (937T)	IS-JB-618	LSH-61306	Level alarm high P&ID: 325-01-613-PD-01
04	C3S02,04	X1:05	IS-BARRIER (937T)	IS-JB-618	LSH-61308	High Level alarm Cooling cyclone P&ID: 3-25-01-613-PD-01
05	C3S02,05	X1:06	IS-BARRIER (937T)	IS-JB-618	LSL-61302	Level alarm low P&ID: 325-01-613-PD-01
06	C3S02,06	X1:07	IS-BARRIER (937T)	IS-JB-618	PSE-61300	Explosion Vent PSE-61300 P&ID: 325-01-613-PD-01
07	C3S02,07	X1:08	IS-BARRIER (937T)	IS-JB-618	PSE-61301	Explosion Vent PSE-61301 P&ID: 325-01-613-PD-01
08	C3S02,08	X1:09	IS-BARRIER (937T)	IS-JB-618	PSE-61304	Explosion Vent PSE-61304 P&ID: 325-01-613-PD-01
09	C3S02,09	X1:10	IS-BARRIER (937T)	IS-JB-618	PSV-61301A	Position Brether Valve High Pressure PSV.. P&ID: 325-01-613-PD-01
10	C3S02,10	X1:11	IS-BARRIER (937T)	IS-JB-618	PSV-61301B	Position Brether Valve Vacuum Pressure P.. P&ID: 325-01-613-PD-01
11	C3S02,11	X1:12	IS-BARRIER (937T)	IS-JB-618	ZS-61310	Position Magnet Door P&ID: 325-01-613-PD-01
12	C3S02,12	X1:13	IS-BARRIER (937T)	IS-JB-618	ZS-61311	Position Magnet Door P&ID: 325-01-613-PD-01
13	C3S02,13	X1:14	IS-BARRIER (937T)	IS-JB-618	SPARE	*Spare I/O Channel* P&ID: 325-01-613-PD-01
14	C3S02,14	X1:15	IS-BARRIER (937T)	IS-JB-618	SPARE	*Spare I/O Channel* P&ID: 325-01-613-PD-01
15	C3S02,15	X1:16	IS-BARRIER (937T)	IS-JB-618	SPARE	*Spare I/O Channel* P&ID: 325-01-613-PD-01
16	C3S02,16	X1:17	IS-BARRIER (937T)	IS-JB-618	SPARE	*Spare I/O Channel* P&ID: 325-01-613-PD-01
17	C3S02,17	X1:18	IS-BARRIER (937T)	IS-JB-618	SPARE	*Spare I/O Channel* P&ID: 325-01-613-PD-01
18	C3S02,18	X1:19	IS-BARRIER (937T)	IS-JB-618	SPARE	*Spare I/O Channel* P&ID: 325-01-613-PD-01
19	C3S02,19	X1:20	IS-BARRIER (937T)	IS-JB-618	SPARE	*Spare I/O Channel* P&ID: 325-01-613-PD-01

PT	PLC ADDR	TB PIN	INTERNAL / BARRIER	FIELD DEST	TAG NUMBER	SERVICE / INSTRUMENT DESCRIPTION
20	C3S02,20	X1:21	IS-BARRIER (937T)	IS-JB-618	SPARE	*Spare I/O Channel* P&ID: 325-01-613-PD-01
21	C3S02,21	X1:22	IS-BARRIER (937T)	IS-JB-618	SPARE	*Spare I/O Channel* P&ID: 325-01-613-PD-01
22	C3S02,22	X1:23	IS-BARRIER (937T)	IS-JB-618	SPARE	*Spare I/O Channel* P&ID: 325-01-613-PD-01
23	C3S02,23	X1:24	FUSE 1492-JD3FB (1A)	JB-618	PSL-61311	Pressure alarm low P&ID: 325-01-613-PD-04
23	C3S02,23	X1:24	IS-BARRIER (937T)	IS-JB-618	SPARE	*Spare I/O Channel* P&ID: 325-01-613-PD-01
24	C3S02,24	X1:25	IS-BARRIER (937T)	IS-JB-618	SPARE	*Spare I/O Channel* P&ID: 325-01-613-PD-01
24	C3S02,24	X1:25	FUSE 1492-JD3FB (1A)	JB-618	SV-61304	PA On/Off Valve for Conveying Cooler Cyc.. P&ID: 325-01-613-PD-01
25	C3S02,25	X1:26	IS-BARRIER (937T)	IS-JB-618	SPARE	*Spare I/O Channel* P&ID: 325-01-613-PD-01
25	C3S02,25	X1:26	FUSE 1492-JD3FB (1A)	JB-618	SV-61304	PA On/Off Valve for Conveying Cooler Cyc.. P&ID: 325-01-613-PD-01
26	C3S02,26	X1:27	IS-BARRIER (937T)	IS-JB-618	SPARE	*Spare I/O Channel* P&ID: 325-01-613-PD-01
26	C3S02,26	X1:27	FUSE 1492-JD3FB (1A)	JB-618	XV-61301	Product feed-out Packing silo P&ID: 3-25-01-613-PD-01
27	C3S02,27	X1:28	IS-BARRIER (937T)	IS-JB-618	SPARE	*Spare I/O Channel* P&ID: 325-01-613-PD-01
27	C3S02,27	X1:28	FUSE 1492-JD3FB (1A)	JB-618	XV-61301	Product feed-out Packing silo P&ID: 3-25-01-613-PD-01
28	C3S02,28	X1:29	IS-BARRIER (937T)	IS-JB-618	SPARE	*Spare I/O Channel* P&ID: 325-01-613-PD-01
29	C3S02,29	X1:30	IS-BARRIER (937T)	IS-JB-618	SPARE	*Spare I/O Channel* P&ID: 325-01-613-PD-01
30	C3S02,30	X1:31	IS-BARRIER (937T)	IS-JB-618	SPARE	*Spare I/O Channel* P&ID: 325-01-613-PD-01
31	C3S02,31	X1:32	IS-BARRIER (937T)	IS-JB-618	SPARE	*Spare I/O Channel* P&ID: 325-01-613-PD-01
	C3S02,00	X1:--	IS-BARRIER (937T)	IS-JB-618	ISV-61301	Instrument ISV-61301 P&ID: 325-01-613-PD-01

CHASSIS C3 SLOT 2 - 1756-IB32 (DI) WIRING SCHEMATIC

MAIN CONTROL CABINET CA1 / CONTROLLOGIX 1756

DWG NO: KAL-JC-WIR-20023

REV: 3.6 DATE: 2026-09-08

DRAWN: AEC-ENG

CHECKED: LEAD-PE

STATUS: APPROVED

SCALE: N.T.S.

PROJECT NO: R5THS00138-JC

SHEET NO: 26 / 40