

MODULE: 1756-IB32 CHASSIS: C4 SLOT: 3 TYPE: DI TERMINAL STRIP: C4S03-X1 POINTS: 31								RATING: 24V DC SINK/SOURCE PANEL: CA1 / MOTOR CONTROL							
PT	PLC ADDR	TB PIN		INTERNAL / BARRIER	FIELD DEST	TAG NUMBER	SERVICE / INSTRUMENT DESCRIPTION	PT	PLC ADDR	TB PIN		INTERNAL / BARRIER	FIELD DEST	TAG NUMBER	SERVICE / INSTRUMENT DESCRIPTION
01	C4S03,01	X1:02		IS-BARRIER (937T)	IS-JB-612	ISV-61304	Explosion isolation flap valve ISV-61304 P&ID: 325-01-613-PD-05	18	C4S03,18	X1:19		IS-BARRIER (937T)	IS-JB-612	SPARE	Spare I/O Channel
02	C4S03,02	X1:03		IS-BARRIER (937T)	IS-JB-612	LSH-61304	Big bag level alarm high P&ID: 325-01-613-PD-03	19	C4S03,19	X1:20		IS-BARRIER (937T)	IS-JB-612	SPARE	Spare I/O Channel
03	C4S03,03	X1:04		IS-BARRIER (937T)	IS-JB-612	LSH-61305	Big bag level alarm high P&ID: 325-01-613-PD-05	20	C4S03,20	X1:21		IS-BARRIER (937T)	IS-JB-612	SPARE	Spare I/O Channel
04	C4S03,04	X1:05		IS-BARRIER (937T)	IS-JB-612	LSH-61307	High Level alarm reject screen P&ID: 3-25-01-613-PD-01	21	C4S03,21	X1:22		IS-BARRIER (937T)	IS-JB-612	SPARE	Spare I/O Channel
05	C4S03,05	X1:06		IS-BARRIER (937T)	IS-JB-612	LSH-61312	Level alarm high P&ID: 325-01-613-PD-05	22	C4S03,22	X1:23		IS-BARRIER (937T)	IS-JB-612	SPARE	Spare I/O Channel
06	C4S03,06	X1:07		IS-BARRIER (937T)	IS-JB-612	PSE-61302	Explosion Vent PSE-61302 P&ID: 325-01-613-PD-03	23	C4S03,23	X1:24		IS-BARRIER (937T)	IS-JB-612	SPARE	Spare I/O Channel
07	C4S03,07	X1:08		IS-BARRIER (937T)	IS-JB-612	PSE-61303	Explosion Vent PSE-61303 P&ID: 325-01-613-PD-05	24	C4S03,24	X1:25		IS-BARRIER (937T)	IS-JB-612	SPARE	Spare I/O Channel
09	C4S03,09	X1:10		IS-BARRIER (937T)	IS-JB-612	RV-61301	Instrument RV-61301	25	C4S03,25	X1:26		IS-BARRIER (937T)	IS-JB-612	SPARE	Spare I/O Channel
10	C4S03,10	X1:11		IS-BARRIER (937T)	IS-JB-612	RV-61304	Instrument RV-61304	26	C4S03,26	X1:27		IS-BARRIER (937T)	IS-JB-612	SPARE	Spare I/O Channel
11	C4S03,11	X1:12		IS-BARRIER (937T)	IS-JB-612	RV-61305	Instrument RV-61305	27	C4S03,27	X1:28		IS-BARRIER (937T)	IS-JB-612	SPARE	Spare I/O Channel
12	C4S03,12	X1:13		IS-BARRIER (937T)	IS-JB-612	SC-61301	Instrument SC-61301	28	C4S03,28	X1:29		IS-BARRIER (937T)	IS-JB-612	SPARE	Spare I/O Channel
13	C4S03,13	X1:14		IS-BARRIER (937T)	IS-JB-612	SC-61302	Instrument SC-61302	29	C4S03,29	X1:30		IS-BARRIER (937T)	IS-JB-612	SPARE	Spare I/O Channel
14	C4S03,14	X1:15		IS-BARRIER (937T)	IS-JB-612	ZS-61312	Position Magnet Door P&ID: 325-01-613-PD-01	30	C4S03,30	X1:31		IS-BARRIER (937T)	IS-JB-612	SPARE	Spare I/O Channel
15	C4S03,15	X1:16		IS-BARRIER (937T)	IS-JB-612	ZS-61313	Position Magnet Door P&ID: 325-01-613-PD-01	31	C4S03,31	X1:32		IS-BARRIER (937T)	IS-JB-612	SPARE	Spare I/O Channel
16	C4S03,16	X1:17		IS-BARRIER (937T)	IS-JB-612	SPARE	Spare I/O Channel		C4S03,00	X1:--		IS-BARRIER (937T)	IS-JB-612	ISV-61303	Explosion isolation flap valve ISV-61303 P&ID: 325-01-613-PD-03
17	C4S03,17	X1:18		IS-BARRIER (937T)	IS-JB-612	SPARE	Spare I/O Channel								
INGREDION (THAILAND) CO., LTD. KALASIN STARCH PLANT - JET COOKER PROJECT								AEC INDUSTRIAL ENGINEERING SYSTEMS INTEGRATION & AUTOMATION							
CHASSIS C4 SLOT 3 - 1756-IB32 (DI) WIRING SCHEMATIC MAIN CONTROL CABINET CA1 / CONTROLLOGIX 1756								DWG NO: KAL-JC-WIR-20030 REV: 3.6 DATE: 2026-09-08							
DRAWN: AEC-ENG CHECKED: LEAD-PE				STATUS: APPROVED SCALE: N.T.S.				PROJECT NO: R5THS00138-JC		SHEET NO: 33 / 40					