

MODULE: 1756-OB32 CHASSIS: C4 SLOT: 4 TYPE: DO TERMINAL STRIP: C4S04-X1 POINTS: 32								RATING: 24V DC SINK/SOURCE PANEL: CA1 / MOTOR CONTROL							
PT	PLC ADDR	TB PIN		INTERNAL / BARRIER	FIELD DEST	TAG NUMBER	SERVICE / INSTRUMENT DESCRIPTION	PT	PLC ADDR	TB PIN		INTERNAL / BARRIER	FIELD DEST	TAG NUMBER	SERVICE / INSTRUMENT DESCRIPTION
01	C4S04,01	X1:02		RELAY 700-HL (24VDC)	JB-606	SPARE	Spare I/O Channel	17	C4S04,17	X1:18		RELAY 700-HL (24VDC)	JB-612	PVM-61301	Start / Stop Command for FVNR PV-61301 (.. P&ID: 325-01-613-PD-03
02	C4S04,02	X1:03		RELAY 700-HL (24VDC)	JB-606	SPARE	Spare I/O Channel	18	C4S04,18	X1:19		RELAY 700-HL (24VDC)	JB-612	SV-61307	Instrument SV-61307 P&ID: 3-25-01-613-PD-01
03	C4S04,03	X1:04		RELAY 700-HL (24VDC)	JB-606	SPARE	Spare I/O Channel	19	C4S04,19	X1:20		RELAY 700-HL (24VDC)	JB-612	SV-61308	Timer compress air pluse solenoid valve P&ID: 325-01-613-PD-03
04	C4S04,04	X1:05		RELAY 700-HL (24VDC)	JB-606	SPARE	Spare I/O Channel	20	C4S04,20	X1:21		RELAY 700-HL (24VDC)	JB-612	SV-61309	Air service P&ID: 325-01-613-PD-03
05	C4S04,05	X1:06		RELAY 700-HL (24VDC)	JB-606	SPARE	Spare I/O Channel	21	C4S04,21	X1:22		RELAY 700-HL (24VDC)	JB-612	SV-61310	Timer compress air pluse solenoid valve P&ID: 325-01-613-PD-05
06	C4S04,06	X1:07		RELAY 700-HL (24VDC)	JB-606	SPARE	Spare I/O Channel	22	C4S04,22	X1:23		RELAY 700-HL (24VDC)	JB-612	SV-61311	Air service P&ID: 325-01-613-PD-05
07	C4S04,07	X1:08		RELAY 700-HL (24VDC)	JB-606	SPARE	Spare I/O Channel	23	C4S04,23	X1:24		RELAY 700-HL (24VDC)	JB-612	XS-61301A	Filter plant in operation P&ID: 325-01-613-PD-02
08	C4S04,08	X1:09		IS-TX-BARRIER (937T)	IS-JB-608	XA-60201	LEL gas Buzzer Alarm P&ID: 325-01-600-PD-03	24	C4S04,24	X1:25		RELAY 700-HL (24VDC)	JB-612	XS-61301B	Material transport in operation P&ID: 325-01-613-PD-02
09	C4S04,09	X1:10		IS-TX-BARRIER (937T)	IS-JB-608	SPARE	Spare I/O Channel	25	C4S04,25	X1:26		RELAY 700-HL (24VDC)	JB-612	XS-61301C	Belt plant in operation P&ID: 325-01-613-PD-02
10	C4S04,10	X1:11		IS-TX-BARRIER (937T)	IS-JB-608	SPARE	Spare I/O Channel	26	C4S04,26	X1:27		RELAY 700-HL (24VDC)	JB-612	XS-61301D	Sequence Stop P&ID: 325-01-613-PD-02
11	C4S04,11	X1:12		IS-TX-BARRIER (937T)	IS-JB-608	SPARE	Spare I/O Channel	27	C4S04,27	X1:28		RELAY 700-HL (24VDC)	JB-612	XS-61301E	Status from Customer Emergency stop P&ID: 325-01-613-PD-02
12	C4S04,12	X1:13		IS-TX-BARRIER (937T)	IS-JB-608	SPARE	Spare I/O Channel	28	C4S04,28	X1:29		RELAY 700-HL (24VDC)	JB-612	XS-61301F	Operation Release P&ID: 325-01-613-PD-02
13	C4S04,13	X1:14		IS-TX-BARRIER (937T)	IS-JB-608	SPARE	Spare I/O Channel	29	C4S04,29	X1:30		RELAY 700-HL (24VDC)	JB-612	XV-61302	Dust collector feed vent P&ID: 325-01-613-PD-02
14	C4S04,14	X1:15		IS-TX-BARRIER (937T)	IS-JB-608	SPARE	Spare I/O Channel	30	C4S04,30	X1:31		RELAY 700-HL (24VDC)	JB-612	XV-61303	Dust collector feed from packer P&ID: 325-01-613-PD-02
15	C4S04,15	X1:16		IS-TX-BARRIER (937T)	IS-JB-608	SPARE	Spare I/O Channel	31	C4S04,31	X1:32		RELAY 700-HL (24VDC)	JB-612	SPARE	Spare I/O Channel
16	C4S04,16	X1:17		RELAY 700-HL (24VDC)	JB-612	PVM-61301	Start / Stop Command for FVNR PV-61301 (.. P&ID: 325-01-613-PD-03		C4S04,00	X1:--		RELAY 700-HL (24VDC)	JB-606	SV-60220	PA On/Off Valve for Chamber PSE purge ai.. P&ID: 325-01-600-PD-04
INGREDION (THAILAND) CO., LTD. KALASIN STARCH PLANT - JET COOKER PROJECT												AEC INDUSTRIAL ENGINEERING SYSTEMS INTEGRATION & AUTOMATION			
CHASSIS C4 SLOT 4 - 1756-OB32 (DO) WIRING SCHEMATIC MAIN CONTROL CABINET CA1 / CONTROLLOGIX 1756												DWG NO: KAL-JC-WIR-20031 REV: 3.6 DATE: 2026-09-08			
DRAWN: AEC-ENG CHECKED: LEAD-PE						STATUS: APPROVED SCALE: N.T.S.						PROJECT NO: R5THS00138-JC		SHEET NO: 34 / 40	