MODULE: 1756-IF16 | CHASSIS: C4 | SLOT: 6 | TYPE: AI | TERMINAL STRIP: C4S06-X1 | POINTS: 8

RATING: 4-20mA CURRENT LOOP (ISOLATED) | PANEL: CA1 / MOTOR CONTROL

PT	PLC ADDR	TB PIN	INTERNAL / BARRIER	FIELD DEST	TAG NUMBER	SERVICE / INSTRUMENT DESCRIPTION
01	C4S06,01	**X1:02**	**IS-TX-BARRIER (937T)**	**IS-JB-608**	**TT-60220**	Gas and Powder Temperature Transmitter f.. P&ID: 325-01-600-PD-04
02	C4S06,02	**X1:03**	**IS-TX-BARRIER (937T)**	**IS-JB-608**	**TT-60221**	Gas and Powder Temperature Transmitter f.. P&ID: 325-01-600-PD-04
03	C4S06,03	**X1:04**	**IS-TX-BARRIER (937T)**	**IS-JB-608**	**TT-60222**	Gas and Powder Temperature Transmitter f.. P&ID: 325-01-600-PD-04
04	C4S06,04	**X1:05**	**IS-TX-BARRIER (937T)**	**IS-JB-608**	**TT-60223**	Gas and Powder Temperature Transmitter f.. P&ID: 325-01-600-PD-04
05	C4S06,05	**X1:06**	**IS-TX-BARRIER (937T)**	**IS-JB-608**	**XT-60201**	LEL gas analyzer P&ID: 325-01-600-PD-03
06	C4S06,06	**X1:07**	**IS-TX-BARRIER (937T)**	**IS-JB-612**	**DPT-61310**	Vent filter pressure P&ID: 325-01-613-PD-03
07	C4S06,07	**X1:08**	**IS-TX-BARRIER (937T)**	**IS-JB-612**	**DPT-61312**	Instrument DPT-61312 P&ID: 325-01-613-PD-05
	C4S06,00	**X1:--**	**IS-TX-BARRIER (937T)**	**IS-JB-608**	**PT-60220**	Gas Pressure Transmitter for Chamber (CH.. P&ID: 325-01-600-PD-04

INGREDION (THAILAND) CO., LTD. KALASIN STARCH PLANT - JET COOKER PROJECT			**AEC INDUSTRIAL ENGINEERING** SYSTEMS INTEGRATION & AUTOMATION
CHASSIS C4 SLOT 6 - 1756-IF16 (AI) WIRING SCHEMATIC MAIN CONTROL CABINET CA1 / CONTROLLOGIX 1756			**DWG NO:** **KAL-JC-WIR-20033** REV: 3.6 DATE: 2026-09-08
DRAWN: AEC-ENG CHECKED: LEAD-PE	**STATUS: APPROVED** SCALE: N.T.S.	**PROJECT NO:** R5THS00138-JC	**SHEET NO:** **36 / 40**