

MODULE: 1756-OB32 CHASSIS: C5 SLOT: 3 TYPE: DO TERMINAL STRIP: C5S03-X1 POINTS: 32																RATING: 24V DC SINK/SOURCE PANEL: CA1 / MOTOR CONTROL																																							
PT								PLC ADDR								TB PIN								INTERNAL / BARRIER								FIELD DEST								TAG NUMBER								SERVICE / INSTRUMENT DESCRIPTION							
01								C5S03,01								X1:02								 RELAY 700-HL (24VDC)								RIO-200								XV-20201								Slurry Preparation Tank 1 P&ID: 325-01-200-PD-01							
02								C5S03,02								X1:03								 RELAY 700-HL (24VDC)								RIO-200								XV-20202								Slurry Preparation Tank 1 P&ID: 325-01-200-PD-01							
03								C5S03,03								X1:04								 RELAY 700-HL (24VDC)								RIO-200								XV-20203								Slurry Preparation Tank 1 P&ID: 325-01-200-PD-01							
04								C5S03,04								X1:05								 RELAY 700-HL (24VDC)								RIO-200								XV-20211								Slurry Preparation Tank 2 P&ID: 325-01-200-PD-01							
05								C5S03,05								X1:06								 RELAY 700-HL (24VDC)								RIO-200								XV-20212								Slurry Preparation Tank 2 P&ID: 325-01-200-PD-01							
06								C5S03,06								X1:07								 RELAY 700-HL (24VDC)								RIO-200								XV-20213								Slurry Preparation Tank 2 P&ID: 325-01-200-PD-01							
07								C5S03,07								X1:08								 RELAY 700-HL (24VDC)								RIO-200								XV-913201								Outlet LPG line P&ID: 3-25-01-913-PD-02							
08								C5S03,08								X1:09								 RELAY 700-HL (24VDC)								RIO-200								SPARE								Spare I/O Channel							
09								C5S03,09								X1:10								 RELAY 700-HL (24VDC)								RIO-200								SPARE								Spare I/O Channel							
10								C5S03,10								X1:11								 RELAY 700-HL (24VDC)								RIO-200								SPARE								Spare I/O Channel							
11								C5S03,11								X1:12								 RELAY 700-HL (24VDC)								RIO-200								SPARE								Spare I/O Channel							
12								C5S03,12								X1:13								 RELAY 700-HL (24VDC)								RIO-200								SPARE								Spare I/O Channel							
13								C5S03,13								X1:14								 RELAY 700-HL (24VDC)								RIO-200								SPARE								Spare I/O Channel							
14								C5S03,14								X1:15								 RELAY 700-HL (24VDC)								RIO-200								SPARE								Spare I/O Channel							
15								C5S03,15								X1:16								 RELAY 700-HL (24VDC)								RIO-200								SPARE								Spare I/O Channel							
16								C5S03,16								X1:17								 RELAY 700-HL (24VDC)								RIO-200								SPARE								Spare I/O Channel							
17								C5S03,17								X1:18								 RELAY 700-HL (24VDC)								RIO-200								SPARE								Spare I/O Channel							
18								C5S03,18								X1:19								 RELAY 700-HL (24VDC)								RIO-200								SPARE								Spare I/O Channel							
19								C5S03,19								X1:20								 RELAY 700-HL (24VDC)								RIO-200								SPARE								Spare I/O Channel							
20								C5S03,20								X1:21								 RELAY 700-HL (24VDC)								RIO-200								SPARE								Spare I/O Channel							
21								C5S03,21								X1:22								 RELAY 700-HL (24VDC)								RIO-200								SPARE								Spare I/O Channel							
22								C5S03,22								X1:23								 RELAY 700-HL (24VDC)								RIO-200								SPARE								Spare I/O Channel							
23								C5S03,23								X1:24								 RELAY 700-HL (24VDC)								RIO-200								SPARE								Spare I/O Channel							
24								C5S03,24								X1:25								 RELAY 700-HL (24VDC)								RIO-200								SPARE								Spare I/O Channel							
25								C5S03,25								X1:26								 RELAY 700-HL (24VDC)								RIO-200								SPARE								Spare I/O Channel							
26								C5S03,26								X1:27								 RELAY 700-HL (24VDC)								RIO-200								SPARE								Spare I/O Channel							
27								C5S03,27								X1:28								 RELAY 700-HL (24VDC)								RIO-200								SPARE								Spare I/O Channel							
28								C5S03,28								X1:29								 RELAY 700-HL (24VDC)								RIO-200								SPARE								Spare I/O Channel							
29								C5S03,29								X1:30								 RELAY 700-HL (24VDC)								RIO-200								SPARE								Spare I/O Channel							
30								C5S03,30								X1:31								 RELAY 700-HL (24VDC)								RIO-200								SPARE								Spare I/O Channel							
31								C5S03,31								X1:32								 RELAY 700-HL (24VDC)								RIO-200								SPARE								Spare I/O Channel							
								C5S03,00								X1:--								 RELAY 700-HL (24VDC)								RIO-200								XA-92201								LEL gas Buzzer Alarm P&ID: 325-01-923-PD-03							
INGREDION (THAILAND) CO., LTD. KALASIN STARCH PLANT - JET COOKER PROJECT																AEC INDUSTRIAL ENGINEERING SYSTEMS INTEGRATION & AUTOMATION																																							
CHASSIS C5 SLOT 3 - 1756-OB32 (DO) WIRING SCHEMATIC MAIN CONTROL CABINET CA1 / CONTROLLOGIX 1756																DWG NO: KAL-JC-WIR-20036 REV: 3.6 DATE: 2026-09-08																																							
DRAWN: AEC-ENG CHECKED: LEAD-PE								STATUS: APPROVED SCALE: N.T.S.								PROJECT NO: R5THS00138-JC				SHEET NO: 39 / 40																																			