



CUSTOMER: Ingredion (Thailand) Co., Ltd.		LOCATION: Kalasin			
PROJECT TITLE: Project SPRINT 18K TPA Spray Dry		CUSTOMER P.O. NO.: 7001731642			
PACKAGE: LEL Gas Analyzer		EPM PROJECT NO: 6626014			
DOCUMENT TITLE: Explosionproof Certificate					
CUSTOMER COMMENTS					
☐ APPROVED WITH NO COMMENTS - SUBMIT FINAL DOCUMENTS ☐ APPROVED WITH COMMENTS - CORRECT AND RE-SUBMIT, COMMENCE FABRICATION BASED ON CORRECTION ☐ REJECT - NOT RELEASE FOR FABRICATION, CORRECT AND RE-SUBMIT FOR APPROVAL ☐ FOR INFORMATION - FOR INFORMATION ONLY Name: Signature: Date:		<u>REMARKS</u> _____ _____ _____ _____ _____ _____			
0	For Information	Daungjai	Somchai	Visit	2-Feb-26
REV NO.	DESCRIPTION	PREPARED	CHECKED	APPROVED	DATE
NOTES:		CUSTOMER DOC. NO.:		EPM DOC. NO.:	
				6626014-33-115-001	
	SHEET NO:	ISSUE DATE:	02-Feb-26	5 SHEET(S) (Included Cover Page)	REV. 0



EU-TYPE EXAMINATION CERTIFICATE

Equipment intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU

Certificate Number: **CSANe 23ATEX1008X** Issue: **2**

Equipment: **Combustible Gas Transmitter 925 (Transmitter) 905 (Junction Box) 625ND (Sensor)**

Applicant: **Rosemount Inc.**

Address: 6021 Innovation Blvd
Shakopee
Minnesota 55379-4676
USA

This equipment and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

CSA Group Netherlands B.V., notified body number 2813 in accordance with Articles 17 and 21 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in the confidential reports listed in Section 14.2.

Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the schedule to this certificate, has been assured by compliance with the following documents:

EN IEC 60079-0:2018 EN 60079-1:2014 EN 60079-29-1:2016

If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to Specific Conditions of Use identified in the schedule to this certificate.

This EU-Type Examination Certificate relates only to the design and construction of the specified equipment. If applicable, further requirements of this Directive apply to the manufacture and supply of this equipment.

The marking of the equipment shall include the following:



II 2G

Ex db IIC T5 Gb

Combustible Gas Detector, Model: 925 (Transmitter), 905 (Junction Box), and 625ND (Sensor)

Transmitter Operating temperature range: -55 °C to +75 °C

Sensor Operating temperature range: -40 °C to +75 °C

Junction Box Operating temperature range: -40 °C to +75 °C

Signed: Michelle Halliwell

Title: Senior Director of Operations



Project Number 80242886

This certificate and its schedules may only be reproduced in its entirety and without change
CSA Group Netherlands B.V. Utrechtseweg 310, Building B42, 6812AR Arnhem, The Netherlands



SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE

CSANe 23ATEX1008X
Issue 2

13 DESCRIPTION OF EQUIPMENT

Model Codes:

925FGD ABC

Model	925	Gas Detection Transmitter
Output(A)	1	Analog, HART
Enclosure(B)	A	925 Housing Aluminum
	S	925 Housing Stainless Steel
Conduit(C)	1	¾ NPT
	2	M25

625NDABC

Model(ND)	625	Non-Dispersive, Infrared Sensor
Enclosure(A)	A	625ND Housing, Aluminum
	S	625ND Housing, Stainless Steel
Threading(B)	1	¾ NPT
Gases(C)	G01	Ethane
	G02	Propane
	G03	Butane
	G04	Ethylene

905AB

Model	905	Junction Box
Enclosure(A)	A	905 Housing Aluminum
	S	905 Housing Stainless Steel
Conduit(B)	3	¾ NPT
	4	M25

The 925FGD is a fixed general purpose flammable gas detector compatible with the 625ND sensor. The 925FGD is a fully-assembled unit for either sensor-direct mount or sensor-remote-mount installations. For remote mount installations, the Rosemount 925FGD will consist of one standalone 925 transmitter along with one 905 junction box with a 625ND sensor housing wired and attached. For either configuration, the 925FGD with or without the sensor module for instances where sensor modules will be installed after the initial transmitter installation. The 925FGD transmitter, 925, consists of the transmitter electronics, an LCD display, and infrared touch buttons contained in an explosion-proof housing. The transmitter provides outputs, including 0-20 mA analog signal, fault relay, alarm relays, and HART® protocol. The transmitter is also equipped with status indication LEDs. All 625 sensors are smart sensors, meaning all configuration, calibration, and gas sensing data is stored directly on or generated directly from the sensor. This data is then communicated to the 925 transmitter, which displays information on the LOI and generates outputs for communication with site control systems. For combustible hydrocarbon gas detection, the 925FGD incorporates the 625ND sensor module. The Rosemount 625ND sensor module uses non-dispersive infrared technology to measure combustible hydrocarbon gas using absorption spectroscopy in the infrared sensor bands.

Project Number 80242886

This certificate and its schedules may only be reproduced in its entirety and without change
CSA Group Netherlands B.V. Utrechtseweg 310, Building B42, 6812AR Arnhem, The Netherlands



SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE

CSANe 23ATEX1008X
Issue 2

Variation 1 - This variation introduced the following changes:

- i. Introduction of new 905 Junction Box design.
- ii. ATEX standard reference correction.

Variation 2 - This variation introduced the following changes:

- i. Update to the 925 Quick Start Guide
- ii. Update Model Codes

14 DESCRIPTIVE DOCUMENTS

14.1 Drawings

Refer to Certificate Annexe.

14.2 Associated Reports and Certificate History

Issue	Date	Report number	Comment
0	30 March 2023	R70219959A	The release of the prime certificate.
1	15 August 2024	R80208274A	The introduction of variation 1.
2	13 June 2025	R80242885A	The introduction of variation 2.

15 SPECIFIC CONDITIONS OF USE (denoted by X after the certificate number)

15.1 Connect ONLY to approved SELV/PELV power supply.

15.2 Compliance to Ex dust ignition protection standards does not imply that the equipment will detect gas during and after exposure to dust and fibers in suspension in air.

16 ESSENTIAL HEALTH AND SAFETY REQUIREMENTS OF ANNEX II (EHSRs)

The relevant EHSRs that are not addressed by the standards listed in this certificate have been identified and individually assessed in the reports listed in Section 14.2.

17 CONDITIONS OF MANUFACTURE

17.1 The use of this certificate is subject to the Regulations Applicable to Holders of CSA Group Netherlands B.V. certificates.

17.2 Holders of EU-Type Examination Certificates are required to comply with the conformity to type requirements defined in Article 13 of Directive 2014/34/EU.

Project Number 80242886

This certificate and its schedules may only be reproduced in its entirety and without change
CSA Group Netherlands B.V. Utrechtseweg 310, Building B42, 6812AR Arnhem, The Netherlands

Certificate Annexe



Certificate Number: CSANe 23ATEX1008X

Equipment: Combustible Gas Transmitter 925 (Transmitter) 905 (Junction Box)
625ND (Sensor)

Applicant: Rosemount Inc.

Issue 0

Drawing	Sheets	Rev.	Date (Stamp)	Title
00625-1000	1 of 6	AE	13 Mar 23	905 and 625 Approvals Alum & SST
00925-1000	1 to 8	AD	13 Mar 23	925 Approvals Alum & SST
00625-3000	1 to 1	AA	13 Mar 23	SCH 625 Sensor Wiring Board
00625-3003	1 of 1	AA	13 Mar 23	SCH 625, CPU Board
00625-3006	1 to 1	AC	13 Mar 23	SCH 625 NDIR Sensor
00625-3009	1 of 1	AB	13 Mar 23	SCH 625 Junction Board
00925-3000	1 to 3	AC	13 Mar 23	SCH 925 GDT CPU Board
00925-3003	1 to 1	AB	13 Mar 23	SCH 925 GDT Display Board
00925-3006	1 to 2	AC	13 Mar 23	SCH 925 GDT Terminal Board

Issue 1

Drawing	Sheets	Rev.	Date (Stamp)	Title
00625-1000	1 to 6	AF	17 Jul 24	625 and 905 Approvals Alum & SST
00905-1000	1 to 5	AA	17 Jul 24	905 Approvals Alum & SST
00825-0100-4925	1 to 35	AC	17 Jul 24	QSG 925

Issue 2

Drawing	Sheets	Rev.	Date (Stamp)	Title
00825-0100-4925	1 to 40	AE	21 May 25	QSG 925

Project Number 80242886

This certificate and its schedules may only be reproduced in its entirety and without change
CSA Group Netherlands B.V. Utrechtseweg 310, Building B42, 6812AR Arnhem, The Netherlands