



Certificate of Compliance

Certificate: 2673306

Master Contract: 249581

Project: 2673306

Date Issued: May 22, 2014

Issued to: HKC Co., Ltd.

Sunggok-Dong 155
Byeolmang-ro, Danwon-gu
Ansan-si, Gyeonggi-do 425-836
South Korea
Attention: JY Bak

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Wardell Dumas

Issued by: Wardell Dumas

PRODUCTS

CLASS 3221 02 - VALVES - General purpose Actuators

CLASS 3221 82 - VALVES - Actuators - Certified to US Standards

APL Series Limit Switch Boxes – position signaling and indicating for valves or actuators.

APL2xxN series, Type 4X

xx =	<i>Electrical</i>
10, 13	250Vac max, 5.6A max
20	8.2Vdc, 0-100mA
23	5-60Vdc, 4-100mA

APL3xxN series, Type 4X

xx =	<i>Electrical</i>
10 – 16	250Vac max, 5.6A max



Certificate: 2673306

Master Contract: 249581

Project: 2673306

Date Issued: May 22, 2014

20	8.2Vdc, 0-100mA
23	5-60Vdc, 4-100mA
30	200Vdc max, 1.5A max

Notes:

- 1) Not intended for direct connection with motor(s).

APPLICABLE REQUIREMENTS

C22.2 No 139-13	Electrically Operated Valves
ANSI/UL 429 (7th Ed)	Electrically Operated Valves
C22.2 No 94.1-07/UL 50 (12th Ed)	Enclosures for Electrical Equipment, Non-environmental Considerations
C22.2 No 94.2-07/UL 50E (1st Ed)	Enclosures for Electrical Equipment, Environmental Considerations