



FUNCTIONAL SAFETY CERTIFICATE

This is to certify that the

APL Series Valve Position Monitor

manufactured by

HKC Co. Ltd.

26, Emtibeui 28-ro,
Siheung-si,
Gyeonggi-do,
Republic of Korea

have been assessed by Sira Certification Service with reference to the
CASS methodologies and found to meet the requirements of

IEC 61508-2:2010 Routes 1_H & 1_S Systematic Capability (SC3)

as an element/subsystem suitable for use in safety related systems performing safety
functions up to and including

SIL 2 capable with HFT=0 (1oo1)*
SIL 3 capable with HFT=1 (1oo2)*

when used in accordance with the scope and conditions of this certificate.

* This certificate does not waive the need for further functional safety verification to
establish the achieved Safety Integrity Level (SIL) of the safety related system

Certification Decision:

James Lynskey

Initial Certification : 04/03/2021

This certificate re-issued : -

Renewal date : 03/03/2026

This certificate may only be reproduced in its entirety, without any change.



Certificate No.: Sira FSP 20007 / 00
Form 7016 issue 4
Page 1 of 5



Sira Certification Service Part of CSA Group UK

Unit 6 Hawarden Industrial Park,
Hawarden, CH5 3US, United Kingdom
Tel: +44 (0) 1244 670900
Email: ukinfo@csagroup.org
Web: www.csagroupuk.org