

KALASIN ENGINEERING — C1 (MAIN CONTROLLER RACK (CHASSIS 1))

SLOT-BY-SLOT I/O SOURCE AND DESTINATION WIRING SCHEDULE

Project Ref: x2608003
Rack Location: Control Cabinet CA1 (Main Control Room)
Network: Stratix 5400 / EN4TR Ring Node 1 (192.168.1.10)
Revision: Rev 3.6 | Date: 28-Sep-2026

CHASSIS ID C1	ACTIVE SLOTS 8 Slots	TOTAL CAPACITY 224 Channels	ACTIVE POINTS 138 Points	SPARE POINTS 86 (38.4%)	PANEL LOCATION Control Cabinet CA
------------------	-------------------------	--------------------------------	-----------------------------	----------------------------	--------------------------------------

C1 SLOT 03 — 1756-IB32 (DI)																
Rack: Main Controller Rack (Chassis 1) Location: Control Cabinet CA1 (Main Control Room) Protocol: Stratix 5400 / EN4TR Ring Node 1 (192.168.1.10)																
SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)							SIGNAL SPEC			DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C1-S03-P00	0	1	1756-IB32	Spare_DI_0	Pin 1	C1S3:1/C1S03-X1:1	DI	24VDC Dry Contact	SPARE	CA1	Main Control Cabinet	C1S03-X1	-	Spare	Spare Channel	-
C1-S03-P01	1	2	1756-IB32	Spare_DI_0	Pin 2	C1S3:2/C1S03-X1:2	DI	24VDC Dry Contact	SPARE	CA1	Main Control Cabinet	C1S03-X1	-	Spare	Spare Channel	-
C1-S03-P02	2	3	1756-IB32	Spare_DI_0	Pin 3	C1S3:3/C1S03-X1:3	DI	24VDC Dry Contact	SPARE	CA1	Main Control Cabinet	C1S03-X1	-	Spare	Spare Channel	-
C1-S03-P03	3	4	1756-IB32	Spare_DI_0	Pin 4	C1S3:4/C1S03-X1:4	DI	24VDC Dry Contact	SPARE	CA1	Main Control Cabinet	C1S03-X1	-	Spare	Spare Channel	-
C1-S03-P04	4	5	1756-IB32	Spare_DI_0	Pin 5	C1S3:5/C1S03-X1:5	DI	24VDC Dry Contact	SPARE	CA1	Main Control Cabinet	C1S03-X1	-	Spare	Spare Channel	-
C1-S03-P05	5	6	1756-IB32	Spare_DI_0	Pin 6	C1S3:6/C1S03-X1:6	DI	24VDC Dry Contact	SPARE	CA1	Main Control Cabinet	C1S03-X1	-	Spare	Spare Channel	-
C1-S03-P06	6	7	1756-IB32	Spare_DI_0	Pin 7	C1S3:7/C1S03-X1:7	DI	24VDC Dry Contact	SPARE	CA1	Main Control Cabinet	C1S03-X1	-	Spare	Spare Channel	-
C1-S03-P07	7	8	1756-IB32	Spare_DI_0	Pin 8	C1S3:8/C1S03-X1:8	DI	24VDC Dry Contact	SPARE	CA1	Main Control Cabinet	C1S03-X1	-	Spare	Spare Channel	-
C1-S03-P08	8	9	1756-IB32	Spare_DI_0	Pin 9	C1S3:9/C1S03-X1:9	DI	24VDC Dry Contact	SPARE	CA1	Main Control Cabinet	C1S03-X1	-	Spare	Spare Channel	-
C1-S03-P09	9	10	1756-IB32	Spare_DI_0	Pin 10	C1S3:10/C1S03-X1:10	DI	24VDC Dry Contact	SPARE	CA1	Main Control Cabinet	C1S03-X1	-	Spare	Spare Channel	-
C1-S03-P10	10	11	1756-IB32	Spare_DI_0	Pin 11	C1S3:11/C1S03-X1:11	DI	24VDC Dry Contact	SPARE	CA1	Main Control Cabinet	C1S03-X1	-	Spare	Spare Channel	-
C1-S03-P11	11	12	1756-IB32	Spare_DI_0	Pin 12	C1S3:12/C1S03-X1:12	DI	24VDC Dry Contact	SPARE	CA1	Main Control Cabinet	C1S03-X1	-	Spare	Spare Channel	-
C1-S03-P12	12	13	1756-IB32	Spare_DI_0	Pin 13	C1S3:13/C1S03-X1:13	DI	24VDC Dry Contact	SPARE	CA1	Main Control Cabinet	C1S03-X1	-	Spare	Spare Channel	-

Source Specification (PLC Rack / Card Pin / Eplan Wire Tag)							Signal Spec			Destination Specification (Field JB / MCC / Terminal Pin / Instrument Tag)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C1-S03-P13	13	14	1756-IB32	Spare_DI_0	Pin 14	C1S3:14/C1S03-X1:14	DI	24VDC Dry Contact	SPARE	CA1	Main Control Cabinet	C1S03-X1	-	Spare	Spare Channel	-
C1-S03-P14	14	15	1756-IB32	Spare_DI_0	Pin 15	C1S3:15/C1S03-X1:15	DI	24VDC Dry Contact	SPARE	CA1	Main Control Cabinet	C1S03-X1	-	Spare	Spare Channel	-
C1-S03-P15	15	16	1756-IB32	Spare_DI_0	Pin 16	C1S3:16/C1S03-X1:16	DI	24VDC Dry Contact	SPARE	CA1	Main Control Cabinet	C1S03-X1	-	Spare	Spare Channel	-
C1-S03-P16	16	17	1756-IB32	FSL-40201_DI_1	Pin 17	C1S3:17/C1S03-X2:17	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S03-X2	-	FSL-40201	Flow Switch	3-25-01-402-PD-01
C1-S03-P17	17	18	1756-IB32	FSL-40202_DI_1	Pin 18	C1S3:18/C1S03-X2:18	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S03-X2	-	FSL-40202	Flow Switch	3-25-01-402-PD-01
C1-S03-P18	18	19	1756-IB32	FT-40201_DI_1	Pin 19	C1S3:19/C1S03-X2:19	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S03-X2	-	FT-40201	Coriolis Flow Transmitter	3-25-01-402-PD-02
C1-S03-P19	19	20	1756-IB32	FT-40202_DI_1	Pin 20	C1S3:20/C1S03-X2:20	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S03-X2	-	FT-40202	Magnetic Flow Transmitter	3-25-01-402-PD-02
C1-S03-P20	20	21	1756-IB32	HV-40201_DI_1	Pin 21	C1S3:21/C1S03-X2:21	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S03-X2	-	HV-40201	Manual Valve With Position Switch	3-25-01-402-PD-01
C1-S03-P21	21	22	1756-IB32	HV-40202_DI_1	Pin 22	C1S3:22/C1S03-X2:22	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S03-X2	-	HV-40202	Manual Valve With Position Switch	3-25-01-402-PD-01
C1-S03-P22	22	23	1756-IB32	HV-40203_DI_1	Pin 23	C1S3:23/C1S03-X2:23	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S03-X2	-	HV-40203	Manual Valve With Position Switch	3-25-01-402-PD-01
C1-S03-P23	23	24	1756-IB32	HV-40204_DI_1	Pin 24	C1S3:24/C1S03-X2:24	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S03-X2	-	HV-40204	Manual Valve With Position Switch	3-25-01-402-PD-01
C1-S03-P24	24	25	1756-IB32	HV-40205_DI_1	Pin 25	C1S3:25/C1S03-X2:25	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S03-X2	-	HV-40205	Manual Valve With Position Switch	3-25-01-402-PD-02
C1-S03-P25	25	26	1756-IB32	HV-40206_DI_1	Pin 26	C1S3:26/C1S03-X2:26	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S03-X2	-	HV-40206	Manual Valve With Position Switch	3-25-01-402-PD-02

SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)							SIGNAL SPEC			DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C1-S03-P26	26	27	1756-IB32	XV-40201A_DI_1	Pin 27	C1S3:27/C1S03-X2:27	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S03-X2	-	XV-40201A		3-25-01-402-PD-01
C1-S03-P27	27	28	1756-IB32	XV-40201A_DI_2	Pin 28	C1S3:28/C1S03-X2:28	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S03-X2	-	XV-40201A		3-25-01-402-PD-01
C1-S03-P28	28	29	1756-IB32	XV-40201B_DI_1	Pin 29	C1S3:29/C1S03-X2:29	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S03-X2	-	XV-40201B		3-25-01-402-PD-01
C1-S03-P29	29	30	1756-IB32	XV-40201B_DI_2	Pin 30	C1S3:30/C1S03-X2:30	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S03-X2	-	XV-40201B		3-25-01-402-PD-01
C1-S03-P30	30	31	1756-IB32	XV-40201C_DI_1	Pin 31	C1S3:31/C1S03-X2:31	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S03-X2	-	XV-40201C		3-25-01-402-PD-01
C1-S03-P31	31	32	1756-IB32	XV-40201C_DI_2	Pin 32	C1S3:32/C1S03-X2:32	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S03-X2	-	XV-40201C		3-25-01-402-PD-01

C1 SLOT 04 — 1756-IB32 (DI)																
Rack: Main Controller Rack (Chassis 1) Location: Control Cabinet CA1 (Main Control Room) Protocol: Stratix 5400 / EN4TR Ring Node 1 (192.168.1.10)														Capacity: 32 Pts Active: 32 Spare: 0 (0.0%)		
Source Specification (PLC Rack / Card Pin / ePlan Wire Tag)							Signal Spec			Destination Specification (Field JB / MCC / Terminal Pin / Instrument Tag)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C1-S04-P00	0	1	1756-IB32	XV-40201D_DI_1	Pin 1	C1S4:1/TBDI1:1A	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S04-X1	–	XV-40201D		3-25-01-402-PD-01
C1-S04-P01	1	2	1756-IB32	XV-40201D_DI_2	Pin 2	C1S4:2/TBDI1:2A	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S04-X1	–	XV-40201D		3-25-01-402-PD-01
C1-S04-P02	2	3	1756-IB32	XV-40201E_DI_1	Pin 3	C1S4:3/TBDI1:3A	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S04-X1	–	XV-40201E		3-25-01-402-PD-01
C1-S04-P03	3	4	1756-IB32	XV-40201E_DI_2	Pin 4	C1S4:4/TBDI1:4A	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S04-X1	–	XV-40201E		3-25-01-402-PD-01
C1-S04-P04	4	5	1756-IB32	XV-40201F_DI_1	Pin 5	C1S4:5/TBDI1:5A	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S04-X1	–	XV-40201F		3-25-01-402-PD-01
C1-S04-P05	5	6	1756-IB32	XV-40201F_DI_2	Pin 6	C1S4:6/TBDI1:6A	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S04-X1	–	XV-40201F		3-25-01-402-PD-01
C1-S04-P06	6	7	1756-IB32	XV-40201G_DI_1	Pin 7	C1S4:7/TBDI1:7A	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S04-X1	–	XV-40201G		3-25-01-402-PD-01
C1-S04-P07	7	8	1756-IB32	XV-40201G_DI_2	Pin 8	C1S4:8/TBDI1:8A	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S04-X1	–	XV-40201G		3-25-01-402-PD-01
C1-S04-P08	8	9	1756-IB32	XV-40201H_DI_1	Pin 9	C1S4:9/TBDI1:9A	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S04-X1	–	XV-40201H		3-25-01-402-PD-01
C1-S04-P09	9	10	1756-IB32	XV-40201H_DI_2	Pin 10	C1S4:10/TBDI1:10A	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S04-X1	–	XV-40201H		3-25-01-402-PD-01
C1-S04-P11	11	12	1756-IB32	XV-40202A_DI_2	Pin 12	C1S4:12/TBDI1:12A	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S04-X1	–	XV-40202A		3-25-01-402-PD-01
C1-S04-P12	12	13	1756-IB32	XV-40202B_DI_1	Pin 13	C1S4:13/TBDI1:13A	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S04-X1	–	XV-40202B		3-25-01-402-PD-01
C1-S04-P13	13	14	1756-IB32	XV-40202B_DI_2	Pin 14	C1S4:14/TBDI1:14A	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S04-X1	–	XV-40202B		3-25-01-402-PD-01
C1-S04-P14	14	15	1756-IB32	XV-40202C_DI_1	Pin 15	C1S4:15/TBDI1:15A	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S04-X1	–	XV-40202C		3-25-01-402-PD-01
C1-S04-P15	15	16	1756-IB32	XV-40202C_DI_2	Pin 16	C1S4:16/TBDI1:16A	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S04-X1	–	XV-40202C		3-25-01-402-PD-01
C1-S04-P16	16	17	1756-IB32	XV-40202D_DI_1	Pin 17	C1S4:17/C1S04-X2:17	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S04-X2	–	XV-40202D		3-25-01-402-PD-01
C1-S04-P17	17	18	1756-IB32	XV-40202D_DI_2	Pin 18	C1S4:18/C1S04-X2:18	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S04-X2	–	XV-40202D		3-25-01-402-PD-01

SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)							SIGNAL SPEC			DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C1-S04-P18	18	19	1756-IB32	XV-40202E_DI_1	Pin 19	C1S4:19/TBDI1:17A	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S04-X2	-	XV-40202E		3-25-01-402-PD-01
C1-S04-P19	19	20	1756-IB32	XV-40202A_DI_1	Pin 20	C1S4:20/TBDI1:18A	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S04-X2	-	XV-40202A		3-25-01-402-PD-01
C1-S04-P19	19	20	1756-IB32	XV-40202E_DI_2	Pin 20	C1S4:20/TBDI1:18A	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S04-X2	-	XV-40202E		3-25-01-402-PD-01
C1-S04-P20	20	21	1756-IB32	XV-40202F_DI_1	Pin 21	C1S4:21/TBDI1:19A	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S04-X2	-	XV-40202F		3-25-01-402-PD-01
C1-S04-P21	21	22	1756-IB32	XV-40202F_DI_2	Pin 22	C1S4:22/TBDI1:20A	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S04-X2	-	XV-40202F		3-25-01-402-PD-01
C1-S04-P22	22	23	1756-IB32	XV-40202G_DI_1	Pin 23	C1S4:23/TBDI1:21A	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S04-X2	-	XV-40202G		3-25-01-402-PD-01
C1-S04-P23	23	24	1756-IB32	XV-40202G_DI_2	Pin 24	C1S4:24/TBDI1:22A	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S04-X2	-	XV-40202G		3-25-01-402-PD-01
C1-S04-P24	24	25	1756-IB32	XV-40202H_DI_1	Pin 25	C1S4:25/TBDI1:23A	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S04-X2	-	XV-40202H		3-25-01-402-PD-01
C1-S04-P25	25	26	1756-IB32	XV-40202H_DI_2	Pin 26	C1S4:26/TBDI1:24A	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S04-X2	-	XV-40202H		3-25-01-402-PD-01
C1-S04-P26	26	27	1756-IB32	XV-40203B_DI_1	Pin 27	C1S4:27/TBDI1:25A	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S04-X2	-	XV-40203B		3-25-01-402-PD-02
C1-S04-P27	27	28	1756-IB32	XV-40203B_DI_2	Pin 28	C1S4:28/TBDI1:26A	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S04-X2	-	XV-40203B		3-25-01-402-PD-02
C1-S04-P28	28	29	1756-IB32	XV-40203C_DI_1	Pin 29	C1S4:29/TBDI1:27A	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S04-X2	-	XV-40203C		3-25-01-402-PD-02
C1-S04-P29	29	30	1756-IB32	XV-40203C_DI_2	Pin 30	C1S4:30/TBDI1:28A	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S04-X2	-	XV-40203C		3-25-01-402-PD-02
C1-S04-P30	30	31	1756-IB32	XV-40203D_DI_1	Pin 31	C1S4:31/TBDI1:29A	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S04-X2	-	XV-40203D		3-25-01-402-PD-02
C1-S04-P31	31	32	1756-IB32	XV-40203D_DI_2	Pin 32	C1S4:32/TBDI1:30A	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S04-X2	-	XV-40203D		3-25-01-402-PD-02

C1 SLOT 05 — 1756-IB32 (DI)																
Rack: Main Controller Rack (Chassis 1) Location: Control Cabinet CA1 (Main Control Room) Protocol: Stratix 5400 / EN4TR Ring Node 1 (192.168.1.10)													Capacity: 32 Pts Active: 12 Spare: 20 (62.5%)			
Source Specification (PLC Rack / Card Pin / Eplan Wire Tag)							Signal Spec			Destination Specification (Field JB / MCC / Terminal Pin / Instrument Tag)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C1-S05-P00	0	1	1756-IB32	XV-40203E_DI_1	Pin 1	C1S5:1/TBDI2:1A	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S05-X1	–	XV-40203E		3-25-01-402-PD-02
C1-S05-P01	1	2	1756-IB32	XV-40203E_DI_2	Pin 2	C1S5:2/TBDI2:2A	DI	24VDC Dry Contact	ACTIVE	JB-401	Infeed 2nd Floor	C1S05-X1	–	XV-40203E		3-25-01-402-PD-02
C1-S05-P02	2	3	1756-IB32	Spare_DI_0	Pin 3	C1S5:3/TBDI2:3A	DI	24VDC Dry Contact	SPARE	JB-401	Infeed 2nd Floor	C1S05-X1	–	Spare	Spare Channel	–
C1-S05-P03	3	4	1756-IB32	Spare_DI_0	Pin 4	C1S5:4/TBDI2:4A	DI	24VDC Dry Contact	SPARE	JB-401	Infeed 2nd Floor	C1S05-X1	–	Spare	Spare Channel	–
C1-S05-P04	4	5	1756-IB32	Spare_DI_0	Pin 5	C1S5:5/TBDI2:5A	DI	24VDC Dry Contact	SPARE	JB-401	Infeed 2nd Floor	C1S05-X1	–	Spare	Spare Channel	–
C1-S05-P05	5	6	1756-IB32	Spare_DI_0	Pin 6	C1S5:6/TBDI2:6A	DI	24VDC Dry Contact	SPARE	JB-401	Infeed 2nd Floor	C1S05-X1	–	Spare	Spare Channel	–
C1-S05-P06	6	7	1756-IB32	Spare_DI_0	Pin 7	C1S5:7/TBDI2:7A	DI	24VDC Dry Contact	SPARE	JB-401	Infeed 2nd Floor	C1S05-X1	–	Spare	Spare Channel	–
C1-S05-P07	7	8	1756-IB32	Spare_DI_0	Pin 8	C1S5:8/TBDI2:8A	DI	24VDC Dry Contact	SPARE	JB-401	Infeed 2nd Floor	C1S05-X1	–	Spare	Spare Channel	–
C1-S05-P08	8	9	1756-IB32	Spare_DI_0	Pin 9	C1S5:9/TBDI2:9A	DI	24VDC Dry Contact	SPARE	JB-401	Infeed 2nd Floor	C1S05-X1	–	Spare	Spare Channel	–
C1-S05-P09	9	10	1756-IB32	Spare_DI_0	Pin 10	C1S5:10/TBDI2:10A	DI	24VDC Dry Contact	SPARE	JB-401	Infeed 2nd Floor	C1S05-X1	–	Spare	Spare Channel	–
C1-S05-P10	10	11	1756-IB32	Spare_DI_0	Pin 11	C1S5:11/TBDI2:11A	DI	24VDC Dry Contact	SPARE	JB-401	Infeed 2nd Floor	C1S05-X1	–	Spare	Spare Channel	–
C1-S05-P11	11	12	1756-IB32	Spare_DI_0	Pin 12	C1S5:12/TBDI2:12A	DI	24VDC Dry Contact	SPARE	JB-401	Infeed 2nd Floor	C1S05-X1	–	Spare	Spare Channel	–
C1-S05-P12	12	13	1756-IB32	Spare_DI_0	Pin 13	C1S5:13/TBDI2:13A	DI	24VDC Dry Contact	SPARE	JB-401	Infeed 2nd Floor	C1S05-X1	–	Spare	Spare Channel	–
C1-S05-P13	13	14	1756-IB32	Spare_DI_0	Pin 14	C1S5:14/TBDI2:14A	DI	24VDC Dry Contact	SPARE	JB-401	Infeed 2nd Floor	C1S05-X1	–	Spare	Spare Channel	–
C1-S05-P14	14	15	1756-IB32	Spare_DI_0	Pin 15	C1S5:15/TBDI2:15A	DI	24VDC Dry Contact	SPARE	JB-401	Infeed 2nd Floor	C1S05-X1	–	Spare	Spare Channel	–
C1-S05-P15	15	16	1756-IB32	Spare_DI_0	Pin 16	C1S5:16/TBDI2:16A	DI	24VDC Dry Contact	SPARE	JB-401	Infeed 2nd Floor	C1S05-X1	–	Spare	Spare Channel	–
C1-S05-P16	16	17	1756-IB32	ES-60202_DI_1	Pin 17	C1S5:17/C1S05-X2:17	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S05-X2	–	ES-60202		–

SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)							SIGNAL SPEC			DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C1-S05-P17	17	18	1756-IB32	FS-60205_DI_1	Pin 18	C155:18/C1505-X2:18	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C1505-X2	-	FS-60205	Flow Switch	3-25-01-602-PD-01
C1-S05-P18	18	19	1756-IB32	LSL-60201_DI_1	Pin 19	C155:19/TBDI2:17A	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C1505-X2	-	LSL-60201		3-25-01-602-PD-11
C1-S05-P19	19	20	1756-IB32	SV-60201_DI_1	Pin 20	C155:20/TBDI2:18A	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C1505-X2	-	SV-60201		3-25-01-602-PD-08
C1-S05-P20	20	21	1756-IB32	SV-60201_DI_2	Pin 21	C155:21/TBDI2:19A	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C1505-X2	-	SV-60201		3-25-01-602-PD-08
C1-S05-P21	21	22	1756-IB32	SV-60202_DI_1	Pin 22	C155:22/TBDI2:20A	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C1505-X2	-	SV-60202		3-25-01-602-PD-08
C1-S05-P22	22	23	1756-IB32	SV-60202_DI_2	Pin 23	C155:23/TBDI2:21A	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C1505-X2	-	SV-60202		3-25-01-602-PD-08
C1-S05-P23	23	24	1756-IB32	SV-60203_DI_1	Pin 24	C155:24/TBDI2:22A	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C1505-X2	-	SV-60203		3-25-01-602-PD-08
C1-S05-P24	24	25	1756-IB32	SV-60203_DI_2	Pin 25	C155:25/TBDI2:23A	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C1505-X2	-	SV-60203		3-25-01-602-PD-08
C1-S05-P25	25	26	1756-IB32	VS-60205_DI_1	Pin 26	C155:26/TBDI2:24A	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C1505-X2	-	VS-60205	Vibration Switch	3-25-01-602-PD-01
C1-S05-P26	26	27	1756-IB32	Spare_DI_0	Pin 27	C155:27/TBDI2:25A	DI	24VDC Dry Contact	SPARE	JB-601	Spray Dryer 1st Floor	C1505-X2	-	Spare	Spare Channel	-
C1-S05-P27	27	28	1756-IB32	Spare_DI_0	Pin 28	C155:28/TBDI2:26A	DI	24VDC Dry Contact	SPARE	JB-601	Spray Dryer 1st Floor	C1505-X2	-	Spare	Spare Channel	-
C1-S05-P28	28	29	1756-IB32	Spare_DI_0	Pin 29	C155:29/TBDI2:27A	DI	24VDC Dry Contact	SPARE	JB-601	Spray Dryer 1st Floor	C1505-X2	-	Spare	Spare Channel	-
C1-S05-P29	29	30	1756-IB32	Spare_DI_0	Pin 30	C155:30/TBDI2:28A	DI	24VDC Dry Contact	SPARE	JB-601	Spray Dryer 1st Floor	C1505-X2	-	Spare	Spare Channel	-
C1-S05-P30	30	31	1756-IB32	Spare_DI_0	Pin 31	C155:31/TBDI2:29A	DI	24VDC Dry Contact	SPARE	JB-601	Spray Dryer 1st Floor	C1505-X2	-	Spare	Spare Channel	-
C1-S05-P31	31	32	1756-IB32	Spare_DI_0	Pin 32	C155:32/TBDI2:30A	DI	24VDC Dry Contact	SPARE	JB-601	Spray Dryer 1st Floor	C1505-X2	-	Spare	Spare Channel	-

C1 SLOT 06 — 1756-IB32 (DI)													Capacity: 32 Pts Active: 23 Spare: 9 (28.1%)				
Rack: Main Controller Rack (Chassis 1) Location: Control Cabinet CA1 (Main Control Room) Protocol: Stratix 5400 / EN4TR Ring Node 1 (192.168.1.10)																	
Source Specification (PLC Rack / Card Pin / Eplan Wire Tag)							Signal Spec			Destination Specification (Field JB / MCC / Terminal Pin / Instrument Tag)							
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing	
C1-S06-P00	0	1	1756-IB32	XA-60202A_DI_1	Pin 1	C1S6:1/TBDI3:1A	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S06-X1	–	XA-60202A		–	
C1-S06-P01	1	2	1756-IB32	XA-60202B_DI_1	Pin 2	C1S6:2/TBDI3:2A	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S06-X1	–	XA-60202B		–	
C1-S06-P02	2	3	1756-IB32	XA-60202C_DI_1	Pin 3	C1S6:3/TBDI3:3A	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S06-X1	–	XA-60202C		–	
C1-S06-P03	3	4	1756-IB32	XA-60202D_DI_1	Pin 4	C1S6:4/TBDI3:4A	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S06-X1	–	XA-60202D		–	
C1-S06-P04	4	5	1756-IB32	XA-60202E_DI_1	Pin 5	C1S6:5/TBDI3:5A	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S06-X1	–	XA-60202E		–	
C1-S06-P05	5	6	1756-IB32	XA-60202F_DI_1	Pin 6	C1S6:6/TBDI3:6A	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S06-X1	–	XA-60202F		–	
C1-S06-P06	6	7	1756-IB32	XA-60202G_DI_1	Pin 7	C1S6:7/TBDI3:7A	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S06-X1	–	XA-60202G		–	
C1-S06-P07	7	8	1756-IB32	XA-60202H_DI_1	Pin 8	C1S6:8/TBDI3:8A	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S06-X1	–	XA-60202H		–	
C1-S06-P08	8	9	1756-IB32	XA-60202I_DI_1	Pin 9	C1S6:9/TBDI3:9A	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S06-X1	–	XA-60202I		–	
C1-S06-P09	9	10	1756-IB32	XA-60202J_DI_1	Pin 10	C1S6:10/TBDI3:10A	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S06-X1	–	XA-60202J		–	
C1-S06-P10	10	11	1756-IB32	XA-60202K_DI_1	Pin 11	C1S6:11/TBDI3:11A	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S06-X1	–	XA-60202K		–	
C1-S06-P11	11	12	1756-IB32	XA-60202L_DI_1	Pin 12	C1S6:12/TBDI3:12A	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S06-X1	–	XA-60202L		–	
C1-S06-P12	12	13	1756-IB32	XA-60202M_DI_1	Pin 13	C1S6:13/TBDI3:13A	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S06-X1	–	XA-60202M		–	
C1-S06-P13	13	14	1756-IB32	XV-60202_DI_1	Pin 14	C1S6:14/TBDI3:14A	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S06-X1	–	XV-60202		3-25-01-602-PD-11	
C1-S06-P14	14	15	1756-IB32	XV-60202_DI_2	Pin 15	C1S6:15/TBDI3:15A	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S06-X1	–	XV-60202		3-25-01-602-PD-11	
C1-S06-P15	15	16	1756-IB32	XV-60205A_DI_1	Pin 16	C1S6:16/TBDI3:16A	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S06-X1	–	XV-60205A		3-25-01-602-PD-01	
C1-S06-P16	16	17	1756-IB32	XV-60205A_DI_2	Pin 17	C1S6:17/C1S06-X2:17	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S06-X2	–	XV-60205A		3-25-01-602-PD-01	

SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)							SIGNAL SPEC			DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C1-S06-P17	17	18	1756-IB32	XV-60240D_DI_1	Pin 18	C1S6:18/C1S06-X2:18	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S06-X2	-	XV-60240D		-
C1-S06-P18	18	19	1756-IB32	XV-60240D_DI_2	Pin 19	C1S6:19/TBDI3:17A	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S06-X2	-	XV-60240D		3-25-01-602-PD-05
C1-S06-P19	19	20	1756-IB32	XV-60240D_DI_1	Pin 20	C1S6:20/TBDI3:18A	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S06-X2	-	XV-60240D		-
C1-S06-P20	20	21	1756-IB32	XV-60240D_DI_2	Pin 21	C1S6:21/TBDI3:19A	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S06-X2	-	XV-60240D		3-25-01-602-PD-05
C1-S06-P21	21	22	1756-IB32	YA-60205_DI_1	Pin 22	C1S6:22/TBDI3:20A	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S06-X2	-	YA-60205		-
C1-S06-P22	22	23	1756-IB32	YI-60205_DI_1	Pin 23	C1S6:23/TBDI3:21A	DI	24VDC Dry Contact	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S06-X2	-	YI-60205		-
C1-S06-P23	23	24	1756-IB32	Spare_DI_0	Pin 24	C1S6:24/TBDI3:22A	DI	24VDC Dry Contact	SPARE	JB-601	Spray Dryer 1st Floor	C1S06-X2	-	Spare	Spare Channel	-
C1-S06-P24	24	25	1756-IB32	Spare_DI_0	Pin 25	C1S6:25/TBDI3:23A	DI	24VDC Dry Contact	SPARE	JB-601	Spray Dryer 1st Floor	C1S06-X2	-	Spare	Spare Channel	-
C1-S06-P25	25	26	1756-IB32	Spare_DI_0	Pin 26	C1S6:26/TBDI3:24A	DI	24VDC Dry Contact	SPARE	JB-601	Spray Dryer 1st Floor	C1S06-X2	-	Spare	Spare Channel	-
C1-S06-P26	26	27	1756-IB32	Spare_DI_0	Pin 27	C1S6:27/TBDI3:25A	DI	24VDC Dry Contact	SPARE	JB-601	Spray Dryer 1st Floor	C1S06-X2	-	Spare	Spare Channel	-
C1-S06-P27	27	28	1756-IB32	Spare_DI_0	Pin 28	C1S6:28/TBDI3:26A	DI	24VDC Dry Contact	SPARE	JB-601	Spray Dryer 1st Floor	C1S06-X2	-	Spare	Spare Channel	-
C1-S06-P28	28	29	1756-IB32	Spare_DI_0	Pin 29	C1S6:29/TBDI3:27A	DI	24VDC Dry Contact	SPARE	JB-601	Spray Dryer 1st Floor	C1S06-X2	-	Spare	Spare Channel	-
C1-S06-P29	29	30	1756-IB32	Spare_DI_0	Pin 30	C1S6:30/TBDI3:28A	DI	24VDC Dry Contact	SPARE	JB-601	Spray Dryer 1st Floor	C1S06-X2	-	Spare	Spare Channel	-
C1-S06-P30	30	31	1756-IB32	Spare_DI_0	Pin 31	C1S6:31/TBDI3:29A	DI	24VDC Dry Contact	SPARE	JB-601	Spray Dryer 1st Floor	C1S06-X2	-	Spare	Spare Channel	-
C1-S06-P31	31	32	1756-IB32	Spare_DI_0	Pin 32	C1S6:32/TBDI3:30A	DI	24VDC Dry Contact	SPARE	JB-601	Spray Dryer 1st Floor	C1S06-X2	-	Spare	Spare Channel	-

C1 SLOT 07 — 1756-OB32 (DO)

Rack: Main Controller Rack (Chassis 1) | Location: Control Cabinet CA1 (Main Control Room) | Protocol: Stratix 5400 / EN4TR Ring Node 1 (192.168.1.10)

Capacity: 32 Pts | Active: 16 | Spare: 16 (50.0%)

SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)							SIGNAL SPEC			DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C1-S07-P00	0	1	1756-OB32	Spare_D0_0	Pin 1	C1S7:1/TBDI4:1A	DO	24VDC Sourcing	SPARE	CA1	Main Control Cabinet	C1S07-X1	-	Spare	Spare Channel	-
C1-S07-P01	1	2	1756-OB32	Spare_D0_0	Pin 2	C1S7:2/TBDI4:2A	DO	24VDC Sourcing	SPARE	CA1	Main Control Cabinet	C1S07-X1	-	Spare	Spare Channel	-
C1-S07-P02	2	3	1756-OB32	Spare_D0_0	Pin 3	C1S7:3/TBDI4:3A	DO	24VDC Sourcing	SPARE	CA1	Main Control Cabinet	C1S07-X1	-	Spare	Spare Channel	-
C1-S07-P03	3	4	1756-OB32	Spare_D0_0	Pin 4	C1S7:4/TBDI4:4A	DO	24VDC Sourcing	SPARE	CA1	Main Control Cabinet	C1S07-X1	-	Spare	Spare Channel	-
C1-S07-P04	4	5	1756-OB32	Spare_D0_0	Pin 5	C1S7:5/TBDI4:5A	DO	24VDC Sourcing	SPARE	CA1	Main Control Cabinet	C1S07-X1	-	Spare	Spare Channel	-
C1-S07-P05	5	6	1756-OB32	Spare_D0_0	Pin 6	C1S7:6/TBDI4:6A	DO	24VDC Sourcing	SPARE	CA1	Main Control Cabinet	C1S07-X1	-	Spare	Spare Channel	-
C1-S07-P06	6	7	1756-OB32	Spare_D0_0	Pin 7	C1S7:7/TBDI4:7A	DO	24VDC Sourcing	SPARE	CA1	Main Control Cabinet	C1S07-X1	-	Spare	Spare Channel	-
C1-S07-P07	7	8	1756-OB32	Spare_D0_0	Pin 8	C1S7:8/TBDI4:8A	DO	24VDC Sourcing	SPARE	CA1	Main Control Cabinet	C1S07-X1	-	Spare	Spare Channel	-
C1-S07-P08	8	9	1756-OB32	Spare_D0_0	Pin 9	C1S7:9/TBDI4:9A	DO	24VDC Sourcing	SPARE	CA1	Main Control Cabinet	C1S07-X1	-	Spare	Spare Channel	-
C1-S07-P09	9	10	1756-OB32	Spare_D0_0	Pin 10	C1S7:10/TBDI4:10A	DO	24VDC Sourcing	SPARE	CA1	Main Control Cabinet	C1S07-X1	-	Spare	Spare Channel	-
C1-S07-P10	10	11	1756-OB32	Spare_D0_0	Pin 11	C1S7:11/TBDI4:11A	DO	24VDC Sourcing	SPARE	CA1	Main Control Cabinet	C1S07-X1	-	Spare	Spare Channel	-
C1-S07-P11	11	12	1756-OB32	Spare_D0_0	Pin 12	C1S7:12/TBDI4:12A	DO	24VDC Sourcing	SPARE	CA1	Main Control Cabinet	C1S07-X1	-	Spare	Spare Channel	-
C1-S07-P12	12	13	1756-OB32	Spare_D0_0	Pin 13	C1S7:13/TBDI4:13A	DO	24VDC Sourcing	SPARE	CA1	Main Control Cabinet	C1S07-X1	-	Spare	Spare Channel	-
C1-S07-P13	13	14	1756-OB32	Spare_D0_0	Pin 14	C1S7:14/TBDI4:14A	DO	24VDC Sourcing	SPARE	CA1	Main Control Cabinet	C1S07-X1	-	Spare	Spare Channel	-
C1-S07-P14	14	15	1756-OB32	Spare_D0_0	Pin 15	C1S7:15/TBDI4:15A	DO	24VDC Sourcing	SPARE	CA1	Main Control Cabinet	C1S07-X1	-	Spare	Spare Channel	-
C1-S07-P15	15	16	1756-OB32	Spare_D0_0	Pin 16	C1S7:16/TBDI4:16A	DO	24VDC Sourcing	SPARE	CA1	Main Control Cabinet	C1S07-X1	-	Spare	Spare Channel	-
C1-S07-P16	16	17	1756-OB32	XV-40202E_D0_1	Pin 17	C1S7:17/C1S07-X2:17	DO	24VDC Sourcing	ACTIVE	JB-401	Infeed 2nd Floor	C1S07-X2	-	XV-40202E		3-25-01-402-PD-01

SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)							SIGNAL SPEC			DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C1-S07-P17	17	18	1756-OB32	XV-40202F_D0_1	Pin 18	C1S7:18/C1S07-X2:18	DO	24VDC Sourcing	ACTIVE	JB-401	Infeed 2nd Floor	C1S07-X2	-	XV-40202F		3-25-01-402-PD-01
C1-S07-P18	18	19	1756-OB32	XV-40202G_D0_1	Pin 19	C1S7:19/TBDI4:17A	DO	24VDC Sourcing	ACTIVE	JB-401	Infeed 2nd Floor	C1S07-X2	-	XV-40202G		3-25-01-402-PD-01
C1-S07-P19	19	20	1756-OB32	XV-40202H_D0_1	Pin 20	C1S7:20/TBDI4:18A	DO	24VDC Sourcing	ACTIVE	JB-401	Infeed 2nd Floor	C1S07-X2	-	XV-40202H		3-25-01-402-PD-01
C1-S07-P20	20	21	1756-OB32	XV-40203B_D0_1	Pin 21	C1S7:21/TBDI4:19A	DO	24VDC Sourcing	ACTIVE	JB-401	Infeed 2nd Floor	C1S07-X2	-	XV-40203B		3-25-01-402-PD-02
C1-S07-P21	21	22	1756-OB32	XV-40203C_D0_1	Pin 22	C1S7:22/TBDI4:20A	DO	24VDC Sourcing	ACTIVE	JB-401	Infeed 2nd Floor	C1S07-X2	-	XV-40203C		3-25-01-402-PD-02
C1-S07-P22	22	23	1756-OB32	XV-40203D_D0_1	Pin 23	C1S7:23/TBDI4:21A	DO	24VDC Sourcing	ACTIVE	JB-401	Infeed 2nd Floor	C1S07-X2	-	XV-40203D		3-25-01-402-PD-02
C1-S07-P23	23	24	1756-OB32	XV-40203E_D0_1	Pin 24	C1S7:24/TBDI4:22A	DO	24VDC Sourcing	ACTIVE	JB-401	Infeed 2nd Floor	C1S07-X2	-	XV-40203E		3-25-01-402-PD-02
C1-S07-P24	24	25	1756-OB32	SV-40201_D0_1	Pin 25	C1S7:25/TBDI4:23A	DO	24VDC Sourcing	ACTIVE	JB-401	Infeed 2nd Floor	C1S07-X2	-	SV-40201		3-25-01-402-PD-01
C1-S07-P25	25	26	1756-OB32	SV-40202_D0_1	Pin 26	C1S7:26/TBDI4:24A	DO	24VDC Sourcing	ACTIVE	JB-401	Infeed 2nd Floor	C1S07-X2	-	SV-40202		3-25-01-402-PD-01
C1-S07-P26	26	27	1756-OB32	SV-40203_D0_1	Pin 27	C1S7:27/TBDI4:25A	DO	24VDC Sourcing	ACTIVE	JB-401	Infeed 2nd Floor	C1S07-X2	-	SV-40203		3-25-01-402-PD-01
C1-S07-P27	27	28	1756-OB32	SV-40204_D0_1	Pin 28	C1S7:28/TBDI4:26A	DO	24VDC Sourcing	ACTIVE	JB-401	Infeed 2nd Floor	C1S07-X2	-	SV-40204		3-25-01-402-PD-01
C1-S07-P28	28	29	1756-OB32	XV-40201A_D0_1	Pin 29	C1S7:29/TBDI4:27A	DO	24VDC Sourcing	ACTIVE	JB-401	Infeed 2nd Floor	C1S07-X2	-	XV-40201A		3-25-01-402-PD-01
C1-S07-P29	29	30	1756-OB32	XV-40201B_D0_1	Pin 30	C1S7:30/TBDI4:28A	DO	24VDC Sourcing	ACTIVE	JB-401	Infeed 2nd Floor	C1S07-X2	-	XV-40201B		3-25-01-402-PD-01
C1-S07-P30	30	31	1756-OB32	XV-40201C_D0_1	Pin 31	C1S7:31/TBDI4:29A	DO	24VDC Sourcing	ACTIVE	JB-401	Infeed 2nd Floor	C1S07-X2	-	XV-40201C		3-25-01-402-PD-01
C1-S07-P31	31	32	1756-OB32	XV-40201D_D0_1	Pin 32	C1S7:32/TBDI4:30A	DO	24VDC Sourcing	ACTIVE	JB-401	Infeed 2nd Floor	C1S07-X2	-	XV-40201D		3-25-01-402-PD-01

C1 SLOT 08 — 1756-OB32 (DO)																
Rack: Main Controller Rack (Chassis 1) Location: Control Cabinet CA1 (Main Control Room) Protocol: Stratix 5400 / EN4TR Ring Node 1 (192.168.1.10)														Capacity: 32 Pts Active: 20 Spare: 12 (37.5%)		
Source Specification (PLC Rack / Card Pin / Eplan Wire Tag)							Signal Spec			Destination Specification (Field JB / MCC / Terminal Pin / Instrument Tag)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C1-S08-P00	0	1	1756-OB32	XV-40201E_DO_1	Pin 1	C1S8:1/RL.1:A1	DO	24VDC Sourcing	ACTIVE	JB-401	Infeed 2nd Floor	C1S08-X1	–	XV-40201E		3-25-01-402-PD-01
C1-S08-P01	1	2	1756-OB32	XV-40201F_DO_1	Pin 2	C1S8:2/RL.2:A1	DO	24VDC Sourcing	ACTIVE	JB-401	Infeed 2nd Floor	C1S08-X1	–	XV-40201F		3-25-01-402-PD-01
C1-S08-P02	2	3	1756-OB32	XV-40201G_DO_1	Pin 3	C1S8:3/RL.3:A1	DO	24VDC Sourcing	ACTIVE	JB-401	Infeed 2nd Floor	C1S08-X1	–	XV-40201G		3-25-01-402-PD-01
C1-S08-P03	3	4	1756-OB32	XV-40201H_DO_1	Pin 4	C1S8:4/RL.4:A1	DO	24VDC Sourcing	ACTIVE	JB-401	Infeed 2nd Floor	C1S08-X1	–	XV-40201H		3-25-01-402-PD-01
C1-S08-P04	4	5	1756-OB32	XV-40202A_DO_1	Pin 5	C1S8:5/RL.5:A1	DO	24VDC Sourcing	ACTIVE	JB-401	Infeed 2nd Floor	C1S08-X1	–	XV-40202A		3-25-01-402-PD-01
C1-S08-P05	5	6	1756-OB32	XV-40202B_DO_1	Pin 6	C1S8:6/RL.6:A1	DO	24VDC Sourcing	ACTIVE	JB-401	Infeed 2nd Floor	C1S08-X1	–	XV-40202B		3-25-01-402-PD-01
C1-S08-P06	6	7	1756-OB32	XV-40202C_DO_1	Pin 7	C1S8:7/RL.7:A1	DO	24VDC Sourcing	ACTIVE	JB-401	Infeed 2nd Floor	C1S08-X1	–	XV-40202C		3-25-01-402-PD-01
C1-S08-P07	7	8	1756-OB32	XV-40202D_DO_1	Pin 8	C1S8:8/RL.8:A1	DO	24VDC Sourcing	ACTIVE	JB-401	Infeed 2nd Floor	C1S08-X1	–	XV-40202D		3-25-01-402-PD-01
C1-S08-P08	8	9	1756-OB32	Spare_DO_0	Pin 9	C1S8:9/RL.9:A1	DO	24VDC Sourcing	SPARE	JB-401	Infeed 2nd Floor	C1S08-X1	–	Spare	Spare Channel	–
C1-S08-P09	9	10	1756-OB32	Spare_DO_0	Pin 10	C1S8:10/RL.10:A1	DO	24VDC Sourcing	SPARE	JB-401	Infeed 2nd Floor	C1S08-X1	–	Spare	Spare Channel	–
C1-S08-P10	10	11	1756-OB32	Spare_DO_0	Pin 11	C1S8:11/RL.11:A1	DO	24VDC Sourcing	SPARE	JB-401	Infeed 2nd Floor	C1S08-X1	–	Spare	Spare Channel	–
C1-S08-P11	11	12	1756-OB32	Spare_DO_0	Pin 12	C1S8:12/RL.12:A1	DO	24VDC Sourcing	SPARE	JB-401	Infeed 2nd Floor	C1S08-X1	–	Spare	Spare Channel	–
C1-S08-P12	12	13	1756-OB32	Spare_DO_0	Pin 13	C1S8:13/RL.13:A1	DO	24VDC Sourcing	SPARE	JB-401	Infeed 2nd Floor	C1S08-X1	–	Spare	Spare Channel	–
C1-S08-P13	13	14	1756-OB32	Spare_DO_0	Pin 14	C1S8:14/RL.14:A1	DO	24VDC Sourcing	SPARE	JB-401	Infeed 2nd Floor	C1S08-X1	–	Spare	Spare Channel	–
C1-S08-P14	14	15	1756-OB32	Spare_DO_0	Pin 15	C1S8:15/RL.15:A1	DO	24VDC Sourcing	SPARE	JB-401	Infeed 2nd Floor	C1S08-X1	–	Spare	Spare Channel	–
C1-S08-P15	15	16	1756-OB32	Spare_DO_0	Pin 16	C1S8:16/RL.16:A1	DO	24VDC Sourcing	SPARE	JB-401	Infeed 2nd Floor	C1S08-X1	–	Spare	Spare Channel	–
C1-S08-P16	16	17	1756-OB32	SV-60201_DO_1	Pin 17	C1S8:17/C1S08-X2:17	DO	24VDC Sourcing	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S08-X2	–	SV-60201		3-25-01-602-PD-08

SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)							SIGNAL SPEC			DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG)						
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing
C1-S08-P17	17	18	1756-OB32	SV-60202_DO_1	Pin 18	C1S8:18/C1S08-X2:18	DO	24VDC Sourcing	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S08-X2	-	SV-60202		3-25-01-602-PD-08
C1-S08-P18	18	19	1756-OB32	SV-60230_DO_1	Pin 19	C1S8:19/RL.17:A1	DO	24VDC Sourcing	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S08-X2	-	SV-60230		3-25-01-602-PD-04
C1-S08-P19	19	20	1756-OB32	SV-60203_DO_1	Pin 20	C1S8:20/RL.18:A1	DO	24VDC Sourcing	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S08-X2	-	SV-60203		3-25-01-602-PD-08
C1-S08-P20	20	21	1756-OB32	SV-60240A_DO_1	Pin 21	C1S8:21/RL.19:A1	DO	24VDC Sourcing	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S08-X2	-	SV-60240A		3-25-01-602-PD-05
C1-S08-P21	21	22	1756-OB32	SV-60231_DO_1	Pin 22	C1S8:22/RL.20:A1	DO	24VDC Sourcing	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S08-X2	-	SV-60231		3-25-01-602-PD-04
C1-S08-P22	22	23	1756-OB32	SV-60240B_DO_1	Pin 23	C1S8:23/RL.21:A1	DO	24VDC Sourcing	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S08-X2	-	SV-60240B		3-25-01-602-PD-05
C1-S08-P23	23	24	1756-OB32	SV-60240C_DO_1	Pin 24	C1S8:24/RL.22:A1	DO	24VDC Sourcing	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S08-X2	-	SV-60240C		3-25-01-602-PD-05
C1-S08-P24	24	25	1756-OB32	XV-60240D_DO_1	Pin 25	C1S8:25/RL.23:A1	DO	24VDC Sourcing	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S08-X2	-	XV-60240D		-
C1-S08-P25	25	26	1756-OB32	XV-60251_DO_1	Pin 26	C1S8:26/RL.24:A1	DO	24VDC Sourcing	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S08-X2	-	XV-60251		3-25-01-602-PD-01
C1-S08-P26	26	27	1756-OB32	XV-60202_DO_1	Pin 27	C1S8:27/RL.25:A1	DO	24VDC Sourcing	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S08-X2	-	XV-60202		3-25-01-602-PD-11
C1-S08-P27	27	28	1756-OB32	XV-60205A_DO_1	Pin 28	C1S8:28/RL.26:A1	DO	24VDC Sourcing	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S08-X2	-	XV-60205A		3-25-01-602-PD-01
C1-S08-P28	28	29	1756-OB32	Spare_DO_0	Pin 29	C1S8:29/RL.27:A1	DO	24VDC Sourcing	SPARE	JB-601	Spray Dryer 1st Floor	C1S08-X2	-	Spare	Spare Channel	-
C1-S08-P29	29	30	1756-OB32	Spare_DO_0	Pin 30	C1S8:30/RL.28:A1	DO	24VDC Sourcing	SPARE	JB-601	Spray Dryer 1st Floor	C1S08-X2	-	Spare	Spare Channel	-
C1-S08-P30	30	31	1756-OB32	Spare_DO_0	Pin 31	C1S8:31/RL.29:A1	DO	24VDC Sourcing	SPARE	JB-601	Spray Dryer 1st Floor	C1S08-X2	-	Spare	Spare Channel	-
C1-S08-P31	31	32	1756-OB32	Spare_DO_0	Pin 32	C1S8:32/RL.30:A1	DO	24VDC Sourcing	SPARE	JB-601	Spray Dryer 1st Floor	C1S08-X2	-	Spare	Spare Channel	-

C1 SLOT 09 — 1756-IF16 (AI)											Capacity: 16 Pts Active: 11 Spare: 5 (31.2%)						
Rack: Main Controller Rack (Chassis 1) Location: Control Cabinet CA1 (Main Control Room) Protocol: Stratix 5400 / EN4TR Ring Node 1 (192.168.1.10)																	
SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)							SIGNAL SPEC			DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG)							
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing	
C1-S09-P00	0	1	1756-IF16	FT-40201_AI_1	Pin 1	C1S9:1/RL.33:A1	AI	4-20mA HART	ACTIVE	JB-401	Infeed 2nd Floor	C1S09-X1	-	FT-40201	Coriolis Flow Transmitter	3-25-01-402-PD-02	
C1-S09-P01	1	2	1756-IF16	FT-40201_AI_2	Pin 2	C1S9:2/RL.34:A1	AI	4-20mA HART	ACTIVE	JB-401	Infeed 2nd Floor	C1S09-X1	-	FT-40201	Coriolis Flow Transmitter	3-25-01-402-PD-02	
C1-S09-P02	2	3	1756-IF16	FT-40202_AI_1	Pin 3	C1S9:3/RL.35:A1	AI	4-20mA HART	ACTIVE	JB-401	Infeed 2nd Floor	C1S09-X1	-	FT-40202	Magnetic Flow Transmitter	3-25-01-402-PD-02	
C1-S09-P03	3	4	1756-IF16	LT-40203_AI_1	Pin 4	C1S9:4/RL.36:A1	AI	4-20mA HART	ACTIVE	JB-401	Infeed 2nd Floor	C1S09-X1	-	LT-40203	Level Transmitter	3-25-01-402-PD-02	
C1-S09-P04	4	5	1756-IF16	LT-40201_AI_1	Pin 5	C1S9:5/RL.37:A1	AI	4-20mA HART	ACTIVE	JB-401	Infeed 2nd Floor	C1S09-X1	-	LT-40201	Level Transmitter	3-25-01-402-PD-01	
C1-S09-P05	5	6	1756-IF16	LT-40202_AI_1	Pin 6	C1S9:6/RL.38:A1	AI	4-20mA HART	ACTIVE	JB-401	Infeed 2nd Floor	C1S09-X1	-	LT-40202	Level Transmitter	3-25-01-402-PD-01	
C1-S09-P06	6	7	1756-IF16	pHT-40201_AI_1	Pin 7	C1S9:7/RL.39:A1	AI	4-20mA HART	ACTIVE	JB-401	Infeed 2nd Floor	C1S09-X1	-	pHT-40201	PH Transmitter	3-25-01-402-PD-01	
C1-S09-P07	7	8	1756-IF16	pHT-40202_AI_1	Pin 8	C1S9:8/RL.40:A1	AI	4-20mA HART	ACTIVE	JB-401	Infeed 2nd Floor	C1S09-X1	-	pHT-40202	PH Transmitter	3-25-01-402-PD-01	
C1-S09-P08	8	9	1756-IF16	PT-40201_AI_1	Pin 9	C1S9:9/RL.41:A1	AI	4-20mA HART	ACTIVE	JB-401	Infeed 2nd Floor	C1S09-X1	-	PT-40201	Pressure Transmitter	3-25-01-402-PD-02	
C1-S09-P09	9	10	1756-IF16	PT-40202_AI_1	Pin 10	C1S9:10/RL.42:A1	AI	4-20mA HART	ACTIVE	JB-401	Infeed 2nd Floor	C1S09-X1	-	PT-40202	Pressure Transmitter	3-25-01-402-PD-02	
C1-S09-P10	10	11	1756-IF16	PT-60202_AI_1	Pin 11	C1S9:11/RL.43:A1	AI	4-20mA HART	ACTIVE	JB-401	Infeed 2nd Floor	C1S09-X1	-	PT-60202	Pressure Transmitter	3-25-01-602-PD-01	
C1-S09-P11	11	12	1756-IF16	Spare_AI_0	Pin 12	C1S9:12/RL.44:A1	AI	4-20mA HART	SPARE	JB-401	Infeed 2nd Floor	C1S09-X1	-	Spare	Spare Channel	-	
C1-S09-P12	12	13	1756-IF16	Spare_AI_0	Pin 13	C1S9:13/RL.45:A1	AI	4-20mA HART	SPARE	JB-401	Infeed 2nd Floor	C1S09-X1	-	Spare	Spare Channel	-	
C1-S09-P13	13	14	1756-IF16	Spare_AI_0	Pin 14	C1S9:14/RL.46:A1	AI	4-20mA HART	SPARE	JB-401	Infeed 2nd Floor	C1S09-X1	-	Spare	Spare Channel	-	
C1-S09-P14	14	15	1756-IF16	Spare_AI_0	Pin 15	C1S9:15/RL.47:A1	AI	4-20mA HART	SPARE	JB-401	Infeed 2nd Floor	C1S09-X1	-	Spare	Spare Channel	-	
C1-S09-P15	15	16	1756-IF16	Spare_AI_0	Pin 16	C1S9:16/RL.48:A1	AI	4-20mA HART	SPARE	JB-401	Infeed 2nd Floor	C1S09-X1	-	Spare	Spare Channel	-	

C1 SLOT 10 — 1756-IF16 (AI)											Capacity: 16 Pts Active: 8 Spare: 8 (50.0%)						
Rack: Main Controller Rack (Chassis 1) Location: Control Cabinet CA1 (Main Control Room) Protocol: Stratix 5400 / EN4TR Ring Node 1 (192.168.1.10)																	
SOURCE SPECIFICATION (PLC RACK / CARD PIN / EPLAN WIRE TAG)							SIGNAL SPEC			DESTINATION SPECIFICATION (FIELD JB / MCC / TERMINAL PIN / INSTRUMENT TAG)							
Point Ref ID	Pt	Ch	Module	PLC Tag Name	Card Pin	ePlan Wire Tag	Type	Signal Spec	Status	Destination	Location / Floor	TB / Fuse	Pin	Instrument Tag	Instrument Description	P&ID Drawing	
C1-S10-P00	0	1	1756-IF16	DPI-60240_AI_1	Pin 1	C1S10:1/C1S10-X1:1	AI	4-20mA HART	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S10-X1	–	DPI-60240		–	
C1-S10-P01	1	2	1756-IF16	DPT-60202_AI_1	Pin 2	C1S10:2/C1S10-X1:2	AI	4-20mA HART	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S10-X1	–	DPT-60202	Differential Pressure Transmitte	3-25-01-602-PD-08	
C1-S10-P02	2	3	1756-IF16	FT-60201_AI_1	Pin 3	C1S10:3/C1S10-X1:3	AI	4-20mA HART	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S10-X1	–	FT-60201		3-25-01-602-PD-08	
C1-S10-P03	3	4	1756-IF16	FT-60204_AI_1	Pin 4	C1S10:4/C1S10-X1:4	AI	4-20mA HART	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S10-X1	–	FT-60204		3-25-01-602-PD-10	
C1-S10-P04	4	5	1756-IF16	FT-61307_AI_1	Pin 5	C1S10:5/C1S10-X1:5	AI	4-20mA HART	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S10-X1	–	FT-61307		3-25-01-613-PD-04	
C1-S10-P05	5	6	1756-IF16	PT-60203_AI_1	Pin 6	C1S10:6/C1S10-X1:6	AI	4-20mA HART	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S10-X1	–	PT-60203	Pressure Transmitter	3-25-01-602-PD-08	
C1-S10-P06	6	7	1756-IF16	PT-60204_AI_1	Pin 7	C1S10:7/C1S10-X1:7	AI	4-20mA HART	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S10-X1	–	PT-60204	Pressure Transmitter	3-25-01-602-PD-10	
C1-S10-P07	7	8	1756-IF16	PT-60205_AI_1	Pin 8	C1S10:8/C1S10-X1:8	AI	4-20mA HART	ACTIVE	JB-601	Spray Dryer 1st Floor	C1S10-X1	–	PT-60205	Pressure Transmitter	3-25-01-602-PD-01	
C1-S10-P08	8	9	1756-IF16	Spare_AI_0	Pin 9	C1S10:9/C1S10-X1:9	AI	4-20mA HART	SPARE	JB-601	Spray Dryer 1st Floor	C1S10-X1	–	Spare	Spare Channel	–	
C1-S10-P09	9	10	1756-IF16	Spare_AI_0	Pin 10	C1S10:10/C1S10-X1:10	AI	4-20mA HART	SPARE	JB-601	Spray Dryer 1st Floor	C1S10-X1	–	Spare	Spare Channel	–	
C1-S10-P10	10	11	1756-IF16	Spare_AI_0	Pin 11	C1S10:11/C1S10-X1:11	AI	4-20mA HART	SPARE	JB-601	Spray Dryer 1st Floor	C1S10-X1	–	Spare	Spare Channel	–	
C1-S10-P11	11	12	1756-IF16	Spare_AI_0	Pin 12	C1S10:12/C1S10-X1:12	AI	4-20mA HART	SPARE	JB-601	Spray Dryer 1st Floor	C1S10-X1	–	Spare	Spare Channel	–	
C1-S10-P12	12	13	1756-IF16	Spare_AI_0	Pin 13	C1S10:13/C1S10-X1:13	AI	4-20mA HART	SPARE	JB-601	Spray Dryer 1st Floor	C1S10-X1	–	Spare	Spare Channel	–	
C1-S10-P13	13	14	1756-IF16	Spare_AI_0	Pin 14	C1S10:14/C1S10-X1:14	AI	4-20mA HART	SPARE	JB-601	Spray Dryer 1st Floor	C1S10-X1	–	Spare	Spare Channel	–	
C1-S10-P14	14	15	1756-IF16	Spare_AI_0	Pin 15	C1S10:15/C1S10-X1:15	AI	4-20mA HART	SPARE	JB-601	Spray Dryer 1st Floor	C1S10-X1	–	Spare	Spare Channel	–	
C1-S10-P15	15	16	1756-IF16	Spare_AI_0	Pin 16	C1S10:16/C1S10-X1:16	AI	4-20mA HART	SPARE	JB-601	Spray Dryer 1st Floor	C1S10-X1	–	Spare	Spare Channel	–	