



Republic of the Philippines
Department of the Interior and Local Government
BUREAU OF FIRE PROTECTION
(FIRE STATION LETTERHEAD)



FIRE SAFETY INSPECTION CHECKLIST

I. REFERENCE

Inspection Order No. (IO) : _____
Date Issued : _____
Date Inspected : _____

II. NATURE OF INSPECTION CONDUCTED (Check appropriate box)

- ☐ Inspection during construction
☐ FSIC for Certificate of Annual Inspection (PEZA)
☐ FSIC for Certificate of Occupancy
☐ FSIC for Business Permit (New/Renewal)
☐ Verification Inspection for Compliance:
 ☐ NTC ☐ NTCV ☐ Abatement ☐ Closure

6. Others (Specify) :

III. REQUIREMENTS

- ☐ FSIC for Occupancy:
 Fire Safety Compliance and Commissioning Report (FSCCR) (if applicable) Yes ☐ / No ☐
☐ FSIC for New / Renewal / Annual Inspection / Others:
 Fire Safety Maintenance Report (FSMR) (if applicable) Yes ☐ / No ☐

IV. GENERAL INFORMATION

Name of Building : _____
Address : _____
Business Name : _____
Nature of Business : _____
Name of owner/Representative : _____
Contact No. : _____

- ☐ FSIC for Occupancy:
 • FSEC No. : _____ Date Issued : _____
 • Building Permit : _____ Date Issued : _____
☐ FSIC for New / Renewal / Annual Inspection / Others:
 • FSIC No. (Latest) : _____ Date Issued : _____
 • Certificate of Fire Drill : _____ Date Issued : _____
 • Business Permit No. : _____ Date Issued : _____
 • Fire Insurance Policy No. (If any) : _____ Date Issued : _____



Republic of the Philippines
Department of the Interior and Local Government
BUREAU OF FIRE PROTECTION
(FIRE STATION LETTERHEAD)



CONSTRUCTION TYPE

- ☐ Type I : Concrete & Steel (Fire Resistive)
☐ Type II : Concrete & Exposed Steel (Noncombustible)
☐ Type III : Concrete & Wood (Ordinary)
☐ Type IV : Heavy Timber (Large mass wood)
☐ Type V : Wood frame (Lightweight wood)

WALLS / CEILING INTERIOR FINISH

- ☐ Class A : Flame spread index, 0–25; smoke developed index, 0–450
☐ Class B : Flame spread index, 26–75; smoke developed index, 0–450
☐ Class C : Flame spread index, 76–200; smoke developed index, 0–450

(Note: Flame Spread Index can be seen in the technical specification of the product)

FLOOR INTERIOR FINISH

- ☐ Class I : Critical radiant flux, not less than 0.45 W/cm².
☐ Class II : Critical radiant flux, not more than 0.22 W/cm², but less than 0.45 W/cm²

(Note: Flame Spread Index can be seen in the technical specification of the product)

SECTIONAL OCCUPANCY (INDICATE SPECIFIC USAGE OF EACH FLOOR, PART OR PORTION OF THE BUILDING)

Basement : _____
Ground floor : _____
Second floor : _____
Third floor : _____
Fourth Floor : _____
Nth Floor : _____

Use separate sheet if necessary

GENERAL OCCUPANCY CLASSIFICATION

- ☐ Assembly ☐ Educational ☐ Day Care ☐ Health Care
☐ Detention and Correctional ☐ Residential ☐ Residential Board and Care
☐ Mercantile ☐ Business ☐ Industrial ☐ Storage ☐ Special Structure.

OTHER INFORMATION

Maximum Occupant Load: _____ P/Floor Number of Stories: _____ Storey

Building Height : _____ m Highrise : ☐ Yes / ☐ No



Republic of the Philippines
Department of the Interior and Local Government
BUREAU OF FIRE PROTECTION
(FIRE STATION LETTERHEAD)



V. MEANS OF EGRESS

A. EXIT ACCESS

☐ Doors / ☐ Corridors / ☐ Hallways / ☐ Passageways / ☐ Anterooms / ☐ Ramps

Horizontal components	Actual Dimensions	Passed	Failed	Remarks / Corrective Action
Doors	_____ m	☐	☐	
Corridors / Hallways	_____ m	☐	☐	
Passageways	_____ m	☐	☐	
Lobby / Anteroom	_____ m	☐	☐	



Republic of the Philippines
Department of the Interior and Local Government
BUREAU OF FIRE PROTECTION
(FIRE STATION LETTERHEAD)



Ramps	_____ m	☐	☐	
Common path of travel	_____ m	☐	☐	
Dead end	_____ m	☐	☐	
Travel distance	_____ m	☐	☐	

	Actual Dim.	Passed	Failed
Any door leaf in a means of egress shall leave not less than one-half of the required width of an aisle, a corridor, a passageway, or a landing unobstructed.		☐	☐
Any door leaf in a means of egress shall not project more than 180 mm into the required width of an aisle, a corridor, a passageway, or a landing, unless the door leaf is equipped with an approved self-closing device.		☐	☐
At least two (2) means of egress for each room with occupant load ≥ 50 or with hazard content.		☐	☐
Each guest door used as means of egress shall at least 20 minutes fire resistant.		☐	☐
Doors that open directly onto exit access corridors shall be self-closing and self-latching.		☐	☐
There shall no openings in corridor partitions other than door openings.		☐	☐
Free from any obstruction.		☐	☐
No flammable material stored.		☐	☐

B. EXITS

- ☐ Normal Stairs / ☐ Curved Stairs / ☐ Spiral Stairs / ☐ Winding Stairs
☐ Horizontal Exits / ☐ Outside Stairs / Exit Passageways / Fire Escape Stairs
☐ Fire Escape Ladder (for 1 & 2 family dwelling only)
☐ Slide Escape (for Industrial Occupancy Only)

Components	Clear Width	Passed	Failed	Remarks / Corrective Action
Exits Doors	_____ m	☐	☐	
Normal Stairs	_____ m	☐	☐	
Curve stairs	_____ m	☐	☐	
Winding Stairs	_____ m	☐	☐	
Horizontal Exits	_____ m	☐	☐	
Outside Stairs	_____ m	☐	☐	



Republic of the Philippines
Department of the Interior and Local Government
BUREAU OF FIRE PROTECTION
(FIRE STATION LETTERHEAD)



Exit Passageways	_____ m	☐	☐	
Fire Escape Stairs	_____ m	☐	☐	
Fire Escape Ladders	_____ m	☐	☐	
Slide Escape	_____ m	☐	☐	

	Actual Dim.	Passed	Failed
At least two (2) means of egress for each floor.		☐	☐
Doors assembly: 60 minutes fire resistant for three (3) communicating level and below.		☐	☐
Doors assembly: 90 minutes fire resistant for four (4) communicating level and above.		☐	☐
Exits Doors provided with Re-entry mechanism at every four (4) storey.		☐	☐
Stair thread: Minimum depth = 280 mm.		☐	☐
Stair riser: Minimum / Maximum height = 100 mm / 180 mm.		☐	☐
Minimum stair head room: 2000mm		☐	☐
Stair provided with Guard and Handrails.		☐	☐
Maximum handrails projections: 114 mm.		☐	☐
Stair landing shall not be less than the required width of exit door.		☐	☐
Exits doors open and close properly		☐	☐
Doors swing in direction of egress.		☐	☐
Exit Doors provided with panic hardware, vision panel, and self-closing mechanism.		☐	☐
There shall be no enclosed usable space under the stairs in an exit enclosure nor shall the open space under such stairs be used for any purpose.		☐	☐
Interior finish: Class B		☐	☐

C. EXITS DISCHARGE

	Actual Dim.	Passed	Failed
Remoteness of exit discharge not less than ½ of length of the overall dimension of the building or area to be served.		☐	☐
Remoteness of exit discharge not less than 1/3 of length of the overall dimension of the building or area to be served is the bldg. is protected throughout by ASASS.		☐	☐
Exterior grounds are kept clear of objects that might impede evacuation or firefighting equipment		☐	☐
Terminate directly at a public way or at an exterior exit discharge.		☐	☐



Republic of the Philippines
Department of the Interior and Local Government
BUREAU OF FIRE PROTECTION
(FIRE STATION LETTERHEAD)



VI. SIGNS, LIGHTING, AND EXITS SIGNAGE

A. MARKING OF MEANS OF EGRESS (EXIT)

	Actual Dim.	Passed	Failed
Minimum letter height, 150 mm		☐	☐
EXIT signs are posted along Exit access, Exits and Exit discharge		☐	☐
EXIT signs are properly illuminated		☐	☐

B. MARKING OF MEANS OF EGRESS (EMERGENCY EVACUATION PLAN)

	Passed	Failed
Posted on strategic and conspicuous location inside the building	☐	☐
Drawn with a photo-luminescent background to be readable in case of power failure. Containing the following basic information below 1. "You Are Here/ room number/ building" Marking 2. Fire Exits 3. Primary Route to Exit (Nearest to the viewer) 4. Secondary Route to Exit (Second nearest to the viewer) 5. Fire alarm pull stations and annunciators 6. Fire extinguishers/ hose cabinets 7. Emergency Light 8. First Aid Kits locations (if applicable) 9. Emergency Call stations (if applicable) 10. Areas of safe refuge (for high-rise building) 11. Assembly areas instructions 12. "In Case of Emergency" instructions	☐	☐



Republic of the Philippines
Department of the Interior and Local Government
BUREAU OF FIRE PROTECTION
(FIRE STATION LETTERHEAD)



Emergency Evacuation Plan:

	Actual Dim.	Passed	Failed
Size 330.2 mm wide x 215.9 mm height (Floor area < 50 m ²) • Room or spaces		☐	☐
Size 609.6 mm wide x 457.2 mm height (Floor area = 50 – 150 m ²) • Room or spaces • Building lobbies upon entry. • Elevator lobbies at every floor. • Hallways and corridors. • On every bend/corner Or every 15m interval in the case of long hallway.		☐	☐
Size 609.6 mm height x 914.4 mm (Floor area ≥ 151 m ²) • Room or spaces • Upon entry of the building • Area of assembly or every 25m interval in the case auditorium & gymnasium.		☐	☐

Symbols/icons/logos to be used for the marking shall be in accordance with NFPA 170, Standard for Signs and Symbols.

C. ILLUMINATION OF MEANS OF EGRESS

(All Data Below Shall be Referred from Manufacturers Specifications)

	Actual Lux/Time	Passed	Failed
Floors and other walking surfaces: shall be at least 1 ft-candle (10.8 lux), measured at the floor.		☐	☐
In assembly occupancies: walking surfaces of exit access shall be at least 0.2 ft-candle (2.2 lux)		☐	☐
Stairs: shall be at least 10 ft-candle (108 lux), measured at the walking surfaces.		☐	☐
Emergency Lighting ☐ Illumination not less than an average of 1 ft-candle (10.8 lux) and, at any point, not less than 0.1 ft-candle (1.1 lux), measured along the path of egress at floor level. ☐ Emergency lighting system shall be arranged to provide the required illumination automatically in the event of any interruption of normal lighting (e.g. Failure of a public utility, etc..) for a period at least 1.5-hour. ☐ Periodic Testing of Emergency Lighting Equipment (Written record)		☐	☐

VII. HAZARD

Hazard Contents : _____ Quantity (Vol. / Weight) :



Republic of the Philippines
Department of the Interior and Local Government
BUREAU OF FIRE PROTECTION
(FIRE STATION LETTERHEAD)



Hazard Identification : _____ Within MAQ : ☐ Yes / ☐ No

Placard

Hazard Identification No. : _____ Hazard Classification : ☐ Low / ☐ Ordinary / ☐ High

Class : _____ Flash Point :

Low hazard contents shall be classified as those of such low combustibility that no self-propagating fire therein can occur.

Ordinary hazard contents shall be classified as those that are likely to burn with moderate rapidity or to give off a considerable volume of smoke.

High hazard contents shall be classified as those that are likely to burn with extreme rapidity or from which explosions are likely.

A. OTHER FLAMMABLE LIQUIDS (I.E. ALCOHOL, ETHER, ETC...)

	Passed	Failed
Stored in sealed metal containers	☐	☐
Properly dispensed as per SOP	☐	☐
Provided with "NO SMOKING" sign.	☐	☐

B. MISCELLANEOUS HAZARDS (MECHANICAL EQUIPMENT ROOM, STORAGE, SUPPLY ROOM)

	Passed	Failed
All no smoking areas has adequate signs.	☐	☐
Gasoline/ Diesel is stored in the proper place and in a metal safety can.	☐	☐

C. HOUSEKEEPING, MAINTENANCE, STORAGE & WASTE DISPOSAL

	Passed	Failed
Brooms, mops, rags and other cleaning supplies stored in metal cabinets or approved cans	☐	☐
Paints, solvents and other flammables stored in metal cabinet: oily rags in metal containers	☐	☐
Dry leaves, shrubbery trimmings and other combustibles kept away from buildings	☐	☐

VIII. FIRE PROTECTION



Republic of the Philippines
Department of the Interior and Local Government
BUREAU OF FIRE PROTECTION
(FIRE STATION LETTERHEAD)



A. Automatic Fire Suppression System (Sprinkler)

Item to Inspect	Procedure How to Inspect	Passed	Failed
Sprinkler Pumps	Check automatic start and pressure.	☐	☐
Sprinkler Valves	Valves are locked in the open position, no leaks, corrosion, or other defects noted.	☐	☐
Sprinkler water flow alarm	Open test valve and ensure manual alarm bell functions and sprinkler pumps start.	☐	☐

B. Wet Standpipe/Fire Hose Cabinet

Cabinet Door Operative	Check that door is unobstructed and opens properly.	☐	☐
Hose Condition	Check that hose is not rotted, wet, moldy, etc.	☐	☐
Nozzle	Check that nozzle is in place and operates correctly.	☐	☐
Hose hung properly	Check that the hose is hung properly so that it can easily be un-rolled if needed.	☐	☐
Valves and valve handles	Check that valve handles are in place and that valves operate properly and are in the open position.	☐	☐

C. Fire Pump

Pump System	Inspect accuracy of pressure gauges and sensors	☐	☐
Pipings	Check pipings if there is leak	☐	☐
Motor	Check unusual noise or vibrations	☐	☐
Electrical System	Check if there is corrosion in PCBs, cracked cable/wire insulation, leak in plumbing parts, sign of water in electrical part	☐	☐

D. Fire Detection System

Fire Detection System	Random Test of call points and smoke detectors.	☐	☐
-----------------------	---	--------------------------	--------------------------

E. Fire Alarm Facilities

Location Signs	Check all signs are in place and legible.	☐	☐
Alarm Panels	Check that all alarm panels are functioning correctly and are unobstructed.	☐	☐

F. Lifts (Elevator)

Lifts	All lifts "home" to ground floor during fire test, doors open and lift stops.	☐	☐
Fans	All lift fans operate correctly.	☐	☐
Fireman's lift	Fireman's lift can be keyed to operate during fire alarm test.	☐	☐

G. First Aid Fire Protection (Fire Extinguishers)



Republic of the Philippines
Department of the Interior and Local Government
BUREAU OF FIRE PROTECTION
(FIRE STATION LETTERHEAD)



Fire Extinguisher Size	Minimal sizes of fire extinguishers for the listed grades of hazards shall be provided on the basis of table 7 & 8 of RIRR of RA 9514.	☐	☐
Minimum number of Extinguisher.	The minimum number of extinguisher shall be sufficient to meet the requirements of table 7 & 8 of RIRR of RA 9514.	☐	☐
Location	All extinguishers are in their proper location.	☐	☐
Seals & Tags	Extinguisher seals and tags are intact and extinguisher was serviced in the last 12 months.	☐	☐
Markings	Proper marking on extinguisher to indicate the type of fire the extinguisher can be used on.	☐	☐
Condition	No leaks, corrosion or other defects noticed.	☐	☐
Pressure	Pressure gauge reads in the "green" area.	☐	☐

H. Emergency Lighting Systems

Battery Lights	All battery powered emergency lighting turns on when mains power is removed	☐	☐
----------------	---	--------------------------	--------------------------

I. Kitchen

Hoods & Vents	Hoods, vents, fans and ducts in good condition and free from grease	☐	☐
Hood Filters	Date of Last Cleaning	☐	☐

J. BUILDING SERVICE EQUIPMENT

	Passed	Failed
1. Utilities: Cooking equipment protected by AKHFSS (Restaurant and similar establishment with Occupant Load > 50p)	☐	☐
2. Heating, Ventilating and Air-conditioning: Design & Installation in accordance with PMEC	☐	☐
3. Smoke Control Systems/Smoke Management shall be provided in the following: ☐ All high-rise buildings (stairwells, at least 1 elevator shaft, zoned smoke control, and vestibule). ☐ Pressurization of smoke refuge area. ☐ Every Atrium of covered mall of over 2- levels / Other type of Occupancy over 3 – levels. ☐ Underground structure and windowless facilities. ☐ All movie houses. ☐ All other buildings or structures with at least 1,115 m ² single floor area.	☐	☐
4. Rubbish Chutes, Laundry Chutes, and Flue-Fed Incinerators: <i>(not apply to detached single- or two-family dwelling)</i> ☐ Chutes & Incinerators shall be enclosed. ☐ Design and Maintained in accordance with the latest edition of PMEC.	☐	☐



Republic of the Philippines
Department of the Interior and Local Government
BUREAU OF FIRE PROTECTION
(FIRE STATION LETTERHEAD)



K. FIRE WALL (FW) (if required)

Provided with Fire Wall (minimum 2 hours fire resistance)	☐ Yes / ☐ No
FW extension above the roof surface shall not be less than 760mm (See MC No. 2021-064 dated 28 June 2021 for Alternative)	☐ Yes / ☐ No
Wall type: ☐ 125mm Solid Concrete / ☐ 150mm Solid Masonry / ☐ 200mm Hollow Unit Masonry	

DEFECTS/DEFICIENCIES (Attached pictures, sketch and others)

ITEM IV :

ITEM V :

ITEM VI :

ITEM VII :

ITEM VIII :

IX. RECOMMENDATIONS

☐ Comply the following DEFECTS/DEFICIENCIES stated above and pay the corresponding Fire Code Fees including the Storage Clearance Fee, Conveyance Clearance Fee before the issuance of Fire Safety Inspection Certificate (FSIC)

☐ For issuance of ☐ Notice to Comply

☐ Notice to Correct Violation

☐ Closure Order

☐ Abatement Order with Administrative Fine

☐ Closure Order for the non-payment of Administrative Fine

☐ Notice of Disapproval (NOD)

ACKNOWLEDGED BY:

Signature Over Printed Name of
Owner/ Representative

Fire Safety Inspector/s

Team Leader

Date & Time :

RECOMMEND APPROVAL:

CHIEF, FIRE SAFETY ENFORCEMENT SECTION/UNIT

APPROVAL:

CITY/ MUNICIPAL FIRE MARSHAL